

# REGULATORY DOCKET FILE COPY

OCTOBER 24 1980

Dockets Nos. 50-317  
and 50-318

Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

Distribution:

- |                    |                         |
|--------------------|-------------------------|
| Docket             | J. Roe                  |
| NRC PDR            | PMKreutzer (3)          |
| Local PDR          | M. Williams             |
| ORB#3 Reading      | OELD                    |
| NRR Reading        | OI&E (3)                |
| H. R. Denton       | B. Jones (4) <i>cel</i> |
| E. G. Case         | ACRS (16)               |
| R. Hartfield, MPA  | OPA (Clare Miles)       |
| G. Bennington, MPA | NSIC                    |
| D. Eisenhut        | TERA                    |
| R. Purple          | Secretariat (SECY)      |
| T. Novak           | R. Diggs                |
| R. Tedesco         | J. Heltemes, AEOD       |
| G. Lainas          | Project Manager         |
| <i>J. Murray</i>   | RAClark                 |

Dear Mr. Lundvall:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

- Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to IEB-79-01R, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Original Signed By

Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure: Order **8011070597**

cc w/enclosure: See Next Page

RECEIVED DISTRIBUTION SERVICES UNIT  
 1980 NOV 5 AM 8 39  
 US NRC  
 DISTRIBUTION SERVICES  
 BRANCH

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORB#3:DL	D:DL
SURNAME	PMKreutzer/JL	PM <i>Cyl</i> C.L.	RAClark	M. Williams	D. Eisenhut
DATE	10/24/80	10/24/80	10/24/80	10/24/80	10/24/80



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 24, 1980

Dockets Nos. 50-317  
and 50-318

Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

Dear Mr. Lundvall:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL  
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
Ref (b) Inspection and Enforcement Bulletin Supplement No. 2 to  
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

A handwritten signature in cursive script, appearing to read "Robert A. Clark".

Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure:  
Order

cc w/enclosure: See Next Page

cc:

James A. Biddison, Jr.  
General Counsel  
G and E Building  
Charles Center  
Baltimore, Maryland 21203

George F. Trowbridge, Esquire  
Shaw, Pittman, Potts and  
Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Mr. R. C. L. Olson  
Baltimore Gas and Electric Company  
Room 922 - G and E Building  
Post Office Box 1475  
Baltimore, Maryland 21203

Mr. Leon B. Russell  
Plant Superintendent  
Calvert Cliffs Nuclear Power Plant  
Baltimore Gas & Electric Company  
Lusby, Maryland 20657

Bechtel Power Corporation  
ATTN: Mr. J. C. Judd  
Chief Nuclear Engineer  
15740 Shady Grove Road  
Gaithersburg, Maryland 20760

Combustion Engineering, Inc.  
ATTN: Mr. P. W. Kruse, Manager  
Engineering Services  
Post Office Box 500  
Windsor, Connecticut 06095

Calvert County Library  
Prince Frederick, Maryland 20678

Director, Department of State Planning  
301 West Preston Street  
Baltimore, Maryland 21201

Mr. R. M. Douglass, Manager  
Quality Assurance Department  
Room 923 Gas & Electric Building  
P. O. Box 1475  
Baltimore, Maryland 21203

Mr. Bernard Fowler  
President, Board of County  
Commissioners  
Prince Frederick, Maryland 20768

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region III Office  
ATTN: EIS COORDINATOR  
Curtis Building (Sixth Floor)  
Sixth and Walnut Streets  
Philadelphia, Pennsylvania 19106

Ralph E. Architzel  
Resident Reactor Inspector  
NRC Inspection and Enforcement  
P. O. Box 437  
Lusby, Maryland 20657

Mr. Charles B. Brinkman  
Manager - Washington Nuclear  
Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
4853 Cordell Ave., Suite A-1  
Bethesda, Maryland 20014

Administrator, Power Plant Siting Program  
Energy and Coastal Zone Administration  
Department of Natural Resources  
Tawes State Office Building  
Annapolis, Maryland 21204

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of	)	
	)	
BALTIMORE GAS AND ELECTRIC COMPANY	)	Docket Nos. 50-317
(Calvert Cliffs Nuclear Power	)	and 50-318
Plant, Unit Nos. 1 and 2)	)	

ORDER FOR MODIFICATION OF LICENSES

I.

Baltimore Gas and Electric Company (licensee) is the holder of License Nos. DPR-53 and DPR-69 which authorize the operation of the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 at steady state reactor power levels not in excess of 2700 megawatts thermal (rated power). The facilities consist of two Pressurized Water Reactors located at the licensee's site in Calvert County, Maryland.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B<sup>1</sup> and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

<sup>1</sup>

Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

### III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating License Nos. DPR-53 and DPR-69 are hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-53 and DPR-69 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V.

The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to George F. Trowbridge, Esq., Shaw, Pittman, Potts and Trowbridge, 1800 M Street, N. W., Washington, D. C. 20036, attorney for the licensee.




If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhower, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980  
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE OCCURRENCES submitted to the Commission.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of reactor tests and experiments.
- f. Records of changes made to Operating Procedures.
- g. Records of radioactive shipments.
- h. Records of sealed source and fission detector leak tests and results.
- i. Records of annual physical inventory of all sealed source material of record.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of facility radiation and contamination surveys.

## ADMINISTRATIVE CONTROLS

- d. Records of radiation exposure for all individuals entering radiation control areas.
- e. Records of gaseous and liquid radioactive material released to the environs.
- f. Records of transient or operational cycles for those facility components identified in Table 5.7.1.
- g. Records of training and qualification for current members of the plant staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities identified in the NRC approved QA Manual as lifetime records.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the POSRC and the OSSRC.
- l. Records of Environmental Qualification which are covered under the provisions of paragraph 6.13.

### 5.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

### 5.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR Part 20:

- a. A high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by issuance of a Special or Radiation Work Permit and any individual or group of individuals permitted to enter such areas shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.

## ADMINISTRATIVE CONTROLS

- b. A high radiation area in which the intensity of radiation is greater than 1000 mrem/hr shall be subject to the provisions of 6.12.1.a, above, and in addition locked barricades shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Shift Supervisor on duty.

### 6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-53 and DPR-69 dated October 24, 1980.

6.13.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.

## ADMINISTRATIVE CONTROLS

### 6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE OCCURRENCES submitted to the Commission.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of reactor tests and experiments.
- f. Records of changes made to Operating Procedures.
- g. Records of radioactive shipments.
- h. Records of sealed source and fission detector leak tests and results.
- i. Records of annual physical inventory of all sealed source material of record.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of facility radiation and contamination surveys.

## ADMINISTRATIVE CONTROLS

- d. Records of radiation exposure for all individuals entering radiation control areas.
- e. Records of gaseous and liquid radioactive material released to the environs.
- f. Records of transient or operational cycles for those facility components identified in Table 5.7-1.
- g. Records of training and qualification for current members of the plant staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities identified in the NRC approved QA Manual as lifetime records.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the POSRC and the OSSRC.
- l. Records of Environmental Qualification which are covered under the provisions of paragraph 6.13.

### 6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

### 6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR Part 20:

- a. A high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by issuance of a Special or Radiation Work Permit and any individual or group of individuals permitted to enter such areas shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.

## ADMINISTRATIVE CONTROLS

- b. A high radiation area in which the intensity of radiation is greater than 1000 mrem/hr shall be subject to the provisions of 6.12.1.a, above, and in addition locked barricades shall be provided to prevent unauthorized entry into such areas and the keys shall be maintained under the administrative control of the Shift Supervisor on duty.

### 6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-53 and DPR-69 dated October 24, 1980.

6.13.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.