

DEC 01 1981

Dockets Nos. 50-317
and 50-318

Mr. A. E. Lundvall, Jr.
Vice President- Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

The Commission has filed the enclosed "Notice of Consideration of Modification to Facilities' Spent Fuel Storage Pool" with the Office of the Federal Register for publication. This notice relates to your request of October 30, 1981, regarding modification of the Calvert Cliffs Nuclear Power Plant Spent Fuel Storage Pool to permit storage of 1830 fuel assemblies.

DISTRIBUTION:

Docket File
NRC PDR
L PDR
NSIC
TERA
ORB #3 Rdg.
D. Eisenhut
J. Heltemes
RAClark
TColburn
PMKreutzer-3
I&E-4
OELD

DJaffe
ACRS-10
Gray File

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Operating Reactors

CP
3

Enclosure:

cc:w/enclosure:
See next page



8201050368 B11201
PDR ADOCK 05000317
PDR

Handwritten notes: 12/2/81, C.M.S., OELD, and other signatures.

OFFICE	PKreutzer	DJaffe	RAClark	OELD		
SURNAME	ORB#3	ORB#3	ORB#3	ORB#3		
DATE	11/24/81	11/24/81	11/24/81	11/24/81		

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Judd
Chief Nuclear Engineer
15740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. P. W. Kruse, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Public Document Room
Calvert County Library
Prince Frederick, MD 20678

Director, Department of State Planning
301 West Preston Street
Baltimore, MD 21201

Mr. R. M. Douglass, Manager
Quality Assurance Department
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. T. L. Syndor, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: Regional Radiation Representative
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, MD 20014

Mr. J. A. Tierman, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Taves State Office Building
Annapolis, MD 21204



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DISTRIBUTION:
Docket File
ORB#3 Rdg
PMKreutzer

Docket No. 50-309/50-318

DEC 1 1981

Docketing and Service Section
Office of the Secretary of the Commission

SUBJECT: BALTIMORE GAS AND ELECTRIC COMPANY, Calvert Cliffs Nuclear
Power Plant Units Nos. 1 and 2

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Other: Notice of Consideration of Proposed Modification to
Facilities' Spent Fuel Storage Pool

Division of Licensing
Office of Nuclear Reactor Regulation

Enclosure:
As Stated

ORB#3:DL

PMKreutzer/pn

12/ /81

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKETS NOS. 50-317 AND 50-318BALTIMORE GAS AND ELECTRIC COMPANYNOTICE OF CONSIDERATION OF PROPOSED MODIFICATION TO
FACILITIES' SPENT FUEL STORAGE POOL

The United States Nuclear Regulatory Commission (the Commission) is considering the approval of a modification to the spent fuel storage pool of the Calvert Cliffs Nuclear Power Plant Units Nos. 1 and 2 (the facilities), located in Calvert County, Maryland. Operation of the facilities is authorized by Facility Operating Licenses Nos. DPR-53 and DPR-69, issued to Baltimore Gas and Electric Company (the licensee).

The facilities share a common pool that is divided in two sections and connected by a transfer canal. On September 19, 1980, the NRC issued Amendments 47 and 30 for Calvert Cliffs Units 1, and 2, respectively which authorize a maximum fuel storage capacity of 1760 fuel assemblies. By application dated October 30, 1981, the licensee requested an increase in the maximum authorized fuel storage capacity from 1760 to 1830 fuel assemblies. The modification will require changes to the Technical Specifications and issuance of a license amendment for each facility.

Prior to approval of the proposed modification and license amendments authorizing use of the modified pool, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

8201050371 811201
PDR ADDCK 05000317
P PDR

(2)

By December 31, 1981, the licensee may file a request for a hearing with respect to issuance of the amendments to the subject facility operating licenses and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene.

(3)

Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner may file a supplement to the petition to intervene which may include a list of the contentions which are sought to be litigated in the matter. The bases for each contention must be set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendments under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Docketing and Service Section, or may be delivered to the Commission's Public Document Room, 1717 H Street, N.W. Washington, D. C. by the above date.

(4)

Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at (800) 325-6000 (in Missouri (800) 342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to Robert A. Clark; (petitioner's name and telephone number); (date petition was mailed); (Calvert Cliffs); and (publication date and page number of this FEDERAL REGISTER notice). A copy of the petition should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to James A. Biddison, Jr. General Counsel, G and E Building, Charles Center, Baltimore, Maryland 21203, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the Atomic Safety and Licensing Board designated to rule on the petition and/or request, that the petitioner has made a substantial showing of good cause for the granting of a late petition and/or request. That determination will be based upon a balancing of the factors specified in 10 CFR §2.714 (d).

For further details with respect to this action, see the application for amendment dated October 30, 1981, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W. and at the Calvert County Library, Prince Frederick, Maryland.

Dated at Bethesda, Maryland this 1st day of December, 1981.

FOR THE NUCLEAR REGULATORY COMMISSION

Charles M. Trammell
Charles M. Trammell, Acting Chief
Operating Reactors Branch #3
Division of Licensing