

DCS MS-010

JUN 7 1983

RAClark ✓ Docket File
NRC PDR
Local PDR
ORB#3 Rdg
DEisenhut
PMKreutzer
DHJaffe
OELD
SECY
LJHarmon
TBarnhart
LSchneider
DBrinkman
ACRS (10)
RDiggs
NSIC

Docket No. 50-317

Mr. A. E. Lundvall, Jr.
Vice President-Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

Enclosed is a copy of a "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Prior Hearing" for your information. This notice relates to your March 7, 1983 application for revised Limiting Conditions for Operation and Surveillance Requirements for containment tendons, as contained in the Appendix A Technical Specifications for Calvert Cliffs Unit 1.

The notice, which affords an opportunity for hearing, has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Notice

cc: See next page

8306290194 830607
PDR ADOCK 05000317
PDR

*cc: see previous concurrence page

OFFICE ▶	ORB#3:DL*	ORB#3:DL*	ORB#3:DL*	AD:OR:DL*	OELD	DJR:PA	
SURNAME ▶	PKreutzer	DJaffe:dd	RAClark	GCLainas		DEisenhut	
DATE ▶	3/29/83	3/26/83	3/29/83	3/29/83	6/2/83	6/3/83	

RAClark

Docket File
NRC PDR
Local PDR
ORB#3 Rdg
DEisenhut
PMKreutzer
DHJaffe
OELD
SECY
LJHarmon
TBarnhart
LSchneider
DBrinkman
ACRS (10)
RDiggs
NSIC

Docket No. 50-317

Mr. A. E. Lundvall, Jr.
Vice President-Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

Enclosed is a copy of a "Notice of Consideration of Issuance of Amendment to Facility Operating License" for your information. This notice relates to your March 7, 1983 application for revised Limiting Conditions for Operation and Surveillance Requirements for containment tendons, as contained in the Appendix A Technical Specifications for Calvert Cliffs Unit 1.

The notice, which affords an opportunity for hearing, has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Notice

cc: See next page

*Refer to D. J.
Pac. Division
Lundvall
3/29/83*

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	AD:DR	OELD	DLR:	
SURNAME	PKreutzer	DJaffe	RAClark	GCLinas		DGEisenhut	
DATE	3/29/83	3/29/83	3/29/83	3/29/83	3/29/83	3/29/83	

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Ventura
Calvert Cliffs Project Engineer
15740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. R. R. Mills, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Mr. R. M. Douglass, Manager
Quality Assurance Department
Baltimore Gas & Electric Company
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. S. M. Davis, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: Regional Radiation Representative
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, MD 20814

Mr. J. A. Tiernan, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Tawes State Office Building
Annapolis, MD 21204

Regional Administrator
Nuclear Regulatory Commission, Region I
Office of Executive Director for Operations
631 Park Avenue
King of Prussia, Pennsylvania 19406

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-317BALTIMORE GAS AND ELECTRIC COMPANYNOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TOFACILITY OPERATING LICENSE ANDOPPORTUNITY FOR PRIOR HEARING

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-53 issued to Baltimore Gas and Electric Company (the licensee), for operation of the Calvert Cliffs Nuclear Power Plant, Unit No. 1 located in Calvert County, Maryland.

The amendment would revise the Limiting Conditions for Operation and Surveillance Requirements for containment tendons as contained in the Appendix A Technical Specifications for Calvert Cliffs Unit No. 1 in accordance with the licensee's application dated March 7, 1983. The proposed changes in the Technical Specifications include a provision to allow normalization of tendon lift-off forces in determining continued containment tendon integrity. In addition, a 90 day period would now be permitted to investigate evidence of possible abnormal degradation of the tendon system.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By July 18, 1983 the licensee or a petitioner may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written petition for leave to intervene. Requests for a hearing and petitions "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2.

8306290202 830607
PDR ADOCK 05000317
P PDR

- 2 -

If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

No later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set

- 3 -

forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at (800) 325-6000 (in Missouri (800) 342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to Robert A. Clark: (petitioner's name and telephone number), (date petition was mailed); (plant name), and (publication date and page number of this FEDERAL REGISTER notice). A copy of the petition should also be sent to the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to James A. Biddison, Jr., General Counsel, G and E Building, Charles Center, Baltimore, Maryland 21203, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained

- 4 -

absent a determination by the Commission, the presiding officer or the Atomic Safety and Licensing Board designated to rule on the petition and/or request. That determination will be based upon a balancing of the factors specified in 10 CFR §2.714(a)(1)(i)-(v) and §2.714(d).

For further details with respect to this action, see the application for amendment dated March 7, 1983, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Calvert County Library, Prince Frederick, Maryland.

Dated at Bethesda, Maryland this 7th day of June, 1983.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing