

February 12, 2001

MEMORANDUM TO: Ashok C. Thadani, Director
Office of Nuclear Regulatory Research

FROM: Thomas L. King, Director/**RA**/
Division of Risk Analysis and Applications
Office of Nuclear Regulatory Research

SUBJECT: MEETING WITH EXELON GENERATION COMPANY AND
OTHER INTERESTED STAKEHOLDERS REGARDING THE
PEBBLE BED MODULAR REACTOR

On January 31, 2001, from 1:30 PM to 4:00 PM, the NRC staff met with the representatives of Exelon (Exelon Nuclear and Exelon Generation Company) and other interested stakeholders to discuss the Pebble Bed Modular Reactor (PBMR) design, technology and the potential for Exelon's request for NRC review. The meeting was widely attended with representatives from industry, public interest groups, the national laboratories and ACRS. Attachment 1 contains a list of attendees. Presentation material distributed at this meeting is also included (Attachment 2).

In their opening remarks, W. Travers (NRC) and A. Thadani (NRC) stated the purpose of the meeting as an opportunity to learn more about the PBMR design with the principal focus on various technical and licensing issues. Referring to the NRC's advanced reactor policy, both emphasized the need for identifying key issues and their resolution, and soliciting Commission approval before proceeding with interactions on the PBMR design.

Exelon presenters were W. Sproat, V. Nilekani, K. Borton and J. Muntz. Following introductions, Exelon stated that their main objectives were to initiate a dialogue with the NRC on the PBMR licensing process by providing a summary of the PBMR design and identifying potential design and licensing issues and share initial thoughts on the licensing approach and projected schedule.

Phase 1 of the PBMR project has a multi-national ownership: Exelon Generation (12.5%), British Nuclear Fuel, Ltd. (22.5%), ESKOM (40%) and the Republic of South Africa (RSA) (25%). The design feasibility study for a 100 MWe PBMR is scheduled to be completed by June 2001 and the decision to build a prototype plant in South Africa is to be made by the end of 2001. If built, the prototype module will be a full-scale facility. This facility would allow testing under postulated accident conditions. Exelon's decision to proceed with the PBMR project will be based on several factors such as whether this design can be a source of low-cost electrical energy, with a high safety level, to be able to successfully compete in the U.S. energy markets.

The PBMR is a high temperature gas-cooled reactor (HTGR) with helium as a coolant, typically, at 900°C and 1000 psi. The reactor pressure vessel is made of steel and is about 19.5-ft diameter and 65-ft high, which is housed in a 175-ft square and 108-ft high reactor building - about two-thirds of which is below grade. The accidents for which the plant is to be designed to accommodate without loss of fuel integrity include a range of internal and external events, including ATWS and station blackout. The fuel element is a multi-layer 60-mm diameter graphite sphere (about the size of a tennis ball), in which low-enriched UO_2 is embedded in the form of coated particles about 0.5 mm in diameter. This sphere is not only a carrier of the fuel, but it is also the neutron moderator. The core contains 330,000 spherical fuel elements and 110,000 graphite spheres. The fuel spheres are similar to those used in Germany at AVR Jülich - a small research reactor which operated for 22 Years, and at thorium high temperature reactor (THTR) Hamm-Uentrop - a 300 MWe demonstration reactor, which operated for 6 years.

According to Exelon, the safety of the PBMR design is inherent in (1) low ratio of power density to heat capacity leading to slow temperature change in the event of failure affecting heat production and heat removal; (2) high temperature resistance of the ceramic fuel elements and structural material of the core (the failure rate of fuel elements is negligible up to temperatures of 2000°C); (3) strong negative temperature and power coefficients of reactivity under all operating conditions (low excess reactivity is possible in continuously-fueled pebble bed); (4) plant design features mitigate air and water ingress; and (5) helium - a chemically inert, single-phase, neutron-transparent gas - is used as a coolant. In addition to the fuel design and use of passive systems, other features are: its modular design; continuous power generation augmented by on-line fuel loading and unloading (plant outage 30 days every 6 years for turbine and generator maintenance); direct cycle gas turbine; on-site spent-fuel storage for 40 years; and low excess reactivity.

Exelon identified various design issues as well as alternate potential licensing schemes under either 10 CFR Part 50 or Part 52 licensing processes including early site permit. Issues included: qualification of the fuel and its fabrication as an integral aspect of the facility certification; development of the source term; assessment of a leak-tight versus vented containment; materials qualification, such as, high temperature metal creep, and thermal fatigue; verification and validation of design and safety analysis codes; and PRA and classification of SSCs. Other concerns which also need to be addressed include: regulatory treatment of non-safety systems; and determination of appropriate tests, including NDE.

In closing remarks, A. Thadani stated the need (1) to identify key issues for the NRC to develop the needed technical expertise to work efficiently and effectively; (2) to seek Commission approval of a review plan before proceeding; and (3) for the industry to provide more information to help the staff develop the plan.

For further information, please contact Thomas L. King at (301)-415-5790 or tlk@nrc.gov.

cc: SECY
OGC
OCA
OPA
CFO
CIO

Attachments: As stated

Distribution: (w/attachments) DRAA Chron, MWeber (NMSS)

w/o attachments

WTravers TKing RTripathi MMayfield FEltawila SRubin ALevin
CEmeigh TKress MEI-zeftawy SMorris RCarusso SARndt GBagchi
KErwin JGolder BJazinski RBarrett DCarlson

All attendees listed in Attachment 1

DOCUMENT NAME: G:\Tom's General\Meeting Notice EXELON-1-31-01.WPD

OAD in ADAMS? (Y or N) Y ADAMS ACCESSION NO.: _____ TEMPLATE NO. RES-____
Publicly Available? (Y or N) Y DATE OF RELEASE TO PUBLIC _____ SENSITIVE? _____

*See previous concurrence

OFFICE	DRAA*		DRAA		
NAME	Tripathi		King		
DATE	02/8/1		02/12/1		

January 31, 2001

Meeting Between NRC and Exelon on PBMR

List of Attendees

<u>Name</u>	<u>Organization</u>	<u>Telephone #</u>
Thomas King	NRC/RES/DRAA	301-415-5790
Stu Rubin	NRC/RES/DSRE	301-415-7480
David Brown	Exelon Corp.	202-347-7500
Neil McDermott	Exelon Corp.	610-765-6909
Joe Green	Stone & Webster	617-589-1400
Ed Wallace	Exelon Corp.	610-765-5721
John Hufnagel	Exelon Corp.	610-765-5507
Ron Smard	NEI	202-739-8128
Alan Levin	NRC/OCM/RAM	301-415-1750
Howard Brusck	Westinghouse	412-256-2800
Vijay M. Nilekani	Exelon	610-765-5950
Bill Travers	NRC/EDO	301-415-1700
Jim Muntz	Exelon Corp.	610-765-5660
Kevin Borton	Exelon Corp.	610-765-5528
Ward Sproat	Exelon Corp.	610-765-5930
David W. Woods	Exelon Corp.	610-765-6900
Ed Cullen	Exelon Corp.	610-765-5700
Tom Clements	Nuclear Control Institute	202-822-8444
Kenneth Chuck Wade	DOE	301-903-1031
Chuck Emeigh	NRC/NMSS	301-415-7836
Tatsuya Taminami	Tokyo Electric	202-657-0790
Jenny Weil	McGraw-Hill	202-383-2161
Geary Mizuno	NRC/OGC/Rulemaking & Fuel Cycle	301-415-1639
Jim Kendall	IAEA/Nuclear Energy Dept.	431260022820
John Matthews	Morgan Lewis	202-467-7524
John Ireland	Los Alamos National Labs.	505-667-8777
Syd Ball	Oak Ridge National Lab.	865-574-0415
Robert E. Uhrig	University of Tenn and NRC/ACRS	352-367-0374
Thomas S. Kress	ACRS	865-483-7548
Herb Fontecilla	Dominion	703-838-2314
Med El-Zeftawy	NRC/ACRS	301-415-6889
Jan Freeman	Exelon Corp.	610-765-6906
Mike Callahan	GSI	202-544-4522
Jim Muckerheide	Mass	508-820-2039
Rod Adams	Adams Atomic Engines, Inc.	727-641-1081

<u>Name</u>	<u>Organization</u>	<u>Telephone #</u>
Cal Reid	Bechtel	301-228-6533
Dave Lockbaum	Union of Concerned Scientists	202-223-6133
Dean Raleigh	US, Scientech	301-258-2551
Scott Morris	NRC/EDO	301-415-1730
Rogon Huston	Licensing Support Services	703-671-9738
Madeline A. Feltus	US Department of Energy	301-903-2308
Mark Haynes	General Atomics	202-496-8209
Edwin Lynien	Nuclear Control Institute	202-822-6594
Patricia Bryant	Nuclear Energy institute	202-739-8020
Jackie Carney	Foundation for Nuclear Studies	202-544-1488
Ralph Caruso	NRR/DSSA	301-415-1813
Steven Arndt	NRC/RES	301-415-6502
Russ Bell	NEI	202-739-8089
Goutam Bagchi	NRC/NRR	301-415-3298
Ken Erwin	NRC/NMSSS/SFPO	301-415-2443
Jennifer Golder	NRC/OCFO/DPBA/PAB	301-415-0115
Bob Jasinski	NRC/OPA	301-415-8200
Theodore Rockwell	Radiation Science & Health, Inc.	301-652-9509
Richard Barrett	NRC/NRR	301-415-3183
Craig D. Sellers	Innovative Technology Solns .	410-394-1504
John M. Osborne	Constellation Nuclear	410-495-2252
Len Ward	ISL, Inc.	301-255-2279
Robert A. Bari	BNL	631-344-2629
Mark R. Holbrook	INEEL	208-526-4362
Steve Frantz	Morgan, Lewis & Bochnius, LLP	202-467-7460
Peter Murray	Westinghouse	301-881-7040
Terry Rudek	Westinghouse	860-285-2170
Charles Brinkman	Westinghouse	301-881-7040
Stan Ritterbusch	Westinghouse	860-285-5206
Paul Gunter	NIRS	202-328-0002
Tom Miller	USDOE	301-903-4517
Ashok C. Thadani	NRC/RES	301-415-6641
Jerry Wilson	NRC/NRR/DRIP	301-415-3145
Jeff Benjamin	UP Licensing - Exelon	630-663-7969
Farouk Eltawila	NRC/RES	301-415-7499
Margaret Federline	NRC/RES	301-415-8003
Carl Paperiello	NRC/EDO	301-415-1705
Howard Faulkner	NRC/OIP	301-415-2762
Raji R. Tripath	NRC/RES	301-415-7472
Carey W. Fleming	Winslow & Strawn	202-371-5839
Gail H. Marcus	DOE/NE	202-586-2240
Joe Muscara	NRC/RES/DET/MEB	301-415-5844