

PCR  
014

U. S. NUCLEAR REGULATORY COMMISSION  
BALTIMORE GAS AND ELECTRIC COMPANY  
DOCKET NOS. 50-317 AND 50-318  
NOTICE OF ISSUANCE OF AMENDMENTS TO  
FACILITY OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment Nos. 115 and 98 to Facility Operating License Nos. DPR-53 and DPR-69, issued to Baltimore Gas and Electric Company (the licensee), which revised the Technical Specifications for operation of the Calvert Cliffs Nuclear Power Plant, Units 1 and 2 (the facility), located in Calvert County, Maryland. The amendments were effective as of the date of their issuance.

The amendments revise provisions in the Technical Specifications (TS) to allow use of the 4-inch post-accident hydrogen purge line for containment purge during normal operation. The TS are changed as follows: (1) TS 3.6.1.8, "Containment Vent System," which requires the containment vent valves (MOV 6900 and 6901) to be closed during reactor operation will be deleted upon initial operability of the Containment Radiation Signal isolation input to motor operated valves (MOVs) 6900 and 6901; (2) the isolation times for MOVs 6900 and 6901 are decreased from less than or equal to 20 seconds to less than or equal to 15 seconds as required by TS 3.6.4.1, "Containment Isolation Valves"; (3) the notation at the end of TS Table 3.6-1, "Containment Isolation Valves," has been changed to reflect deletion of TS 3.6.1.8; and (4) a requirement has been added to TS Table 3.6-1 to limit the use of the containment vent valves to containment pressure control, containment radioactivity control, and surveillance purposes.

8603030497 860220  
PDR ADOCK 05000317  
P PDR

The applications for the amendments comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments.

Notice of Consideration of Issuance of Amendments and Opportunity for Prior Hearing in connection with this action was published in the FEDERAL REGISTER on March 11, 1985 (50 FR 9733) and December 13, 1985 (50 FR 50973). No request for a hearing or petition for leave to intervene was filed following this notice.


The Commission has prepared an Environmental Assessment and Finding of No Significant Impact related to the action and has concluded that an environmental impact statement is not warranted because there will be no environmental impact attributable to the action significantly beyond that which has been predicted and described in the Commission's Final Environmental Statement for the facility dated April 1973.

For further details with respect to the action see (1) the applications for amendments dated December 22, 1983 and March 26, 1984, (2) Amendment Nos. 115 and 98 to Facility Operating License Nos. DPR-53 and DPR-69, (3) the Commission's related Safety Evaluation dated February 20, 1986, and (4) the Environmental Assessment dated December 31, 1985. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Calvert County Library, Prince Frederick, Maryland. A copy of items (2), (3) and (4) may be obtained

upon request addressed to the U. S. Nuclear Regulatory Commission,  
Washington, D. C. 20555, Attention: Director, Division of PWR Licensing-B.

Dated at Bethesda, Maryland, this 20th day of February, 1986.


FOR THE NUCLEAR REGULATORY COMMISSION



Donald E. Setts, Acting Director  
PWR Project Directorate #8  
Division of PWR Licensing-B

DISTRIBUTION:

Docket File	BGrimes
NRC PDR	LTremper
L PDR	LFMB
SECY	JPartlow
PBD#8 Rdg	OPA
FMiraglia	TBarnhart-8
PMKreutzer-3	EJordan
DJaffe	WRegan
OELD	LJHarmon
ACRS-10	CC File

PBD#8 PKreutzer 2/13/86	 PBD#8 DJaffe;ef 2/13/86	OELD <i>Overhead</i> 2/14/86	PBD#8 ATHadani 2/13/86 Signed 2/20/86 PK for AT
-------------------------------	--	------------------------------------	--