

Entergy Nuclear Generation Company Pilgrim Nuclear Power Station 600 Rocky Hill Road Plymouth, MA 02360

AD47

J. F. Alexander Director Nuclear Assessment

10CFR50.60

February 8, 2001 ENGC Ltr. 2.01.023

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555-0001

> Docket No. 50-293 License No. DPR-35

Withdrawal of Request to Use ASME Code-Case N-588

Background

By letter dated January 19, 2001, Entergy Nuclear Generation Company-Pilgrim requested an exemption that would allow Pilgrim's use of ASME Code-Case N-588. This exemption request was submitted in support of a Pilgrim Technical Specification amendment request dated November 22, 2000, concerning pressure-temperature curves.

Withdrawal Request

This letter withdraws Pilgrim's January 19, 2001 exemption request that would allow using ASME Code-Case N-588.

Reason for Withdrawal

Pilgrim's limiting reactor vessel welds are axial. Pilgrim's November 22, 2000, amendment request references ASME Code-Case N-588. However, ASME Code-Case N-588 is concerned with circumferential reactor vessel welds, and is, therefore, not essential to the November 22, 2000, amendment request. Telephone discussion between Pilgrim and the NRC staff on February 5, 2001, also indicates that ASME Code-Case N-588 is not essential to the proposed pressure-temperature curves. Therefore, Pilgrim withdraws its exemption request allowing the use of ASME Code-Case N-588.

Please contact P.M. Kahler at (508) 830-7939 if you require further information on this issue.

Sincerely

cc: attached

cc: Mr. Alan B. Wang, Project Manager Project Directorate I-3 Office of Nuclear Reactor Regulation Mail Stop: OWFN 14B20 1 White Flint North 11855 Rockville Pike Rockville, MD 20852

2

U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Senior Resident Inspector Pilgrim Nuclear Power Station Mr. Robert Hallisey Radiation Control Program Commonwealth of Massachusetts Exec Offices of Health & Human Services Dept. of Public Health 174 Portland Street Boston, MA 02114

Mr. Steven Mc Grail, Director Mass. Energy Management Agency 400 Worcester Road P.O. Box 1496 Framingham, MA 01701-0317