

UNITED STATES NOCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

May 31, 1989

Docket Nos. 50-317 and 50-318

> Mr. G. C. Creel Vice President - Nuclear Energy Baltimore Gas and Electric Company Calvert Cliffs Nuclear Power Plant MD Rtes. 2 & 4 P. O. Box 1535 Lusby, Maryland 20657

Dear Mr. Creel:

8906080076 890531 PDR ADOCK 0500031

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. 64603 AND 64604)

The Commission has issued the enclosed Amendment No.138 to Facility Operating License No. DPR-53 and Amendment No.121 to Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated January 20, 1987, as supplemented on January 12 and June 28, 1988.

These amendments delete the current requirement of Technical Specification (TS) Surveillance Requirement 4.6.4.1.2.c to verify that the containment purge air inlet valves (CPA-1410-CV and CPA-1411-CV) and the containment purge air outlet valves (CPA-1412-CV and CPA-1413-CV) close to their actuation positions upon receiving a safety injection actuation system (SIAS) test signal. This amendment also deletes reference to the SIAS action concerning the containment purge valves from TS Table 3.3-3, "Engineered Safety Feature Actuation System Instrumentation," Table 3.3-4, "Engineered Safety Feature Actuation System Instrumentation Trip Valves," and Table 4.3-2, "Engineered Safety Feature Actuation System Surveillance Requirements."

In addition, your January 20, 1987 application, as supplemented on January 12, 1988, requested an additional TS modification. This change would have eliminated redundancy and consolidated containment purge valve TS requirements by relocating their surveillance test requirements from TS 3/4.6.4, "Containment Isolation Valves," and TS 3/4.9.9, "Refueling Operations - Containment Purge Valve Isolation System," into an expanded TS 3/4.9.4, "Refueling Operations - Containment Penetrations." Subsequently,

)Fol All

Mr. G. C. Creel

51

May 31, 1989

in your June 28, 1988 supplement, you requested the withdrawal of this proposed TS modification. The NRC staff concurs with this request and has withdrawn this proposed change from further consideration.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly <u>Federal Register</u> notice. Also, the Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication.

Sincerely,

Sett alexander Mr. Hul

Scott Alexander McNeil, Project Manager Project Directorate I-1 Division of Reactor Projects, I/II

Enclosures:

- 1. Amendment No. 138to DPR-53
- 2. Amendment No. 121to DPR-69
- 3. Safety Evaluation
- 4. Notice of Withdrawal

cc: w/enclosures
See next page

DISTUTEDITON	DISTRIBUT	TION
--------------	-----------	------

Docket file	NRC PDR
PDI-1 Rdg	Local PDR
SVarga	BBoger
CVogan	RCapra
SMcNeil	LTripp, RI
OGC	DHagan
EJordan	BGrimes
TMeek (8)	WJones
JCalvo	ACRS (10)
ARM/LFMB	DLaBarge
JWermiel	-

[AMEND 317/318 TACS 64603/64604]

¥

		\cap			Van	
OFC :PD1	-1	PDI-1	:OGC NOC	:PDI-1	:SPI(B	
NAME :CVc	igan 🔊	SMcNeil#r	NROMNEY	:RCapra	:JWermiel	
DATE : 5/	h ⁴ /89	5/24/89	5/26/89	5 / 31/89	5 124/89	

OFFICIAL RECORD COPY

N

cc:

5 .

1

Mr. William T. Bowen, President Calvert County Board of Commissioners Prince Frederick, Maryland 20768

D. A. Brune, Esq. General Counsel Baltimore Gas and Electric Company P. O. Box 1475 Baltimore, Maryland 21203

Mr. Jay E. Silberg, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, NW Washington, DC 20036

Mr. W. J. Lippold, General Supervisor Technical Services Engineering Calvert Cliffs Nuclear Power Plant MD Rts 2 & 4, P. O. Rox 1535 Lusby, Maryland 20657

Resident Inspector c/o U.S.Nuclear Regulatory Commission P. O. Box 437 Lusby, Maryland 20657

Department of Natural Resources Energy Administration, Power Plant Siting Program ATTN: Mr. T. Magette Tawes State Office Building Annapolis, Maryland 21204

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406 Calvert Cliffs Nuclear Power Plant



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-317

CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 138 License No. DPR-53

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated January 20, 1987, as supplemented on January 12 and June 28, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-53 is hereby amended to read as follows:



(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.138, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Roberta. Copu

Robert A. Capra, Director Project Directorate I-1 Division of Reactor Projects, I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: May 31, 1989



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 121 License No. DPR-69

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated January 20, 1987, as supplemented on January 12 and June 28, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2 of Facility Operating License No. DPR-69 is hereby amended to read as follows:

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.121, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Rober a. Cape

Robert A. Capra, Director Project Directorate I-1 Division of Reactor Projects, I/II

Attachment: Changes to the Technical Specifications

· .

Date of Issuance: May 31, 1989

ATTACHMENT TO LICENSE AMENDMENTS AMENDMENT NO. 138 FACILITY OPERATING LICENSE NO. DPR-53 AMENDMENT NO. 121 FACILITY OPERATING LICENSE NO. DPR-69 DOCKET NOS. 50-317 AND 50-318

Revise Appendix A as follows:

~

, . . .

Remove Pages	<u>Insert Pages</u>		
3/4 3-13	3/4 3-13		
3/4 3-14*	3/4 3-14*		
3/4 3-17*	3/4 3-17*		
3/4 3-18	3/4 3-18		
3/4 3-23	3/4 3-23		
3/4 3-24*	3/4 3-24*		
3/4 6-19*	3/4 6-19*		
3/4 6-20	3/4 6-20		
3/4 6-21	3/4 6-21		
3/4 6-22*	3/4 6-22*		

*Overleaf pages provided for continuity purposes only.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT			TOTAL NO. <u>OF Channels</u>	CHANNELS TO TRIP	CHANNELS OPERABLE	APPLICA Modes <u>Ac</u>	BLE TION
6.	CONTAINMENT PURGE VALVES ISOLATION						
	a.	Manual (Purge Valve Control Switches)	2/Penetration	1/Penetration	2/Penetration	6**	8
	b.	Containment Radiation - High Area Monitor	4	2	3	6**	8
7.	LOSS	OF POWER					
	a.	4.16 kv Emergency Bus Undervoltage (Loss of Voltage)	4/Bus	2/Bus	3/Bus	1, 2, 3	7*
	b.	4.16 kv Emergency Bus Undervoltage (Degraded Voltage)	4/Bus	2/Bus	3/Bus	1, 2, 3	7*

** Must be **OPERABLE** only in **MODE** 6 when the valves are required **OPERABLE** and they are open.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

RT CLI	FUN	NCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
FFS -	8.	CVCS ISOLATION					
UNIT 1		a. Manual (CVCS Isolation Valve Control Switches)	l/Valve	l/Valve	l/Valve	1, 2, 3, 4	6
		b. West Penetration Room/Letdown Heat Exchanger Room Pressure - High	4	2	3	1, 2, 3, 4	7*
3/4 3-14	9.	AUXILIARY FEEDWATER ACTUATION SYSTEM (AFAS)					
		a. Manual (Trip Buttons)	2 sets of 2 per S/G	l set of 2 per S/G	2 sets of 2 per S/G	1, 2, 3	6
		b. Steam Generator Level - Low	4/SG	2/SG	3/SG	1, 2, 3	7
Amen		c. Steam Generator ∆P High	4/SG	2/SG	3/SG	1,2,3	7

TABL	.E 3	.3-	4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

FUN	CTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1.	SAFETY INJECTION (SIAS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure - High	<pre>< 4.75 psig</pre>	<u><</u> 4.75 psig
	c. Pressurizer Pressure - Low	> 1725 psia	<u>></u> 1725 psia
2.	CONTAINMENT SPRAY (CSAS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure High	<pre>< 4.75 psig</pre>	<u><</u> 4.75 psig
3.	CONTAINMENT ISOLATION (CIS) # a. Manual CIS (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure - High	4.75 psig	<u><</u> 4.75 psig
4.	MAIN STEAM LINE ISOLATION a. Manual (MSIV Hand Switches and Feed Head Isolation Hand Switches)	Not Applicable	Not Applicable
	b. Steam Generator Pressure - Low	<u>></u> 685 psia	<u>></u> 685 psia

Containment isolation of non-essential penetrations is also initiated by SIAS (functional units l.a and l.c).

22	TABLE 3.3-4 (Continued)						
ALVERT ALVERT		ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES					
CLIFFS - CLIFFS -	<u>Fun</u>	CTION/	AL UNIT	TRIP VALUE	ALLOWABLE VALUES		
	э.	CONTAINMENT SUMP RECIRCULATION (RAS)			(
21		d.	Manual RAS (Irip Buttons)	Not Applicable	Not Applicable		
		b.	Refueling Water Tank - Low	24 inches above tank bottom	≥ 24 inches above tank bottom		
	6.	CONT	AINMENT PURGE VALVES ISOLATION				
3/4		a.	Manual (Purge Valve Control Switches)	Not Applicable	Not Applicable		
1 3-18		b.	Containment Radiation - High Area Monitor	<u><</u> 220 mr/hr	<u>≤</u> 220 mr/hr		
	7.	LOSS	OF POWER				
		a.	4.16 kv Emergency Bus Undervoltage (Loss of Voltage)	2450 \pm 105 volts with a 2 \pm 0.2 second time delay	2450 \pm 105 volts with a 2 \pm 0.2 second time delay		
Amendment N Amendment N		b.	4.16 kv Emergency Bus Undervoltage (Degraded Voltage)	3628 \pm 25 volts with a 8 \pm 0.4 second time delay	3628 <u>+</u> 25 volts with a 8 <u>+</u> 0.4 second time delay		
•••							

-

N

.

3/4 3-18

Amendment No. #0%/53, 138 Amendment No. 3%/22%/36, 121

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Fun</u>	CTIONAL UNIT	CHANNEL <u>CHECK</u>	CHANNEL <u>CALIBRATION</u>	CHANNEL FUNCTIONAL <u>TEST</u>	MODES IN WHICH SURVEILLANCE <u>REQUIRED</u>
5.	CONTAINMENT SUMP RECIRCULATION (RAS)				
	a. Manual RAS (Trip Buttons) b. Refueling Water Tank - Low c. Automatic Actuation Logic	NA NA NA	NA R NA	R M M(1)	NA 1, 2, 3 1, 2, 3
6.	CONTAINMENT PURGE VALVES ISOLATION				
	a. Manual (Purge Valve Control Switches b. Containment Radiation - High Area Monitor) NA S	NA R	R M	NA 6**
7.	LOSS OF POWER				
	 a. 4.16 kv Emergency Bus Undervoltage (Loss of Voltage) b. 4.16 kv Emergency Bus Undervoltage 	NA	R	M	1, 2, 3
	(Degraded Voltage)	NA	R	M	1, 2, 3
8.	CVCS ISOLATION				
	West Penetration Room/Letdown Heat Exchanger Room Pressure - High	NA	R	M	1, 2, 3, 4
9.	AUXILIARY FEEDWATER				
	a. Manual (Trip Buttons) b. Steam Generator Level - Low c. Steam Generator▲P - High d. Automatic Actuation Logic	NA S S NA	NA R R NA	R M M M(1)	NA 1, 2, 3 1, 2, 3 1, 2, 3 1, 2, 3

** Must be OPERABLE only in MODE 6 when the valves are required OPERABLE and they are open.

TABLE 4.3-2 (Continued)

TABLE NOTATION

- The logic circuits shall be tested manually at least once per 31 days.
- (3) SIAS logic circuits A-5, B-5, A-10 and B-10 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (4) CIS logic circuits A-5 and B-5 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (5) SGIS logic circuits A-1 and B-1 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (6) CSAS logic circuits A-3 and B-3 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.

CAL	<u>TABLE 3.6-1</u>						
.VER							
T CLIF	PENETRATION NO.	ISOLATION CHANNEL	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)		
FS - UNIT 1	1A	SIAS A SIAS A SIAS A SIAS B	PS-5465-CV PS-5466-CV PS-5467-CV PS-5464-CV	R.C. and Pressurizer Sampling	<7 <7 <7 <7 <7		
	1B	SIAS A SIAS B	WGS-2180-CV WGS-2181-CV	Containment Vent Header to Waste Gas	<7 <7		
3/	10	SIAS A SIAS B	CVC-506-CV CVC-505-CV	RCP Seals Controlled Bleedoff	<7 <7		
4 6-19	1D	NA	PS-6529-SV*	Post Accident Sampling Liquid Return to RC Drain Tank	NA	-	
Am	2A 	SIAS A SIAS B NA NA	CVC-515-CV CVC-516-CV CVC-105 CVC-103	Letdown Line	<13 <13 NA NA		
endment No. 🖌	2B	NA NA NA NA	CVC-517-CV CVC-518-CV CVC-519-CV CVC-435-RV CVC-184	Charging Line	NA NA NA NA NA		

•

€ /5/ , *bh*, 103

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

PENETRATION <u>NUMBER</u>	ISOLATION <u>CHANNELS</u>	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)
7A	NA NA	Blind Flange ILRT-1	ILRT	NA NA
7B	NA NA	Blind Flange ILRT-2	ILRT	NA NA
8	SIAS A SIAS B	EAD-5462-MOV EAD-5463-MOV	Containment Normal Sump	≤ 13 ≤ 13
9	NA NA	SI-340 SI-326	Containment Spray	NA NA
10	NA NA	SI-330 SI-316	Containment Spray	NA NA
13	CRS A CRS B	CPA-1410-CV(3) CPA-1411-CV(3)	Purge Air Inlet	<u><</u> 7** <u><</u> 7**

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

PENETRATION <u>NUMBER</u>	ISOLATION <u>Channels</u>	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION <u>TIME (SECONDS)</u>
14	CRS A CRS B	CPA-1412-CV(3) CPA-1413-CV(3)	Purge Air Outlet	<u><</u> 7** <u><</u> 7**
15	SIAS A SIAS B	RE-5291-CV RE-5292-CV	Purge Air Monitor	<u>≤</u> 7 <u>≤</u> 7
16	CIS A	CC-3832-CV	Component Cooling Water Inlet	<u><</u> 18
18	CIS B	CC-3833-CV	Component Cooling Water Outlet	<u>≤</u> 18
19A	NA CIS A	IA-337 IA-2080-MOV	Instrument Air	NA ≤ 13
19B	NA NA	PA-1040* PA-1044*	Plant Air	NA NA
20A	NA NA NA NA	N ₂ -344 N ₂ -612-CV* N ₂ -622-CV* N ₂ -632-CV* N ₂ -642-CV*	Nitrogen Supply	NA NA NA NA

CAL	TABLE 3.6-1 (Continued)					
-VER			CONTAINMENT I	SOLATION VALVES		
T CLIF	PENETRATION NO.	ISOLATION CHANNEL	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)	
INN - S	20B	NA NA	N2-389 N2-345	Nitrogen Supply	NA NA	
1	200	NA NA	N2-346 N2-392	Nitrogen Supply	NA NA	
	23	SIAS A	RCW-4260-CV	R.C. Drain Tank Drains	<7	
3/4 6	24	SIAS B	PS-6531-SV	Oxygen Sample Line	<u><7</u>	
-22	37	NA NA	PSW-1019 PSW-1008	Plant Water	NA NA	
	38	NA	DW-5460-CV*	Demineralized Water	NA	
Amendm	39	NA NA	SI-463 SI-455	Safety Injection Tank Test Line	NA NA	
ent No. ⁄ g /	41	NA NA	SI-652-MOV (2) SI-651-MOV (2)	Shutdown Cooling	NA NA	
5 , 103						

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>Fun</u> 6.	ICTION/	AL UNIT FAINMENT PURGE VALVES ISOLATION	TOTAL NO. <u>Of Channels</u>	CHANNELS <u>To TRIP</u>	MINIMUM CHANNELS <u>OPERABLE</u>	APPLIC/ Modes	ABLE <u>Action</u>
	a.	Manual (Purge Valve	2/Penetration	1/Penetration	2/Penetration	6**	0
	b.	Containment Radiation - High Area Monitor	4	2	3	6**	
7.	LOSS	OF POWER					-
	a.	4.16 kv Emergency Bus Undervoltage (Loss of Voltage)	4/Bus	2/Bus	3/Bus	1, 2, 3	7*
	b.	4.16 kv Emergency Bus Undervoltage (Degraded Voltage)	4/Bus	2/Bus	3/Bus	1, 2, 3	7*

** Must be OPERABLE only in MODE 6 when the valves are required OPERABLE and they are open.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCT	IONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
8. C	VCS ISOLATION					
a	. Manual (CVCS Isolation Valve Control Switches)	l/Valve	l/Valve	l/Valve	1, 2, 3, 4	6
b	. West Penetration Room/Letdown Heat Exchanger Room Pressure - High	4	2	3	1, 2, 3, 4	7*
9. A	UXILIARY FEEDWATER					
a	. Manual	2 sets of 2 per S/G	1 set of 2 per S/G	2 sets of 2 per S/G	1, 2, 3	6
þ	. Steam Generator Level - Low	4/SG	2/SG	3/SG	1, 2, 3	7
С	. Steam Generator ∆P High	- 4/SG	2/SG	3/SG	1, 2, 3	7

CALVERT CLIFFS - UNIT 2

3/4 3-14

TABLE 3.3-4

1

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
 SAFETY INJECTION (SIAS) a. Manual (Trip Buttons) 	Not Applicable	Not Applicable
b. Containment Pressure - High	4.75 psig	<u><</u> 4.75 psig
c. Pressurizer Pressure - Low	<u>≥</u> 1725 psia	<u>></u> 1725 psia
 CONTAINMENT SPRAY (CSAS) a. Manual (Trip Buttons) 	Not Applicable	Not Applicable
b. Containment Pressure High	<u><</u> 4.75 psig	<u><</u> 4.75 psig
<pre>3. CONTAINMENT ISOLATION (CIS) # a. Manual CIS (Trip Buttons)</pre>	Not Applicable	Not Applicable
b. Containment Pressure - High	' <u><</u> 4.75 psig	<u><</u> 4.75 psig
4. MAIN STEAM LINE ISOLATION a. Manual (MSIV Hand Switches and Feed Head Isolation Hand Switches)	Not Applicable	Not Appliest's
	NOT APPITCADIE	NOT APPIICADIE
b. Steam Generator Pressure - Low	<u>></u> 685 psia	≥ 685 psia

Containment isolation of non-essential penetrations is also initiated by SIAS (functional units l.a and l.c).

CALVERT CLIFFS - UNIT 2

3/4 3-17

-

.

TUATION SYSTEM INSTRUMENTATION TR TRIP VALUE Not Applicable > 24 inches above	RIP_VALUES ALLOWABLE VALUES Not Applicable
TRIP VALUE Not Applicable > 24 inches above	ALLOWABLE <u>VALUES</u> Not Applicable
Not Applicable > 24 inches above	Not Applicable
Not Applicable > 24 inches above	Not Applicable
> 24 inches above	
tank bottom	≥ 24 inches above tank bottom
Not Applicable	Not Applicable
<u>≤</u> 220 mr/hr	≤ 220 mr/hr
2450 \pm 105 volts with a 2 \pm 0.2 second time delay	2450 \pm 105 volts with a 2 \pm 0.2 second time delay
3628 \pm 25 volts with a 8 \pm 0.4 second time delay	3628 \pm 25 volts with a 8 \pm 0.4 second time delay
)) Not Applicable $\leq 220 \text{ mr/hr}$ $2450 \pm 105 \text{ volts with a}$ $2 \pm 0.2 \text{ second time delay}$ $3628 \pm 25 \text{ volts with a}$ $8 \pm 0.4 \text{ second time delay}$

.

CALVERT CLIFFS - UNIT 2

3/4 3-18

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUN</u>	CTIONAL_UNIT	CHANNEL <u>CHECK</u>	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL <u>TEST</u>	MODES IN WHICH SURVEILLANCE <u>REQUIRED</u>
5.	CONTAINMENT SUMP RECIRCULATION (RAS)				
	a. Manual RAS (Trip Buttons) b. Refueling Water Tank - Low c. Automatic Actuation Logic	NA NA NA	NA R NA	R M M(1)	NA 1, 2, 3 1, 2, 3
6.	CONTAINMENT PURGE VALVES ISOLATION	·			
	a. Manual (Purge Valve Control Switch b. Containment Radiation - High Area Monitor	nes) NA S	NA R	R M	NA 6**
7.	LOSS OF POWER		•		
	 a. 4.16 kv Emergency Bus Undervoltage (Loss of Voltage) b. 4.16 kv Emergency Bus Undervoltage 	NA	R	M	1, 2, 3
	(Degraded Voltage)	NA	R	М	1, 2, 3
8.	CVCS ISOLATION				
	West Penetration Room/Letdown Heat Exchanger Room Pressure - High	NA	R	M	1, 2, 3, 4
9.	AUXILIARY FEEDWATER				
	a. Manual (Trip Buttons) b. Steam Generator Level - Low c. Steam Generator △ P - High	NA S S	NA R R	R M M(1)	NA 1, 2, 3 1, 2, 3
	u. Automatic Actuation Logic	11/3	NO.	11/17	1, 2, 3

** Must be OPERABLE only in MODE 6 when the valves are required OPERABLE and they are open.

CALVERT CLIFFS - UNIT 2

3/4 3-23

Amendment No. 3//22//36/ 37//51, 121

TABLE 4.3-2 (Continued)

TABLE NOTATION

- The logic circuits shall be tested manually at least once per 31 days.
- (3) SIAS logic circuits A-5, B-5, A-10 and B-10 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (4) CIS logic circuits A-5 and B-5 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (5) SGIS logic circuits A-1 and B-1 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.
- (6) CSAS logic circuits A-3 and B-3 may be exempted from testing during operation; however, these logic circuits shall be tested at least once per 18 months during shutdown.

.....

1

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

PENETRATION NUMBER	ISOLATION <u>Channels</u>	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)
7A	NA NA	Blind Flange ILRT-1	ILRT	NA NA
7B	NA NA	Blind Flange ILRT-2	ILRT	NA NA
8	SIAS A SIAS B	EAD-5462-MOV EAD-5463-MOV	Containment Normal Sump	≤ 13 ≤ 13
9	NA NA	SI-340 SI-326	Containment Spray	NA NA
10	NA NA	SI-330 SI-316	Containment Spray	NA NA
13	CRS A CRS B	CPA-1410-CV(3) CPA-1411-CV(3)	Purge Air Inlet	<u><</u> 7** <u><</u> 7**

3/4 6-20

CAL		<u>TABLE 3.6-1</u>					
.VER			CONTAINMENT IS	SOLATION VALVES			
T CLIF	PENETRATION NO.	ISOLATION CHANNEL	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)		
FS - UNIT 2	1A	SIAS A SIAS A SIAS A SIAS B	PS-5465-CV PS-5466-CV PS-5467-CV PS-5464-CV	R.C. and Pressurizer Sampling	<u><</u> 7		
	18	SIAS A SIAS B	VGS-2180-CV WGS-2181-CV	Containment Vent Header to Waste Gas	<7 <7		
3/4 6-19	10	SIAS A SIAS B	CVC-506-CV CVC-505-CV	RCP Seals Controlled Bleedoff	<7 <7		
	1D	NA	PS-6529SV*	Post Accident Sampling Liquid Return to RC Drain Tank	NA		
Ame	2A	SIAS A SIAS B NA NA	CVC-515-CV CVC-516-CV CVC-105 CVC-103	Letdown Line	<13 <13 NA NA		
endment No. 🛃 , 🔊 ,	28	NA NA NA NA	CVC-517-CV CVC-518-CV CVC-519-CV CVC-435-RV CVC-184	Charging Line	NA NA NA NA NA		

-85

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

ì

PENETRATION <u>NUMBER</u>	ISOLATION <u>CHANNELS</u>	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)
14	CRS A CRS B	CPA-1412-CV(3) CPA-1413-CV(3)	Purge Air Outlet	≤7** ≤7**
15	SIAS A SIAS B	RE-5291-CV RE-5292-CV	Purge Air Monitor	<u>≤</u> 7 <u>≤</u> 7
16	CIS A	CC-3832-CV	Component Cooling Water Inlet	<u><</u> 18
18	CIS B	CC-3833-CV	Component Cooling Water Outlet	≤ 18
19A	NA CIS A	IA-175 IA-2080-MOV	Instrument Air	NA ≤ 13
19B	NA NA	PA-137* PA-1044*	Plant Air	NA NA
20A	NA NA NA NA	N ₂ -347 N ₂ -612-CV* N ₂ -622-CV* N ₂ -632-CV* N ₂ -642-CV*	Nitrogen Supply	NA NA NA NA NA

CA		TABLE 3.6-1 (Continued)						
LVERT (CONTAINMENT IS	SOLATION VALVES				
	PENETRATION	ISOLATION CHANNEL	ISOLATION VALVE IDENTIFICATION NO.	FUNCTION	ISOLATION TIME (SECONDS)			
	208	NA NA	N2-348 N2-395	Nitrogen Supply	NA NA			
117 0	20C	NA NA	N2-349 N2-398	Nitrogen Supply	NA NA			
	23	SIAS A	RCW-4260-CV	R.C. Drain Tank Drains	<u><</u> 7			
	24	SIAS B	PS-6531-SV	Oxygen Sample Line	<u><</u> 7			
2/1 6. 21	37	NA NA	PSW-1020 PSW-1009	Plant Water	NA NA			
0	38	NA	DW-5460-CV*	Demineralized Water	NA			
	39	NA NA	SI-463 SI-455	Safety Injection Tank Test Line	NA NA			
	41	NA NA	SI-652-MOV (2) SI-651-MOV (2)	Shutdown Cooling	NA NA			

Ś c S

3/4 9-22

Amendment No. A/7, 85



SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NO. 138 TO FACILITY OPERATING LICENSE NO. DPR-53 AND AMENDMENT NO. 121 TO FACILITY OPERATING LICENSE NO. DPR-69 BALTIMORE GAS AND ELECTRIC COMPANY

CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2

DOCKET NOS. 50-317 AND 50-318

INTRODUCTION

8906080082 890531

PDR

ADOCK 05000317

PDC

NUCLEAR REGULA

By its letters dated January 20, 1987, as supplemented on January 12 and June 28, 1988, the Baltimore Gas and Electric Company (BG&E, the licensee) proposed a change to the Units 1 and 2 Technical Specifications (TS). The proposed change would delete the current requirement of Technical Specification (TS) Surveillance Requirement 4.6.4.1.2.c to verify that the containment purge air inlet valves (CPA-1410-CV and CPA-1411-CV) and the containment purge air outlet valves (CPA-1412-CV and CPA-1413-CV) close to their actuation positions upon receiving a safety injection actuation system (SIAS) test signal. In addition, reference to the SIAS action of the containment purge valves would be deleted from TS Tables 3.3-3, "Engineered Safety Feature Actuation System Instrumentation," Table 3.3-4, "Engineered Safety Feature Actuation System Instrumentation Trip Valves," and Table 4.3-2, "Engineered Safety Feature Actuation System Surveillance Requirements."

In addition, the January 20, 1987 application, as supplemented on January 12, 1988, requested an additional TS modification. This change would have eliminated redundancy and consolidated containment purge valve TS requirements by relocating their surveillance test requirements from TS 3/4.6.4, "Containment Isolation Valves," and TS 3/4.9.9, "Refueling Operations - Containment Purge Valve Isolation System," into an expanded TS 3/4.9.4, "Refueling Operations - Containment Penetrations." Subsequently, in the June 28, 1988 supplement, the licensee requested the withdrawal of this proposed TS modification. The NRC staff concurred with this request and has withdrawn this proposed change from further consideration.

The June 28, 1988 submittal also provided camera-ready copies of the proposed TS changes. Other than the withdrawal of the proposed TS change, discussed previously, the June 28, 1988 supplement did not affect the proposed TS changes noticed in the Federal Register (54 FR 18615) on May 1, 1989 and did not affect the staff's proposed no significant hazards determination.

DISCUSSION AND EVALUATION

The licensee has requested the deletion of the SIAS test requirements of TS 4.6.4.1.2.c and TS 3/4.3.2, "Engineered Safety Feature Actuation System Instrumentation," for the containment purge valves as this test is unnecessary and serves no safety function.

SIAS performs its safety functions when the unit is in operating modes 1-4 (Power Operations through Hot Shutdown) and is not required to be operable while in modes 5 or 6 (Cold Shutdown and Refueling). One of the functions is to close the containment purge valves. However, TS Limiting Condition for Operation (LCO) 3.6.1.7 requires, while in modes 1-4, the containment purge valves to be closed by isolating air to their air operators and by maintaining their solenoid air supply valves deenergized. This requirement renders moot the need for testing the SIAS actuation of the containment purge valves as these valves are always closed during operating modes where SIAS is required to be operable (modes 1-4). In addition, the action requirements for an open containment purge valve of TS 3.6.1.7 are more restrictive than those presently applicable in TS 3/4.6.4.

The notes in TS Tables 3.3-3, 3.3-4 and 4.3-2 are for information purposes only and impose no operability or testing requirements. Thus, the deletion of the information statement, that "Containment purge valve isolation is also initiated by SIAS (functional units 1.a, 1.b, and 1.c)," would have no effect upon previously evaluated accidents.

Section 6.2.4, "Containment Isolation System," of NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," (SRP) specifies that containment purge valves should be capable of operating in response to diverse containment isolation parameters, not including the high radiation signal. Additionally, the SRP states that the design of the control systems for automatic containment isolation valves shall be such that resetting the isolation signal will not result in an automatic reopening of containment isolation valves. With the deletion of the SIAS test requirements for the containment purge valves, compliance with these recommendations shall no longer be demonstrated at Calvert Cliffs.

However, SRP Section 6.2.4 states that if containment purge valves fail to satisfy the recommendations provided therein, they must be sealed closed during plant operational conditions where reactor coolant system temperature is 200°F or above. As previously noted, TS 3.6.1.7 imposes this specific requirement upon the Calvert Cliffs purge valves, specifying that they must be closed by isolating air to their air operators and by maintaining their solenoid air supply valves deenergized. Consequently, no diverse parameter is needed to actuate the isolation of these valves during modes 1-4 as they will already be sealed closed. Furthermore, hypothetical

- 2 -

improper maintenance on SIAS, resulting in the initiation of an open signal to the containment purge valves upon a SIAS actuation or gang reopening of valves on a SIAS signal override will have no effect upon these valves as they are incapable of operating in modes 1-4 due to the isolation of air to their operators and to the deenergization of their solenoid air supply valves. Thus, the TS 3.6.1.7 requirement to seal closed the containment purge valves during modes 1-4 eliminates 1) the need for diverse SIAS closure of these valves and 2) any safety-significant effects potentially arising from the lack of testing of the containment purge valve SIAS actuation capability which is physically remaining in place (i.e., valve opening on a SIAS closure signal or gang reopening of valves on a SIAS signal override). Consequently, the NRC staff has determined that this proposed change to the Units 1 and 2 TS is acceptable.

INTENT

The intent of this change is to eliminate the requirement to test the SIAS actuation of the containment purge valves due to the requirement of TS 3.6.1.7 (sealing closed the containment purge valves during modes 1-4) which renders the need for this test moot.

ENVIRONMENTAL CONSIDERATION

These amendments involve a change to a surveillance requirement. The staff has determined that these amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

CONCLUSION

1

The Commission made a proposed determination that the amendments involve no significant hazards consideration, which was published in the Federal Register (54 FR 18615) on May 1, 1989. The Commission consulted with the State of Maryland. No public comments were received, and the State of Maryland did not have any comments.

Based on the considerations discussed above, the staff concludes that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

PRINCIPAL CONTRIBUTOR:

S. A. McNeil

2

Dated: May 31, 1989

7590-01

UNITED STATES NUCLEAR REGULATORY COMMISSION BALTIMORE GAS AND ELECTRIC COMPANY DOCKET NOS. 50-317 AND 50-318 NOTICE OF WITHDRAWAL OF APPLICATION FOR AMENDMENTS TO FACILITY OPERATING LICENSES

The United States Nuclear Regulatory Commission (the Commission) has granted the request of the Baltimore Gas and Electric Company (the licensee) to withdraw a portion of its January 20, 1987 application, as supplemented on January 12, 1988, for proposed amendments to Facility Operating License Nos. DPR-53 and DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, located in Calvert County, Maryland.

The proposed amendments would have revised the Units 1 and 2 Technical Specifications by eliminating redundancy and consolidating containment purge value TS requirements by relocating their surveillance test requirements from TS 3/4.6.4, "Containment Isolation Values," and TS 3/4.9.9, "Refueling Operations - Containment Purge Value Isolation System," into an expanded TS 3/4.9.4, "Refueling Operations - Containment Penetrations."

The Commission has previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 1, 1989 (54 FR 18615). However, by letter dated June 28, 1988, the licensee had withdrawn this proposed change.

For further details with respect to this action, see the application for amendment dated January 20, 1987, as supplemented January 12, 1988, and

8906080083 890 PDR ADOCK 050 the licensee's letter dated June 28, 1988, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and the Calvert County Library, Prince Frederick, Maryland.

Dated at Rockville, Maryland, this ^{31st} day of ^{May 1989}.

FOR THE NUCLEAR REGULATORY COMMISSION

Sett alexander Ma That

Scott Alexander McNeil, Project Manager Project Directorate I-1 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation



OFFICIAL RECORD COPY

- 2 -