February 19, 1991 💛

Docket Nos. 50-317 and 50-318

> Mr. G. C. Creel Vice President - Nuclear Energy Baltimore Gas and Electric Company Calvert Cliffs Nuclear Power Plant MD Rts 2 & 4 P. O. Box 1535 Lusby, Maryland 20657

Distribution	
Docket File	NRC & Local PDRs
PDI-1 Reading	SVarga
EGreenman	CVogan
DMcDona1d	OGC
DHagan	GHill (8)
Wanda Jones	JCalvo
ACRS (10)	GPA/PA
OC/LFMB	Plant File
RACapra	JLinville

Dear Mr. Creel:

SUBJECT: CORRECTIONS TO AMENDMENTS NO. 149 AND NO. 130 FOR CALVERT CLIFFS UNITS 1 AND 2, RESPECTIVELY (TAC NOS. 72075 AND 72076)

By letter dated April 16, 1990, the Commission issued Amendment No. 149 to Facility Operating License No. DPR-53 and Amendment No. 130 to Facility Operating License No. DPR-69 for the Calvert Cliffs Power Plant, Unit Nos. 1 and 2, respectively.

Your letter dated February 1, 1991, noted that two footnotes associated with Table 3.3-5 were inadvertently deleted from the second page when your staff prepared the final Technical Specification pages for the requested amendments identified above. Although these footnotes were not required for the Auxiliary Feedwater (AFW) Pumps, which were the subject of the amendment request, they are applicable to other components on the first (unchanged) page of the table.

We have verified that the correction is consistent with the amendments and their supporting safety evaluation. As was noted in your letter, this was clearly an administrative error. Enclosed are the corrected pages 3/4-21 for Facility Operating License Nos. DPR-53 and DPR-69. Please replace the existing pages with the corrected pages.

Sincerely.

Original Signed By:

Daniel G. McDonald, Senior Project Manager Project Directorate I-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

9102270340 910219 PDR ADOCK 05000317 PDR

Enclosure: As stated

cc w/enclosure: See next page

OFC	:PDI-1:LA	PDI J OPM	:PDI-1:D	:	**************************************	Λ
NAME	لرن CVogan:	DMcDonald:cs	RACapra	:		Veol
DATE	: 2 / 19/91	2/19/91	2/19/91			(XPU)
2	OFFICIAL RECORD Document Name:	COPY CC 1/2 TAC NOS.	72075/72076			.(1

Mr. G. C. Creel Baltimore Gas & Electric Company

cc:

Mr. William T. Bowen, President Calvert County Board of Commissioners Prince Frederick, Maryland 20678

D. A. Brune, Esq. General Counsel Baltimore Gas and Electric Company P. O. Box 1475 Baltimore, Maryland 21203

Mr. Jay E. Silberg, Esq. Shaw, Pittman, Potts and Trowbridge 2300 N Street, NW Washington, DC 20037

Ms. G. L. Adams, Licensing Calvert Cliffs Nuclear Power Plant MD Rts 2 & 4, P. O. Box 1535 Lusby, Maryland 20657

Resident Inspector c/o U.S.Nuclear Regulatory Commission P. O. Box 437 Lusby, Maryland 20657

Mr. Richard McLean Administrator - Radioecology Department of Natural Resources 580 Taylor Avenue Tawes State Office Building PPER B3 Annapolis, Maryland 21401

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406 Calvert Cliffs Nuclear Power Plant

Mr. Joseph H. Walter Engineering Division Public Service Commission of Maryland American Building 231 E. Baltimore Street Baltimore, Maryland 21202-3486

Ms. Kirsten A. Burger, Esq. Maryland People's Counsel American Building, 9th Floor 231 E. Baltimore Street Baltimore, Maryland 21202

Ms. Patricia Birnie Co-Director Maryland Safe Energy Coalition P. O. Box 902 Columbia, Maryland 21044

ï

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INITIATING SIGNAL AND FUNCTION		NG SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS	
6. <u>Steam Generator Pressure-Low</u>				
	a. b.	Main Steam Isolation Feedwater Isolation	<pre>≤ 6.9 </pre> ≤ 80	
7.	<u>Refueling Water Tank-Low</u>			
	a.	Containment Sump Recirculation	<u><</u> 80	
8.	Reactor Trip			
	a.	Feedwater Flow Reduction to 5%	<u><</u> 20	
9.	Loss of Power			
	a.	4.16 kv Emergency Bus Under- voltage (Loss of Voltage)	<u><</u> 2.2***	
	b.	4.16 kv Emergency Bus Under- voltage (Degraded Voltage)	<u><</u> 8.4***	
10.	<u>Stea</u>	am Generator Level-Low		
	a.	Steam Driven AFW Pump	<u><</u> 180	
	b.	Motor Driven AFW Pump	<u><</u> 180	
11.	1. <u>Steam Generator △P-High</u>			
	a.	Auxiliary Feedwater Isolation	<u>≤</u> 20.0	

TABLE NOTATION

- * Diesel generator starting and sequence loading delays included.
- ** Diesel generator starting and sequence loading delays <u>not</u> included. Offsite power available.
- *** Response time measured from the incidence of the undervoltage condition to the diesel generator start signal.
- (1) Header fill time not included.

9102280067 910219 PDR ADDCK 05000317 P PDR

CALVERT CLIFFS - UNIT 1

Amendment No. 40/84/71/72/ 88,149

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INITIATING SIGNAL AND FUNCTION		IG SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
6.	<u>Stea</u>		
	a.	Main Steam Isolation	<u><</u> 6.9
	b.	Feedwater Isolation	≤ 80
7.	<u>Refu</u>	eling Water Tank-Low	
	a.	Containment Sump Recirculation	<u><</u> 80
8.	<u>Reac</u>	tor Trip	
	a.	Feedwater Flow Reduction to 5%	<u><</u> 20
9.	<u>Loss</u>	of Power	
	a.	4.16 kv Emergency Bus Under- voltage (Loss of Voltage)	<u><</u> 2.2***
	b.	4.16 kv Emergency Bus Under- voltage (Degraded Voltage)	<u><</u> 8.4***
10.	<u>Stea</u>	<u>m Generator Level - Low</u>	
	a.	Motor Driven AFW Pump	<u><</u> 180
	b.	Steam Driven AFW Pump	<u><</u> 180
11.	<u>Stea</u>	m Generator △P-High	
	a.	Auxiliary Feedwater Isolation	<u><</u> 20.0

TABLE NOTATION

- * Diesel generator starting and sequence loading delays included.
- ** Diesel generator starting and sequence loading delays <u>not</u> included. Offsite power available.
- *** Response time measured from the incidence of the undervoltage condition to the diesel generator start signal.