

*Docket File*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 8, 1990

Docket Nos. 50-317  
and 50-318

Mr. G. C. Creel  
Vice President - Nuclear Energy  
Baltimore Gas and Electric Company  
Calvert Cliffs Nuclear Power Plant  
MD Rts. 2 & 4  
P. O. Box 1535  
Lusby, Maryland 20657

Dear Mr. Creel:

SUBJECT: CORRECTION TO AMENDMENTS NO. 99 (CALVERT CLIFFS UNIT 1) AND  
81 (CALVERT CLIFFS UNIT 2)

By letter dated February 22, 1985, the Commission issued Amendment No. 99 to Facility Operating License No. DPR-53 and Amendment No. 81 to Facility Operating License No. DPR-69 for the Calvert Cliffs Power Plant, Unit Nos. 1 and 2, respectively.

Your staff has recently identified an incorrect measurement range in Table 3.3-6, page 3/4 3-26 of Facility Operating License No. DPR-69 due to an administrative error when the amendments were issued. The current value for the containment purge and exhaust isolation monitors is a measurement range of  $10^{-4}$  -  $10^4$  mr/hr. The correct range is  $10^{-1}$  -  $10^4$  mr/hr.

Another error was also identified in the same Table and page of Facility Operating License No. DPR-53. The current values for the containment RCS leakage detection gaseous activity monitor and the particulate activity monitor are measurement ranges of  $1-10^6$  CPM. The correct range for these instruments is  $10^1$  -  $10^6$  CPM.

Enclosed are the corrected pages 3/4 3-26 for Facility Operating License Nos. DPR-53 and DPR-69. Also enclosed are pages 3/4 3-25 which have no changes, but are included as single sided copies in lieu of double sided pages. We have verified that the corrections are consistent with the amendments and the supporting safety evaluation. Please replace the existing pages with the corrected pages.

9005170047 900508  
PDR ADOCK 05000317  
P FDC

*DF01  
11*

Mr. G. C. Creel

- 2 -

Please accept our apologies for any inconvenience these errors may have caused. We will work closely with your staff to eliminate administrative errors prior to the issuance of future amendments.

Sincerely,

ORIGINAL SIGNED BY:

Daniel G. McDonald, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures: As stated

cc: See next page

Distribution:

Docket File  
NRC/Local PDRs  
PDI-1 Rdg  
SVarga  
BBoger  
RACapra  
DMcDonald  
CVogan  
OGC  
EJordan  
ACRS(10)  
Plant File  
JLinville

PDI-1  
CVogan *W*  
5/8/90

*DMcDonald*  
PDI-1  
DMcDonald:rsc  
5/8/90

PDI-1 *RGC*  
RACapra  
5/8/90

DOCUMENT NAME: MEMO CORRECT AMDMT NOS 99/81

Mr. G. C. Creel  
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

Mr. William T. Bowen, President  
Calvert County Board of  
Commissioners  
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter  
Engineering Division  
Public Service Commission of Maryland  
American Building  
231 E. Baltimore Street  
Baltimore, Maryland 21202-3486

D. A. Brune, Esq.  
General Counsel  
Baltimore Gas and Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203

Ms. Kirsten A. Burger, Esq.  
Maryland People's Counsel  
American Building, 9th Floor  
231 E. Baltimore Street  
Baltimore, Maryland 21202

Mr. Jay E. Silberg, Esq.  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, NW  
Washington, DC 20037

Ms. Patricia Birnie  
Co-Director  
Maryland Safe Energy Coalition  
P. O. Box 902  
Columbia, Maryland 21044

Ms. G. L. Adams, Licensing  
Calvert Cliffs Nuclear Power Plant  
MD Rts 2 & 4, P. O. Box 1535  
Lusby, Maryland 20657

Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 437  
Lusby, Maryland 20657

Mr. Richard McLean  
Administrator - Radioecology  
Department of Natural Resources  
580 Taylor Avenue  
Tawes State Office Building  
PPER B3  
Annapolis, Maryland 21401

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

INSTRUMENTATION

3/4.3.3 MONITORING INSTRUMENTATION

RADIATION MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

---

3.3.3.1 The radiation monitoring instrumentation channels shown in Table 3.3-6 shall be OPERABLE with their alarm/trip setpoints within the specified limits.

APPLICABILITY: As shown in Table 3.3-6.

ACTION:

- a. With a radiation monitoring channel alarm/trip setpoint exceeding the value shown in Table 3.3-6, adjust the setpoint to within the limit within 4 hours or declare the channel inoperable.
- b. With one or more radiation monitoring channels inoperable, take the ACTION shown in Table 3.3-6.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

---

4.3.3.1 Each radiation monitoring instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations during the modes and at the frequencies shown in Table 4.3-3.

9005170056 900508  
PDR ADOCK 05000317  
P FDC

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM/TRIP SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
1. AREA MONITOR					
a. Containment					
i. Purge & Exhaust Isolation	3	6	≤ 200 mr/hr	10 <sup>-1</sup> - 10 <sup>4</sup> mr/hr	16
b. Containment Area High Range	2	1, 2, 3, & 4	≤ 10 R/hr	1 - 10 <sup>8</sup> R/hr	30
2. PROCESS MONITORS					
a. Containment					
i. Gaseous Activity					
a) RCS Leakage Detection	1	1, 2, 3, & 4	Not Applicable	10 <sup>1</sup> - 10 <sup>6</sup> cpm	14
ii. Particulate Activity					
a) RCS Leakage Detection	1	1, 2, 3, & 4	Not Applicable	10 <sup>1</sup> - 10 <sup>6</sup> cpm	14
b. Noble Gas Effluent Monitors					
i. Main Vent Wide Range	1	1, 2, 3, & 4	*	10 <sup>-7</sup> to 10 <sup>+5</sup> μCi/cc	30
ii. Main Steam Header	2	1, 2, 3, & 4	*	10 <sup>-2</sup> to 10 <sup>5</sup> R/hr	30

\* Alarm setpoint to be specified in a controlled document (e.g., setpoint control manual).

## INSTRUMENTATION

### 3/4.3.3 MONITORING INSTRUMENTATION

#### RADIATION MONITORING INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.3.1 The radiation monitoring instrumentation channels shown in Table 3.3-6 shall be **OPERABLE** with their alarm/trip setpoints within the specified limits.

**APPLICABILITY:** As shown in Table 3.3-6.

#### **ACTION:**

- a. With a radiation monitoring channel alarm/trip setpoint exceeding the value shown in Table 3.3-6, adjust the setpoint to within the limit within 4 hours or declare the channel inoperable.
- b. With one or more radiation monitoring channels inoperable, take the **ACTION** shown in Table 3.3-6.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.3.3.1 Each radiation monitoring instrumentation channel shall be demonstrated **OPERABLE** by the performance of the **CHANNEL CHECK**, **CHANNEL CALIBRATION** and **CHANNEL FUNCTIONAL TEST** operations during the modes and at the frequencies shown in Table 4.3-3.

TABLE 3.3-6  
RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM/TRIP SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
<b>1. AREA MONITORS</b>					
a. Containment					
i. Purge & Exhaust Isolation	3	6	≤ 200 mr/hr	10 <sup>-1</sup> - 10 <sup>4</sup> mr/hr	16
b. Containment Area High Range	2	1, 2, 3, & 4	≤ 10 R/hr	1 - 10 <sup>8</sup> R/hr	30
<b>2. PROCESS MONITORS</b>					
a. Containment					
i. Gaseous Activity					
a) RCS Leakage Detection	1	1, 2, 3, & 4	Not Applicable	10 <sup>1</sup> - 10 <sup>6</sup> cpm	14
ii. Particulate Activity					
a) RCS Leakage Detection	1	1, 2, 3, & 4	Not Applicable	10 <sup>1</sup> - 10 <sup>6</sup> cpm	14
b. Noble Gas Effluent Monitors					
i. Main Vent Wide Range	1	1, 2, 3, & 4	*	10 <sup>-7</sup> to 10 <sup>5</sup> μCi/cc	30
ii. Main Steam Header	2	1, 2, 3, & 4	*	10 <sup>-2</sup> to 10 <sup>5</sup> R/hr	30

\* Alarm setpoint to be specified in a controlled document (e.g., setpoint control manual).