



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 12, 1990

Docket Nos. 50-317
and 50-318

Mr. G. C. Creel
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4
P. O. Box 1535
Lusby, Maryland 20657

Dear Mr. Creel:

SUBJECT: CALVERT CLIFFS POWER PLANT, UNIT NOS. 1 AND 2 - CORRECTION TO
AMENDMENTS (TAC NOS. 54523 AND 54524)

By letter dated September 28, 1990, the Commission issued Amendment No. 147 to Facility Operating License No. DPR-53 and Amendment No. 148 to Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2. The amendments added Technical Specifications (TS) relating to surveillance, operability, and reporting requirements for the reactor vessel level monitoring systems (RVLMS) TS 34.3.3.6, "Post Accident Instrumentation," including TS Tables 3.3-10 and 4.3-10, and TS 6.9.2, "Special Reports." In addition, the applicable Bases sections of the TS were updated to reflect the changes.

The Commission inadvertently assigned Amendment No. 148 to Facility Operating License No. DPR-69. The correct Amendment No. is 128. The corrected TS pages are enclosed.

Also, due to an administrative error, the existing amendment numbers for the Unit Nos. 1 and 2 overleaf pages were inadvertently crossed out although these pages contained no revisions. A copy of the corrected pages for both Units 1 and 2 are enclosed (Pages B 3/4/43-4 and 6-18).

01110
9010240001 901012
PDR ADOCK 05000317
F FDC


Handwritten signature
11

Mr. G. C. Creel

- 2 -

We apologize for any inconvenience these errors may have caused.

Sincerely,

A handwritten signature in black ink, appearing to read "Daniel G. McDonald". The signature is fluid and cursive, with a large initial "D" and "M".

Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc: See next page

Mr. G. C. Creel
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

Mr. William T. Bowen, President
Calvert County Board of
Commissioners
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esq.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Ms. Kirsten A. Burger, Esq.
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Mr. Jay E. Silberg, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Ms. Patricia Birnie
Co-Director
Maryland Safe Energy Coalition
P. O. Box 902
Columbia, Maryland 21044

Ms. G. L. Adams, Licensing
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4,
P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
P. O. Box 437
Lusby, Maryland 20657

Mr. Richard McLean
Administrator - Radioecology
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
PPER B3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. G. C. Creel

- 2 -

We apologize for any inconvenience these errors may have caused.

Sincerely,

ORIGINAL SIGNED BY:

Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc: See next page

Distribution:

Docket File	OGC
NRC/Local PDRs	DHagan
PDI-1 Rf	EJordan
SVarga	GHill(8)
BBoger	Wanda Jones
CVogan	JCalvo
RCapra	ACRS(10)
DMcDonald	GPA/PA
OC/LFMB	Plant File
MWaterman	

PDI-1:LA *CV*
CVogan:rsc
10/12/90

DMcDonald
PDI-1:PM
DMcDonald
10/12/90

PDI-1:D
RACapra

DOCUMENT NAME: CORRECTION LTR CC 54524

INSTRUMENTATION

BASES

3/4.3.3.9 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The alarm/trip setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of Specification 3.11.2.1.a based on average annual X/Q. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR 50.

3/4.3.3.10 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The alarm/trip setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR 50.

9010240002 901012
PDR ADOCK 05000317
PDC

ADMINISTRATIVE CONTROLS

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The radioactive Effluent Release Report to be submitted 60 days after January 1 of each year shall also include an assessment of radiation doses to the likely most exposed **MEMBER OF THE PUBLIC** from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, Environmental Radiation Protection Standards for Nuclear Power Operation. Acceptable methods for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Rev. 1, October 1977, and NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants".

The Radioactive Effluent Release Reports shall include the following information for each class of solid waste (as defined by 10 CFR Part 61) shipped offsite during the report period:

- a. Container volume,
- b. Total curie quantity (specify whether determined by measurement or estimate),
- c. Principal radionuclides (specify whether determined by measurement or estimate),
- d. Source of waste and processing employed (e.g., dewatered spent resin, compacted dry waste, evaporator bottoms),
- e. Solidification agent or absorbent (e.g., cement).

The Radioactive Effluent Release Reports shall include a list and description of unplanned releases from the site to **UNRESTRICTED AREAS** of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Radioactive Effluent Release Reports shall include any changes made during the reporting period to the **PROCESS CONTROL PROGRAM (PCP)**, and to the **OFFSITE DOSE CALCULATION MANUAL (ODCM)**, as well as a listing of new locations for dose calculations identified by the annual land use census pursuant to Specification 3.12.2.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the NRC Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification:

TABLE 3.3-10

POST-ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Containment Pressure	2	31
2. Wide Range Logarithmic Neutron Flux Monitor	2	31
3. Reactor Coolant Outlet Temperature	2	31
4. Pressurizer Pressure	2	31
5. Pressurizer Level	2	31
6. Steam Generator Pressure	2/steam generator	31
7. Steam Generator Level (Wide Range)	2/steam generator	31
8. Auxiliary Feedwater Flow Rate	2/steam generator	31
9. RCS Subcooled Margin Monitor	1	31
10. PORV/Safety Valve Acoustic Flow Monitoring	1/valve	31
11. PORV Solenoid Power Indication	1/valve	31
12. Feedwater Flow	2	31
13. Containment Water Level (Wide Range)	2	32, 33
14. Reactor Vessel Water Level	2*	34, 35

* A channel has eight sensors in a probe. A channel is operable if four or more sensors, one or more in the upper three and three or more in the lower five, are operable.

TABLE 3.3-10 (Continued)

ACTION STATEMENTS

- ACTION 31 - With the number of OPERABLE post-accident monitoring channels less than required by Table 3.3-10, either restore the inoperable channel to OPERABLE status within 30 days or be in HOT SHUTDOWN within the next 12 hours.
- ACTION 32 - With the number of OPERABLE post-accident monitoring channels one less than the minimum channel operable requirement in Table 3.3-10, operation may proceed provided the inoperable channel is restored to OPERABLE status at the next outage of sufficient duration.
- ACTION 33 - With the number of OPERABLE post-accident monitoring channels two less than required by Table 3.3-10, either restore one inoperable channel to OPERABLE status within 30 days or be in HOT SHUTDOWN within the next 12 hours.
- ACTION 34 - With the number of OPERABLE Post-Accident Monitoring Channels one less than the minimum Channel OPERABLE requirement in Table 3.3-10, either restore the system to OPERABLE status within 7 days if repairs are feasible without shutting down or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event, outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- ACTION 35 - With the number of OPERABLE Channels two less than required by Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 48 hours if repairs are feasible without shutting down or:
1. Initiate an alternate method of monitoring for core and reactor coolant system voiding;
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event, outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status; and
 3. Restore the system to OPERABLE status at the next scheduled refueling.

TABLE 4.3-10

POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R
2. Wide Range Logarithmic Neutron Flux Monitor	M	N.A.
3. Reactor Coolant Outlet Temperature	M	R
4. Pressurizer Pressure	M	R
5. Pressurizer Level	M	R
6. Steam Generator Pressure	M	R
7. Steam Generator Level (Wide Range)	M	R
8. Auxiliary Feedwater Flow Rate	M	R
9. RCS Subcooled Margin Monitor	M	R
10. PORV/Safety Valve Acoustic Monitor	N.A.	R
11. PORV Solenoid Power Indication	N.A.	N.A.
12. Feedwater Flow	M	R
13. Containment Water Level (Wide Range)	M	R
14. Reactor Vessel Water Level	M	N.A.

INSTRUMENTATION

BASES

3/4.3.3.6 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables following an accident. This capability is consistent with the recommendations of Regulatory Guide 1.97, "Instrumentation for Light-Water-Cooled Nuclear Plants to Assess Plant Conditions During and Following an Accident," December 1975, and NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations."

The subcooled Margin Monitor (SMM), the Heated Junction Thermocouple (HJTC), and the Core Exit Thermocouples (CET) comprise the Inadequate Core Cooling (ICC) instrumentation required by Item II.F.2 NUREG-0737, the Post TMI-2 Action Plan. The function of the ICC instrumentation is to enhance the ability of the plant operator to diagnose the approach to, and recovery from, ICC. Additionally, they aid in tracking reactor coolant inventory. These instruments are included in the Technical Specifications at the request of NRC Generic Letter 83-37. These instruments are not required by the accident analysis, nor to bring the plant to HOT STANDBY or COLD SHUTDOWN.

In the event more than four sensors in a Reactor Vessel Level channel are inoperable, repairs may only be possible during an extended COLD SHUTDOWN. This is because the sensors are accessible only after the plant has been cooled down and drained, and the missile shield has been moved. If only one channel is inoperable, it should be restored to OPERABLE status in accordance with the schedule outlined in a Special Report. If both channels are inoperable, the system shall be restored to OPERABLE status in the next refueling outage.

3/4.3.3.7 FIRE DETECTION INSTRUMENTATION

OPERABILITY of the fire detection instrumentation ensures that adequate warning capability is available for the prompt detection of fires. This capability is required in order to detect and locate fires in their early stages. Prompt detection of fires will reduce the potential for damage to safety related equipment and is an integral element in the overall facility fire protection program.

In the event that a portion of the fire detection instrumentation is inoperable, the establishment of frequent fire patrols in the affected areas is required to provide detection capability until the inoperable instrumentation is restored to operability.

INSTRUMENTATION

BASES

3/4.3.3.9 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The alarm/trip setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of Specification 3.11.2.1.a based on average annual X/Q. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

3/4.3.3.10 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The alarm/trip setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

ADMINISTRATIVE CONTROLS

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The radioactive Effluent Release Report to be submitted 60 days after January 1 of each year shall also include an assessment of radiation doses to the likely most exposed **MEMBER OF THE PUBLIC** from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, Environmental Radiation Protection Standards for Nuclear Power Operation. Acceptable methods for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Rev. 1, October 1977, and NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants".

The Radioactive Effluent Release Reports shall include the following information for each class of solid waste (as defined by 10 CFR Part 61) shipped offsite during the report period:

- a. Container volume,
- b. Total curie quantity (specify whether determined by measurement or estimate),
- c. Principal radionuclides (specify whether determined by measurement or estimate),
- d. Source of waste and processing employed (e.g., dewatered spent resin, compacted dry waste, evaporator bottoms),
- e. Solidification agent or absorbent (e.g., cement).

The Radioactive Effluent Release Reports shall include a list and description of unplanned releases from the site to **UNRESTRICTED AREAS** of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Radioactive Effluent Release Reports shall include any changes made during the reporting period to the **PROCESS CONTROL PROGRAM (PCP)**, and to the **OFFSITE DOSE CALCULATION MANUAL (ODCM)**, as well as a listing of new locations for dose calculations identified by the annual land use census pursuant to Specification 3.12.2.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the NRC Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification:

ADMINISTRATIVE CONTROLS

- a. ECCS Actuation, Specifications 3.5.2 and 3.5.3
- b. Inoperable Seismic Monitoring Instrumentation, Specification 3.3.3.3.
- c. Inoperable Meteorological Instrumentation, Specification 3.3.3.4.
- d. Seismic event analysis, Specification 4.3.3.3.2.
- e. Core Barrel Movement, Specification 3.4.11.
- f. Fire Detection Instrumentation, Specification 3.3.3.7.
- g. Fire Suppression Systems, Specifications 3.7.11.1, 3.7.11.2, 3.7.11.3, 3.7.11.4, and 3.7.11.5.
- h. Penetration Fire Barriers, Specification 3.7.12.
- i. Steam Generator Tube Inspection Results, Specification 4.4.5.5.a and c.
- j. Specific Activity of Primary Coolant, Specification 3.4.8.
- k. Containment Structural Integrity, Specification 4.6.1.6.
- l. Radioactive Effluents - Calculated Dose and Total Dose, Specifications 3.11.1.2, 3.11.2.2, 3.11.2.3, and 3.11.4.
- m. Radioactive Effluents - Liquid Radwaste, Gaseous Radwaste and Ventilation Exhaust Treatment Systems Discharges, Specifications 3.11.1.3 and 3.11.2.4.
- n. Radiological Environmental Monitoring Program, Specification 3.12.1.
- o. Radiation Monitoring Instrumentation, Specification 3.3.3.1 (Table 3.3-6).
- p. Overpressure Protection Systems, Specification 3.4.9.3.
- q. Hydrogen Analyzers, Specification 3.6.5.1.
- r. Post-Accident Instrumentation, Specification 3.3.3.6