

February 15, 2001

Mr. Mike Reandeau
Director - Licensing
Clinton Power Station
P.O. Box 678
Mail Code #V920
Clinton, IL 61727

SUBJECT: CLINTON POWER STATION - EXTENSION OF EMERGENCY DIESEL
GENERATOR ALLOWED OUTAGE TIME TO 14 DAYS (TAC NO. MB0861)

Dear Mr. Reandeau:

By letter dated December 29, 2000, AmerGen Energy Company, LLC (AmerGen, the licensee) submitted an application for license amendment to extend the Technical Specification (TS) allowed outage time (AOT) from 72 hours to 14 days for the Division 1 and 2 diesel generators (DGs).

Subsequently, by letter dated January 14, 2001, AmerGen requested enforcement discretion for the Division 2 DG, due to high vibration of a bearing during the 24-hour surveillance test. AmerGen also requested exigent review of the amendment request. The U.S. Nuclear Regulatory Commission (NRC) staff granted the enforcement discretion as discussed in a letter dated January 18, 2001. In that letter, the staff stated that it would review and issue the license amendment request as promptly as possible (i.e., exigent review schedule).

Upon further review, the NRC staff has found that permanent risk informed TS changes of a magnitude such as this one should not be reviewed and approved on an exigent basis. This particular risk informed permanent TS change requires a careful review because of the risk significance. We believe that this constitutes special circumstances under which exigent review is not appropriate following issuance of enforcement discretion. Therefore, the staff will review your amendment request on a normal priority schedule instead of an exigent schedule.

Contact me if you have any questions.

Sincerely,

/RA/

Jon B. Hopkins, Senior Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: See next page

Mike Reandeau

Clinton Power Station, Unit 1
AmerGen Energy Company, LLC

cc:

J. Michael Heffley
Vice President
Clinton Power Station
P.O. Box 678
Clinton, IL 61727

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
ATTN: Mr. Frank Niziolek
1035 Outer Park Drive
Springfield, IL 62704

Patrick Walsh
Manager Nuclear Station
Engineering Department
Clinton Power Station
P.O. Box 678
Clinton, IL 61727

Kevin P. Gallen
Morgan, Lewis & Bockius LLP
1800 M Street, NW
Washington, DC 20036

Resident Inspector
U.S. Nuclear Regulatory Commission
RR#3, Box 229 A
Clinton, IL 61727

R. T. Hill
Licensing Services Manager
General Electric Company
175 Curtner Avenue, M/C 481
San Jose, CA 95125

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, IL 61727

J. W. Blattner
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, IL 60603

Mr. Mike Reandeau
Director - Licensing
Clinton Power Station
P.O. Box 678
Mail Code #V920
Clinton, IL 61727

February 15, 2001

SUBJECT: CLINTON POWER STATION - EXTENSION OF EMERGENCY DIESEL
GENERATOR ALLOWED OUTAGE TIME TO 14 DAYS (TAC NO. MB0861)

Dear Mr. Reandeau:

By letter dated December 29, 2000, AmerGen Energy Company, LLC (AmerGen, the licensee) submitted an application for license amendment to extend the Technical Specification (TS) allowed outage time (AOT) from 72 hours to 14 days for the Division 1 and 2 diesel generators (DGs).

Subsequently, by letter dated January 14, 2001, AmerGen requested enforcement discretion for the Division 2 DG, due to high vibration of a bearing during the 24-hour surveillance test. AmerGen also requested exigent review of the amendment request. The U.S. Nuclear Regulatory Commission (NRC) staff granted the enforcement discretion as discussed in a letter dated January 18, 2001. In that letter, the staff stated that it would review and issue the license amendment request as promptly as possible (i.e., exigent review schedule).

Upon further review, the NRC staff has found that permanent risk informed TS changes of a magnitude such as this one should not be reviewed and approved on an exigent basis. This particular risk informed permanent TS change requires a careful review because of the risk significance. We believe that this constitutes special circumstances under which exigent review is not appropriate following issuance of enforcement discretion. Therefore, the staff will review your amendment request on a normal priority schedule instead of an exigent schedule.

Contact me if you have any questions.

Sincerely,
/RA/

Jon B. Hopkins, Senior Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: See next page

DISTRIBUTION:

PD3-2 r/f OGC
PUBLIC ACRS
GGrant, RIII

OFFICE	PM:PD3-2	LA:PD3-2	SC:PD3-2
NAME	JHopkins	THarris	AMendiola
DATE	2/8/01	2/9/01	2/15/01

DOCUMENT NAME: G:\PDIII-2\CLINTON\edg-review-ltr.wpd
OFFICIAL RECORD COPY