

Exelon Generation Company, LLC
Dresden Nuclear Power Station
6500 North Dresden Road
Morris, IL 60450-9765

www.exeloncorp.com

10 CFR 50.4

February 12, 2001

PSLTR: #01-0020

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555


Dresden Nuclear Power Station Units 2 and 3
Facility Operating License Nos. DPR-19 and DPR-25
Docket Nos. 50-237 and 50-249

Subject: Monthly Operating Data Report for January 2001

In accordance with Technical Specifications, Section 6.9.A, we are submitting the January 2001, Monthly Report for Dresden Nuclear Power Station, Units 2 and 3.

Should you have any questions concerning this letter, please contact Mr. D.F. Ambler, Regulatory Assurance Manager, at (815) 942-2920 extension 3800.

Respectfully,



Preston Swafford
Site Vice President
Dresden Nuclear Power Station

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector - Dresden Nuclear Power Station

IE24

ATTACHMENT

DRESDEN NUCLEAR POWER STATION UNITS 2 AND 3

MONTHLY OPERATING REPORT

FOR JANUARY 2001

EXELON GENERATING COMPANY, LLC

FACILITY OPERATING LICENSES NOS. DPR-19 AND DPR-25

NRC DOCKET NOS. 50-237 AND 50-249

TABLE OF CONTENTS

- I. Introduction**
- II. Summary of Operating Experience**
 - A. Unit 2 Monthly Operating Experience Summary
 - B. Unit 3 Monthly Operating Experience Summary
- III. Operating Data Statistics**
 - A. Operating Data Report - Dresden Unit 2
 - B. Operating Data Report - Dresden Unit 3
- IV. Unit Shutdowns**
 - A. Unit 2 Shutdowns
 - B. Unit 3 Shutdowns
- V. Amendments to Facility Licenses or Technical Specifications**
- VI. Unique Reporting Requirements**
 - A. Main Steam Relief and/or Safety Valve Operations

I. Introduction

Dresden Nuclear Power Station is a two reactor generating facility owned and operated by the Exelon Generating Company, LLC. Dresden Station is located at the confluence of the Kankakee and Des Plaines Rivers, in Grundy County, near Morris, Illinois.

Dresden Units 2 and 3 are General Electric Boiling Water Reactors; each licensed at 2527 megawatts thermal. The gross outputs of Units 2 and 3 are 832 and 834 megawatts electrical, respectively, with design net electrical output ratings of 795 MWe each. The commercial service date for Unit 2 is August 11, 1970 and October 30, 1971 for Unit 3.

Waste heat is rejected to a man-made cooling lake using the Kankakee River for make up and the Illinois River for blowdown.

The Architect-Engineer for Dresden Units 2 and 3 was Sargent and Lundy of Chicago, Illinois.

II. SUMMARY OF OPERATING EXPERIENCE FOR JANUARY 2001

A. UNIT 2 MONTHLY OPERATING EXPERIENCE SUMMARY

Unit 2 operated throughout the period at full power except for short periods for maintenance and surveillances.

B. UNIT 3 MONTHLY OPERATING EXPERIENCE SUMMARY

Unit 3 operated throughout the period at full power except for short periods for maintenance and surveillances.

III. OPERATING DATA STATISTICS

A. Dresden Unit 2 Operating Data Report for January 2001

DOCKET NO. 050-237
DATE February 12, 2001
COMPLETED BY Sherry Butterfield
TELEPHONE (815) 942-2920

OPERATING STATUS

1. REPORTING PERIOD: January 2001
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth): 2,527
MAXIMUM DEPENDABLE CAPACITY (MWe NET): 772
DESIGN ELECTRICAL RATING (MWe Net): 795
3. POWER LEVEL TO WHICH RESTRICTED (MWe Net): No Restrictions
4. REASONS FOR RESTRICTIONS (IF ANY): See Section 2.1 of this report.

Unit Two Monthly Operating Status			
	This Month	Year to Date	Cumulative
5. Hours in Period	744	744	267,144
6. Reactor Critical - Hours	744	744	200,272
7. Reactor Reserve Shutdown - Hours	0	0	0
8. Hours Generator On-Line	744	744	191,888
9. Unit Reserve Shutdown - Hours	0	0	4
10. Thermal Energy Generated - MWhGross	1,876,471	1,876,471	411,667,817
11. Electrical Energy Generated - MWeGross	623,074	623,074	131,947,216
12. Electrical Energy Generated - MWe Net	597,484	597,484	125,007,471
13. Reactor Service Factor - Percent	100.0%	100.0%	75.0%
14. Reactor Availability Factor - Percent	100.0%	100.0%	75.0%
15. Generator Service Factor - Percent	100.0%	100.0%	71.8%
16. Generator Availability Factor - Percent	100.0%	100.0%	71.8%
17. Capacity Factor - (Using MDC Net) Percent	104.0%	104.0%	60.6%
18. Capacity Factor - (Using DER Net) Percent	101.1%	101.1%	58.9%
19. Forced Outage Factor - Percent	0%	0.0%	12.0%

III. OPERATING DATA REPORT

B. Dresden Unit Three Operating Data Report for January 2001

DOCKET NO. 050-249
DATE February 12, 2001
COMPLETED BY Sherry Butterfield
TELEPHONE (815) 942-2920

OPERATING STATUS

1. REPORTING PERIOD: January 2001
2. CURRENTLY AUTHORIZED POWER LEVEL (MWth): 2,527
MAXIMUM DEPENDABLE CAPACITY (MWe Net): 773
DESIGN ELECTRICAL RATING (MWe Net): 795
3. POWER LEVEL TO WHICH RESTRICTED: No Restrictions
4. REASONS FOR RESTRICTIONS (IF ANY): See Section 2.2 of this report.

Unit Three Monthly Operating Status			
	This Month	Year to Date	Cumulative
5. Hours in Period	744	744	256,464
6. Reactor Critical - Hours	744	744	187,324
7. Reactor Reserve Shutdown - Hours	0	0	0
8. Hours Generator On-Line	744	744	179,546
9. Unit Reserve Shutdown - Hours	0	0	1
10. Thermal Energy Generated - MWh Gross	1,877,759	1,877,759	385,283,400
11. Electrical Energy Generated - MWe Gross	617,547	617,547	123,594,294
12. Electrical Energy Generated - MWe Net	595,974	595,974	117,432,557
13. Reactor Service Factor - Percent	100.0%	100.0%	73.4%
14. Reactor Availability Factor - Percent	100.0%	100.0%	73.4%
15. Generator Service Factor - Percent	100.0%	100.0%	70.0%
16. Generator Availability Factor - Percent	100.0%	100.0%	70.0%
17. Capacity Factor - (Using MDC Net) Percent	103.8%	103.8%	57.9%
18. Capacity Factor - (Using DER Net) Percent	100.9%	100.9%	56.3%
19. Forced Outage Factor - Percent	0	0.0%	12.4%

IV. UNIT SHUTDOWNS

A. Unit 2 Shutdowns for January 2001

NO	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR(3)	CORRECTIVE ACTIONS/ COMMENTS
None						

B. Unit 3 Shutdowns for January 2001

NO	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR(3)	CORRECTIVE ACTIONS/ COMMENTS
None						

LEGEND:

(1) Type:

- F - Forced
- S - Scheduled

(2) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training & Licensing Exam
- F. Administrative
- G. Operational Error
- H. Other (Explain)

(3) Method

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)
- 5. Load Reduction

V. Amendments to Facility Licenses or Technical Specifications

Dresden Nuclear Power Station implemented the Condensate Storage Tank (CST) Level Amendment No. 182 for Unit 2 and 177 for Unit 3 in January 2001.

VI. Unique Reporting Requirements

A. Main Steam Relief and/or Safety Valve Operations

Unit 2 - None
 Unit 3 - None