

May 23, 1998

SEE: REPORT

Mr. Charles H. Cruse
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: ISSUANCE OF AMENDMENTS FOR CALVERT CLIFFS NUCLEAR POWER PLANT
UNIT NO. 1 (TAC NO. M97855) AND UNIT NO. 2 (TAC NO. M97856)

Dear Mr. Cruse:

The Commission has issued the enclosed Amendment No. 228 to Facility Operating License No. DPR-53 and Amendment No. 202 to Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated January 31, 1997, as supplemented February 13, February 28, March 25, April 16, August 19, and September 29, 1997, January 22, March 17, April 8, April 21, and May 22, 1998.

The amendments revise the TS for a reduction of the total reactor coolant system flow limit from 370,000 gallons per minute (gpm) to 340,000 gpm in support of increased steam generator tube plugging.

As an administrative action which does not authorize any action outside the scope of your application, the staff has added a license condition to Appendix C of the license. The inclusion of this condition was discussed with your staff and agreed to by submittal dated May 22, 1998.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-317
and 50-318

Enclosures: 1. Amendment No. 228 to DPR-53
2. Amendment No. 202 to DPR-69
3. Safety Evaluation

NRC FILE CENTER COPY

cc w/encls: See next page

DOCUMENT NAME: G:\CC1-2\CCM97855.AMD *See previous concurrence
To receive a copy of this document, indicate in the box: "C" = Copy without
attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM: PDI-1	E	LA: PDI-1	D: PDI-1	OGC*	
NAME	AD: Dromerick:lcc	SLittle	SBajwa	MYoung		
DATE	05/21/98	05/21/98	05/21/98	05/21/98	05/21/98	05/21/98

9806010139 980523
PDR ADOCK 05000317
PDR

DATED: ~~May 23, 1998~~

AMENDMENT NO.228 TO FACILITY OPERATING LICENSE NO. DPR-53-CALVERT CLIFFS
UNIT 1

AMENDMENT NO.202 TO FACILITY OPERATING LICENSE NO. DPR-69-CALVERT CLIFFS
UNIT 2

Docket File

PUBLIC

PDI-1 Reading

J. Zwolinski

S. Bajwa

S. Little

A. Dromerick

OGC

G. Hill (2 of each Docket No.), T-5 C3

W. Beckner, 013H3

ACRS

C. Hehl, Region I

L. Doerflein, Region I

F. Orr

J. Hayes

C. Wu

T. Harris (e-mail SE only), TLH3

cc: Plant Service list

DATED: May 23, 1998

AMENDMENT NO. 228 TO FACILITY OPERATING LICENSE NO. DPR-53-CALVERT CLIFFS
UNIT 1

AMENDMENT NO. 202 TO FACILITY OPERATING LICENSE NO. DPR-69-CALVERT CLIFFS
UNIT 2

Docket File

PUBLIC

PDI-1 Reading

J. Zwolinski

S. Bajwa

S. Little

A. Dromerick

OGC

G. Hill (2 of each Docket No.), T-5 C3

W. Beckner, 013H3

ACRS

C. Hehl, Region I

L. Doerflein, Region I

F. Orr

J. Hayes

C. Wu

T. Harris (e-mail SE only), TLH3

cc: Plant Service list

May 23, 1998

Mr. Charles H. Cruse
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: ISSUANCE OF AMENDMENTS FOR CALVERT CLIFFS NUCLEAR POWER PLANT
UNIT NO. 1 (TAC NO. M97855) AND UNIT NO. 2 (TAC NO. M97856)

Dear Mr. Cruse:

The Commission has issued the enclosed Amendment No.228 to Facility Operating License No. DPR-53 and Amendment No.202 to Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated January 31, 1997, as supplemented February 13, February 28, March 25, April 16, August 19, and September 29, 1997, January 22, March 17, April 8, April 21, and May 22, 1998.

The amendments revise the TS for a reduction of the total reactor coolant system flow limit from 370,000 gallons per minute (gpm) to 340,000 gpm in support of increased steam generator tube plugging.

As an administrative action which does not authorize any action outside the scope of your application, the staff has added a license condition to Appendix C of the license. The inclusion of this condition was discussed with your staff and agreed to by submittal dated May 22, 1998.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-317
and 50-318

Enclosures: 1. Amendment No.228 to DPR-53
2. Amendment No.202 to DPR-69
3. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\CC1-2\CCM97855.AMD *See previous concurrence
To receive a copy of this document, indicate in the box: "C" = Copy without
attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM: PDI-1	E	LA: PDI-1	D: PDI-1	OGC*	
NAME	AD: Dromerick:lcc	SLittle	SBajwa	MYoung		
DATE	05/21/98	05/21/98	05/23/98	05/21/98		05/ /98



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 23, 1998

Mr. Charles H. Cruse
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: ISSUANCE OF AMENDMENTS FOR CALVERT CLIFFS NUCLEAR POWER PLANT
UNIT NO. 1 (TAC NO. M97855) AND UNIT NO. 2 (TAC NO. M97856)

Dear Mr. Cruse:

The Commission has issued the enclosed Amendment No. 228 to Facility Operating License No. DPR-53 and Amendment No. 202 to Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated January 31, 1997, as supplemented February 13, February 28, March 25, April 16, August 19, and September 29, 1997, January 22, March 17, April 8, April 21, and May 22, 1998.

The amendments revise the TS for a reduction of the total reactor coolant system flow limit from 370,000 gallons per minute (gpm) to 340,000 gpm in support of increased steam generator tube plugging.

As an administrative action which does not authorize any action outside the scope of your application, the staff has added a license condition to Appendix C of the license. The inclusion of this condition was discussed with your staff and agreed to by submittal dated May 22, 1998.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, reading "Alexander W. Dromerick", is positioned above the typed name.

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-317
and 50-318

Enclosures: 1. Amendment No. 228 to DPR-53
2. Amendment No. 202 to DPR-69
3. Safety Evaluation

cc w/encs: See next page

Mr. Charles H. Cruse
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of
Maryland
6 St. Paul Centre
Baltimore, MD 21202-6806

D. A. Brune, Esquire
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P. O. Box 33111
Baltimore, MD 21218

Mr. Terrence J. Camilleri, Director, NRM
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Mr. Larry Bell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
P. O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean
Administrator - Radioecology
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406