

PPL Susquehanna, LLC
707 Salem Boulevard
P.O. Box 487
Berwick, PA 18603
(570) 542-1504



Fax

To: NRC From: B. Shrew
Fax: 301-415-7010 Date: 2-12-01
Phone: _____ Pages: 8
Re: _____ CC: _____

- Urgent For Review Please Comment Please Reply Please Recycle

•Comments:

IE24

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-388
Completed by: L. L. Fuller

Date: 2-09-01
Telephone: (570) 542-3858

Challenges to Main Steam Safety Relief Valves

None.

Major Changes to Radioactive Waste Treatment System

None.

UNIT SHUTDOWNS



DOCKET NO. 50-388
 UNIT Two
 DATE 2-09-01
 COMPLETED BY L. L. Fuller
 TELEPHONE (570) 542-3858

REPORT MONTH January 2001

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Cause & Corrective Action to Prevent Recurrence
						No Shutdowns this month.

Summary: Unit 2 reduced power to 81% on January 13 for a Control Rod Pattern Adjustment. The unit returned to 100% power on January 13. Unit 2 reduced power to 81% on January 26 for Control Rod Scram Timing. The unit returned to 100% power on January 27. Unit 2 reduced power to 82% on January 29 to fix a loose connection on a 500KV overhead ground wire. The unit returned to 100% power on January 29.

1.

2.

3.

F. Forced
 S. Scheduled


Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & Licensee Exam
- F - Administrative
- G - Operational Error (Explain)

Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continuation from previous month
- 5 - Other

OPERATING DATA REPORT



DOCKET NO. 50-388
 UNIT Two
 DATE 2-09-01
 COMPLETED BY L. L. Fuller
 TELEPHONE (570) 542-3858

OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U2)
2. Reporting Period: January 2001
3. Design Electrical Rating (Net MWe): 1100
4. Maximum Dependable Capacity (Net MWe): 1094

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>744</u>	<u>139,993</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>744.0</u>	<u>120,660.6</u>
7. Hours Generator On-Line	<u>744</u>	<u>744.0</u>	<u>118,816.9</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>821,623</u>	<u>821,623</u>	<u>123,229,308</u>

NOTES:

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-387
Completed by: L. L. Fuller

Date: 2-09-01
Telephone: (570) 542-3858


Challenges to Main Steam Safety Relief Valves

None.

Major Changes to Radioactive Waste Treatment System

None.

UNIT SHUTDOWNS



DOCKET NO. 50-387
 UNIT One
 DATE 2-09-01
 COMPLETED BY L. L. Fuller
 TELEPHONE (570) 542-3858

REPORT MONTH January 2001

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Cause & Corrective Action To Prevent Recurrence
						No shutdowns this month.

Summary: Unit 1 operated at 100% power all month.


1.
 F. Forced
 S. Scheduled

2.
 Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction

 E - Operator Training & Licensee Exam
 F - Administrative
 G - Operational Error (Explain)

3.
 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation from
 previous month
 5 - Other

OPERATING DATA REPORT



DOCKET NO.	<u>50-387</u>
UNIT	<u>One</u>
DATE	<u>2-09-01</u>
COMPLETED BY	<u>L. L. Fuller</u>
TELEPHONE	<u>(570) 542-3858</u>

OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U1)
2. Reporting Period: January 2001
3. Design Electrical Rating (Net MWe): 1100
4. Maximum Dependable Capacity (Net MWe): 1090

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>744</u>	<u>154,753</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>744.0</u>	<u>126,286.2</u>
7. Hours Generator On-Line	<u>744</u>	<u>744.0</u>	<u>124,185.5</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>819,348</u>	<u>819,348</u>	<u>126,633,297</u>

NOTES:

Bryce L. Shriver
Vice President - Nuclear Site Operations

PPL Susquehanna, LLC
707 Salem Boulevard
P.O. Box 467
Berwick, PA 18603-0467
Tel. 570.542.3120 Fax 570.542.1504
blshriver@pplweb.com



February 12, 2001

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
MONTHLY OPERATING REPORTS
Docket Nos. 50-387/NPF-14 and 50-388/NPF-22
PLA - 0005279 FILE: R41-2A

The January 2001 Monthly Operating Reports for Susquehanna SES Units 1 and 2 are attached.

Very truly yours,


Bryce L. Shriver

LLF/cmm

cc: NRC Region 1
NRC Sr. Resident Inspector, Mr. S. Hansell
NRC Sr. Project Manager, Mr. R. G. Schaaf