VIRGINIA ELECTRIC AND POWER COMPANY RICHMOND, VIRGINIA 23261 February 14,2001

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555-0001 Serial No. 01-094 SPS Lic/JSA R0 Docket Nos. 50-280 50-281 License Nos. DPR-32 DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY SURRY POWER STATION UNITS 1 AND 2 MONTHLY OPERATING REPORT

The Monthly Operating Report for Surry Power Station Units 1 and 2 for the month of January 2001 is provided in the attachment.

The Unit Fuel Handling report for the July 2000 Monthly Operating Report 00-07 did not identify a fuel assembly change-out in cask TN-32-01 when an anomaly was noted during cask offload. This information has been submitted on page fourteen of this report.

If you have any questions or require additional information, please contact us.

Very truly yours,

Towers for

R. H. Blount II, Site Vice Président Surry Power Station

Attachment

Commitments made by this letter: None



Serial No. 01-094: SPS Monthly Operating Report Page 2 of 2

cc: United States Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center 61 Forsyth Street, SW, Suite 23 T85 Atlanta, Georgia 30303-8931

> Mr. R. A. Musser NRC Senior Resident Inspector Surry Power Station

.

.

VIRGINIA ELECTRIC AND POWER COMPANY SURRY POWER STATION MONTHLY OPERATING REPORT REPORT NO. 01- 01

Approved:

Blowers for 2/14/2001 Site Vice President Date

TABLE OF CONTENTS

. .

Section	Page
Operating Data Report - Unit No. 1	3
Operating Data Report - Unit No. 2	4
Unit Shutdowns and Power Reductions - Unit No. 1	5
Unit Shutdowns and Power Reductions - Unit No. 2	6
Average Daily Unit Power Level - Unit No. 1	7
Average Daily Unit Power Level - Unit No. 2	8
Summary of Operating Experience - Unit Nos. 1 and 2	9
Facility Changes That Did Not Require NRC Approval	10
Procedure or Method of Operation Changes That Did Not Require NRC Approval	11
Tests and Experiments That Did Not Require NRC Approval	12
Chemistry Report	13
Fuel Handling - Unit Nos. 1 and 2	14
Description of Periodic Test(s) Which Were Not Completed Within the Time Limits Specified in Technical Specifications	18

Surry Monthly Operating Report No. 01-01 Page 3 of 18

OPERATING DATA REPORT

Docket No.: 50-280 Date: 02/02/01 Completed By: R. Stief Telephone: (757) 365-2486

1.	Unit Name:	Surry Unit 1
2.	Reporting Period:	January 2001
3.	Licensed Thermal Power (MWt):	2546
4.	Nameplate Rating (Gross MWe):	847.5
5.	Design Electrical Rating (Net MWe):	788
6.	Maximum Dependable Capacity (Gross MWe):	842
7.	Maximum Dependable Capacity (Net MWe):	810

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Maximum Dependable Capacity (Net Mwe) value for Surry has been revised to reflect increased unit output resulting from performance upgrades and improvements.

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

_

.

	· · · · · · · · · · · · · · · ·	This Month	Year-To-Date	Cumulative
11.	Hours in Reporting Period	744.0	744.0	246432.0
12.	Hours Reactor Was Critical	744.0	744.0	179048.1
13.	Reactor Reserve Shutdown Hours	0.0	0.0	3774.5
14.	Hours Generator On-Line	744.0	744.0	176464.7
15.	Unit Reserve Shutdown Hours	0.0	0.0	3736.2
16.	Gross Thermal Energy Generated (MWH)	1891840.9	1891840.9	418744588.7
17.	Gross Electrical Energy Generated (MWH)	631852.0	631852.0	137570255.0
18.	Net Electrical Energy Generated (MWH)	609600.0	609600.0	131260828.0
19.	Unit Service Factor	100.0%	100.0%	71.6%
20.	Unit Availability Factor	100.0%	100.0%	73.1%
21.	Unit Capacity Factor (Using MDC Net)	101.2%	101.2%	68.2%
22.	Unit Capacity Factor (Using DER Net)	104.0%	104.0%	67.6%
23.	Unit Forced Outage Rate	0.0%	0.0%	13.2%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Type a	and duration of scheduled shutdowns are no longer provided.	
]	[Reference: Letter S/N 00-069, dated February 7, 2000]	

25. If Shut Down at End of Report Period, Estimated Date of Start-up: Estimated start-up dates are no longer

Estimated start-up dates are no longer provided. [Reference: Letter S/N 00-069, dated February 7, 2000]

26. Unit In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

FORECAST	ACHIEVED

OPERATING DATA REPORT

 Docket No.:
 50-281

 Date:
 02/02/01

 Completed By:
 R. Stief

 Telephone:
 (757) 365-2486

1.	Unit Name:	Surry Unit 2
2.	Reporting Period:	January 2001
3.	Licensed Thermal Power (MWt):	2546
4.	Nameplate Rating (Gross MWe):	847.5
5.	Design Electrical Rating (Net MWe):	788
6.	Maximum Dependable Capacity (Gross MWe):	847
7.	Maximum Dependable Capacity (Net MWe):	815

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Maximum Dependable Capacity (Net Mwe) value for Surry has been revised to reflect increased unit output resulting from performance upgrades and improvements.

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

		This Month	Year-To-Date	Cumulative
11.	Hours in Reporting Period	744.0	744.0	243313.0
12.	Hours Reactor Was Critical	744.0	744.0	176332.9
13.	Reactor Reserve Shutdown Hours	0.0	0.0	328.1
14.	Hours Generator On-Line	744.0	744.0	174155.1
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	1894162.9	1894162.9	414115723.8
17.	Gross Electrical Energy Generated (MWH)	638040.0	638040.0	136048172.0
18.	Net Electrical Energy Generated (MWH)	615961.0	615961.0	129852268.0
19.	Unit Service Factor	100.0%	100.0%	71.6%
20.	Unit Availability Factor	100.0%	100.0%	71.6%
21.	Unit Capacity Factor (Using MDC Net)	101.6%	101.6%	68.1%
22.	Unit Capacity Factor (Using DER Net)	105.1%	105.1%	67.7%
23.	Unit Forced Outage Rate	0.0%	0.0%	10.5%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Type and duration of scheduled shutdowns are no longer provided.	
[Reference: Letter S/N 00-069, dated February 7, 2000]	

25. If Shut Down at End of Report Period, Estimated Date of Start-up: Estimated start-up dates are no longer

Estimated start-up dates are no longer provided. [Reference: Letter S/N 00-069, dated February 7, 2000]

26. Unit In Test Status (Prior to Commercial Operation):

	FORECAST	ACHIEVED
INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION		

Surry Monthly Operating Report No. 01-01 Page 5 of 18

UNIT SHUTDOWN AND POWER REDUCTION (EQUAL TO OR GREATER THAN 20%)

.

•

REPORT MONTH: January 2001

Docket No.: 50-280 Unit Name: Surry Unit 1 Date: 02/02/01 Completed by: R. Stief Telephone: (757) 365-2486

None during the Reporting Period

F: S:	(1) Forced Scheduled	REAS A - B - C - D - E - G - H	(2) SON: Equipment Failure (Explain) Maintenance or Test Refueling Regulatory Restriction Operator Training & Licensing Examination Administrative Operational Error (Explain) Other (Explain)	MI 1 2 3 4	ETH - - -	(3) IOD: Manual Manual Scram Automatic Scram Other (Explain)
	(4)					(5)
Exh for	Exhibit G - Instructions for Preparation of Data Entry Sheets Exhibit 1 - Same Source for Licensee Event Report (LER) File (NUREG 0161)					

Surry Monthly Operating Report No. 01-01 Page 6 of 18

UNIT SHUTDOWN AND POWER REDUCTION (EQUAL TO OR GREATER THAN 20%)

REPORT MONTH: January 2001

Docket No.: 50-281 Unit Name: Surry Unit 2 Date: 02/02/01 Completed by: R. Stief Telephone: (757) 365-2486

None during the Reporting Period

(1)

(2) REASON:

- F: Forced S: Scheduled
- Equipment Failure (Explain) Α-
- В -Maintenance or Test
 - -Refueling
 - -**Regulatory Restriction**
- D -
- Е **Operator Training & Licensing Examination**
- F -Administrative
- G-**Operational Error (Explain)**
- Other (Explain) н

(3) METHOD:

- 1 -Manual
- Manual Scram 2 -
- 3 Automatic Scram
- 4 Other (Explain)
- (5) Exhibit 1 - Same Source

(4)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 0161)

С

AVERAGE DAILY UNIT POWER LEVEL

Docket No .:	50-280
Unit Name:	Surry Unit 1
Date:	02/02/01
Completed by:	R. Stief
Telephone:	(757) 365-2486

MONTH: January 2001

Day	Average Daily Power Level (MWe - Net)	Day	Average Daily Power Level (MWe - Net)
1	821	17	817*
2	820*	18	820*
3	821*	19	802*
4	820*	20	820*
5	821*	21	820*
6	821*	22	820*
7	821*	23	820*
8	820*	24	820*
9	820*	25	820*
10	821*	26	820*
11	821*	27	811*
12	820*	28	820*
13	821*	29	820*
14	820*	30	
15	820*	31	824
16	817*		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe - Net for each day in the reporting month. Compute to the nearest whole megawatt.

* NOTE:

Figures for January 2 - 30 were calculated due to the degraded condition of the Megawatt Integrator.

AVERAGE DAILY UNIT POWER LEVEL

50-281
Surry Unit 2
02/02/01
R. Stief
(757) 365-2486

MONTH: January 2001

.

Day	Average Daily Power Level (MWe - Net)	Day	Average Daily Power Level (MWe - Net)
1	827	17	829
2	827	18	828
3	828	19	828
4	829	20	829
5	828	21	829
6	828	22	828
7	828	23	828
8	828	24	828
9	828	25	828
10	828	26	828
11	828	27	828
12	828	28	828
13	828	29	827
14	828	30	827
15	828	31	827
16	829		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe - Net for each day in the reporting month. Compute to the nearest whole megawatt.

SUMMARY OF OPERATING EXPERIENCE

MONTH/YEAR: January 2001

The following chronological sequence by unit is a summary of operating experiences for this month that required load reductions or resulted in significant non-load related incidents.

UNIT ONE:

.

01/01/01	0000	Unit started the month at 100% / 851 MWe.
01/05/01	1015	"B" phase voltage of Main Generator Exciter reads 2% lower accounting for lower MWe reading.
01/05/01	1705	Testing indicates the degraded MWe metering "B" phase line connection accounts for 3-5 Mwe
		loss.
01/19/01	0019	Commenced ramp down to 90% for 1-OSP-TM-001.
01/19/01	0108	Stopped ramp at 90% power / 760 MWe (indicated).
01/19/01	0553	Commenced ramp to 100% power.
01/19/01	0642	Ramp stopped at 97.5% / 825 MWe (indicated) for turnover.
01/19/01	0905	Unit at 100% / 841 MWe (indicated).
01/27/01	0052	Commenced ramp to 90% power for 1-OSP-TM-001.
01/27/01	0153	Completed ramp. Unit at 90% / 765 MWe (indicated).
01/27/01	0430	Unit at 100% / 830 MWe (indicated).
01/30/01	1800	Temporary Modification installed for MW, VARS and "B" Phase voltage indication.
01/31/01	2400	Unit finished the month at 100% / 851 MWe.

UNIT TWO:

01/01/01	0000	Unit started the month at 100% / 855 MWe.
01/31/01	2400	Unit finished the month at 100% / 855 MWe.

Surry Monthly Operating Report No. 01-01 Page 10 of 18

FACILITY CHANGES THAT DID NOT REQUIRE NRC APPROVAL

-

.

.

DCP 93-033	Design Change Package (Safety Evaluation 93-135)	06/17/93
	Design Change Package 93-033, "MI Programs Plant Walkdowns/USI A-46 (Seismic)/Surry/Units 1 & 2" required walkdowns and modifications to be primplement the seismic portion of the Individual Plant Examination of Exter (IPEEE) program for Unresolved Safety Issue (USI) A-46, "Verification of Seismi of Mechanical and Electrical Equipment in Operating Reactors".	and IPEEE erformed to rnal Events c Adequacy
DCP 99-085	Design Change Package (Safety Evaluation 99-117)	12/09/99
	Design Change Package 99-085, "Permanent Water Shields for Rea Stand/Surry/Units 1 & 2" replaced the existing fiberglass water shield ta containment with stainless steel water shields for radiation shielding inside the Head Stand.	actor Head anks inside the Reactor
TM S2-00-014, Rev. 1	Temporary Modification (Safety Evaluation 00-144)	01/03/01
	Temporary Modification S2-00-014 substitutes a Safety Injection accumulator relate existing one that is leaking nitrogen. Revision 1 revised the support configuration field information was available.	lief valve for ation design
TSR 00-056	Temporary Shielding Request (Safety Evaluation 01-002)	01/18/01
	Temporary Shielding Request 00-056 installs temporary shielding on check value and surrounding piping to reduce personnel exposure during work and passage The shielding will remain until hot spots in the area can be removed or until the made permanent by a future Design Change.	re 1-CH-478 in the area. shielding is
TM S2-01-001	Temporary Modification (Safety Evaluation 01-004)	01/23/01
	Temporary Modification S2-01-001 installed an electrical jumper to ensure that steam flow indication for loop FC-495 remained in service while the resistor of flow selector switch was being replaced.	t channel IV n the steam
TM S1-01-001	Temporary Modification (Safety Evaluation 01-005)	01/25/01
	Temporary Modification S1-01-001 provides the necessary material and wiring remove the degraded B-Phase potential from the Megawatt Integrator in the M Room and reconfigure the Integrator using A-Phase and C-Phase potentials.	changes to Aain Control

PROCEDURE OR METHOD OF OPERATION CHANGES THAT DID NOT REQUIRE NRC APPROVAL

MONTH/YEAR: January 2001

0-MCM-1910-10	Mechanical Corrective Maintenance Procedure	01/18/01
	(Safety Evaluations 01-003, 006)	01/25/01

Mechanical Corrective Maintenance Procedure 0-MCM-1910-10, "Maintenance of Swinging Safety-Related Special Purpose Fire Doors", was revised to incorporate the installation of temporary seals on doors 1-BS-DR-14 and 2-BS-DR-27 to maintain the barrier's functions and allow for floor seals removal during maintenance and repair.

Surry Monthly Operating Report No. 01-01 Page 12 of 18

TESTS AND EXPERIMENTS THAT DID NOT REQUIRE NRC APPROVAL

.

.

MONTH/YEAR: January 2001

None during the Reporting Period

Surry Monthly Operating Report No. 01-01 Page 13 of 18

CHEMISTRY REPORT

MONTH/YEAR: January 2001

		Unit No. 1			Unit No. 2	
Primary Coolant Analysis	Max.	Min.	Avg.	Max.	Max. Min.	
Gross Radioactivity, μCi/ml	2.76E-1	1.50E-1	2.05E-1	2.34E-1	1.40E-1	1.97E-1
Suspended Solids, ppm	-	_	-	-	-	-
Gross Tritium, μCi/ml	1.08E+0	1.01E+0	1.03E+0	8.68E-1	6.31E-1	6.94E-1
131 uCi/ml	3.10E-4	9.98E-5	2.31E-4	2.23E-4	7.59E-5	1.16E-4
131/133	0.11	0.03	0.08	0.18	0.06	0.09
	42	20.0	41.2	20.4	20.6	22.5
	43	0.11	41.5	0.42	2 15	33.5
Beren 10 nnm*	165.9	147.9	156.0	2.42	2.15	2.5
	103.8	147.0	100.2	230.3	< 0.005	< 0.005
Chlorido ppm	≥ 0.005	≥ 0.005	≥ 0.005	0.005	≥ 0.005	<u> </u>
pH @ 25 degree Celsius	6.97	6.63	6.72	6.55	6.31	6.42

* Boron - 10 = Total Boron x 0.196

Comments:

.

.

None

. .

New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
Spent Fuel Cask TN-32-01	07/06/00	1	D05	LM008E	3.3250	Visible blister noted on the assembly after being removed from the cask.
	07/19/00	1	5S4	LM0ERU	3.6005	Fuel loaded from spent fuel pool to cask as replacement for assembly D05
Spent Fuel Cask TN-32-07	01/24/01	32	0P1	LM05Y5	3.6070	Fuel unloaded from cask due to potential fuel leak
			0P8	LM05XF	3.6070	
			0R8	LM0C1R	3.5947	
			0S8	LMOESV	3.5955	
			1P2	LM05XG	3.6070	
			1P8	LM05X6	3.6070	
			1R4	LM0C1W	3.5986	
			2C4	LM08MK	3.3990	
			2E2	LM0DFS	3.5973	
			2P0	LM05X9	3.6070	
			2P1	LM05XB	3.6070	
			2P2	LM05X4	3.6070	

. . .

_	New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
				2P2	LM05X4	3.6070	
				2P4	LM05XN	3.6070	
				2P6	LM05XX	3.6070	
				3P1	LM05XP	3.6070	
				3P4	LM05YC	3.6070	
				4C0	LM08N8	3.3990	
				4P2	LM05YT	3.6070	
				4P3	LM05YB	3.6070	
				4P4	LM05YM	3.6070	
				4P6	LM05YL	3.6070	
				5E4	LMODEH	3.6048	
				5P2	LM05Y9	3.6070	
				5P3	LM05XU	3.6070	
				5P4	LM09PH	3.6070	
				5P5	LM05XM	3.6070	
				5P8	LM05YD	3.6070	
				582		3 5971	
				5112		0.001	
				5R6	LM0C1Z	3.5901	

. .

New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
			5R9	LM0C2B	3.5885	
			6P5	LM09PG	3.6070	
Spent Fuel			6P7	LM05YJ	3.6070	Fuel loaded to
Cask TN-32-07	01/25/01	32	3U3	LMONCE	4.0093	cask as replacements
			4U0	LM0NC9	3.9886	
			5U2	LMONCL	4.0008	
			2U8	LMONBW	3.7914	
			2U2	LMONBV	3.7955	
			2U4	LMONBL	3.7941	
			2U3	LMONBR	3.7933	
			2U7	LMONBP	3.7853	
			0U3	LM0NB8	3.7943	
			0U4	LM0NB9	3.7868	
			3U5	LMONCH	4.0090	
			0U5	LM0NB5	3.7952	
			3U8	LM0NC8	4.0054	
			3U4	LMONBZ	4.0058	
			1U5	LMONBJ	3.7943	

New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
			1U2	LMONBX	3.7948	
			2U1	LMONBY	3.8033	
			2U6	LMONBS	3.7849	
			1U7	LMONBK	3.7833	
			1U3	LMONBG	3.8009	
			0U1	LMONB6	3.7763	
			0U6	LMONBA	3.7948	
			0U7	LMONBD	3.7953	
			4T0	LM0K98	3.7985	
			3T9	LM0K9D	3.7939	
			3T8	LM0K9G	3.7987	
			3T7	LM0K82	3.7892	
			1B1	LM08LM	3.2170	
			0B6	LM08LT	3.2170	
			0B3	LM08LS	3.2170	
			0B2	LM08LV	3.2170	
			0B1	LM08M2	3.2170	

DESCRIPTION OF PERIODIC TEST(S) WHICH WERE NOT COMPLETED WITHIN THE TIME LIMITS SPECIFIED IN TECHNICAL SPECIFICATIONS

MONTH/YEAR: January 2001

None during the Reporting Period