REACTOR COOLANT SYSTEM

OPERATIONAL LEAKAGE

LIMITING CONDITION FOR OPERATION

- 3.4.6.2 Reactor Coolant System leakage shall be limited to:
 - a. No PRESSURE BOUNDARY LEAKAGE,
 - b. 1 GPM UNIDENTIFIED LEAKAGE,
 - c. 150 GPD primary-to-secondary leakage through the tubes of any one steam generator,
 - d. 10 GPM IDENTIFIED LEAKAGE from the Reactor Coolant System,
 - e. 10 GPM CONTROLLED LEAKAGE, and
 - f. 5 GPM leakage from any Reactor Coolant System Pressure Isolation Valve as specified in Table 3.4-2.

APPLICABILITY: MODES 1, 2, 3 and 4

ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE, reduce the leakage rate to within limits within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours except as permitted by paragraph c below.
- c. In the event that integrity of any pressure isolation valve specified in Table 3.4-2 cannot be demonstrated, POWER OPERATION may continue, provided that at least two valves in each high pressure line having a non-functional valve are in and remain in, the mode corresponding to the isolated condition.(a)
- d. The provisions of Section 3.0.4 are not applicable for entry into MODES 3 and 4 for the purpose of testing the isolation valves in Table 3.4-2.

^(a)Motor operated valves shall be placed in the closed position and power supplies deenergized.

DAVIS-BESSE, UNIT 1

3/4 4-15

Order dtd. 4/20/81 Amendment No. 135,180²²⁰