

REGULATORY DOCKET FILE COPY

OCT 24 1980

Docket No. 50-244

RECEIVED DISTRIBUTION
SERVICES UNIT

1980 NOV 19 AM 9 41

U.S. NRC
DISTRIBUTION SERVICES
WASHINGTON, D.C.

Mr. Leon D. White, Jr.
Vice President
Electric and Steam Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Mr. White:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT (SEP
TOPIC III-12) - R. E. GINNA NUCLEAR POWER PLANT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for R. E. Ginna Nuclear Power Plant. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

ORIGINAL SIGNED BY

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order (w/attachments)

cc w/enclosure: See Next Page

8011240 003

OFFICE	DL:ORB #5/LA	DL:ORB #5/PM	DL:ORB #5/C	DL:ORB #2/PM	DL:DIR
SURNAME	HAMILTON	SNOWICKI	DCRUTCHFIELD	MAYNARD	DESENHUT
DATE	10/24/80	10/24/80	10/24/80	10/24/80	10/24/80

Distribution:

Docket

NRC PDR	H. Smith
Local PDR	J. Roe
ORB #5 Reading	S. Norris
NRR Reading	M. Williams
H. R. Denton	OELD
E. G. Case	OI&E (3)
R. Hartfield, MPA	B. Jones (4)
G. Bennington, MPA	ACRS (16)
D. Eisenhut	OPA (Clare Miles)
R. Purple	NSIC
T. Novak	TERA
R. Tedesco	Secretariat (SECY)
G. Lainas	R. Diggs
J. Murray, OELD	J. Heltemes, AEOD
D. Crutchfield	Project Manager
G. Cwalina	Gray File
	Xtra Cys (6)
	J. Murray



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 24, 1980

Docket No. 50-244

Mr. Leon D. White, Jr.
Vice President
Electric and Steam Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Mr. White:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT (SEP
TOPIC III-12) - R. E. GINNA NUCLEAR POWER PLANT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for R. E. Ginna Nuclear Power Plant. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Dennis M. Crutchfield
Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order (w/attachments)

cc w/enclosure: See Next Page

Mr. Leon D. White, Jr.

- 2 -

October 24, 1980

cc w/enclosure:

Harry H. Voigt, Esquire
LeBoeuf, Lamb, Leiby and MacRae
1333 New Hampshire Avenue, N. W.
Suite 1100
Washington, D. C. 20036

Mr. Michael Slade
12 Trailwood Circle
Rochester, New York 14618

Rochester Committee for
Scientific Information
Robert E. Lee, Ph.D.
P. O. Box 5236 River Campus
Station
Rochester, New York 14627

Jeffrey Cohen
New York State Energy Office
Swan Street Building
Core 1, Second Floor
Empire State Plaza
Albany, New York 12223

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Rochester Public Library
115 South Avenue
Rochester, New York 14604

Supervisor of the Town
of Ontario
107 Ridge Road West
Ontario, New York 14519

Resident Inspector
R. E. Ginna Plant
c/o U. S. NRC
1503 Lake Road
Ontario, New York 14519

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region II Office
ATTN: EIS COORDINATOR
26 Federal Plaza
New York, New York 10007

Herbert Grossman, Esq., Chairman
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Richard F. Cole
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Emmeth A. Luebke
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Thomas B. Cochran
Natural Resources Defense Council, Inc.
1725 I Street, N. W.
Suite 600
Washington, D. C. 20006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of Rochester Gas
& Electric Company

R. E. Ginna Nuclear Power Plant

)
)
)

Docket No. 50-244

ORDER FOR MODIFICATION OF LICENSE

I.

Rochester Gas & Electric Company (the licensee) is the holder of Provisional Operating License No. DPR-18, which authorizes the operation of R. E. Ginna Nuclear Power Plant at steady-state reactor power levels not in excess of 1520 megawatts thermal (rated power). The facility consists of a pressurized water reactor located at the licensee's site in Wayne County, New York.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

8011240 007

- 2 -

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-013¹ and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

¹

Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-013 was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

- 3 -

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

- 4 -

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Provisional Operating License No. DPR-18 is hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

- 5 -

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of License No. DPR-18 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V

The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Harry H. Voight, Esquire, LeBoeuf, Lamb, Leiby & MacRae, 1333 New Hampshire Avenue, N. W., Suite 1100, Washington, D. C. 20036, attorney for the licensee.


- 6 -

If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Wisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

- c. Records of plant radiation and contamination surveys.
- d. Records of off-site environmental monitoring surveys.
- e. Records of radiation exposure of all plant personnel, including all contractors and visitors to the plant who enter radiation control areas.
- f. Records of radioactivity in liquid and gaseous material released to the environmental and radioactive waste shipments.
- g. Records of transient or operational cycles for those facility components designed for limited number of transients or cycles.
- h. Records of training and qualification for current station technical and operations staff members.
- i. Records of in-service inspections performed pursuant to these Technical Specifications.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR Section 50.59.
- k. Records of meetings of the PORC and the NSARB.
- l. Records of Quality Assurance activities as required by the QA Manual.
- m. Records for Environmental Qualification which are covered under the provisions of paragraph 6.14.

8011240 011

6.14 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-18 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.