

May 28, 1981

Docket No. 50-244  
LS05-81-05-060

DISTRIBUTION:

~~Docket~~  
NRC PDR  
LPDR  
TERA  
NSIC  
ORB#5 RF  
RSnaider  
HSmith (2)  
RDiggs  
OI&E (5)  
ACRS (10)  
GDeegan (4)  
BScharf (10)

Gray File  
Xtra Cy (6)

*Correction to  
Amdt 40 to  
DPR-18*

Mr. John E. Maier, Vice President  
Electric and Steam Production  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Maier:

By letter dated April 17, 1981, we issued Amendment No. 40 to Provisional Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant. Amendment No. 40 approved technical specifications regarding control and position indication and control rod misalignment.

Page 3.5-4a, as issued by Amendment No. 40, did not include changes incorporated by Amendment No. 38, and of course, did not include corrections to Amendment No. 38 pages issued by our letter dated May 6, 1981. Therefore, we have reissued, as enclosed, page 3.5-4a to incorporate Amendments No. 38 and 40.

We regret any inconvenience this error may have caused you.


Sincerely,

Original signed by  
Dennis M. Crutchfield

Dennis M. Crutchfield, Chief  
Operating Reactors Branch 5

Enclosure:  
Corrected page 3.5-4a

cc: See next page



8106120416

P

OFFICE	ORB 5	ORB 5	ORB 5				
SURNAME	RPSnaider	HSmith	DMCrutchfield				
DATE	5/28/81	5/28/81	5/28/81				



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 28, 1981

Docket No. 50-244  
LS05-81-05-060

Mr. John E. Maier, Vice President  
Electric and Steam Production  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, New York 14649

Dear Mr. Maier:

By letter dated April 17, 1981, we issued Amendment No. 40 to Provisional Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant. Amendment No. 40 approved technical specifications regarding control rod position indication and control rod misalignment.

Page 3.5-4a, as issued by Amendment No. 40, did not include changes incorporated by Amendment No. 38, and of course, did not include corrections to Amendment No. 38 pages issued by our letter dated May 6, 1981. Therefore, we have reissued, as enclosed, page 3.5-4a to incorporate Amendments No. 38 and 40.

We regret any inconvenience this error may have caused you.

Sincerely,

  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch 5  
Division of Licensing

Enclosure:  
Corrected page 3.5-4a

cc: See next page

Mr. John E. Maier

- 2 -

May 28, 1981

cc w/enclosure:

Harry H. Voigt, Esquire  
LeBoeuf, Lamb, Leiby and MacRae  
1333 New Hampshire Avenue, N. W.  
Suite 1100  
Washington, D. C. 20036

Mr. Michael Slade  
12 Trailwood Circle  
Rochester, New York 14618

Ezra Bialik  
Assistant Attorney General  
Environmental Protection Bureau  
New York State Department of Law  
2 World Trade Center  
New York, New York 10047

Jeffrey Cohen  
New York State Energy Office  
Swan Street Building  
Core 1, Second Floor  
Empire State Plaza  
Albany, New York 12223

Director, Technical Development  
Programs  
State of New York Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Rochester Public Library  
115 South Avenue  
Rochester, New York 14604

Supervisor of the Town  
of Ontario  
107 Ridge Road West  
Ontario, New York 14519

Resident Inspector  
R. E. Ginna Plant  
c/o U. S. NRC  
1503 Lake Road  
Ontario, New York 14519

U. S. Environmental Protection  
Agency  
Region II Office  
ATTN: EIS COORDINATOR  
26 Federal Plaza  
New York, New York 10007

Herbert Grossman, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Richard F. Cole  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Thomas B. Cochran  
Natural Resources Defense Council, Inc.  
1725 I Street, N. W.  
Suite 600  
Washington, D. C. 20006

	1 NO. of CHANNELS	2 NO. of CHANNELS TO TRIP	3 MIN. OPERABLE CHANNELS	4 MIN. DEGREE OF REDUNDANCY	5 PERMISSIBLE BYPASS CONDITIONS	6 OPERATOR ACTION IF CONDITIONS OF COLUMN 3 or 5 CANNOT BE MET
17. Circulating Water Flood Protection						
a. Screenhouse	2	1	2+	-*		Power operation may be continued for a period of up to 7 days with 1 channel inoperable or for a period of 24 hrs. with two channels inoperable.
b. Condenser	2	1	2+	-*		Power operation may be continued for a period of up to 7 days with 1 channel inoperable or for a period of 24 hrs. with two channels inoperable.
1/18. Loss of Voltage/ Degraded Voltage 480 Volt Safe- guards Bus	4/bus	2/bus	2/bus	*		Maintain hot shut-down or place bus on diesel generator.

NOTE 1: When block condition exists, maintain normal operation.

F.P. = Full Power

\* Not Applicable

\*\*\* If a functional unit is operating with the minimum operable channels, the number of channels to trip the reactor will be column 3 less column 4.

+ A channel is considered operable with 1 out of 2 logic or 2 out of 3 logic.

1/Effective 30 days after completion of necessary modifications and no later than completion of the Spring 1982 refueling outage

8106120419\*

3.5-4a

Amendment No. 1A, 3B, 4C  
(Correction - May 6, 1981)