

October 3, 1988

Docket No. 50-244

Mr. Robert C. Mecredy, Manager,
Nuclear Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Mr. Mecredy:

SUBJECT: ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE NO. DPR-18
(TAC #66351)

The Commission has issued the enclosed Amendment No. 31 to Facility Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant in response to your application dated May 13, 1988.

The amendment revises the Technical Specifications to reflect replacement of steam generator snubbers with rigid structural supports (bumpers).

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance has been forwarded to the Office of the Federal Register for publication.

Sincerely,

15/

Carl Stahle, Project Manager
Project Directorate I-3
Division of Reactor Projects I/II

Enclosures:

- 1. Amendment No. 31 to License No. DPR-18
- 2. Safety Evaluation

cc w/enclosures:
See next page

*See previous concurrence

OFC	: PD#1-3	: PD#I-3	: OSC-Rock	: DIR/PDI-3	:	:
NAME	: *MRushbrook	: *CStahle:ck	:	: RWessman	:	:
DATE	: 09/13/88	: 09/13/88	: 09/16/88	: 09/23/88	:	:

OFFICIAL RECORD COPY

8810100163 881003
PDR ADDCK 05000244
P PNU

NFO1
11

CP1

Docket No. 50-244

Mr. Robert C. Mecredy, Manager,
Nuclear Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Mr. Mecredy:

SUBJECT: ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE NO. DPR-18
(TAC #66351)

The Commission has issued the enclosed Amendment No. to Facility
Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant
in response to your application dated May 13, 1988.

The amendment revises the Technical Specifications to ~~remove the listing of~~
~~snubbers from the Technical Specifications.~~

A copy of our related Safety Evaluation is also enclosed. A Notice of
Issuance has been forwarded to the Office of the Federal Register for
publication.

Sincerely,

Carl Stahle, Project Manager
Project Directorate I-3
Division of Reactor Projects I/II

Enclosures:

1. Amendment No. to License No. DPR-18
2. Safety Evaluation

cc w/enclosures:
See next page

Reflect replacement of steam generator snubbers with rigid structural supports (bumpers)

reflect that bumpers may be substituted for snubbers

JMS for

APH

OFC	: PD#1-3	: PD#1-3	: NEB	: OGC-Rock	: DIRPD#1-3:	:	:
NAME	: MRushbrook	: CStahle:ck	: LMarsh	: W	: RWessman	:	:
DATE	: 9/13/88	: 9/13/88	:	: 9/13/88	:	:	:

OFFICIAL RECORD COPY

Providing change is made as indicated.

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 31, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

15/

Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 3, 1988

APK

*See previous concurrence

OFC	: PD#1-3	: PD#1-3	: OGC-Rock	: DIRPD#1-3:	:	:
NAME	: *MRushbrook	: *CStahle	:	: <i>Wessman</i>	:	:
DATE	: 09/13/88	: 09/13/88	: <i>9/1/88</i>	: <i>10/3/88</i>	:	:

OFFICIAL RECORD COPY

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance:

OFC	: PD#1-3	: PD#1-3	: OGC	: DIRPD#1-3:	:	:	:
NAME	: MRush	: CStahle	:	:	:	:	:
DATE	: 9/2/88	: 9/13/88	: 9/13/88	: 1/1	:	:	:

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 3, 1988

Docket No. 50-244

Dr. Robert C. Mecredy, General Manager,
Nuclear Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, New York 14649

Dear Dr. Mecredy:

SUBJECT: ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE NO. DPR-18
(TAC #66351)

The Commission has issued the enclosed Amendment No. 31 to Facility Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant in response to your application dated May 13, 1988.

The amendment revises the Technical Specifications to reflect replacement of steam generator snubbers with rigid structural supports (bumpers).

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance has been forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "C. Stahle for".

Carl Stahle, Project Manager
Project Directorate I-3
Division of Reactor Projects I/II

Enclosures:

1. Amendment No. 31 to License No. DPR-18
2. Safety Evaluation

cc w/enclosures:
See next page

Robert C. Mecredy, General Manager, Nuclear Production.
Rochester Gas and Electric Corporation R. E. Ginna Nuclear Power Plant

cc:

Harry H. Voigt, Esquire
LeBoeuf, Lamb, Leiby and MacRae
1333 New Hampshire Avenue, N.W.
Suite 1100
Washington, D.C. 20036

Mr. Bruce A. Snow, Superintendent
Nuclear Production
Rochester Gas & Electric Corporation
89 East Avenue
Rochester, N.Y. 14649-0001

Ezra Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Charlie Donaldson, Esq.
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
R.E. Ginna Plant
c/o U.S. NRC
1503 Lake Road
Ontario, New York 14519

Stanley B. Klimberg, Esquire
General Counsel
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Supervisor of the Town of Ontario
1850 Ridge Road
Ontario, New York 14519

Ms. Donna Ross
Division of Policy Analysis & Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R.E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31
License No. DPR-18

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Rochester Gas and Electric Corporation (the licensee) dated May 13, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. DPR-18 is hereby amended to read as follows:

8810100166 881003
PDR ADOCK 05000244
P PNU

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 31, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard H. Wessman, Director
Project Directorate I-3
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 3, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 31

FACILITY OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Revise Appendix A as follows:

REMOVE

page 3.13-1

INSERT

page 3.13-1

3.13 Shock Suppressors (Snubbers)

Applicability:

Applies to the operability of all safety-related shock suppressors (snubbers) listed in Table 3.13-1.

Objective

To specify the requirements for operability of shock suppressors (snubbers).

Specifications:

- 3.13.1 The reactor shall not be made critical unless (1) all shock suppressors (snubbers) listed in Table 3.13.1 are operable.
- 3.13.2 Continued hot shutdown or power operation is permitted for a period up to 72 hours without the conditions of 3.13.1 being met. If the conditions of 3.13-1 are not met in that 72 hour period, then the reactor shall be in a cold shutdown condition within the next 36 hours.

Basis

Shock suppressors (snubbers) are required to be operable to ensure that the structural integrity of the reactor coolant system and all other safety related systems is maintained during and following a seismic or other event initiating dynamic loads.

Snubbers may be replaced by rigid structural supports (bumpers) provided an analysis is performed to demonstrate that appropriate acceptance criteria are satisfied for design basis seismic and pipe break events and provided that the bumpers are inspected periodically in a manner appropriate for rigid structural supports.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 31 TO FACILITY OPERATING LICENSE NO. DPR-18
ROCHESTER GAS AND ELECTRIC CORPORATION
R. E. GINNA NUCLEAR POWER PLANT
DOCKET NO. 50-244

1.0 BACKGROUND

On September 22, 1987, RG&E notified the NRC (Reference 1) that it intends to replace six of the eight hydraulic snubbers per steam generator with bumpers (rigid structural members) at the R. E. Ginna Nuclear Power Plant. The purpose of this replacement is to reduce required maintenance activities and aid in keeping radiation exposures as-low-as-reasonably-achievable.

Reference 1 also indicated that the analysis that will provide justification for the snubber replacement will involve the application of updated pipe break design criteria (leak-before-break) to reduce maximum loads on the reactor coolant loop system and its supports, and the change in MEB BTP 3-1 to eliminate arbitrary intermediate breaks in the main steam and feedwater lines.

RG&E intended to perform this replacement as a plant modification subject to review per 10CFR50.59. After evaluation of the technical material in Reference 1 and communication with the licensee, the EMEB staff concluded that the replacement of these snubbers would require a licensing amendment. This conclusion was based on the Statement of Consideration on the amendment to GDC-4, 10 CFR Part 50, Appendix A, which stated that changing heavy-component support load path designs would involve an unreviewed safety question and would thus require a licensing amendment, 51 Federal Register, 12502 (April 11, 1986).

On May 13, 1988, RG&E submitted an Application for Amendment to the Operating License (Reference 2) to reflect replacement of steam generator snubbers with rigid structural members (bumpers). Included in Reference 2 are also a report summarizing the safety evaluation analyses which were performed to demonstrate no adverse consequences as a result of the snubber replacement and responses to a series of questions from the EMEB staff which were transmitted to RG&E on April 13, 1988 (Reference 3).

2.0 EVALUATION

2.1 ANALYSIS

The upper portion of each of the two steam generators (SG) at R. E. Ginna is currently restrained against lateral seismic and pipe break loads by eight large capacity hydraulic snubbers. The snubbers are installed in four pairs, with one pair approximately parallel to the hot leg. The redesigned SG upper support configuration will retain this latter pair of snubbers while replacing

8810100167 881003
PDR ADOCK 05000244
P PNU

the other six with rigid structural members (bumpers). Each of these bumpers consists of a structural assembly which is rigid in compression and permits freedom of movement in the tensile direction.

The size and design of these bumpers were based on the primary loop qualification performed by the NSSS vendor, Westinghouse Electric Corporation (WEC). The reactor coolant system (RCS) with the modified SG upper lateral support configurations was analyzed for dead weight, internal pressure, thermal expansion, seismic events (OBE & SSE), postulated pipe ruptures at the main steam and feedwater nozzles and postulated pipe ruptures at the pressurizer surge, SI accumulator and RHR auxiliary line nozzles. No pipe breaks or asymmetric blow-down loads were postulated in the RCS piping itself, since an exemption to GDC-4 was granted to R. E. Ginna by letter dated September 9, 1986 (Reference 4).

The postulated pipe break locations in the main steam and feedwater systems were reviewed in accordance with NRC Generic Letter 87-11 (Reference 5). Based on the provisions of this letter RG&E determined that the terminal end pipe break postulated at the steam generator feedwater inlet nozzle defined the limiting pipe break design basis load for the SG upper lateral support system under faulted conditions.

The static, thermal and seismic analyses of the RCS were performed using a two-loop model to obtain component and support loads and displacements. The seismic analysis was performed using the envelope response spectrum method with uniform modal damping equal to 2% (OBE) and 4% (SSE) of critical damping. These damping values were approved by the NRC (AEC) for use in WEC RCS analyses by letter dated May 16, 1974 (Reference 6). The new SG upper lateral supports designs were represented by members with different stiffnesses in tension and compression, but were modeled by members with the average stiffness in the analyses. Likewise, the existing tubular support columns under the steam generators and reactor coolant pumps were modeled by members with the average of the stiffnesses in tension and compression. The staff reviewed these linear approximations to essentially non-linear members, and concluded that they were appropriate for the analysis of the R. E. Ginna RCS on the basis that substantial margin was calculated in these members with respect to their load capacities. However, the staff intends to seek, on a generic basis, additional clarification on this subject from Westinghouse since this approach was also used in other Westinghouse plants.

The pipe-rupture analyses were performed on a one-loop model using a dynamic time history method. Pipe breaks were postulated at the loop branch connections of the pressurizer surge, RHR and SI accumulator piping systems. The transient forcing functions representing thrust and jet impingement were applied to the RCS analytical model at the lumped mass points where each auxiliary line joins the RCS. The blowdown forcing functions which represent traveling compression blowdown waves within the RCS were also applied to the model at each change in piping direction or change in flow area. The forcing functions due to the pipe breaks postulated at the main steam outlet nozzle and the feedwater inlet nozzle are applied at these locations on the SG.

All analyses of the RCS were performed using the proprietary WEC computer program "WESTDYN". This program performs both response spectrum analysis and time history analysis. The analyses of the equipment supports were performed using the widely used structural computer program "STRU DL", of which WEC has a proprietary version. The basis and application of these programs was reviewed and accepted by the staff in 1981 (Reference 7).

The piping stresses for the normal, upset, emergency and faulted plant conditions were evaluated using the requirements of ANSI B31.1, 1967 Edition (Reference 8). The design of the bumpers and equipment supports was based on requirements of the current edition of the original design code, AISC Manual of Steel Construction, (8th Edition), and the provisions of the ASME B&PV Code Section III, Subsection NF and Appendix F, 1974 Edition.

2.2 RESULTS

The results of the analyses show that the maximum stresses in the RCS piping with the redesigned steam generator lateral support configuration are within the appropriate design stress limits for the various plant conditions. Likewise, the stresses and loads in the RCS heavy equipment nozzles and supports were also shown to have adequate margin as compared to the corresponding design limits.

With the redesigned steam generator upper lateral support configuration, the analysis generated revised forces and moments in the RCS. These revised loads were compared with the corresponding loads for this plant in Generic Letter 84-04. This comparison verified that the leak-before-break conclusions for Ginna in WCAP-9558, Rev. 1, (Reference 9), remain valid for the redesigned support configuration. The stresses in the main steam lines were evaluated, and the maximum stress intensity at all intermediate locations between terminal ends for combined pressure, dead weight, thermal and OBE loading was shown to be less than the threshold stress intensity specified in GL 87-11, thus providing justification for not specifying intermediate break locations in the main steam lines inside containment.

Prior to this stress evaluation, the controlling design load for the SG upper lateral support system was an arbitrary intermediate pipe break in the horizontal main steam line near the top of the SG. With this calculation, the loading on the SG due to a main steam postulated break at the terminal end changed to the vertical direction along the axis of the SG. Similar considerations are also applicable to the feedwater lines, in which case the previously defined loads due to a postulated terminal-end break at the feedwater inlet nozzle became the limiting pipe break design basis load under faulted conditions.

WEC also performed an evaluation of the building structures which provide the anchors for the bumpers and the snubbers, and were found to be adequate for the design loads associated with the new SG upper support configurations.

The maximum piping stresses in the RCS in the cold shut-down condition under dead weight pressure, and seismic loading (SSE) were found to be well within the allowable stress (emergency condition). Likewise, all loads on the primary equipment supports were found to be well within the capacity for the corresponding support components.

3.0 ENVIRONMENTAL CONSIDERATION

The proposed amendment was noticed for hearing, 53 Federal Register 27913 (July 25, 1988) and no comments or requests for hearing were received. An Environmental Assessment and Finding of No Significant Impact was published in 53 Federal Register 38821 (October 3, 1988).

4.0 CONCLUSION

Based on the review of the analyses and results provided, the staff finds that RG&E has shown that the RCS and the heavy component supports with the proposed steam generator support configuration meet the design code limits specified in the FSAR when designed against the specified design basis loads. The intended modifications are therefore found to be acceptable as are the proposed modifications to Section 3.13 of the Technical Specifications in Appendix A of the facility operating license.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: October 3, 1988

Principal Contributor: Ledyard Marsh, MEB

5.0 REFERENCES

1. September 22, 1987, letter from R. W. Kober, (RG&E) to C. Stahle (NRC), "Steam Generator Snubber Replacement Program at the R. E. Ginna Nuclear Power Plant," with attachment.
2. May 13, 1988, letter from B. A. Snow, (RG&E) to C. Stahle (NRC), with attached report "Steam Generator Hydraulic Snubber Replacement Program", Revision 2, dated May 8, 1988.
3. April 13, 1988, letter from C. Stahle, (NRC) to R. W. Kober (RG&E) "Snubber Replacement Program at Ginna".
4. September 9, 1987, letter from D. C. DiIanni, (NRC) to R. W. Kober (RG&E).
5. June 19, 1987, letter from F. J. Miraglia, "Relaxation in Arbitrary Intermediate Pipe Rupture Requirements (Generic Letter 87-11)".
6. May 16, 1964, letter from D. B. Vassallo, (AEC) to R. Salvatori, (Westinghouse Electric Corporation).
7. April 7, 1981, letter from R. L. Tedesco, (NRC) to T. M. Anderson, (WEC) on the approval of WCAP-8252.
8. ANSI B31.1 Power Piping Code 1967 Edition, including Summer 1973 Addenda.
9. WCAP-9558, Rev. 1, "Mechanical Fracture Evaluation of Reactor Coolant Pipe Containing a Postulated Circumferential Thin Wall Crack", June 1980.

Dated October 3, 1988

AMENDMENT NO. 31 TO FACILITY OPERATING LICENSE DPR-18, R. E. GINNA NUCLEAR POWER

Distribution:

Docket File 50-244 ←
NRC PDR
Local PDR
PDI-3 Reading
R. Wessman
C. Stahle
M. Rushbrook
OGC-Rockville
D. Hagan
E. Jordan
B. Grimes
T. Barnhart (4)
W. Jones
E. Butcher
ACRS (10) - P-312 Phillips
GPA/PA
ARM/LFMB
L. Marsh, MEB
L. Shao
J. Richardson
J. Wiggins, Region I