



Monticello Nuclear Generating Plant  
2807 West County Road 75  
Monticello, MN 55362-9637

Operated by Nuclear Management  
Company LLC

February 12, 2001

Technical Specification 6.7.A.6

US Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

Revised Annual Report of Safety Relief Valve Challenges  
January 1 through December 31, 2000

On January 23, 2001, the Nuclear Management Company submitted to the NRC the Annual Report of Safety Relief Valve Challenges January 1 through December 31, 2000 for the Monticello Nuclear Generating Plant. A typographical error exists in the body of the January 23, 2001 letter. The sentence: "For the period of January 1, 2000 to December 31, 200" should have read: "For the period of January 1, 2000 to December 31, 2000" (emphasis added). The entire content of the January 23, 2001 letter is correctly repeated below.

In accordance with Monticello Technical Specification Section 6.7.A.6, and NUREG 0737 item II.K.3.3, the following Annual Report of Safety Relief Valve Failures and Challenges is provided:

Failures:

For the period of January 1, 2000 to December 31, 2000, no safety/relief valve (SRV) failures occurred.

Challenges:

2/28/2000 All eight SRVs were manually opened at reactor pressure of approximately 150 psig in accordance with a surveillance test performed during plant startup.

This letter contains no new NRC commitments, nor does it modify any prior commitments. Please contact Sam Shirey at (763) 295-1449 if you require additional information concerning this report.

Byron D. Day  
Plant Manager  
Monticello Nuclear Generating Plant

c: Next page

A001

cc: Director, Office of Nuclear Regulatory Research  
Regional Administrator-III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
Minnesota Department of Commerce