

10 CFR 50.90

February 20, 2001
5928-01-20054

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Dear Sir or Madam:

**SUBJECT: THREE MILE ISLAND, UNIT 1 (TMI UNIT 1)
OPERATING LICENSE NO. DPR-50
DOCKET NO. 50-289
LICENSE AMENDMENT REQUEST NO. 302, TRANSMITTAL OF
CAMERA-READY TECHNICAL SPECIFICATION PAGE**

This letter transmits the camera-ready Technical Specification page to support NRC issuance of an amendment approving TMI Unit 1 License Amendment Request No. 302.

Please contact David J. Distel at (610) 765-5517, if you have any questions regarding this submittal.

Very truly yours,



G. B. Rombold
Manager, TMI Unit 1 Licensing

GBR/djd

Enclosure: TMI Unit 1 Technical Specification Revised Page for License
Amendment Request No. 302

cc: H. J. Miller, USNRC Regional Administrator, Region I
J. D. Orr, USNRC TMI Unit 1 Resident Inspector
T. G. Colburn, USNRC TMI Unit 1 Senior Project Manager
File No. 00121

A001

ENCLOSURE 1

TMI Unit 1 Technical Specification Revised Page for

License Amendment Request No. 302

5.4.2 SPENT FUEL STORAGE (Reference 1)

- a. Irradiated fuel assemblies will be stored, prior to offsite shipment, in the stainless steel lined spent fuel pools, which are located in the fuel handling building.
- b. Whenever there is fuel in the pool except for initial fuel loading, the spent fuel pool is filled with water borated to the concentration used in the reactor cavity and fuel transfer canal.
- c. Deleted.
- d. The fuel assembly storage racks provided and the number of fuel elements each will store are listed by location below:

	Spent Fuel Pool A North End of Fuel Handling Building	Spent Fuel Pool B South End of Fuel Handling Building	Dry New Fuel Storage Area Fuel Handling Building
Fuel Assys.	846 *	496	54
Cores	4.78	2.8	0.37

NOTE: * Includes three spaces for accommodating failed fuel containers. An additional 648 storage locations can be installed to provide a total of 1494 locations or 8.44 cores.

- e. All of the fuel assembly storage racks provided are designed to Seismic Class 1 criteria to the accelerations indicated below:

	Fuel Handling Building Dry New Fuel Storage Area And Spent Fuel Pool A	Fuel Handling Building Spent Fuel Pool B
Horiz.	0.38 g	**
Vertical	0.25 g	**

NOTE: ** The "B" pool fuel storage racks are designed using the floor response spectra of the Fuel Handling Building.

- f. **DELETED**

- g. When spent fuel assemblies are stored in the Spent Fuel Pool "A", Region II storage locations, the combination of initial enrichment and cumulative burnup for spent fuel assemblies shall be within the acceptable area of Figure 5-4.
- h. When spent fuel assemblies are stored in the Spent Fuel Pool "B", storage locations, the combination of initial enrichment and cumulative burnup for spent fuel assemblies shall be within the acceptable area of Figure 5-5.

REFERENCES

- (1) UFSAR, Section 9.7 - "Fuel Handling System"