Distribution Docket ORB #3 Local PDR NRC PDR VStello BGrimes TIppolito PPolk SSheppard Attorney, OELD OI&E (5) BJones (4) BScharf (10) JMcGouah DEisenhut ACRS (16) OPA (CMiles) DRoss

TERA JRBuchanan RDiggs

Docket No. 50-333

NOV 2 2 1978

Mr. George T. Berry General Manager and Chief Engineer Power Authority of the State Of New York 10 Columbus Circle New York, New York 10019

Dear Mr. Berry:

The Commission has issued the enclosed Amendment No.42-to Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power Plant. The amendment consists of changes to the Technical Specifications in partial response to your application submitted by letter dated August 10, 1978.

This amendment revises the Technical Specifications to reflect the installation of the Analog Transmitter/Trip Unit System (ATTUS). Prior to your application the staff had reviewed and approved the General Electric Topical Reports NEDO-21617 and NEDO-21617-1, "Analog Transmitter/Trip Unit System." Therefore, our present review covered those site specific design areas as related to the FitzPatrick installation.

Copies of the Safety Evaluation and the Notice of Issuance are also

Sincerely,

Original signed by

Thomas A. Ippolito, Chief Operating Reactors Branch #3 Division of Operating Reactors

1.	Amendment No License No	42 to DPR-59				CPI
3.	Notice	ation			1	(-1)
	w/enclosures:	See next pag			11/20/78 745	01
OFFICE	ORB #3		OELD	ORB_#3	ASR	
SURNAME >	35/12/20	<pre>? "PPolk:mjf</pre>	KARMAN	TIP to	Glainas	•••••••
	del 18	11/ /78	11/2//78	11/2/78	11/10/78	
EC FORM 318 (9-76) NRCM 0240						

7812080168

Enclosures

N



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

November 22, 1978

Docket No. 50-333

Mr. George T. Berry
General Manager and Chief
Engineer
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Dear Mr. Berry:

The Commission has issued the enclosed Amendment No. 42 to Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power Plant. The amendment consists of changes to the Technical Specifications in partial response to your application submitted by letter dated August 10, 1978.

This amendment revises the Technical Specifications to reflect the installation of the Analog Transmitter/Trip Unit System (ATTUS). Prior to your application the staff had reviewed and approved the General Electric Topical Reports NEDO-21617 and NEDO-21617-1, "Analog Transmitter/Trip Unit System." Therefore, our present review covered those site specific design areas as related to the FitzPatrick installation.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Hermolito, Chief

Thomas A. Ippolito, Chief Operating Reactors Branch #3 Division of Operating Reactors

Enclosures:

- 1. Amendment No. 42 to
- License No. DPR-59
- 2. Safety Evaluation
- 3. Notice

cc w/enclosures: See next page

7812080168

Power Authority of the State of New York

- 2 -

November 22, 1978

cc: Lewis R. Bennett, Assistant General Manager/General Counsel Power Authority of the State of New York 10 Columbus Circle New York, New York 10019

> Mr. Peter W. Lyon Manager-Nuclear Operations Power Authority of the State of New York 10 Columbus Circle New York, New York 10019

Mr. J. D. Leonard, Jr. Resident Manager James A. Fitzpatrick Nuclear Power Plant P. O. Box 41 Lycoming, New York 13093

Director, Technical Development Programs State of New York Energy Office Agency Building 2 Empire State Plaza Albany, New York 12223

George M. Wilverding, Licensing Licensing Supervisor Power Authority of the State of New York 10 Columbus Circle New York, New York 10019

Mr. Robert P. Jones, Supervisor Town of Scriba R. D. #4 Oswego, New York 13126

Oswego County Office Building 46 E. Bridge Street Oswego, New York 13126 Chief, Energy Systems Analyses Branch (AW-459) Office of Radiation Programs U. S. Environmental Protection Agency Room 645, East Tower 401 M Street, S. W. Washington, D. C. 20460

U. S. Environmental Protection Agency Region II Office ATTN: EIS COORDINATOR 26 Federal Plaza New York, New York 10007

١



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20665

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 42 License No. DPR-59

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Power Authority of the State of New York (the licensee) dated August 10, 1978, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (1) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (i1) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR- is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 42, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

7812080/70

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Fatipalito Thomas A. Ippolito, Chief Operating Reactors Branch #3 Division of Operating Reactors

Attachment: Changes to the Technical Specifications

Date of Issuance: November 22, 1978

.

ATTACHMENT TO LICENSE AMENDMENT NO. 42

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove	<u>Replace</u>
· 44	44
46	46

ALACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT FUNCTIONAL TESTS MINIMUM FUNCTIONAL TEST FREQUENCIES FOR SAFETY INSTRUMENT AND CONTROL CIRCUITS

•	Group (2)	Functional Test	(Uninum Frequency (3)
Mode Switch in Shutdown	٨	Place Hode Switch in Shutdown.	Lach refueling outer.
Manual Scraw	Å	Trip Channel And Alarm	hvery 3 months.
RPS Channel Test Switch	X	Trip Channel and Alarm	Every refueling outage or after channel maintenance.
IRM High Plux	с	Trip Channel and Alarr. (9)	Unce per week during refueling or startup and before each Startup.
Inoperative	C	Trip Channel and Alarm (*)	Once per week during tetueling or startup and before each startup.
APKM High Plux Inoperative Downscale Plow Bias High Plux in Startup or kefuel	6 9 6 6 7	Trip Output Relays (4) Trip Output Relays (4) Trip Output Relays (4) Calibrate Plow Blas Signal (4) Trip Output Kelays (4)	Once/week. Unce/week. Once/week. Unce/wonth. [1] Once per week during refueling or startup and before each Startup.
Nigh Meactor Freesure	В	Trip Channel and Alartii (4)	Uncrymonth. (1) (Instrument Check
high Dryvell Pressure	A	Trip Channel and Alarm	Unce/month. (1) once per day)
Reactor Low Nater Lovel (5)	k	Trip Channel and Alarm	Unce/month. (1)
High Water Lovel in Scram DiBcharge Tank	# A	Trip Channel and Alarm	Every 3 months.
Main Steam Line High Rudiation	1	Trip Channel and Alarm (4)	Dnce/wek.
Kain Steam Line Isolation Valve Clonure	A	Trip Channel and Alarm	Once/month. (1)
Furbine Control Valve EHC Dil Pressure	A	Trly Channel And Alarm	Once/month.
Turbine Pirst Stage Pressure Permissive	A	Trip Channel and Alarm	Every 3 months. (1)
Turbine Stop Valve Closure	A	Trip Channel and Alarm	Once/month. (1)

Amendment No. 42

)

gaimab

1/11/ 1-1-5

٠

NINTERS EVERPICATION PERMITERS FOR TO VOLOR PRODUCTION DESIGNATI CONTAFTS

	FAGLA & MANICUS	estus estenent brohunde	v	Reactor Preasury vermination
		(c) wion	¥	Turbine Stop Valve Clowice
	(5) +10-1			drif breaunte irzh
				LURPING CONCLOT ANTAN ANTAN
		source stuneary brahards	V	stundin that milat foote a
	that a substance			эктеплитеч
	•			Turbing Place blage Pressure
	EASTA & NOULD	esting prevente Source	7	
		(6)		
			а	notsetces upth entiress nimm
	BILLION E YINY	aottos Juarrus hrabaata		
				(.)087L0
		(c) 430H	¥	evial noiselont only manys nick
	(5) #308	137 - 1-11	•	AMO (CA
		(c) +30N	N	spandoerd marad of fewar retry delu
	[5] #10-1	•		HOUGELE TAN NOCES WALL
	Contract of Basel	Prennuce Scandard	7	fornt ant-u totta
	adicon f want	• • •		ATTURAL TIMATO HOTH
	CALL 2 INVICUS	Scandard Presente Source	¥	
	Fillarm F mont		a	нтар мечерок ревните
1	Once/Uperating cycle	Standard Presents Source	Я	· ·
1	olime antita of		a	Lumpis Mari
	FAULA P MACKE	TIP SYNEEM TEAVER	4	
	- · · · · ·	-> INOS		
		JIUNNING Disbasta disk and	9	Isanic metricity
ohi	the the the physical and the	MULT PUT THINK THAT	9	Lease, second
	41180		·	anta dolu mart
	1	"envoluted bolloring	_	XNIA HOTH RAT
	AND STORAL MINING AND	Compartance to Apply of	3	
			11 00019	Lanioit Juminitient
	HINTE Frence CY (2)	[#] U()] + P 4() [*.)		

}

711.0

KOTES FUR TAILE 9.1-2

enciteratilizeds nucle to break eitern bebutent at aquory serif to notifitizeeb a et

'**'**'

1

· · · · · · · ·

1.01



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 42 TO FACILITY OPERATING LICENSE NO. DPR-59

POWER AUTHORITY OF THE STATE OF NEW YORK

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

DOCKET NO. 50-333

By letter dated August 10, 1978, the Power Authority of the State of New York (licensee) proposed changes to the Technical Specifications appended to Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power Plant. The proposed changes make certain modifications to the reactor protection system. These modifications involve installing a new design improvement for safety system instrumentation for General Electric Company boiling water reactors in the reactor protection system. This new design of safety system instrumentation is referred to by the supplier (General Electric Company) as the Analog Transmitter Trip Unit System (ATTUS). This system is being supplied as original equipment in the GE/BWR 6 and has been made available to BWR 4 owners as a backfit. GE developed ATTUS to off-set operating disadvantages of the direct pressure and differential pressure actuated switches of the original safety system instrumentation.

The new analog transmitter/trip unit system is comprised of an analog transmitter and trip unit/calibration system (Model 510DU). GE presented ATTUS to the NRC staff for licensing under topical report NEDO-21617 of April 1977 and NEDO-21617-1 of January 1978. The staff reviewed and found acceptable ATTUS in its letter to GE dated June 27, 1978.

The staff in its approval of ATTUS required from those licensees who are backfitting their nuclear units, certain plant specific information in order to interface the review with the staff's review of the topical report on the subject. The particular information required of the licensees' is the environmental qualification and the divisional separation of the hardware installed for the plant backfit.

EVALUATION

7812080173

GE identified in its topical report (NEDO-21617) hardware application for reactor vessel pressure that provides inputs to the reactor protection system as the backfit to the FitzPatrick plant. The equipment components to be used at the FitzPatrick plant include four analog transmitters (Rosemount Model 1151) and the trip unit/calibration system (Rosemount Model 510DU). This new equipment is located in the reactor building. The trip unit/calibration system is qualified for maximum environmental abnormal exposure test conditions of 171°F, 99% humidity, 7 in. w.g. atmos. and 1.9 x 10^{5} R radiation exposure. The transmitters are qualified to

test conditions of 303° F, steam humidity, 60 psig pressure and 5 x 10^{6} R radiation exposure. The transmitters and trip unit/calibration systems are to be located in the reactor building where temperature is maintained at approximately 75°F by the ventilation system. The radiation level in the area is between 1 to 3 millirem per hour. Typical maximum credible accident conditions for the reactor building of Mark I containment are 130° F, 80-100% humidity and 2 psig. No credit is taken for post accident monitoring for this instrumentation. We find the environmental qualifications for this equipment to be acceptable.

The seismic tests for electrical components were conducted according to IEEE-344-1975 to acceleration levels in excess of the magnitudes expected at the hardware mounting locations. The three axes were tested independently at low g levels for dwell times of 30 to 35 seconds to determine if the hardware had any resonances. Since no resonant frequencies were found, all testing was performed at 33 Hz. Seismic testing of components was reviewed and found acceptable under the topical report NEDO-21617.

The licensee has documented that the new transmitters will replace in the same location the original reactor vessel pressure sensors. The trip unit/calibration systems will be mounted in four separate existing cabinets in the reactor building. The original separation criteria is satisfied. The licensee has documented that divisional separation for all wiring for the four reactor vessel pressure subchannels is in accordance with IEEE Standard 279 (1971). The arrangement of cables and raceways is designed to preserve the independence of redundant reactor protection system. The criteria for all areas of the plant require that a minimum horizontal distance of 3 feet or a minimum vertical distance of 7 feet will be maintained between cable trays, conduits, and armor cables which carry redundant circuits. Redundant cables are run in separate cable trays or conduits which are physically separated and follow different routes to and from power sources to loads and from sensors to protective devices. We find this acceptable.

The proposed equipment modifications required the following minor changes be made to Technical Specifications (T.S.) tables 4.1-1 and 4.1-2.

- 1. The group identification for high reactor pressure was changed from on-off sensors to analog devices in both tables.
- 2. Minimum calibration frequency for high reactor pressure was changed from 3 months to once/operating cycle in table 4.1-2.
- 3. Instrument check once per day was added in parenthesis to functional test frequency for high reactor pressure in table 4.1-1. We find these changes acceptable.

Based on our review of the licensee's submittals, we find the proposed modifications to the reactor protection system satisfy the requirements for environmental/seismic qualification and divisional separation; and are, therefore, acceptable. We also find that changes to T.S. tables 4.1-1 and 4.1-2 are acceptable.

ENVIRONMENTAL CONSIDERATION

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR \$51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: November 22, 1978

7590-01

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-333

POWER AUTHORITY OF THE STATE OF NEW YORK

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 42 to Facility Operating License No. DPR-59, issued to Power Authority of the State of New York (the licensee), which revised Technical Specifications for operation of the James A. FitzPatrick Nuclear Power Plant (the facility) located in Oswego County, New York. The amendment is effective as of its date of issuance.

This amendment revises the Technical Specifications to reflect the installation of the Analog Transmitter/Trip Unit System (ATTUS).

The application for the amendment complies with the standards and r-quirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

7812080176

For further details with respect to this action, see (1) the application for amendment dated August 10, 1978, (2) Amendment No. 42 to License No. DPR-59, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Oswego County Office Building, 46 East Bridge Street, Oswego, New York. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 22nd day of November 1978.

FOR THE NUCLEAR REGULATORY COMMISSION

Thomas A. Ippolito, Chief

Thomas #."Ippolito, Chief Operating Reactors Branch #3 Division of Operating Reactors

- 2 -