

May 20, 1996

Dr. Robert C. Mecredy  
Vice President, Nuclear Operations  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, NY 14649

SUBJECT: ISSUANCE OF AMENDMENT NO. 63 TO FACILITY OPERATING LICENSE  
NO. DPR-18, R. E. GINNA NUCLEAR POWER PLANT (TAC NO. M94771)

Dear Dr. Mecredy:

The Commission has issued the enclosed Amendment No. 63 to Facility Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant. This amendment is in response to your application dated February 9, 1996.

This amendment changes the Technical Specification setpoints for the steam generator water level-high feedwater isolation function.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Guy S. Vissing, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosures: 1. Amendment No. 63 to License No. DPR-18  
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION: See attached sheet

DOCUMENT NAME: G:\GINNA\GI94771.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDI-1	PM:PDI-1	OGC	D:PDI-1	
NAME	SLittle	GVissing:smm	ETBOLLON	SShankman	JHitchcock
DATE	05/3/96	05/6/96	05/13/96	05/20/96	05/ /96

OFFICIAL RECORD COPY

DFD 1 1/1

9605230195 960520  
PDR ADDCK 05000244  
P PDR

NRC FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 20, 1996

Dr. Robert C. Mecredy  
Vice President, Nuclear Operations  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, NY 14649

SUBJECT: ISSUANCE OF AMENDMENT NO. 63 TO FACILITY OPERATING LICENSE  
NO. DPR-18, R. E. GINNA NUCLEAR POWER PLANT (TAC NO. M94771)

Dear Dr. Mecredy:

The Commission has issued the enclosed Amendment No. 63 to Facility Operating License No. DPR-18 for the R. E. Ginna Nuclear Power Plant. This amendment is in response to your application dated February 9, 1996.

This amendment changes the Technical Specification setpoints for the steam generator water level-high feedwater isolation function.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Guy S. Vissing".

Guy S. Vissing, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosures: 1. Amendment No. 63 to  
License No. DPR-18  
2. Safety Evaluation

cc w/encls: See next page

Dr. Robert C. Mecredy

R.E. Ginna Nuclear Power Plant

cc:

Peter D. Drysdale, Senior Resident Inspector  
R.E. Ginna Plant  
U.S. Nuclear Regulatory Commission  
1503 Lake Road  
Ontario, NY 14519

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. F. William Valentino, President  
New York State Energy, Research,  
and Development Authority  
2 Rockefeller Plaza  
Albany, NY 12223-1253

Charlie Donaldson, Esq.  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Nicholas S. Reynolds  
Winston & Strawn  
1400 L St. N.W.  
Washington, DC 20005-3502

Ms. Thelma Wideman  
Director, Wayne County Emergency  
Management Office  
Wayne County Emergency Operations Center  
7336 Route 31  
Lyons, NY 14489

Ms. Mary Louise Meisenzahl  
Administrator, Monroe County  
Office of Emergency Preparedness  
111 West Fall Road, Room 11  
Rochester, NY 14620

DATED: May 20, 1996

AMENDMENT NO. 63 TO FACILITY OPERATING LICENSE NO. DPR-18-GINNA NUCLEAR POWER PLANT

**Docket File**

PUBLIC

PDI-1 Reading

S. Varga, 14/E/4

J. Mitchell

S. Little

G. Vissing

H. Balukjian

OGC

G. Hill (2), T-5 C3

C. Grimes, 11/E/22

ACRS

PD plant-specific file

J. Linville, Region I

cc: Plant Service list

230002



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

ROCHESTER GAS AND ELECTRIC CORPORATION

DOCKET NO. 50-244

R. E. GINNA NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 63  
License No. DPR-18


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
  - A. The application for amendment filed by the Rochester Gas and Electric Corporation (the licensee) dated February 9, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-18 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 63, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Jocelyn A. Mitchell, Acting Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 20, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 63

FACILITY OPERATING LICENSE NO. DPR-18

DOCKET NO. 50-244

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

3.3-27

Insert

3.3-27

Table 3.3.2-1 (page 3 of 3)  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	TRIP SETPOINT
<b>5. Feedwater Isolation</b>						
a. Automatic Actuation Logic and Actuation Relays	1,2(c),3(c)	2 trains	E,G	SR 3.3.2.7	NA	NA
b. SG Water Level -High	1,2(c),3(c)	3 per SG	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 94%	≤ 85%
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
<b>6. Auxiliary Feedwater (AFW)</b>						
<b>a. Manual Initiation</b>						
AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
Standby AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	E,G	SR 3.3.2.7	NA	NA
c. SG Water Level -Low Low	1,2,3	3 per SG	D,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≥ 16%	≥ 17%
d. Safety Injection (Motor driven pumps only)	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
e. Undervoltage -Bus 11A and 11B (Turbine driven pump only)	1,2,3	2 per bus	D,G	SR 3.3.2.3 SR 3.3.2.5	≥ 2450 V with ≤ 3.6 sec time delay	≥ 2579 V with ≤ 3.6 sec time delay
f. Trip of Both Main Feedwater Pumps (Motor driven pumps only)	1,2	2 per MFW pump	B,C	SR 3.3.2.4	NA	NA

(c) Except when all Main Feedwater Regulating and associated bypass valves are closed and de-activated or isolated by a closed manual valve.





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 63 TO FACILITY OPERATING LICENSE NO. DPR-18  
ROCHESTER GAS AND ELECTRIC CORPORATION  
R. E. GINNA NUCLEAR POWER PLANT  
DOCKET NO. 50-244

1.0 INTRODUCTION

By letter dated February 9, 1996, the Rochester Gas and Electric Corporation (the licensee) submitted a request for changes to the R. E. Ginna Nuclear Power Plant Technical Specifications (TSs). The requested changes would change the TS setpoints for the steam generator water level-high feedwater isolation function.

The following TS would be changed:

1. Technical Specification Table 3.3.2-1, Function 5b.
  - i. The allowable value would be changed from  $\leq 68\%$  to  $\leq 94\%$ .
  - ii. The trip setpoint value would be changed from  $\leq 67\%$  to  $\leq 85\%$ .

2.0 BACKGROUND

The licensee stated that the Steam Generator (SG) Water Level-High feedwater isolation setpoint is designed to prevent excessive moisture carryover to the main steam system, which would cause excessive wear on the main turbine. SGs separate water in two stages, a primary stage and a secondary stage. Primary separators are located in the steam drum of the generator below the secondary separators, and generally work on the centrifugal principle. The high water level setpoint is chosen such that water in the downcomer is not above the top of these primary separators which would flood them and degrade their performance.

The Ginna Station is planning to replace its SGs during the 1996 Refueling Outage. The original SGs are Westinghouse Model 44 SGs. The primary separator flood point for these generators is at approximately 75 percent narrow range water level. Consequently, a setpoint sufficiently below this value to allow for instrument and process measurement uncertainty is chosen for the current setpoint value of 67 percent narrow range.

Replacement SGs are being manufactured by Babcock and Wilcox International. The flood point for the primary separators on these generators is above

100 percent narrow range level. Consequently, new setpoints sufficiently below 100 percent to account for process measurement uncertainty are chosen for an allowable value (94 percent), and instrument uncertainty for a setpoint value (85 percent). This expanded range allows the operator more time to restore level to nominal conditions using controlled means prior to initiation of feedwater isolation.

Prior to implementing this TS change the SGs must be replaced. No other hardware changes are required.

### 3.0 EVALUATION

The design of the replacement SGs is such that the primary steam separators are located at a higher elevation in the steam drum than in the existing SGs. The bottom of the actual separator is approximately 14 inches above the upper narrow range level tap. Therefore, it is acceptable to operate with water levels above 100 percent narrow range level without degrading separator performance. Since water level above 100 percent cannot be monitored, 100 percent is chosen as the limit.

The Upgraded Final Safety Analysis Report (UFSAR) accident analyses that model this setpoint (Section 15.1.6, Combined Steam-Generator Atmospheric Relief Valve and Feedwater Control Valve Failures) currently use a value of 100 percent narrow range level. Therefore, the accident analysis is not affected by this proposed change as the same 100 percent narrow range level value remains.

The SG Water-Level-High feedwater isolation function is designed to prevent excessive moisture carryover to the main steam system. The proposed setpoint change does not degrade the capability of the moisture separators and therefore this function is unchanged. The UFSAR accident analyses that model this function (UFSAR Section 15.1.6) use a value of 100 percent narrow range level. The revised trip setpoint (85 percent) and allowable value (94 percent) were raised from the previous values to minimize challenges and to avoid trips. They remain bounded by the accident analysis value of 100 percent. Therefore, we find these proposed changes to be acceptable.

### 4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New York State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released.

offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (61 FR 7558). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

## 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: H. Balukjian

Date: May 20, 1996