

February 9, 1987

MEMORANDUM FOR: Sholly Coordinator  
FROM: Daniel R. Muller, Director  
BWR Project Directorate #2  
Division of BWR Licensing  
SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE  
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

DISTRIBUTION:

Docket File OGC - Bethesda  
PD#2 Reading  
HAbelson  
SNorris

Sholly Coordinator (Orig & 1)

Power Authority of the State of New York, Docket No. 50-333, James A.

FitzPatrick Nuclear Power Plant, Oswego County, New York

Date of application for amendment: October 8, 1986

Brief description of amendment: The amendment changes the Technical Specifications to eliminate operability and testing requirements for the recirculation pump discharge bypass valves. The bypass valves and lines are to be removed during the 1987 refueling outage.

Date of issuance: February 9, 1987

Effective date: February 9, 1987

Amendment No.: 104

Facility Operating License No. DPR-59. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 19, 1986 (51 FR 41867)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 9, 1987

No significant hazards consideration comments received: No.

8702180536 870209  
CF ADDCK 05000333  
P CF

Local Public Document Room location: Penfield Library, State University  
College of Oswego, Oswego, New York.

Original signed by  
Daniel R. Muller

Daniel R. Muller, Director  
BWR Project Directorate #2  
Division of BWR Licensing

OFFICIAL RECORD COPY

DBL:PD#2  
SNorris  
1/29/86

DBL:PD#2  
Harrison  
1/29/86

OGC - Bethesda  
bmBoydewide  
2/2/86

DBL:PD#2  
DMuller  
2/19/86