

June 5, 1985

Docket No. 50-333

Mr. John C. Brons
Senior Vice President -
Nuclear Generation
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Brons:

On May 16, 1985, the Commission issued Amendment No. 90 to Facility
Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power
Plant.

Page 33 issued with the amendment failed to reflect changes made by
Amendment No. 89. Enclosed is a corrected page 33.

We regret any inconvenience this change may have created.

Sincerely,

Original signed by/

Harvey I. Abelson, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
HThompson

SNorris
HAbelson
OELD
LJHarmon
ELJordan

BGrimes
TBarnhart (4)
WJones
EButcher
ACRS (10)

OPA, CMiles
RDiggs
Gray File
Extra - 5
JPartlow

DL:ORB#2
SNorris:ajs
6/3/85

DL:ORB#2
HAbelson
6/4/85

DL:ORB#2
DVassallo
6/5/85

8506140465 850605
PDR ADOCK 05000333
P PDR

Mr. John C. Brons
Power Authority of the State of New York

James A. FitzPatrick Nuclear
Power Plant

cc:

Mr. Charles M. Pratt
Assistant General Counsel
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. Jay Dunkleberger
Division of Policy Analysis
and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Post Office Box 136
Lycoming, New York 13093

Thomas A. Murley
Regional Administrator
Region I Office
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Harold Glovier
Resident Manager
James A. FitzPatrick Nuclear
Power Plant
Post Office Box 41
Lycoming, New York 13093

Mr. A. Klausman
Vice President - Quality Assurance
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. J. A. Gray, Jr.
Director - Nuclear Licensing - BWR
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. George Wilverding, Chairman
Safety Review Committee
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Robert P. Jones, Supervisor
Town of Scriba
R. D. #4
Oswego, New York 13126

Mr. Leroy W. Sinclair
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Mr. M. C. Cosgrove
Quality Assurance Superintendent
James A. FitzPatrick Nuclear
Power Plant
Post Office Box 41
Lycoming, New York 13093

3.1 BASES (cont'd)

subchannel. APRM's B, D and F are arranged similarly in the other protection trip system. Each protection trip system has one more APRM than is necessary to meet the minimum number required per channel. This allows the bypassing of one APRM per protection trip system for maintenance, testing or calibration. Additional IRM channels have also been provided to allow for bypassing of one such channel. The bases for the scram setting for the IRM, APRM, high reactor pressure, reactor low water level, main steam isolation valve (MSIV) closure, and generator load rejection, turbine stop valve closure are discussed in Sections 2.1 and 2.2.

Instrumentation for the drywell is provided to detect a loss of coolant accident and initiate the core standby cooling equipment. A high drywell pressure scram is provided at the same setting as the Core and Containment Cooling Systems (ECCS) initiation to minimize the energy which must be accommodated during a loss-of-coolant accident and to prevent return to criticality. This instrumentation is a backup to the reactor vessel water level instrumentation.

High radiation levels in the main steam line tunnel, above normal levels due to the nitrogen and oxygen radioactivity, are an indication of leaking fuel. A scram is initiated whenever such radiation level exceeds three times normal background. The purpose of this scram is to reduce the source of such radiation to the extent necessary to prevent excessive turbine

contamination. Discharge of excessive amounts of radioactivity to the site environs is prevented by the air ejector offgas monitors which cause an isolation of the main condenser offgas line. During the Hydrogen Addition Test, the normal background Main Steam Line Radiation Level is expected to increase by a factor of approximately 5 at the maximum hydrogen addition rate as indicated in note 16, Table 3.1-1. The scram setpoint will be reset to three times the projected background radiation level prior to performance of the test. The setpoint will be restored to normal following completion of the hydrogen addition test.

A Reactor Mode Switch is provided which actuates or bypasses the various scram functions appropriate to the particular plant operating status. Reference paragraph 7.2.3.7 FSAR.

The manual scram function is active in all modes, thus providing for a manual means of rapidly inserting control rods during all modes of reactor operation.

The APRM (high flux in startup or refuel) System provides protection against excessive power levels and short reactor periods in the startup and intermediate power ranges.

The IRM System provides protection against short reactor periods in these ranges.

The Control Rod Drive Scram System is designed so that all of the water which