




INSTRUMENT NUMBER	VALUE	DESCRIPTION	SIZE	NO. OF
2-RHS-003-904-4	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(A)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(B)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(C)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(D)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(E)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(F)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(G)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(H)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(I)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(J)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(K)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(L)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(M)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(N)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(O)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(P)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(Q)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(R)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(S)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(T)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(U)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(V)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(W)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(X)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(Y)	1/2"	VALVE	1/2"	1
2-RHS-012-7-2(Z)	1/2"	VALVE	1/2"	1

- NOTES
1. ALL INSTRUMENT AND EQUIPMENT NUMBERS TO BE PREVIEWED WITH "2RHS" EXCEPT WHERE A DIFFERENT PREFIX IS SHOWN. AN APOSTROPHE (') WILL REPLACE THE DASH (-) IN THE PREFIX FOR EQUIPMENT OR INSTRUMENTS WHICH ARE PART OF NUCLEAR SAFETY FEATURES SYSTEMS.
 2. I.E. IDENTIFICATION NUMBERS ARE SHOWN IN SQUARES TO BE PREVIEWED BY ETC (UNLESS OTHERWISE PREVIEWED).
 3. ALL INSTRUMENTS, TEST, DRAIN, & VENT CONNECTIONS SHALL BE 3/4" EXCEPT AS NOTED.
 4. LINES 1" & SMALLER WHICH ARE PART OF THE REACTOR COOLANT PRESS. BOUNDARY SHALL BE SAFETY CLASS 2.
 5. VALVE POSITIONS ARE SHOWN FOR NORMAL OPERATION OF THE PLANT. THE SYSTEM IS ON STANDBY, READY TO START RCH LFCI MODE OF OPERATION.
 6. ALL INSTRUMENT LINES INSIDE THE DRYWELL ARE CLASS 1516 AND OUTSIDE THE DRYWELL ARE CLASS 1502 UNLESS OTHERWISE NOTED.
 7. - indicates dissimilar metal weld.
 8. 2RHS-012-7-2(A) IS A "FIGURE A" TYPE SPECTACLE FLANGE. THE BLANK INSERT PORTION OF THE FLANGE SHALL BE REMOVED AND DISCARDED WHILE THE FLANGE BORE INSERT SHALL BE REMOVED AND DISCARDED.
 9. 2RHS-012-7-2(A) AND 2RHS-012-7-2(B) SHALL BE DE-ENERGIZED AND DISCONNECTED FROM THEIR POWER SOURCE (BREAKER OPEN) DURING NORMAL PLANT OPERATION TO PRECLUDE THE POSSIBILITY OF SPURIOUS ACTUATION DURING A CONTROL ROOM FIRE (APPENDIX P). THIS IS NOT MEANT TO PRECLUDE USE OF THIS VALVE DURING NORMAL OPERATION, BUT TO ENSURE THAT THE VALVE REMAINS DE-ENERGIZED WHEN NOT IN USE.
 10. DURING PERIODIC SURVEILLANCE TESTING (MODE E) OF GE PROCESS DATA SHEET, THE DRYWELL PLATE OF 2RHS-012-7-2(A) MUST BE REPLACED WITH A TEMPORARY PLATE (EITHER 2RHS-012-7-2(A) OR B) TO PREVENT PUMP FLUIDITY. TEMPORARY PLATES 2RHS-012-7-2(A) AND B ARE IDENTICAL. LINES OF THESE MAY BE INSCRIBED INTO 2RHS-012-7-2(A) AS REQUIRED FOR TESTING PURPOSES. 2RHS-012-7-2(A) SHALL BE REINSTALLED UPON COMPLETION OF TESTING.
 11. - indicates minimum distance for installation.
 12. - indicates equipment supplied by GE-RED.
 13. ACTUAL SOCKET CONNECTION ON 2RHS PENETRATION PIPE.

ORIGINAL

NON SAFETY RELATED
SAFETY RELATED
QUALITY RELATED
(REF. SAR FIG. 5.4-130 & ISPT-31A)

NI NAGARA
MOHAWK

NINE MILE POINT
NUCLEAR STATION - UNIT 2
SCRIBA, N.Y.

PIPING & INSTRUMENTATION DIAGRAM
RESIDUAL HEAT REMOVAL
SYSTEM

SCALE: NONE
DRAWING NO: PID-31A-13