Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

FEB 28 2001

Docket Nos. 50-336
50-423
B18321

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit Nos. 2 and 3
Annual Report

Pursuant to the provisions of Sections 6.9.1.4 and 6.9.1.5 of the Millstone Unit No. 2 Technical Specifications and Section 6.9.1.2 of the Millstone Unit No. 3 Technical Specifications, this report is submitted covering operations for the period January 1, 2000, to December 31, 2000.

Results for Units 2 and 3 are included in this report as Attachments 1 and 2 respectively.

There are no regulatory commitments contained within this letter.

Should you have any questions regarding this report, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

Robert G. Lizotte
Master Process Owner - Assessment

A001

cc: See next page

Attachments (2)

cc: H. J. Miller, Region I Administrator
D. S. Collins, NRC Project Manager, Millstone Unit No. 2
S. R. Jones, Senior Resident Inspector, Millstone Unit No. 2
V. Nerses, NRC Senior Project Manager, Millstone Unit No. 3
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3

Director, Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Attention: REIRS Project Manager
Washington, DC 20555

Docket Nos. 50-336
50-423
B18321

Attachment 1

Millstone Nuclear Power Station Unit Nos. 2 and 3

Millstone Unit No. 2 Annual Report

PEWPDD20
sosinrv

MILLSTONE NUCLEAR POWER STATION
REG. GUIDE 1.16 REPORT

30-jan-2001
Unit: 2

Work & Job Function	# of Personnel			Total Man-mRem		
	Station	Utility	Contract	Station	Utility	Contract
Inservice Inspection						
Engineering Staff	11	7	14	317	122	959
HealthPhysics and Lab	3	0	9	18	0	181
Maint and Construction	13	2	68	137	20	2564
Operations	12	0	0	790	0	0
Supv and Office Staff	6	3	2	83	24	7
Refueling Operations						
Engineering Staff	148	30	58	2087	284	782
HealthPhysics and Lab	51	1	71	4672	26	6455
Maint and Construction	271	67	603	7922	1060	44928
Operations	96	0	11	4403	0	2
Supv and Office Staff	53	17	39	1026	435	169
Routine Oper and Surv						
Engineering Staff	150	33	108	1061	816	316
HealthPhysics and Lab	55	4	66	4180	2	294
Maint and Construction	190	25	141	2663	125	560
Operations	122	0	3	5476	0	9
Supv and Office Staff	32	8	19	65	13	16
Routine Plant Maint						
Engineering Staff	91	24	43	487	232	80
HealthPhysics and Lab	33	1	28	185	0	122
Maint and Construction	316	61	637	6221	1639	2986
Operations	27	0	19	80	0	4
Supv and Office Staff	37	9	73	34	11	81
Special Plant Maint						
Engineering Staff	21	2	5	225	3	5
HealthPhysics and Lab	31	1	3	652	0	27
Maint and Construction	105	11	55	3163	172	188
Operations	35	0	1	399	0	35
Supv and Office Staff	3	1	3	15	1	11
Waste Processing						
Engineering Staff	23	6	9	2	0	1
HealthPhysics and Lab	53	3	70	1399	10	353
Maint and Construction	133	31	230	493	51	489
Operations	2	0	0	8	0	0
Supv and Office Staff	14	2	4	21	0	0
Job Totals						
Engineering Staff	444	102	237	4179	1457	2143
HealthPhysics and Lab	226	10	249	11106	38	7432
Maint and Construction	1028	197	1734	20599	3067	51715
Operations	294	0	34	11156	0	50
Supv and Office Staff	145	40	140	1244	484	284
Unit 2 Total	2137	349	2392	48284	5046	61624

Note: Report contains electronic dosimeter or PIC dose only

Dose of persons with <100 mrem IS INCLUDED

PRIMARY COOLANT IODINE SPIKING

In accordance with Technical Specification 6.9.1.5, the following is a report of primary coolant iodine spiking occurring during 2000.

During 2000, the specific activity of the primary coolant did not exceed the limits in the Technical Specifications.

CHALLENGES TO RELIEF/SAFETY VALVES

In accordance with Technical Specification 6.9.1.5, the following is a report of challenges to relief/safety valves during 2000.

There were no challenges made to the primary relief/safety valves in 2000.

STEAM GENERATOR TUBING INSERVICE INSPECTION

SUMMARY OF EVENTS 2000

In accordance with Technical Specification 6.9.1.5, the following is a report of steam generator tubing inservice inspections performed during 2000.

The steam generator eddy current inspections, conducted at the end of Millstone Unit No. 2 Fuel Cycle 13, were completed on May 9, 2000. After completion of two cycles of operation with the new steam generators, no indications of corrosion or mechanically induced tube degradation have been identified. Consequently, no tube plugging was performed.

The inspection included a one hundred percent bobbin inspection (8523 tubes) performed in Steam Generator Number 2. The subject bobbin inspections were performed full length (i.e., cold leg tube end to hot leg tube end), at speeds up to 38 inches per second. Rows 1 through 15 were tested at lower speeds (i.e., 24 inches per second).

Supplementing the bobbin inspection was an augmented sample (87 locations) inspected using rotating probe coils. The rotating probe used was the Plus Point Coil. The Plus Point Coil was chosen because this probe provides superior detection of both circumferential and axial cracks, and has been qualified per the Pressurized Water Reactor Steam Generator Examination Guidelines, Appendix H, for the detection of cracking mechanisms. The rotating probe coil inspections were performed at areas of special interest (e.g., hot leg tube sheet areas, bulges, dents, and dings) identified during the bobbin inspection. After completion of two cycles of operation, no indications of corrosion or mechanically induced tube degradation have been identified. Consequently, no tube plugging was performed.

In accordance with the standards established per NEI 97-06, "Steam Generator Program Guidelines," a condition monitoring and operational assessment evaluation was performed of the Millstone Unit No. 2 Steam Generators. This evaluation concluded that none of the steam generator performance criteria had been exceeded during Cycle 13 operation. The evaluation also established reasonable assurance that operation of the steam generators, throughout the interval preceding the next examination, will not cause any of the performance criteria to be exceeded.

In accordance with Millstone Unit No. 2 Technical Specification 4.4.5.1.5.b, the following pages provide a listing of imperfections identified during the inspection. Imperfections are defined per Technical Specification 4.4.5.1.4.a.1 as:

> "An exception to the dimensions, finish, or contour of a tube or sleeve from that required by fabrication drawings or specifications. Eddy-current testing indications below 20% of the nominal tube or sleeve wall thickness, if detectable, may be considered as imperfections."

The following report includes all indications detected, such as bulges, dents, dings, and permeability variations.

****
* INSPECTION FINAL REPORT LISTING *
****

*** This report contains all report entries appended to the database for the following test plans ***

All Test Plans in the database are included in summary: 3

	Test Plan Name:	Probe Type:	Probe Size:	Type:
1.	F/L Bobbin HOT LEG	BOBBIN	600UL	HL
2.	Special Interest	MRPC	560PP	HL
3.	PLP - Bounding	MRPC	610PP	HL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1	4	1	0.34	77	INR	6	TSH	+16.36	TECTEH			21H00012	600UL
2			0.76	60	INR	6	01H	+33.25	TECTEH			21H00012	600UL
3			0.48	82	INR	6	02H	+18.43	TECTEH			21H00012	600UL
4			0.45	77	INR	6	04C	+25.28	TECTEH			21H00012	600UL
5	6	1							TECTEH			21H00012	600UL
6	8	1							TECTEH			21H00011	600UL
7	10	1							TECTEH			21H00012	600UL
8	12	1							TECTEH			21H00011	600UL
9	14	1	0.39	81	INR	6	04C	+14.97	TECTEH			21H00012	600UL
10			0.59	92	INR	6	03C	+9.48	TECTEH			21H00012	600UL
11			0.50	83	INR	6	02C	+17.61	TECTEH			21H00012	600UL
12	16	1							TECTEH			21H00011	600UL
13	5	2							TECTEH			21H00012	600UL
14	7	2							TECTEH			21H00011	600UL
15	9	2							TECTEH			21H00012	600UL
16	11	2							TECTEH			21H00011	600UL
17	13	2	0.20	64	INR	6	01H	+27.23	TECTEH			21H00012	600UL
18			0.34	75	INR	6	03C	+27.40	TECTEH			21H00012	600UL
19	15	2	0.46	85	INR	6	01C	+23.31	TECTEH			21H00011	600UL
20					INF		01C	+27.71	TECTEH	HR		21H00011	600UL
21	17	2	9.86	2	INR	1	07H	+1.43	TECTEH			21H00012	600UL
22	19	2							TECTEH			21H00011	600UL
23	21	2							TECTEH			21H00012	600UL
24	23	2	0.39	53	INR	6	05H	+22.31	TECTEH			21H00011	600UL
25	25	2							TECTEH			21H00013	600UL
26	4	3							TECTEH			21H00012	600UL
27	6	3							TECTEH			21H00012	600UL
28	8	3							TECTEH			21H00011	600UL
29	10	3							TECTEH			21H00012	600UL
30	12	3							TECTEH			21H00011	600UL
31	14	3	0.95	57	INR	6	07C	+1.75	TECTEH			21H00012	600UL
32			0.71	70	INR	6	TSC	+6.52	TECTEH			21H00012	600UL
33	16	3							TECTEH			21H00011	600UL
34	18	3							TECTEH			21H00012	600UL
35	20	3							TECTEH			21H00011	600UL
36	22	3							TECTEH			21H00012	600UL
37	24	3			INF		F01	+6.37	TECTEH	HR		21H00011	600UL
38			4.34	182	DNT	P1	F05	-1.63	TECTEH			21H00011	600UL
39			0.62	81	INR	6	01C	+22.58	TECTEH			21H00011	600UL
40	26	3	3.95	184	INR	1	F01	+7.18	TECTEH			21H00014	600UL
41	28	3							TECTEH			21H00013	600UL
42	30	3	0.84	80	INR	6	01C	+22.32	TECTEH			21H00014	600UL
43	32	3							TECTEH			21H00013	600UL
44	5	4							TECTEH			21H00012	600UL
45	7	4	0.37	67	INR	6	06H	+13.76	TECTEH			21H00011	600UL
46			0.47	81	INR	6	04C	+25.85	TECTEH			21H00011	600UL
47	9	4							TECTEH			21H00012	600UL
48	11	4	0.35	67	INR	6	05C	+36.67	TECTEH			21H00011	600UL
49			0.43	76	INR	6	04C	+31.24	TECTEH			21H00011	600UL
50	13	4	0.42	77	INR	6	06H	+3.74	TECTEH			21H00012	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
51			0.34	84	INR	6	05C	+31.21	TECTEH			21H00012	600UL
52	15	4							TECTEH			21H00011	600UL
53	17	4							TECTEH			21H00012	600UL
54	19	4	0.35	47	INR	6	05C	+35.59	TECTEH			21H00011	600UL
55	21	4			INF		F04	+5.20	TECTEH	HR		21H00012	600UL
56					INF		F06	+3.82	TECTEH	HR		21H00012	600UL
57			1.06	81	INR	6	F06	+5.14	TECTEH			21H00012	600UL
58	23	4	2.15	181	INR	P1	F01	-0.09	TECTEH			21H00011	600UL
59					INF		F01	+5.56	TECTEH	HR		21H00011	600UL
60					INF		F01	+7.17	TECTEH	HR		21H00011	600UL
61			4.54	182	DNT	P1	F05	-1.31	TECTEH			21H00011	600UL
62	25	4			INF		F06	+2.12	TECTEH	HR		21H00014	600UL
63			0.44	82	INR	6	F06	+3.73	TECTEH			21H00014	600UL
64			0.61	81	INR	6	01C	+7.21	TECTEH			21H00014	600UL
65	27	4	0.37	107	NQH	3	05H	+12.25	TECTEH			21H00013	600UL
66	29	4							TECTEH			21H00014	600UL
67	31	4							TECTEH			21H00013	600UL
68	33	4							TECTEH			21H00014	600UL
69	35	4							TECTEH			21H00013	600UL
70	37	4							TECTEH			21H00014	600UL
71	39	4							TECTEH			21H00013	600UL
72	4	5	0.52	73	INR	6	05C	+30.45	TECTEH			21H00011	600UL
73	6	5							TECTEH			21H00012	600UL
74	8	5							TECTEH			21H00011	600UL
75	10	5							TECTEH			21H00012	600UL
76	12	5							TECTEH			21H00011	600UL
77	14	5	0.31	51	INR	6	06H	+20.09	TECTEH			21H00012	600UL
78	16	5							TECTEH			21H00011	600UL
79	18	5	0.33	75	INR	6	06H	+3.00	TECTEH			21H00012	600UL
80					INF		06H	+24.85	TECTEH	HR		21H00012	600UL
81			0.42	71	INR	6	06H	+26.70	TECTEH			21H00012	600UL
82			0.41	71	INR	6	06C	+3.40	TECTEH			21H00012	600UL
83			0.47	85	INR	6	04C	+23.01	TECTEH			21H00012	600UL
84			0.40	72	INR	6	02C	+3.23	TECTEH			21H00012	600UL
85	20	5							TECTEH			21H00011	600UL
86	22	5	5.50	180	INR	1	F05	-1.04	TECTEH			21H00012	600UL
87					INF		F05	+0.14	TECTEH	HR		21H00012	600UL
88	24	5	0.41	17	INR	6	F06	+1.63	TECTEH			21H00011	600UL
89			0.22	65	INR	3	05C	+13.22	TECTEH			21H00011	600UL
90	26	5							TECTEH			21H00014	600UL
91	28	5	0.26	83	INR	3	02C	+18.77	TECTEH			21H00013	600UL
92	30	5							TECTEH			21H00014	600UL
93	32	5							TECTEH			21H00013	600UL
94	34	5							TECTEH			21H00014	600UL
95	36	5	0.52	74	INR	6	04C	+21.18	TECTEH			21H00013	600UL
96			0.59	79	INR	6	TSC	+13.57	TECTEH			21H00013	600UL
97	38	5	0.47	66	INR	6	05H	+10.81	TECTEH			21H00014	600UL
98			0.32	84	INR	6	05H	+24.38	TECTEH			21H00014	600UL
99	40	5	0.78	77	INR	6	03H	+8.49	TECTEH			21H00013	600UL
100			0.57	96	INR	6	04H	+2.22	TECTEH			21H00013	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
101			0.29	44	INR	6	F04	+6.59	TECTEH			21H00013	600UL
102					INF		F04	+10.16	TECTEH	HR		21H00013	600UL
103			0.37	77	INR	6	F12	+7.41	TECTEH			21H00013	600UL
104					INF		07C	+3.35	TECTEH	HR		21H00013	600UL
105			0.47	76	INR	6	01C	+3.80	TECTEH			21H00013	600UL
106	42	5							TECTEH			21H00014	600UL
107	44	5	0.46	76	INR	6	02C	+34.86	TECTEH			21H00013	600UL
108	3	6							TECTEH			21H00028	600UL
109	5	6							TECTEH			21H00012	600UL
110	7	6	0.57	84	INR	6	01H	+29.83	TECTEH			21H00011	600UL
111	9	6							TECTEH			21H00012	600UL
112	11	6	0.46	83	INR	6	02H	+24.64	TECTEH			21H00011	600UL
113			0.55	83	INR	6	04C	+30.24	TECTEH			21H00011	600UL
114			0.66	81	INR	6	TSC	+4.36	TECTEH			21H00011	600UL
115			0.47	78	INR	6	TSC	+8.86	TECTEH			21H00011	600UL
116	13	6							TECTEH			21H00012	600UL
117	15	6							TECTEH			21H00011	600UL
118	17	6							TECTEH			21H00012	600UL
119	19	6							TECTEH			21H00011	600UL
120	21	6							TECTEH			21H00012	600UL
121	23	6	0.62	64	INR	6	06C	+35.58	TECTEH			21H00011	600UL
122	25	6							TECTEH			21H00014	600UL
123	27	6							TECTEH			21H00013	600UL
124	29	6							TECTEH			21H00014	600UL
125	31	6							TECTEH			21H00013	600UL
126	33	6	0.68	82	INR	6	03C	+20.10	TECTEH			21H00014	600UL
127	35	6	0.23	124	INR	3	06C	+32.93	TECTEH			21H00013	600UL
128			0.49	81	INR	6	03C	+10.91	TECTEH			21H00013	600UL
129	37	6							TECTEH			21H00014	600UL
130	39	6							TECTEH			21H00013	600UL
131	41	6	0.34	76	INR	6	04H	+19.67	TECTEH			21H00014	600UL
132	43	6							TECTEH			21H00013	600UL
133	45	6							TECTEH			21H00014	600UL
134	47	6	2.68	32	ADS	6	02C	+26.59 TO+39.40	TECTEH			21H00013	600UL
135	49	6							TECTEH			21H00013	600UL
136	2	7							TECTEH			21H00028	600UL
137	4	7							TECTEH			21H00011	600UL
138	6	7							TECTEH			21H00012	600UL
139	8	7							TECTEH			21H00011	600UL
140	10	7	0.71	80	INR	6	01H	+14.83	TECTEH			21H00012	600UL
141			0.57	72	INR	6	01C	+2.72	TECTEH			21H00012	600UL
142	12	7							TECTEH			21H00011	600UL
143	14	7							TECTEH			21H00012	600UL
144	16	7	0.52	75	INR	6	03H	+37.39	TECTEH			21H00011	600UL
145			0.54	87	INR	6	TSC	+7.44	TECTEH			21H00011	600UL
146	18	7							TECTEH			21H00012	600UL
147	20	7							TECTEH			21H00011	600UL
148	22	7	4.86	180	INR	P1	F05	+0.00	TECTEH			21H00012	600UL
149	24	7							TECTEH			21H00011	600UL
150	26	7							TECTEH			21H00014	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
151	28	7	0.65	23	INR	6	03H	+0.38		TECTEH			21H00013	600UL
152					INF		03H	+32.51		TECTEH	HR		21H00013	600UL
153			0.61	72	INR	6	03H	+34.24		TECTEH			21H00013	600UL
154	30	7								TECTEH			21H00014	600UL
155	32	7								TECTEH			21H00013	600UL
156	34	7								TECTEH			21H00014	600UL
157	36	7	0.30	55	INR	6	05H	+9.70		TECTEH			21H00013	600UL
158			4.14	184	INR	P1	F04	+2.22		TECTEH			21H00013	600UL
159	38	7								TECTEH			21H00014	600UL
160	40	7								TECTEH			21H00013	600UL
161	42	7								TECTEH			21H00014	600UL
162	44	7								TECTEH			21H00013	600UL
163	46	7								TECTEH			21H00014	600UL
164	48	7								TECTEH			21H00013	600UL
165	50	7	2.65	185	INR	1	02C	+27.11		TECTEH			21H00030	600UL
166	52	7								TECTEH			21H00029	600UL
167	3	8								TECTEH			21H00028	600UL
168	5	8								TECTEH			21H00012	600UL
169	7	8	0.58	58	INR	6	05H	+5.02		TECTEH			21H00011	600UL
170	9	8								TECTEH			21H00012	600UL
171	11	8								TECTEH			21H00011	600UL
172	13	8								TECTEH			21H00012	600UL
173	15	8								TECTEH			21H00011	600UL
174	17	8								TECTEH			21H00012	600UL
175	19	8								TECTEH			21H00011	600UL
176	21	8			INF		F01	+5.26		TECTEH	HR		21H00012	600UL
177			4.94	181	INR	P1	F01	+7.00		TECTEH			21H00012	600UL
178					INF		F05	+5.26		TECTEH	HR		21H00012	600UL
179	23	8								TECTEH			21H00011	600UL
180	25	8								TECTEH			21H00014	600UL
181	27	8								TECTEH			21H00013	600UL
182	29	8								TECTEH			21H00014	600UL
183	31	8	0.25	107	INR	3	02H	+26.98		TECTEH			21H00013	600UL
184	33	8								TECTEH			21H00014	600UL
185	35	8	0.47	69	INR	6	05C	+34.53		TECTEH			21H00013	600UL
186			0.35	84	INR	6	04C	+13.06		TECTEH			21H00013	600UL
187			0.44	85	INR	6	03C	+10.11		TECTEH			21H00013	600UL
188	37	8	0.49	66	INR	6	07H	+6.94		TECTEH			21H00014	600UL
189	39	8								TECTEH			21H00013	600UL
190	41	8								TECTEH			21H00014	600UL
191	43	8			INF		TSC	+16.34		TECTEH	HR		21H00013	600UL
192			0.83	69	INR	6	TSC	+17.58		TECTEH			21H00013	600UL
193	45	8	0.57	79	INR	6	TSH	+14.62		TECTEH			21H00014	600UL
194			0.90	63	INR	6	04H	+21.99		TECTEH			21H00014	600UL
195	47	8	0.46	89	INR	6	TSC	+12.79		TECTEH			21H00013	600UL
196	49	8	1.55	377	INR	6	03H	+7.24	TO+16.28	TECTEH			21H00013	600UL
197	51	8								TECTEH			21H00030	600UL
198	53	8								TECTEH			21H00029	600UL
199	55	8								TECTEH			21H00030	600UL
200	57	8	0.34	123	INR	3	05C	+39.15		TECTEH			21H00029	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
201	2	9								TECTEH			21H00028	600UL
202	4	9								TECTEH			21H00011	600UL
203	6	9								TECTEH			21H00012	600UL
204	8	9	0.35	61	INR	6	04H	+10.30		TECTEH			21H00011	600UL
205			0.50	63	INR	6	06C	+14.32		TECTEH			21H00011	600UL
206	10	9								TECTEH			21H00012	600UL
207	12	9								TECTEH			21H00011	600UL
208	14	9								TECTEH			21H00012	600UL
209	16	9								TECTEH			21H00011	600UL
210	18	9								TECTEH			21H00012	600UL
211	20	9								TECTEH			21H00011	600UL
212	22	9	3.82	182	INR	P1	F05	+0.00		TECTEH			21H00012	600UL
213	24	9								TECTEH			21H00011	600UL
214	26	9								TECTEH			21H00014	600UL
215	28	9								TECTEH			21H00013	600UL
216	30	9								TECTEH			21H00014	600UL
217	32	9								TECTEH			21H00013	600UL
218	34	9								TECTEH			21H00014	600UL
219	36	9	0.42	83	INR	6	05H	+34.34		TECTEH			21H00013	600UL
220			0.56	67	INR	6	06C	+38.35		TECTEH			21H00013	600UL
221			0.52	73	INR	6	02C	+19.34		TECTEH			21H00013	600UL
222	38	9			NDF	3	TSH	-1.60		TSHTSH			21H00051	610PP
223					INF		07H	+5.81		TECTEH	HR		21H00014	600UL
224					INF		03C	+4.01		TECTEH	HR		21H00014	600UL
225			0.55	85	INR	6	03C	+7.03		TECTEH			21H00014	600UL
226	40	9	0.45	74	INR	6	01H	+30.58		TECTEH			21H00013	600UL
227	42	9								TECTEH			21H00014	600UL
228	44	9	1.54	182	INR	6	02H	+6.81	TO+26.49	TECTEH			21H00013	600UL
229	46	9								TECTEH			21H00014	600UL
230	48	9	0.53	81	INR	6	01C	+24.06		TECTEH			21H00013	600UL
231			0.50	83	INR	6	TSC	+18.36		TECTEH			21H00013	600UL
232					INF		TSC	+19.48		TECTEH	HR		21H00013	600UL
233	50	9								TECTEH			21H00030	600UL
234	52	9	0.29	81	INR	6	02H	+31.54		TECTEH			21H00029	600UL
235			0.41	67	INR	6	07H	+5.88		TECTEH			21H00029	600UL
236			0.38	73	INR	6	02C	+11.48		TECTEH			21H00029	600UL
237	54	9	0.68	81	INR	6	02C	+25.28		TECTEH			21H00030	600UL
238	56	9	0.42	68	INR	6	TSC	+13.74		TECTEH			21H00029	600UL
239	58	9	0.41	89	NQH	3	02H	+6.96		TECTEH			21H00030	600UL
240			0.41	79	INR	6	04H	+22.64		TECTEH			21H00030	600UL
241			12.79	177	INR	3	TSC	+0.05		TECTEH			21H00030	600UL
242	60	9	0.43	78	INR	6	02H	+20.13		TECTEH			21H00029	600UL
243			0.46	72	INR	6	04H	+26.99		TECTEH			21H00029	600UL
244	1	10	13.89	183	DNG	1	04C	+32.29		TECTEH			21H00028	600UL
245			2.39	183	INR	1	03C	+34.77		TECTEH			21H00028	600UL
246	3	10								TECTEH			21H00028	600UL
247	5	10	0.39	87	INR	6	05H	+30.65		TECTEH			21H00012	600UL
248	7	10								TECTEH			21H00011	600UL
249	9	10								TECTEH			21H00012	600UL
250	11	10								TECTEH			21H00011	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
251	13	10							TECTEH			21H00012	600UL
252	15	10							TECTEH			21H00011	600UL
253	17	10	0.39	75	INR	6	03C	+15.82	TECTEH			21H00012	600UL
254					INF		03C	+17.71	TECTEH	HR		21H00012	600UL
255	19	10							TECTEH			21H00011	600UL
256	21	10	0.54	77	INR	6	04H	+34.56	TECTEH			21H00012	600UL
257					INF		F05	+2.45	TECTEH	HR		21H00012	600UL
258	23	10							TECTEH			21H00011	600UL
259	25	10							TECTEH			21H00014	600UL
260	27	10							TECTEH			21H00013	600UL
261	29	10							TECTEH			21H00014	600UL
262	31	10							TECTEH			21H00013	600UL
263	33	10	0.50	75	INR	6	03H	+23.40	TECTEH			21H00014	600UL
264			0.74	41	INR	6	F07	+4.12	TECTEH			21H00014	600UL
265					INF		F08	+8.17	TECTEH	HR		21H00014	600UL
266	35	10	0.37	58	INR	6	06H	+26.95	TECTEH			21H00013	600UL
267	37	10	0.54	83	INR	6	01H	+13.28	TECTEH			21H00014	600UL
268			4.13	183	DNT	P1	F04	+1.83	TECTEH			21H00014	600UL
269	39	10							TECTEH			21H00013	600UL
270	41	10							TECTEH			21H00014	600UL
271					NDF	3	TEH	+16.19	TEHTSH			21H00051	610PP
272	43	10							TECTEH			21H00013	600UL
273	45	10							TECTEH			21H00014	600UL
274	47	10							TECTEH			21H00013	600UL
275	49	10							TECTEH			21H00013	600UL
276	51	10							TECTEH			21H00029	600UL
277	53	10							TECTEH			21H00030	600UL
278	55	10							TECTEH			21H00029	600UL
279	57	10							TECTEH			21H00030	600UL
280	59	10	0.44	77	INR	6	01H	+22.15	TECTEH			21H00029	600UL
281			0.47	76	INR	6	02H	+7.78	TECTEH			21H00029	600UL
282			0.51	68	INR	6	05H	+13.86	TECTEH			21H00029	600UL
283			0.38	83	INR	6	06H	+35.25	TECTEH			21H00029	600UL
284			0.54	77	INR	6	06H	+38.48	TECTEH			21H00029	600UL
285					INF		F06	+3.02	TECTEH	HR		21H00029	600UL
286			0.71	84	INR	6	F06	+4.39	TECTEH			21H00029	600UL
287					INF		F06	+6.11	TECTEH	HR		21H00029	600UL
288			0.56	89	INR	6	F06	+7.31	TECTEH			21H00029	600UL
289	61	10							TECTEH			21H00030	600UL
290	63	10	0.87	76	INR	6	05C	+6.17	TECTEH			21H00029	600UL
291	2	11							TECTEH			21H00028	600UL
292	4	11							TECTEH			21H00011	600UL
293	6	11							TECTEH			21H00012	600UL
294	8	11	0.44	73	INR	6	04C	+8.89	TECTEH			21H00011	600UL
295	10	11							TECTEH			21H00012	600UL
296	12	11	0.66	80	INR	6	03H	+18.58	TECTEH			21H00011	600UL
297			0.55	76	INR	6	03H	+21.39	TECTEH			21H00011	600UL
298			0.47	82	INR	6	03H	+24.35	TECTEH			21H00011	600UL
299			0.45	80	INR	6	03H	+32.77	TECTEH			21H00011	600UL
300			0.53	64	INR	6	03H	+38.20	TECTEH			21H00011	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
301			0.53	79	INR	6	03C	+25.70	TECTEH			21H00011	600UL
302			0.45	80	INR	6	02C	+34.21	TECTEH			21H00011	600UL
303	14	11							TECTEH			21H00012	600UL
304	16	11	0.45	74	INR	6	05H	+6.96	TECTEH			21H00011	600UL
305	18	11							TECTEH			21H00012	600UL
306	20	11	0.61	73	INR	6	03H	+27.70	TECTEH			21H00011	600UL
307			0.76	62	INR	6	05H	+33.55	TECTEH			21H00011	600UL
308	22	11	3.17	25	INR	6	02C	+0.00	TECTEH			21H00012	600UL
309	24	11							TECTEH			21H00011	600UL
310	26	11							TECTEH			21H00014	600UL
311	28	11	0.72	66	INR	6	05C	+32.78	TECTEH			21H00013	600UL
312	30	11							TECTEH			21H00014	600UL
313	32	11	0.61	87	INR	6	04C	+29.68	TECTEH			21H00013	600UL
314	34	11							TECTEH			21H00014	600UL
315	36	11							TECTEH			21H00013	600UL
316	38	11							TECTEH			21H00014	600UL
317	40	11	0.66	72	INR	6	01H	+5.50	TECTEH			21H00013	600UL
318	42	11							TECTEH			21H00014	600UL
319	44	11							TECTEH			21H00013	600UL
320	46	11	0.60	83	INR	6	06C	+4.21	TECTEH			21H00014	600UL
321	48	11							TECTEH			21H00013	600UL
322	50	11	0.70	82	INR	6	02C	+11.65	TECTEH			21H00030	600UL
323	52	11							TECTEH			21H00029	600UL
324	54	11							TECTEH			21H00030	600UL
325	56	11							TECTEH			21H00029	600UL
326	58	11							TECTEH			21H00030	600UL
327	60	11	0.56	75	INR	6	02H	+33.07	TECTEH			21H00029	600UL
328			0.41	74	INR	6	01C	+10.92	TECTEH			21H00029	600UL
329					INF		01C	+12.90	TECTEH	HR		21H00029	600UL
330	62	11							TECTEH			21H00030	600UL
331	64	11							TECTEH			21H00029	600UL
332	66	11							TECTEH			21H00029	600UL
333	1	12							TECTEH			21H00028	600UL
334	3	12							TECTEH			21H00028	600UL
335	5	12	0.83	74	INR	6	06H	+5.34	TECTEH			21H00012	600UL
336	7	12							TECTEH			21H00011	600UL
337	9	12							TECTEH			21H00012	600UL
338					NDF	3	TEH	+16.53	TEHTSH			21H00051	610PP
339	11	12							TECTEH			21H00011	600UL
340	13	12							TECTEH			21H00012	600UL
341	15	12							TECTEH			21H00011	600UL
342	17	12							TECTEH			21H00012	600UL
343	19	12							TECTEH			21H00011	600UL
344	21	12			INF		07H	+44.39	TECTEH	HR		21H00012	600UL
345					INF		F06	+5.06	TECTEH	HR		21H00012	600UL
346					INF		F06	+5.58	TECTEH	HR		21H00012	600UL
347			1.03	48	INR	6	F07	+5.63	TECTEH			21H00012	600UL
348	23	12							TECTEH			21H00011	600UL
349	25	12							TECTEH			21H00013	600UL
350	27	12							TECTEH			21H00013	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
351	29	12							TECTEH			21H00014	600UL
352	31	12	0.44	67	INR	6	TSH	+11.83	TECTEH			21H00013	600UL
353			0.40	83	INR	6	01H	+21.42	TECTEH			21H00013	600UL
354			0.55	63	INR	6	07H	+5.22	TECTEH			21H00013	600UL
355			0.66	67	INR	6	05C	+24.04	TECTEH			21H00013	600UL
356	33	12							TECTEH			21H00014	600UL
357	35	12							TECTEH			21H00013	600UL
358	37	12							TECTEH			21H00014	600UL
359	39	12							TECTEH			21H00013	600UL
360	41	12							TECTEH			21H00014	600UL
361	43	12							TECTEH			21H00013	600UL
362	45	12							TECTEH			21H00014	600UL
363	47	12	0.46	80	INR	6	01H	+22.76	TECTEH			21H00013	600UL
364			0.43	76	INR	6	02H	+37.88	TECTEH			21H00013	600UL
365			0.59	67	INR	6	F07	+6.81	TECTEH			21H00013	600UL
366					INF		F08	+6.01	TECTEH	HR		21H00013	600UL
367	49	12	0.24	115	NQH	3	05H	+21.18	TECTEH			21H00013	600UL
368			0.31	115	NQH	3	05H	+23.67	TECTEH			21H00013	600UL
369			0.78	254	INR	6	F01	+4.58	TECTEH			21H00013	600UL
370					INF		F03	+4.72	TECTEH	HR		21H00013	600UL
371			0.33	120	INR	3	02C	+22.92	TECTEH			21H00013	600UL
372	51	12							TECTEH			21H00030	600UL
373	53	12							TECTEH			21H00029	600UL
374	55	12							TECTEH			21H00030	600UL
375	57	12	0.75	71	INR	6	02H	+3.60	TECTEH			21H00029	600UL
376			0.70	69	INR	6	04H	+20.18	TECTEH			21H00029	600UL
377			0.45	80	INR	6	05H	+3.68	TECTEH			21H00029	600UL
378			0.49	65	INR	6	05H	+13.35	TECTEH			21H00029	600UL
379					INF		F06	+0.00	TECTEH	HR		21H00029	600UL
380					INF		F06	+3.03	TECTEH	HR		21H00029	600UL
381			0.45	98	INR	6	F07	+2.86	TECTEH			21H00029	600UL
382					INF		F08	+6.62	TECTEH	HR		21H00029	600UL
383			0.37	69	INR	6	03C	+25.03	TECTEH			21H00029	600UL
384	59	12	0.53	81	INR	6	02C	+33.00	TECTEH			21H00030	600UL
385			0.80	81	INR	6	01C	+7.90	TECTEH			21H00030	600UL
386			0.57	78	INR	6	01C	+11.65	TECTEH			21H00030	600UL
387			0.54	77	INR	6	TSC	+5.96	TECTEH			21H00030	600UL
388	61	12							TECTEH			21H00029	600UL
389	63	12	0.42	72	INR	6	06C	+3.44	TECTEH			21H00030	600UL
390	65	12							TECTEH			21H00029	600UL
391	67	12							TECTEH			21H00030	600UL
392	69	12	0.43	79	INR	6	06C	+39.50	TECTEH			21H00029	600UL
393			0.35	86	INR	6	05C	+14.64	TECTEH			21H00029	600UL
394	2	13							TECTEH			21H00028	600UL
395	4	13							TECTEH			21H00011	600UL
396	6	13							TECTEH			21H00012	600UL
397	8	13							TECTEH			21H00011	600UL
398	10	13							TECTEH			21H00012	600UL
399	12	13							TECTEH			21H00011	600UL
400	14	13							TECTEH			21H00012	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
401	16	13							TECTEH			21H00011	600UL
402	18	13	0.89	73	INR	6	02H	+27.37	TECTEH			21H00012	600UL
403	20	13							TECTEH			21H00011	600UL
404	22	13							TECTEH			21H00012	600UL
405	24	13	0.85	92	INR	6	04H	+29.57	TECTEH			21H00011	600UL
406	26	13	0.33	74	INR	6	01H	+30.87	TECTEH			21H00014	600UL
407	28	13	0.60	75	INR	6	04H	+14.25	TECTEH			21H00013	600UL
408	30	13							TECTEH			21H00014	600UL
409	32	13							TECTEH			21H00013	600UL
410	34	13							TECTEH			21H00014	600UL
411	36	13	0.43	80	INR	6	01H	+29.72	TECTEH			21H00013	600UL
412	38	13	0.40	65	INR	6	04H	+32.60	TECTEH			21H00014	600UL
413			0.50	73	INR	6	01C	+27.72	TECTEH			21H00014	600UL
414	40	13	0.74	81	INR	6	TSH	+3.08	TECTEH			21H00013	600UL
415			0.57	81	INR	6	TSH	+8.51	TECTEH			21H00013	600UL
416			0.45	83	INR	6	TSC	+21.50	TECTEH			21H00013	600UL
417	42	13							TECTEH			21H00014	600UL
418	44	13	0.64	87	INR	6	02C	+2.45	TECTEH			21H00013	600UL
419			0.75	88	INR	6	TSC	+6.89	TECTEH			21H00013	600UL
420	46	13	0.65	85	INR	6	05H	+18.41	TECTEH			21H00014	600UL
421	48	13	0.43	82	INR	6	01H	+12.19	TECTEH			21H00013	600UL
422			41.98	7	INR	3	TSC	+0.08	TECTEH			21H00013	600UL
423	50	13							TECTEH			21H00030	600UL
424	52	13	0.30	102	INR	3	02C	+17.93	TECTEH			21H00029	600UL
425			0.78	76	INR	6	02C	+33.97	TECTEH			21H00029	600UL
426	54	13	0.59	76	INR	6	03C	+13.53	TECTEH			21H00030	600UL
427	56	13							TECTEH			21H00029	600UL
428	58	13	0.46	57	INR	6	05H	+6.14	TECTEH			21H00030	600UL
429			0.31	95	INR	6	04C	+39.06	TECTEH			21H00030	600UL
430			0.56	80	INR	6	01C	+9.50	TECTEH			21H00030	600UL
431	60	13							TECTEH			21H00029	600UL
432	62	13	0.58	83	INR	6	01C	+32.19	TECTEH			21H00030	600UL
433	64	13							TECTEH			21H00029	600UL
434	66	13							TECTEH			21H00030	600UL
435	68	13	0.49	67	INR	6	06H	+23.68	TECTEH			21H00029	600UL
436			0.37	112	INR	3	F07	+11.40	TECTEH			21H00029	600UL
437					INF		F08	+0.00	TECTEH	HR		21H00029	600UL
438			0.41	75	INR	6	01C	+21.29	TECTEH			21H00029	600UL
439	70	13	0.38	84	INR	6	01H	+5.74	TECTEH			21H00030	600UL
440	72	13	0.33	69	INR	6	05C	+4.63	TECTEH			21H00029	600UL
441	1	14							TECTEH			21H00028	600UL
442	3	14							TECTEH			21H00028	600UL
443	5	14							TECTEH			21H00012	600UL
444	7	14							TECTEH			21H00011	600UL
445	9	14	0.66	83	INR	6	05C	+9.93	TECTEH			21H00012	600UL
446	11	14							TECTEH			21H00011	600UL
447	13	14	0.44	74	INR	6	02H	+4.37	TECTEH			21H00012	600UL
448			0.54	74	INR	6	02C	+31.37	TECTEH			21H00012	600UL
449			0.51	86	INR	6	01C	+27.31	TECTEH			21H00012	600UL
450	15	14	0.58	80	INR	6	01H	+8.98	TECTEH			21H00011	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
451			0.45	64	INR	6	06C	+17.16	TECTEH			21H00011	600UL
452			0.38	82	INR	6	05C	+18.38	TECTEH			21H00011	600UL
453	17	14							TECTEH			21H00012	600UL
454	19	14							TECTEH			21H00011	600UL
455	21	14	0.54	78	INR	6	06C	+7.18	TECTEH			21H00012	600UL
456	23	14							TECTEH			21H00011	600UL
457	25	14	0.47	82	INR	6	04H	+5.46	TECTEH			21H00014	600UL
458			0.47	85	INR	6	03C	+9.16	TECTEH			21H00014	600UL
459			0.67	82	INR	6	02C	+11.68	TECTEH			21H00014	600UL
460	27	14							TECTEH			21H00013	600UL
461	29	14							TECTEH			21H00014	600UL
462	31	14	0.35	120	INR	3	06C	+33.92	TECTEH			21H00013	600UL
463			0.42	75	INR	6	03C	+12.39	TECTEH			21H00013	600UL
464	33	14							TECTEH			21H00014	600UL
465	35	14	0.47	52	INR	6	04H	+39.28	TECTEH			21H00013	600UL
466	37	14							TECTEH			21H00014	600UL
467	39	14							TECTEH			21H00013	600UL
468	41	14	0.95	80	INR	6	05C	+25.70	TECTEH			21H00014	600UL
469	43	14	0.58	65	INR	6	04C	+4.30	TECTEH			21H00013	600UL
470			0.55	70	INR	6	01C	+15.32	TECTEH			21H00013	600UL
471	45	14							TECTEH			21H00014	600UL
472	47	14							TECTEH			21H00013	600UL
473	49	14							TECTEH			21H00013	600UL
474	51	14	0.69	30	INR	6	06H	+23.80	TECTEH			21H00030	600UL
475			1.13	210	INR	6	F12	+0.00	TECTEH			21H00030	600UL
476			0.50	117	INR	3	05C	+3.42	TECTEH			21H00030	600UL
477	53	14	0.32	94	INR	6	02H	+26.31	TECTEH			21H00030	600UL
478	55	14							TECTEH			21H00029	600UL
479	57	14							TECTEH			21H00030	600UL
480	59	14	1.89	180	INR	P1	07C	+1.52	TECTEH			21H00029	600UL
481	61	14							TECTEH			21H00030	600UL
482	63	14	0.50	68	INR	6	F07	+2.17	TECTEH			21H00029	600UL
483					INF		F08	+10.63	TECTEH	HR		21H00029	600UL
484	65	14							TECTEH			21H00030	600UL
485	67	14							TECTEH			21H00029	600UL
486	69	14							TECTEH			21H00030	600UL
487	71	14	0.58	68	INR	6	03C	+25.04	TECTEH			21H00029	600UL
488	73	14							TECTEH			21H00030	600UL
489	75	14							TECTEH			21H00029	600UL
490	2	15							TECTEH			21H00028	600UL
491	4	15	0.41	69	INR	6	05H	+12.14	TECTEH			21H00011	600UL
492	6	15							TECTEH			21H00012	600UL
493	8	15							TECTEH			21H00011	600UL
494	10	15	0.34	83	INR	6	04H	+14.75	TECTEH			21H00012	600UL
495	12	15							TECTEH			21H00011	600UL
496	14	15			INF		05H	+37.70	TECTEH	HR		21H00012	600UL
497	16	15	0.43	65	INR	6	02H	+30.12	TECTEH			21H00011	600UL
498	18	15							TECTEH			21H00012	600UL
499	20	15							TECTEH			21H00011	600UL
500	22	15							TECTEH			21H00012	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
501	24	15	0.51	78	INR	6	03C	+10.71	TECTEH			21H00011	600UL
502			0.44	81	INR	6	01C	+6.08	TECTEH			21H00011	600UL
503	26	15							TECTEH			21H00014	600UL
504	28	15							TECTEH			21H00013	600UL
505	30	15							TECTEH			21H00014	600UL
506	32	15	0.44	76	INR	6	04C	+23.88	TECTEH			21H00013	600UL
507	34	15							TECTEH			21H00014	600UL
508	36	15							TECTEH			21H00013	600UL
509	38	15	0.50	77	INR	6	04H	+13.70	TECTEH			21H00014	600UL
510			0.47	79	INR	6	05C	+26.95	TECTEH			21H00014	600UL
511			0.51	79	INR	6	01C	+13.07	TECTEH			21H00014	600UL
512	40	15							TECTEH			21H00013	600UL
513	42	15	0.54	41	INR	6	05C	+18.56	TECTEH			21H00014	600UL
514	44	15							TECTEH			21H00013	600UL
515	46	15							TECTEH			21H00014	600UL
516	48	15	2.64	48	ADS	6	F01	+1.84 TO+10.22	TECTEH			21H00013	600UL
517	50	15							TECTEH			21H00030	600UL
518	52	15	0.58	106	INR	6	F10	+5.67	TECTEH			21H00029	600UL
519					INF		F11	+6.35	TECTEH	HR		21H00029	600UL
520	54	15	0.31	87	INR	6	05C	+38.98	TECTEH			21H00030	600UL
521			0.23	78	INR	6	04C	+14.69	TECTEH			21H00030	600UL
522	56	15							TECTEH			21H00029	600UL
523	58	15							TECTEH			21H00030	600UL
524	60	15	0.42	74	INR	6	05C	+36.19	TECTEH			21H00029	600UL
525	62	15							TECTEH			21H00030	600UL
526	64	15	0.39	73	INR	6	03H	+31.20	TECTEH			21H00029	600UL
527					INF		07H	+18.95	TECTEH	HR		21H00029	600UL
528			0.69	38	INR	6	F01	+4.87	TECTEH			21H00029	600UL
529			0.44	110	INR	3	06C	+29.53	TECTEH			21H00029	600UL
530			0.50	84	INR	6	04C	+7.19	TECTEH			21H00029	600UL
531			0.40	77	INR	6	04C	+19.70	TECTEH			21H00029	600UL
532			0.42	112	INR	3	02C	+17.92	TECTEH			21H00029	600UL
533	66	15							TECTEH			21H00030	600UL
534	68	15							TECTEH			21H00029	600UL
535	70	15							TECTEH			21H00030	600UL
536	72	15							TECTEH			21H00029	600UL
537	74	15							TECTEH			21H00030	600UL
538	76	15	0.45	80	INR	6	05C	+15.93	TECTEH			21H00029	600UL
539					INF		05C	+18.47	TECTEH	HR		21H00029	600UL
540			0.39	83	INR	6	05C	+20.05	TECTEH			21H00029	600UL
541	78	15	0.31	94	INR	3	01C	+27.27	TECTEH			21H00029	600UL
542	1	16							TECTEH			21H00028	600UL
543	3	16							TECTEH			21H00028	600UL
544	5	16	0.30	86	INR	6	03C	+7.03	TECTEH			21H00012	600UL
545	7	16							TECTEH			21H00011	600UL
546	9	16							TECTEH			21H00012	600UL
547	11	16							TECTEH			21H00011	600UL
548	13	16							TECTEH			21H00012	600UL
549	15	16							TECTEH			21H00011	600UL
550	17	16							TECTEH			21H00012	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
551	19	16	0.79	76	INR	6	01H	+7.98	TECTEH			21H00011	600UL
552	21	16	0.29	80	INR	6	01H	+17.02	TECTEH			21H00012	600UL
553					INF		06H	+21.44	TECTEH	HR		21H00012	600UL
554					INF		F05	+6.81	TECTEH	HR		21H00012	600UL
555					INF		F08	+4.72	TECTEH	HR		21H00012	600UL
556			0.55	67	INR	6	F12	+4.77	TECTEH			21H00012	600UL
557			0.45	71	INR	6	04C	+34.85	TECTEH			21H00012	600UL
558	23	16							TECTEH			21H00011	600UL
559	25	16							TECTEH			21H00014	600UL
560	27	16							TECTEH			21H00013	600UL
561	29	16							TECTEH			21H00014	600UL
562	31	16							TECTEH			21H00013	600UL
563	33	16							TECTEH			21H00014	600UL
564	35	16	0.44	65	INR	6	05H	+32.80	TECTEH			21H00013	600UL
565	37	16	0.44	75	INR	6	02C	+2.32	TECTEH			21H00014	600UL
566	39	16	0.44	84	INR	6	01H	+10.25	TECTEH			21H00013	600UL
567			0.40	80	INR	6	06C	+7.76	TECTEH			21H00013	600UL
568			0.48	70	INR	6	06C	+22.90	TECTEH			21H00013	600UL
569			0.54	87	INR	6	TSC	+2.35	TECTEH			21H00013	600UL
570	41	16	0.75	69	INR	6	TSC	+19.35	TECTEH			21H00014	600UL
571	43	16							TECTEH			21H00013	600UL
572	45	16	0.51	79	INR	6	06C	+11.43	TECTEH			21H00014	600UL
573	47	16							TECTEH			21H00013	600UL
574	49	16	0.43	87	INR	6	03H	+17.49	TECTEH			21H00013	600UL
575	51	16	0.85	78	INR	6	01H	+16.02	TECTEH			21H00030	600UL
576	53	16							TECTEH			21H00029	600UL
577	55	16							TECTEH			21H00030	600UL
578	57	16	0.36	78	INR	6	03H	+5.64	TECTEH			21H00029	600UL
579			0.40	81	INR	6	06H	+32.12	TECTEH			21H00029	600UL
580			0.54	76	INR	6	06C	+33.14	TECTEH			21H00029	600UL
581			0.41	78	INR	6	05C	+26.38	TECTEH			21H00029	600UL
582			0.34	88	INR	6	02C	+5.87	TECTEH			21H00029	600UL
583			0.38	89	INR	6	02C	+37.29	TECTEH			21H00029	600UL
584			0.39	79	INR	6	01C	+6.71	TECTEH			21H00029	600UL
585	59	16	0.56	79	INR	6	01H	+14.82	TECTEH			21H00030	600UL
586			0.37	70	INR	6	02C	+19.37	TECTEH			21H00030	600UL
587	61	16	2.29	31	INR	6	06H	+31.96 TO+41.19	TECTEH			21H00029	600UL
588	63	16							TECTEH			21H00030	600UL
589	65	16	0.25	92	INR	6	F05	+5.36	TECTEH			21H00029	600UL
590			0.35	110	INR	6	F06	+3.30	TECTEH			21H00029	600UL
591			0.37	85	INR	6	TSC	+3.82	TECTEH			21H00029	600UL
592	67	16							TECTEH			21H00030	600UL
593	69	16			INF		F02	+11.30	TECTEH	HR		21H00029	600UL
594			0.18	68	INR	6	F03	+11.20	TECTEH			21H00029	600UL
595			0.50	106	INR	3	F06	+4.13	TECTEH			21H00029	600UL
596			0.70	81	INR	6	TSC	+7.29	TECTEH			21H00029	600UL
597			0.40	72	INR	6	TSC	+13.14	TECTEH			21H00029	600UL
598	71	16							TECTEH			21H00030	600UL
599	73	16							TECTEH			21H00029	600UL
600	75	16			INF		F03	+6.61	TECTEH	HR		21H00030	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
601			0.40	66	INR	6	F04	+5.84	TECTEH			21H00030	600UL
602	77	16							TECTEH			21H00029	600UL
603	79	16							TECTEH			21H00030	600UL
604	81	16	0.35	81	INR	6	06C	+21.92	TECTEH			21H00029	600UL
605	2	17							TECTEH			21H00028	600UL
606	4	17	0.31	65	INR	6	06H	+18.28	TECTEH			21H00011	600UL
607			0.48	87	INR	6	TSC	+17.88	TECTEH			21H00011	600UL
608	6	17							TECTEH			21H00012	600UL
609	8	17							TECTEH			21H00011	600UL
610	10	17							TECTEH			21H00012	600UL
611	12	17							TECTEH			21H00011	600UL
612	14	17							TECTEH			21H00012	600UL
613	16	17	0.30	101	NQH	3	06C	+9.61	TECTEH			21H00011	600UL
614	18	17							TECTEH			21H00012	600UL
615	20	17							TECTEH			21H00011	600UL
616	22	17	0.43	78	INR	6	TSH	+7.69	TECTEH			21H00012	600UL
617					INF		F05	+2.32	TECTEH	HR		21H00012	600UL
618			0.47	57	INR	6	06C	+9.05	TECTEH			21H00012	600UL
619			0.36	89	INR	6	02C	+16.73	TECTEH			21H00012	600UL
620			0.72	77	INR	6	01C	+32.03	TECTEH			21H00012	600UL
621			0.43	93	INR	6	TSC	+1.44	TECTEH			21H00012	600UL
622	24	17							TECTEH			21H00011	600UL
623	26	17	0.43	69	INR	6	05H	+34.16	TECTEH			21H00014	600UL
624			0.51	79	INR	6	04C	+10.12	TECTEH			21H00014	600UL
625	28	17			INF		05C	+8.71	TECTEH	HR		21H00013	600UL
626			0.47	88	INR	6	03C	+8.92	TECTEH			21H00013	600UL
627			0.68	68	INR	6	01C	+12.86	TECTEH			21H00013	600UL
628			0.45	76	INR	6	01C	+20.67	TECTEH			21H00013	600UL
629			0.37	90	INR	6	01C	+25.47	TECTEH			21H00013	600UL
630	30	17							TECTEH			21H00014	600UL
631	32	17	0.54	79	INR	6	F08	+7.54	TECTEH			21H00013	600UL
632			0.50	78	INR	6	02C	+7.88	TECTEH			21H00013	600UL
633	34	17	0.46	81	INR	6	03C	+6.15	TECTEH			21H00014	600UL
634	36	17	0.65	71	INR	6	06H	+38.74	TECTEH			21H00013	600UL
635			0.28	101	NQH	3	TSC	+15.10	TECTEH			21H00013	600UL
636	38	17							TECTEH			21H00014	600UL
637	40	17			INF		04C	+28.76	TECTEH	HR		21H00013	600UL
638			0.33	99	INR	6	04C	+30.38	TECTEH			21H00013	600UL
639	42	17							TECTEH			21H00014	600UL
640	44	17							TECTEH			21H00013	600UL
641	46	17							TECTEH			21H00014	600UL
642	48	17	0.54	75	INR	6	03C	+10.53	TECTEH			21H00013	600UL
643	50	17	0.35	85	INR	6	01C	+20.96	TECTEH			21H00030	600UL
644	52	17			INF		01C	+28.52	TECTEH	HR		21H00029	600UL
645			0.41	81	INR	6	01C	+30.36	TECTEH			21H00029	600UL
646	54	17							TECTEH			21H00030	600UL
647	56	17	0.28	80	INR	6	04H	+7.35	TECTEH			21H00029	600UL
648	58	17	0.48	82	INR	6	06C	+19.70	TECTEH			21H00030	600UL
649	60	17							TECTEH			21H00029	600UL
650	62	17							TECTEH			21H00030	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
651	64	17	0.72	69	INR	6	F07	+9.69	TECTEH			21H00029	600UL
652			0.39	74	INR	6	06C	+17.45	TECTEH			21H00029	600UL
653			0.36	75	INR	6	01C	+6.84	TECTEH			21H00029	600UL
654	66	17							TECTEH			21H00030	600UL
655	68	17	0.79	81	INR	6	06C	+18.55	TECTEH			21H00029	600UL
656	70	17	0.23	176	INR	6	F07	+6.38	TECTEH			21H00030	600UL
657			0.41	83	INR	6	04C	+22.69	TECTEH			21H00030	600UL
658	72	17	0.36	77	INR	6	06H	+18.37	TECTEH			21H00029	600UL
659	74	17							TECTEH			21H00030	600UL
660	76	17	0.60	80	INR	6	02H	+31.18	TECTEH			21H00029	600UL
661			0.36	57	INR	6	06H	+26.97	TECTEH			21H00029	600UL
662	78	17							TECTEH			21H00030	600UL
663	80	17	0.39	87	INR	6	02C	+20.07	TECTEH			21H00029	600UL
664	82	17							TECTEH			21H00037	600UL
665	1	18	0.37	74	INR	6	03H	+4.66	TECTEH			21H00028	600UL
666	3	18							TECTEH			21H00028	600UL
667	5	18							TECTEH			21H00012	600UL
668	7	18	0.45	73	INR	6	01H	+29.00	TECTEH			21H00011	600UL
669	9	18							TECTEH			21H00012	600UL
670	11	18	0.36	89	INR	6	06C	+21.28	TECTEH			21H00011	600UL
671	13	18							TECTEH			21H00012	600UL
672	15	18							TECTEH			21H00011	600UL
673	17	18							TECTEH			21H00012	600UL
674	19	18	0.35	71	INR	6	03H	+5.33	TECTEH			21H00011	600UL
675					INF		06C	+1.06	TECTEH	HR		21H00011	600UL
676			0.30	64	INR	6	06C	+2.16	TECTEH			21H00011	600UL
677	21	18			INF		F01	+5.43	TECTEH	HR		21H00012	600UL
678			4.62	180	INR	P1	F01	+7.55	TECTEH			21H00012	600UL
679					INF		F05	+5.43	TECTEH	HR		21H00012	600UL
680			0.39	73	INR	6	04C	+34.28	TECTEH			21H00012	600UL
681	23	18							TECTEH			21H00011	600UL
682	25	18							TECTEH			21H00014	600UL
683	27	18							TECTEH			21H00013	600UL
684	29	18							TECTEH			21H00014	600UL
685	31	18							TECTEH			21H00013	600UL
686	33	18	0.54	84	INR	6	04H	+17.14	TECTEH			21H00014	600UL
687	35	18	0.77	70	INR	6	TSH	+10.79	TECTEH			21H00013	600UL
688			0.40	71	INR	6	02C	+38.51	TECTEH			21H00013	600UL
689					INF		02C	+43.69	TECTEH	HR		21H00013	600UL
690	37	18							TECTEH			21H00014	600UL
691	39	18							TECTEH			21H00013	600UL
692	41	18							TECTEH			21H00014	600UL
693	43	18							TECTEH			21H00013	600UL
694	45	18							TECTEH			21H00014	600UL
695	47	18							TECTEH			21H00013	600UL
696	49	18							TECTEH			21H00013	600UL
697	51	18	0.32	78	INR	6	F07	+4.09	TECTEH			21H00030	600UL
698					INF		F08	+8.66	TECTEH	HR		21H00030	600UL
699			0.65	88	INR	6	01C	+17.35	TECTEH			21H00030	600UL
700	53	18	0.51	64	INR	6	01H	+5.03	TECTEH			21H00029	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
701			0.43	82	INR	6	05C	+27.11	TECTEH			21H00029	600UL
702			0.42	75	INR	6	04C	+10.74	TECTEH			21H00029	600UL
703			0.31	96	INR	6	03C	+38.63	TECTEH			21H00029	600UL
704	55	18							TECTEH			21H00030	600UL
705	57	18	0.34	71	INR	6	TSH	+20.94	TECTEH			21H00029	600UL
706	59	18	0.17	76	INR	3	F10	+2.75	TECTEH			21H00030	600UL
707					INF		F10	+6.64	TECTEH	HR		21H00030	600UL
708	61	18	0.41	76	INR	6	06C	+22.35	TECTEH			21H00029	600UL
709			0.37	60	INR	6	03C	+11.83	TECTEH			21H00029	600UL
710	63	18	0.45	81	INR	6	05C	+11.70	TECTEH			21H00030	600UL
711	65	18	0.14	54	INR	6	07H	+6.12	TECTEH			21H00029	600UL
712	67	18	0.49	59	INR	6	05H	+24.43	TECTEH			21H00030	600UL
713	69	18	0.37	68	INR	6	05H	+5.00	TECTEH			21H00029	600UL
714	71	18	0.46	85	INR	6	02H	+24.89	TECTEH			21H00030	600UL
715	73	18							TECTEH			21H00029	600UL
716	75	18	0.43	92	INR	6	TSC	+19.01	TECTEH			21H00030	600UL
717	77	18							TECTEH			21H00029	600UL
718	79	18	0.33	83	INR	6	02H	+9.21	TECTEH			21H00030	600UL
719			0.34	84	INR	6	03H	+4.45	TECTEH			21H00030	600UL
720			0.42	73	INR	6	03H	+23.74	TECTEH			21H00030	600UL
721			0.51	77	INR	6	04H	+22.40	TECTEH			21H00030	600UL
722			0.47	76	INR	6	07H	+10.94	TECTEH			21H00030	600UL
723			0.39	92	INR	6	05C	+35.78	TECTEH			21H00030	600UL
724			0.32	75	INR	6	04C	+24.63	TECTEH			21H00030	600UL
725			0.20	308	INR	3	01C	+2.94	TECTEH			21H00030	600UL
726	81	18							TECTEH			21H00029	600UL
727	83	18	0.23	89	INR	3	02H	+16.11	TECTEH			21H00038	600UL
728			0.24	187	INR	3	02H	+18.00	TECTEH			21H00038	600UL
729	85	18							TECTEH			21H00037	600UL
730	2	19							TECTEH			21H00028	600UL
731	4	19							TECTEH			21H00011	600UL
732	6	19							TECTEH			21H00012	600UL
733	8	19							TECTEH			21H00011	600UL
734	10	19							TECTEH			21H00012	600UL
735	12	19							TECTEH			21H00011	600UL
736	14	19							TECTEH			21H00012	600UL
737	16	19							TECTEH			21H00011	600UL
738	18	19							TECTEH			21H00012	600UL
739	20	19	0.38	81	INR	6	02H	+16.52	TECTEH			21H00011	600UL
740			0.35	95	INR	6	03H	+7.56	TECTEH			21H00011	600UL
741			0.49	77	INR	6	05C	+19.10	TECTEH			21H00011	600UL
742	22	19	0.41	57	INR	6	05H	+36.00	TECTEH			21H00012	600UL
743					INF		F05	+1.13	TECTEH	HR		21H00012	600UL
744			0.45	79	INR	6	06C	+8.53	TECTEH			21H00012	600UL
745	24	19							TSHTSH			21H00090	610PP
746			0.47	59	INR	6	06C	+14.33	TECTEH			21H00011	600UL
747	26	19							TSHTSH			21H00090	610PP
748			0.33	50	INR	6	05H	+5.78	TECTEH			21H00014	600UL
749			0.45	60	INR	6	06C	+35.02	TECTEH			21H00014	600UL
750			0.48	83	INR	6	04C	+38.25	TECTEH			21H00014	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
751			0.40	82	INR	6	03C	+14.09	TECTEH			21H00014	600UL
752	28	19							TECTEH			21H00014	600UL
753									TSHTSH			21H00090	610PP
754	30	19							TECTEH			21H00014	600UL
755									TSHTSH			21H00090	610PP
756	32	19							TECTEH			21H00014	600UL
757	34	19							TECTEH			21H00014	600UL
758	36	19							TECTEH			21H00014	600UL
759	38	19							TECTEH			21H00014	600UL
760	40	19							TECTEH			21H00014	600UL
761	42	19							TECTEH			21H00014	600UL
762	44	19							TECTEH			21H00014	600UL
763	46	19							TECTEH			21H00014	600UL
764	48	19							TECTEH	IDOK		21H00015	600UL
765									TECTEH			21H00013	600UL
766	50	19							TECTEH			21H00030	600UL
767	52	19	0.36	77	INR	6	04C	+37.82	TECTEH			21H00029	600UL
768	54	19	0.78	81	INR	6	01H	+9.67	TECTEH			21H00030	600UL
769			0.39	82	INR	6	04C	+7.75	TECTEH			21H00030	600UL
770	56	19	0.72	73	INR	6	06H	+23.74	TECTEH			21H00029	600UL
771			0.41	110	INR	6	F08	+4.86	TECTEH			21H00029	600UL
772	58	19							TECTEH			21H00030	600UL
773	60	19	0.37	82	INR	6	04H	+7.44	TECTEH			21H00029	600UL
774	62	19	0.38	67	INR	6	06H	+33.92	TECTEH			21H00030	600UL
775					INF		02C	+27.04	TECTEH	HR		21H00030	600UL
776			0.39	80	INR	6	02C	+28.91	TECTEH			21H00030	600UL
777	64	19							TECTEH			21H00029	600UL
778	66	19							TECTEH			21H00030	600UL
779	68	19	0.50	75	INR	6	01H	+17.43	TECTEH			21H00029	600UL
780			0.30	83	INR	6	03H	+38.11	TECTEH			21H00029	600UL
781			0.31	51	INR	6	05H	+36.11	TECTEH			21H00029	600UL
782			0.36	85	INR	6	04C	+37.19	TECTEH			21H00029	600UL
783			0.58	74	INR	6	01C	+22.12	TECTEH			21H00029	600UL
784	70	19	0.48	57	INR	6	F06	+10.16	TECTEH			21H00030	600UL
785			0.63	75	INR	6	01C	+19.67	TECTEH			21H00030	600UL
786	72	19							TECTEH			21H00029	600UL
787	74	19							TECTEH			21H00030	600UL
788	76	19							TECTEH			21H00029	600UL
789	78	19	0.35	72	INR	6	02H	+8.46	TECTEH			21H00030	600UL
790			0.41	75	INR	6	02H	+26.20	TECTEH			21H00030	600UL
791	80	19							TECTEH			21H00029	600UL
792	82	19	0.32	139	INR	3	01C	+15.39	TECTEH			21H00038	600UL
793			0.48	123	INR	3	01C	+18.84	TECTEH			21H00038	600UL
794			0.48	123	INR	3	01C	+20.21	TECTEH			21H00038	600UL
795	84	19	0.31	130	INR	3	05C	+8.78	TECTEH			21H00038	600UL
796	86	19							TECTEH			21H00037	600UL
797	1	20							TECTEH			21H00028	600UL
798	3	20							TECTEH			21H00028	600UL
799	5	20	0.52	75	INR	6	01H	+16.29	TECTEH			21H00012	600UL
800			0.78	77	INR	6	06H	+14.46	TECTEH			21H00012	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
801			0.96	76	INR	6	06C	+12.40	TECTEH			21H00012	600UL
802	7	20	0.36	107	INR	3	03H	+11.27	TECTEH			21H00011	600UL
803			0.47	75	INR	6	02C	+17.99	TECTEH			21H00011	600UL
804	9	20							TECTEH			21H00012	600UL
805	11	20							TECTEH			21H00011	600UL
806	13	20							TECTEH			21H00012	600UL
807	15	20							TECTEH			21H00011	600UL
808	17	20	0.40	69	INR	6	04C	+24.09	TECTEH			21H00012	600UL
809	19	20							TECTEH			21H00011	600UL
810	21	20	0.50	77	INR	6	TSH	+18.54	TECTEH			21H00012	600UL
811					INF		F01	+4.96	TECTEH	HR		21H00012	600UL
812			4.22	181	INR	P1	F05	+4.00	TECTEH			21H00012	600UL
813	23	20							TSHTSH			21H00090	610PP
814			0.69	81	INR	6	03H	+28.82	TECTEH			21H00011	600UL
815			0.40	69	INR	6	06C	+35.70	TECTEH			21H00011	600UL
816			0.51	82	INR	6	TSC	+2.25	TECTEH			21H00011	600UL
817					INF		TSC	+3.40	TECTEH	HR		21H00011	600UL
818	25	20	0.43	89	PLP	10	TSH	+0.18	TSHTSH			21H00090	610PP
819			0.41	90	PID	10	TSH	+0.18	TSHTSH			21H00091	610PP
820			1.81	77	INR	6	03H	+13.60	TECTEH			21H00014	600UL
821			0.73	56	INR	6	05H	+31.26	TECTEH			21H00014	600UL
822					INF		F06	+5.48	TECTEH	HR		21H00014	600UL
823			0.63	55	INR	6	F07	+6.10	TECTEH			21H00014	600UL
824	27	20	0.56	89	PLP	10	TSH	+1.48	TSHTSH			21H00090	610PP
825			0.55	89	PID	10	TSH	+1.48	TSHTSH			21H00091	610PP
826			1.31	180	PLP	8	TSH	+1.55	TECTEH			21H00014	600UL
827	29	20	0.70	186	PLP	8	TSH	+2.75	TECTEH			21H00016	600UL
828			0.42	93	PLP	10	TSH	+2.88	TSHTSH			21H00090	610PP
829			0.40	92	PID	10	TSH	+2.88	TSHTSH			21H00091	610PP
830	31	20							TECTEH			21H00015	600UL
831									TSHTSH			21H00090	610PP
832	33	20	0.80	81	INR	6	04H	+11.51	TECTEH			21H00016	600UL
833			0.54	65	INR	6	03C	+2.32	TECTEH			21H00016	600UL
834	35	20							TECTEH			21H00015	600UL
835	37	20							TECTEH			21H00016	600UL
836	39	20							TECTEH			21H00015	600UL
837	41	20							TECTEH			21H00016	600UL
838	43	20	0.37	75	INR	6	05H	+32.34	TECTEH			21H00015	600UL
839	45	20							TECTEH			21H00016	600UL
840	47	20							TECTEH			21H00015	600UL
841	49	20							TECTEH			21H00015	600UL
842	51	20	0.45	83	INR	6	01H	+26.27	TECTEH			21H00030	600UL
843			0.43	117	INR	6	F05	+7.93	TECTEH			21H00030	600UL
844			0.50	72	INR	6	03C	+14.95	TECTEH			21H00030	600UL
845	53	20							TECTEH			21H00029	600UL
846	55	20			INF		TSC	+18.10	TECTEH	HR		21H00030	600UL
847			1.09	82	INR	6	TSC	+20.47	TECTEH			21H00030	600UL
848	57	20	0.50	70	INR	6	03C	+14.15	TECTEH			21H00029	600UL
849	59	20							TECTEH			21H00030	600UL
850	61	20	0.57	62	INR	6	01H	+19.99 TO+29.81	TECTEH			21H00029	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
851			0.51	76	INR	6	06C	+30.41	TECTEH			21H00029	600UL
852			0.44	79	INR	6	02C	+23.80	TECTEH			21H00029	600UL
853	63	20							TECTEH			21H00030	600UL
854	65	20							TECTEH			21H00029	600UL
855	67	20	0.39	81	INR	6	07H	+2.52	TECTEH			21H00030	600UL
856	69	20							TECTEH			21H00029	600UL
857	71	20	0.65	70	INR	6	06H	+6.90	TECTEH			21H00030	600UL
858			0.44	141	INR	6	F04	+2.73	TECTEH			21H00030	600UL
859			0.39	89	INR	6	03C	+8.57	TECTEH			21H00030	600UL
860	73	20							TECTEH			21H00029	600UL
861	75	20							TECTEH			21H00030	600UL
862	77	20	0.54	77	INR	6	02H	+12.16	TECTEH			21H00029	600UL
863	79	20							TECTEH			21H00030	600UL
864	81	20							TECTEH			21H00029	600UL
865	83	20							TECTEH			21H00038	600UL
866	85	20	0.27	85	INR	6	06H	+6.46	TECTEH			21H00037	600UL
867	87	20	0.32	118	INR	3	04H	+13.27	TECTEH			21H00038	600UL
868			0.43	109	INR	3	04H	+18.70	TECTEH			21H00038	600UL
869			0.32	99	INR	3	F04	+10.21	TECTEH			21H00038	600UL
870	89	20							TECTEH			21H00037	600UL
871	2	21	0.39	81	INR	6	05C	+20.13	TECTEH			21H00028	600UL
872	4	21	0.31	65	INR	6	05C	+29.24	TECTEH			21H00011	600UL
873	6	21							TECTEH			21H00012	600UL
874	8	21							TECTEH			21H00011	600UL
875	10	21							TECTEH			21H00012	600UL
876	12	21							TECTEH			21H00011	600UL
877	14	21							TECTEH			21H00012	600UL
878	16	21							TECTEH			21H00011	600UL
879	18	21	0.35	74	INR	6	06C	+9.84	TECTEH			21H00012	600UL
880			0.55	74	INR	6	01C	+21.05	TECTEH			21H00012	600UL
881					INF		TSC	+19.85	TECTEH	HR		21H00012	600UL
882	20	21	0.51	66	INR	6	04H	+7.77	TECTEH			21H00011	600UL
883			0.24	106	INR	3	05H	+35.33	TECTEH			21H00011	600UL
884			0.55	75	INR	6	02C	+17.69	TECTEH			21H00011	600UL
885	22	21							TECTEH			21H00010	600UL
886	24	21							TSHTSH			21H00090	610PP
887			0.58	84	INR	6	02H	+25.40	TECTEH			21H00009	600UL
888					INF		07H	+78.36	TECTEH	HR		21H00009	600UL
889	26	21	0.57	90	PLP	10	TSH	+0.70	TSHTSH			21H00090	610PP
890			0.51	90	PID	10	TSH	+0.70	TSHTSH			21H00091	610PP
891			1.05	180	PLP	8	TSH	+0.76	TECTEH			21H00016	600UL
892	28	21	0.58	89	PLP	10	TSH	+2.21	TSHTSH			21H00090	610PP
893			0.53	89	PID	10	TSH	+2.21	TSHTSH			21H00091	610PP
894			1.08	180	PLP	8	TSH	+2.22	TECTEH			21H00015	600UL
895	30	21							TSHTSH			21H00090	610PP
896			0.50	76	INR	6	04H	+20.07	TECTEH			21H00016	600UL
897	32	21							TECTEH			21H00015	600UL
898	34	21	0.50	75	INR	6	01C	+25.41	TECTEH			21H00016	600UL
899	36	21							TECTEH			21H00015	600UL
900	38	21							TECTEH			21H00016	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
901	40	21							TECTEH			21H00015	600UL
902	42	21	0.47	73	INR	6	06C	+26.55	TECTEH			21H00016	600UL
903	44	21							TECTEH			21H00015	600UL
904					NDF	3	TEH	+18.79	TEHTSH			21H00051	610PP
905	46	21							TECTEH			21H00016	600UL
906	48	21							TECTEH			21H00015	600UL
907	50	21							TECTEH			21H00030	600UL
908	52	21	0.48	78	INR	6	06H	+30.33	TECTEH			21H00029	600UL
909			0.41	74	INR	6	04C	+24.06	TECTEH			21H00029	600UL
910			0.31	108	INR	3	03C	+12.07	TECTEH			21H00029	600UL
911			0.43	77	INR	6	03C	+23.75	TECTEH			21H00029	600UL
912	54	21	0.55	72	INR	6	01H	+13.63	TECTEH			21H00030	600UL
913			0.57	75	INR	6	04H	+37.80	TECTEH			21H00030	600UL
914	56	21	0.38	64	INR	6	05H	+14.16	TECTEH			21H00029	600UL
915			1.01	54	INR	6	06H	+22.17 TO+26.31	TECTEH			21H00029	600UL
916			0.39	73	INR	6	05C	+12.77	TECTEH			21H00029	600UL
917	58	21							TECTEH			21H00030	600UL
918	60	21							TECTEH			21H00029	600UL
919	62	21							TECTEH			21H00030	600UL
920	64	21	0.43	97	INR	6	F06	+11.56	TECTEH			21H00029	600UL
921					INF		F08	+3.86	TECTEH	HR		21H00029	600UL
922	66	21	0.05	252	INR	3	06C	+29.91	TECTEH			21H00030	600UL
923			0.61	92	INR	6	06C	+31.00	TECTEH			21H00030	600UL
924			0.48	78	INR	6	05C	+21.21	TECTEH			21H00030	600UL
925	68	21	0.46	75	INR	6	01H	+8.52	TECTEH			21H00029	600UL
926	70	21							TECTEH			21H00030	600UL
927	72	21							TECTEH			21H00029	600UL
928	74	21	0.46	87	INR	6	03C	+12.63	TECTEH			21H00030	600UL
929	76	21	0.38	60	INR	6	05H	+15.33	TECTEH			21H00029	600UL
930			0.47	84	INR	6	06C	+4.60	TECTEH			21H00029	600UL
931	78	21	0.73	79	INR	6	02C	+9.91	TECTEH			21H00030	600UL
932			0.52	95	INR	6	01C	+7.34	TECTEH			21H00030	600UL
933			0.44	94	INR	6	01C	+12.09	TECTEH			21H00030	600UL
934	80	21							TECTEH			21H00029	600UL
935	82	21							TECTEH			21H00038	600UL
936	84	21							TECTEH			21H00038	600UL
937	86	21							TECTEH			21H00037	600UL
938	88	21	0.39	115	INR	3	06C	+38.50	TECTEH			21H00038	600UL
939			0.35	135	INR	3	05C	+34.17	TECTEH			21H00038	600UL
940			0.62	119	INR	3	04C	+31.65	TECTEH			21H00038	600UL
941			0.43	125	INR	3	01C	+4.72	TECTEH			21H00038	600UL
942	90	21							TECTEH			21H00037	600UL
943	1	22							TECTEH			21H00028	600UL
944	3	22							TECTEH			21H00028	600UL
945	5	22	0.36	77	INR	6	01H	+30.93	TECTEH			21H00012	600UL
946	7	22							TECTEH			21H00011	600UL
947	9	22							TECTEH			21H00012	600UL
948	11	22	0.80	75	INR	6	01H	+19.53	TECTEH			21H00011	600UL
949	13	22							TECTEH			21H00010	600UL
950	15	22							TECTEH			21H00009	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
951	17	22							TECTEH			21H00010	600UL
952	19	22							TECTEH			21H00009	600UL
953	21	22			INF		F01	+5.56	TECTEH	HR		21H00010	600UL
954			4.09	184	INR	P1	F05	+3.31	TECTEH			21H00010	600UL
955					INF		F05	+5.56	TECTEH	HR		21H00010	600UL
956	23	22							TECTEH			21H00009	600UL
957	25	22							TECTEH			21H00016	600UL
958									TSHTSH			21H00090	610PP
959	27	22							TSHTSH			21H00090	610PP
960			0.45	66	INR	6	05H	+22.45	TECTEH			21H00015	600UL
961	29	22							TSHTSH			21H00090	610PP
962			0.43	105	NQH	3	01C	+15.85	TECTEH			21H00016	600UL
963	31	22	0.54	242	INR	6	05C	+32.32	TECTEH			21H00015	600UL
964	33	22							TECTEH			21H00016	600UL
965	35	22	0.70	85	INR	6	05C	+13.28	TECTEH			21H00015	600UL
966			0.59	85	INR	6	04C	+32.64	TECTEH			21H00015	600UL
967			0.45	85	INR	6	01C	+12.36	TECTEH			21H00015	600UL
968	37	22							TECTEH			21H00016	600UL
969	39	22	0.78	76	INR	6	05C	+35.64	TECTEH			21H00015	600UL
970			0.43	79	INR	6	04C	+25.88	TECTEH			21H00015	600UL
971			0.52	72	INR	6	04C	+32.94	TECTEH			21H00015	600UL
972	41	22							TECTEH			21H00016	600UL
973	43	22							TECTEH			21H00015	600UL
974	45	22	0.32	85	NQH	3	TSH	+15.45	TECTEH			21H00016	600UL
975	47	22							TECTEH			21H00015	600UL
976					NDF	3	TEH	+12.44	TEHTSH			21H00051	610PP
977	49	22	0.17	60	INR	6	TSH	+4.27	TECTEH			21H00015	600UL
978	51	22							TECTEH			21H00030	600UL
979	53	22	0.41	68	INR	6	F05	+7.56	TECTEH			21H00029	600UL
980			0.63	76	INR	6	F07	+10.49	TECTEH			21H00029	600UL
981					INF		F08	+1.00	TECTEH	HR		21H00029	600UL
982	55	22	1.04	74	INR	6	05C	+25.03	TECTEH			21H00030	600UL
983			0.53	71	INR	6	05C	+26.42	TECTEH			21H00030	600UL
984	57	22							TECTEH			21H00029	600UL
985	59	22			NDF	3	TEH	+12.65	TEHTSH			21H00051	610PP
986					INF		F03	+10.64	TECTEH	HR		21H00030	600UL
987			1.37	30	INR	6	F04	+11.08	TECTEH			21H00030	600UL
988					INF		04C	+17.62	TECTEH	HR		21H00030	600UL
989			0.44	85	INR	6	04C	+25.18	TECTEH			21H00030	600UL
990	61	22							TECTEH			21H00029	600UL
991	63	22							TECTEH			21H00030	600UL
992	65	22	0.55	75	INR	6	02H	+25.00	TECTEH			21H00029	600UL
993	67	22							TECTEH			21H00030	600UL
994	69	22							TECTEH			21H00029	600UL
995	71	22	0.31	85	INR	6	02H	+38.15	TECTEH			21H00030	600UL
996					INF		07H	+7.19	TECTEH	HR		21H00030	600UL
997			1.14	76	INR	6	07H	+7.62	TECTEH			21H00030	600UL
998	73	22							TECTEH			21H00029	600UL
999	75	22	0.53	70	INR	6	06H	+34.42	TECTEH			21H00030	600UL
1000	77	22							TECTEH			21H00029	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1001	79	22							TECTEH			21H00030	600UL
1002	81	22							TECTEH			21H00029	600UL
1003	83	22							TECTEH			21H00038	600UL
1004	85	22							TECTEH			21H00037	600UL
1005	87	22	0.43	87	INR	3	F08	+7.49	TECTEH			21H00038	600UL
1006					INF		F09	+6.17	TECTEH	HR		21H00038	600UL
1007			0.64	118	INR	3	05C	+2.94	TECTEH			21H00038	600UL
1008			0.34	121	INR	3	02C	+27.06	TECTEH			21H00038	600UL
1009	89	22	0.33	67	INR	6	05H	+9.55	TECTEH			21H00037	600UL
1010			0.33	80	INR	6	F02	+3.39	TECTEH			21H00037	600UL
1011			0.55	84	INR	6	F07	+12.98	TECTEH			21H00037	600UL
1012					INF		F08	+0.70	TECTEH	HR		21H00037	600UL
1013	91	22							TECTEH			21H00038	600UL
1014	93	22	0.41	74	INR	6	04H	+14.67	TECTEH			21H00037	600UL
1015			0.45	71	INR	6	04C	+35.48	TECTEH			21H00037	600UL
1016					INF		02C	+9.92	TECTEH	HR		21H00037	600UL
1017			0.41	112	INR	6	02C	+16.91	TECTEH			21H00037	600UL
1018	2	23							TECTEH			21H00028	600UL
1019	4	23							TECTEH			21H00011	600UL
1020	6	23							TECTEH			21H00012	600UL
1021	8	23							TECTEH			21H00011	600UL
1022	10	23							TECTEH			21H00012	600UL
1023	12	23	0.43	80	INR	6	05C	+32.67	TECTEH			21H00011	600UL
1024	14	23							TECTEH			21H00010	600UL
1025	16	23							TECTEH			21H00009	600UL
1026	18	23							TECTEH			21H00010	600UL
1027	20	23	0.46	96	INR	6	TSH	+15.46	TECTEH			21H00009	600UL
1028					INF		05H	+15.91	TECTEH	HR		21H00009	600UL
1029			0.34	89	INR	6	01C	+5.58	TECTEH			21H00009	600UL
1030	22	23							TECTEH			21H00010	600UL
1031	24	23							TECTEH			21H00009	600UL
1032	26	23	0.40	74	INR	6	01H	+22.26	TECTEH			21H00016	600UL
1033			0.47	77	INR	6	05H	+7.15	TECTEH			21H00016	600UL
1034			0.61	74	INR	6	F06	+11.21	TECTEH			21H00016	600UL
1035					INF		F07	+0.05	TECTEH	HR		21H00016	600UL
1036	28	23	0.57	64	INR	6	02C	+13.76	TECTEH			21H00016	600UL
1037			0.63	86	INR	6	TSC	+21.45	TECTEH			21H00016	600UL
1038	30	23	0.30	78	INR	6	TSH	+15.75	TECTEH			21H00016	600UL
1039			0.47	88	INR	6	07H	+7.11	TECTEH			21H00016	600UL
1040			0.21	54	INR	6	03C	+37.03	TECTEH			21H00016	600UL
1041	32	23							TECTEH			21H00016	600UL
1042	34	23	0.41	66	INR	6	02C	+3.18	TECTEH			21H00016	600UL
1043	36	23	0.52	82	INR	6	01H	+9.10	TECTEH			21H00016	600UL
1044					INF		06H	+27.69	TECTEH	HR		21H00016	600UL
1045			1.16	74	INR	6	06H	+29.22	TECTEH			21H00016	600UL
1046			4.20	180	INR	3	F04	+3.32	TECTEH			21H00016	600UL
1047	38	23	0.40	71	INR	6	04H	+35.47	TECTEH			21H00016	600UL
1048	40	23							TECTEH			21H00016	600UL
1049	42	23							TECTEH			21H00016	600UL
1050	44	23							TECTEH			21H00015	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1051	46	23							TECTEH			21H00016	600UL
1052	48	23							TECTEH			21H00015	600UL
1053	50	23							TECTEH			21H00030	600UL
1054	52	23	0.38	80	INR	6	05C	+37.64	TECTEH			21H00029	600UL
1055	54	23							TECTEH			21H00030	600UL
1056	56	23	0.61	53	INR	6	07H	+9.90	TECTEH			21H00029	600UL
1057			0.46	67	INR	6	F07	+8.79	TECTEH			21H00029	600UL
1058					INF		F08	+1.47	TECTEH	HR		21H00029	600UL
1059	58	23	0.34	92	INR	6	TSH	+6.21	TECTEH			21H00030	600UL
1060			0.38	94	INR	6	02H	+23.00	TECTEH			21H00030	600UL
1061			0.35	69	INR	6	07H	+3.76	TECTEH			21H00030	600UL
1062	60	23	0.57	73	INR	6	03H	+19.87	TECTEH			21H00029	600UL
1063			0.62	59	INR	6	03H	+39.31	TECTEH			21H00029	600UL
1064			0.59	75	INR	6	05H	+22.80	TECTEH			21H00029	600UL
1065			0.37	84	INR	6	03C	+7.34	TECTEH			21H00029	600UL
1066			0.50	75	INR	6	03C	+27.91	TECTEH			21H00029	600UL
1067					INF		TSC	+17.89	TECTEH	HR		21H00029	600UL
1068			0.34	76	INR	6	TSC	+19.38	TECTEH			21H00029	600UL
1069	62	23							TECTEH			21H00030	600UL
1070	64	23	0.46	70	INR	6	F09	+5.53	TECTEH			21H00029	600UL
1071					INF		F10	+5.56	TECTEH	HR		21H00029	600UL
1072			0.39	83	INR	6	04C	+3.77	TECTEH			21H00029	600UL
1073			0.48	91	INR	6	02C	+30.23	TECTEH			21H00029	600UL
1074			0.29	113	INR	3	TSC	+3.87	TECTEH			21H00029	600UL
1075	66	23	0.38	80	INR	6	TSH	+2.34	TECTEH			21H00030	600UL
1076			0.58	76	INR	6	02H	+2.39	TECTEH			21H00030	600UL
1077	68	23	0.56	71	INR	6	07H	+10.60	TECTEH			21H00029	600UL
1078			0.51	83	INR	6	05C	+29.35	TECTEH			21H00029	600UL
1079			0.40	81	INR	6	03C	+20.66	TECTEH			21H00029	600UL
1080			0.52	80	INR	6	01C	+3.48	TECTEH			21H00029	600UL
1081	70	23							TECTEH			21H00030	600UL
1082	72	23	0.33	77	INR	6	04C	+15.34	TECTEH			21H00029	600UL
1083			2.20		ADS	6	01C	+18.33 TO+33.63	TECTEH			21H00029	600UL
1084	74	23	0.45	83	INR	6	04C	+20.61	TECTEH			21H00030	600UL
1085			0.46	86	INR	6	02C	+5.69	TECTEH			21H00030	600UL
1086			0.43	88	INR	6	TSC	+16.56	TECTEH			21H00030	600UL
1087	76	23							TECTEH			21H00029	600UL
1088	78	23	0.25	60	INR	6	TSH	+17.00	TECTEH			21H00030	600UL
1089			0.45	61	INR	6	07H	+12.58	TECTEH			21H00030	600UL
1090	80	23							TECTEH			21H00029	600UL
1091	82	23							TECTEH			21H00038	600UL
1092	84	23	0.41	50	INR	3	F04	+0.00	TECTEH			21H00038	600UL
1093	86	23	0.35	86	INR	6	05C	+3.04	TECTEH			21H00037	600UL
1094	88	23	0.40	121	INR	3	02H	+36.90	TECTEH			21H00038	600UL
1095			0.18	125	INR	3	05H	+28.00	TECTEH			21H00038	600UL
1096			0.34	162	INR	3	05C	+34.79	TECTEH			21H00038	600UL
1097			0.32	134	INR	3	03C	+19.96	TECTEH			21H00038	600UL
1098	90	23							TECTEH			21H00037	600UL
1099	92	23	0.28	111	INR	3	04H	+17.07	TECTEH			21H00038	600UL
1100	94	23							TECTEH			21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1101	1	24							TECTEH			21H00028	600UL
1102	3	24							TECTEH			21H00028	600UL
1103	5	24							TECTEH			21H00012	600UL
1104	7	24							TECTEH			21H00011	600UL
1105	9	24							TECTEH			21H00012	600UL
1106	11	24							TECTEH			21H00011	600UL
1107	13	24							TECTEH			21H00010	600UL
1108	15	24							TECTEH			21H00009	600UL
1109	17	24	0.53	75	INR	6	01C	+6.29	TECTEH			21H00010	600UL
1110	19	24	0.42	68	INR	6	03C	+10.02	TECTEH			21H00009	600UL
1111	21	24	0.37	87	INR	6	01H	+15.36	TECTEH			21H00010	600UL
1112			0.55	74	INR	6	06C	+14.46	TECTEH			21H00010	600UL
1113	23	24							TECTEH			21H00009	600UL
1114	25	24							TECTEH			21H00016	600UL
1115	27	24							TECTEH			21H00016	600UL
1116	29	24			INF		F06	+3.99	TECTEH	HR		21H00016	600UL
1117			0.45	111	INR	6	F06	+5.44	TECTEH			21H00016	600UL
1118	31	24							TECTEH			21H00016	600UL
1119	33	24							TECTEH			21H00016	600UL
1120	35	24			INF		F01	+6.82	TECTEH	HR		21H00016	600UL
1121			0.54	98	INR	6	F01	+8.93	TECTEH			21H00016	600UL
1122	37	24							TECTEH			21H00016	600UL
1123	39	24							TECTEH			21H00016	600UL
1124	41	24	0.40	82	INR	6	TSH	+7.74	TECTEH			21H00016	600UL
1125			0.65	79	INR	6	03H	+15.71	TECTEH			21H00016	600UL
1126			0.40	80	INR	6	05H	+28.89	TECTEH			21H00016	600UL
1127			0.48	81	INR	6	05C	+39.74	TECTEH			21H00016	600UL
1128	43	24							TECTEH			21H00016	600UL
1129	45	24							TECTEH			21H00016	600UL
1130	47	24			INF		F03	+8.00	TECTEH	HR		21H00028	600UL
1131			0.47	91	INR	6	F05	+8.37	TECTEH			21H00028	600UL
1132	49	24							TECTEH			21H00016	600UL
1133	51	24	1.53	81	INR	6	TSH	+1.62	TECTEH			21H00030	600UL
1134			0.35	84	INR	6	01H	+3.21	TECTEH			21H00030	600UL
1135			0.33	72	INR	6	03H	+33.00	TECTEH			21H00030	600UL
1136			0.38	92	INR	6	03C	+6.33	TECTEH			21H00030	600UL
1137			0.55	80	INR	6	TSC	+4.77	TECTEH			21H00030	600UL
1138	53	24							TECTEH			21H00029	600UL
1139	55	24	0.40	82	INR	6	06C	+4.89	TECTEH			21H00030	600UL
1140	57	24	0.33	79	INR	6	02H	+27.67	TECTEH			21H00029	600UL
1141	59	24	0.33	93	INR	6	03H	+27.46	TECTEH			21H00030	600UL
1142	61	24							TECTEH			21H00029	600UL
1143	63	24							TECTEH			21H00030	600UL
1144	65	24	0.53	110	INR	6	F06	+3.93	TECTEH			21H00029	600UL
1145	67	24	0.48	75	INR	6	F06	+7.50	TECTEH			21H00030	600UL
1146					INF		F06	+9.06	TECTEH	HR		21H00030	600UL
1147	69	24							TECTEH			21H00029	600UL
1148	71	24							TECTEH			21H00030	600UL
1149	73	24	0.26	90	INR	6	02H	+26.89	TECTEH			21H00029	600UL
1150					INF		F01	+3.42	TECTEH	HR		21H00029	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1151					INF		F02	+4.32	TECTEH	HR		21H00029	600UL
1152			0.63	90	INR	6	F05	+7.06	TECTEH			21H00029	600UL
1153					INF		F06	+6.22	TECTEH	HR		21H00029	600UL
1154					INF		F07	+7.07	TECTEH	HR		21H00029	600UL
1155	75	24	0.29	92	INR	6	F02	+3.54	TECTEH			21H00030	600UL
1156	77	24							TECTEH			21H00029	600UL
1157	79	24	0.40	77	INR	6	TSC	+19.14	TECTEH			21H00030	600UL
1158	81	24							TECTEH			21H00029	600UL
1159	83	24							TECTEH			21H00038	600UL
1160	85	24							TECTEH			21H00037	600UL
1161	87	24	0.37	124	INR	3	06H	+20.86	TECTEH			21H00038	600UL
1162			0.47	148	INR	3	F04	+11.84	TECTEH			21H00038	600UL
1163	89	24	0.33	82	INR	6	F08	+2.98	TECTEH			21H00037	600UL
1164					INF		F09	+11.46	TECTEH	HR		21H00037	600UL
1165	91	24							TECTEH			21H00038	600UL
1166	93	24							TECTEH			21H00037	600UL
1167	95	24							TECTEH			21H00038	600UL
1168	97	24	0.28	83	INR	6	05C	+6.55	TECTEH			21H00037	600UL
1169	2	25							TECTEH			21H00028	600UL
1170	4	25	0.54	81	INR	6	03H	+14.02	TECTEH			21H00011	600UL
1171			0.34	111	INR	3	04H	+24.06	TECTEH			21H00011	600UL
1172	6	25							TECTEH			21H00012	600UL
1173	8	25	0.36	76	INR	6	03C	+34.80	TECTEH			21H00011	600UL
1174	10	25							TECTEH			21H00012	600UL
1175	12	25							TECTEH			21H00011	600UL
1176	14	25							TECTEH			21H00010	600UL
1177	16	25							TECTEH			21H00009	600UL
1178	18	25	0.47	76	INR	6	01H	+12.66	TECTEH			21H00010	600UL
1179	20	25							TECTEH			21H00009	600UL
1180	22	25	4.09	184	DNT	P1	F05	+1.24	TECTEH			21H00010	600UL
1181			0.65	77	INR	6	05C	+17.67	TECTEH			21H00010	600UL
1182	24	25	0.44	96	INR	6	TSH	+9.93	TECTEH			21H00009	600UL
1183			0.29	104	NQH	3	03H	+3.42	TECTEH			21H00009	600UL
1184			0.34	106	INR	6	04C	+38.75	TECTEH			21H00009	600UL
1185			0.26	47	INR	3	03C	+39.32	TECTEH			21H00009	600UL
1186					INF		01C	+10.38	TECTEH	HR		21H00009	600UL
1187			0.28	99	NQH	3	01C	+23.43	TECTEH			21H00009	600UL
1188	26	25							TECTEH			21H00018	600UL
1189	28	25	0.51	64	INR	6	03H	+34.14	TECTEH			21H00017	600UL
1190	30	25	0.35	129	INR	3	02H	+13.66	TECTEH			21H00018	600UL
1191	32	25							TECTEH			21H00017	600UL
1192	34	25							TECTEH			21H00018	600UL
1193	36	25							TECTEH			21H00017	600UL
1194	38	25							TECTEH			21H00018	600UL
1195	40	25	0.40	78	INR	6	02H	+22.99	TECTEH			21H00017	600UL
1196			0.35	76	INR	6	02C	+19.69	TECTEH			21H00017	600UL
1197	42	25							TECTEH			21H00018	600UL
1198	44	25							TECTEH			21H00017	600UL
1199	46	25							TECTEH			21H00028	600UL
1200	48	25							TECTEH			21H00017	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1201	50	25	0.70	76	INR	6	TSH	+3.40	TECTEH			21H00030	600UL
1202			0.43	80	INR	6	03H	+7.55	TECTEH			21H00030	600UL
1203			0.49	81	INR	6	01C	+30.21	TECTEH			21H00030	600UL
1204					INF		01C	+31.79	TECTEH	HR		21H00030	600UL
1205	52	25							TECTEH			21H00030	600UL
1206	54	25	0.46	75	INR	6	02H	+9.30	TECTEH			21H00030	600UL
1207			0.42	101	INR	6	F06	+6.98	TECTEH			21H00030	600UL
1208	56	25	0.62	123	INR	6	F01	+7.92	TECTEH			21H00030	600UL
1209					INF		F01	+9.61	TECTEH	HR		21H00030	600UL
1210			0.41	93	INR	6	F06	+8.26	TECTEH			21H00030	600UL
1211	58	25							TECTEH			21H00030	600UL
1212	60	25	0.43	87	INR	6	06C	+38.23	TECTEH			21H00030	600UL
1213			0.46	80	INR	6	05C	+22.06	TECTEH			21H00030	600UL
1214			0.69	50	INR	6	01C	+3.76	TECTEH			21H00030	600UL
1215	62	25	0.38	80	INR	6	03H	+14.68	TECTEH			21H00030	600UL
1216			0.42	116	INR	3	03H	+32.36	TECTEH			21H00030	600UL
1217			0.38	67	INR	6	04H	+3.79	TECTEH			21H00030	600UL
1218			0.44	75	INR	6	04H	+20.59	TECTEH			21H00030	600UL
1219			0.61	68	INR	6	04H	+36.82	TECTEH			21H00030	600UL
1220			1.07	58	INR	6	06H	+16.85 TO+27.74	TECTEH			21H00030	600UL
1221			0.62	82	INR	6	06H	+36.58	TECTEH			21H00030	600UL
1222			0.68	69	INR	6	07H	+10.68	TECTEH			21H00030	600UL
1223			0.46	75	INR	6	F12	+4.27	TECTEH			21H00030	600UL
1224					INF		07C	+8.66	TECTEH	HR		21H00030	600UL
1225			0.37	93	INR	6	05C	+32.57	TECTEH			21H00030	600UL
1226			0.30	83	INR	6	04C	+24.30	TECTEH			21H00030	600UL
1227			0.44	75	INR	6	03C	+31.59	TECTEH			21H00030	600UL
1228					INF		01C	+26.12	TECTEH	HR		21H00030	600UL
1229			0.41	73	INR	6	01C	+28.13	TECTEH			21H00030	600UL
1230	64	25							TECTEH			21H00030	600UL
1231	66	25							TECTEH			21H00030	600UL
1232	68	25	0.50	91	INR	6	03C	+38.38	TECTEH			21H00030	600UL
1233			0.67	81	INR	6	02C	+17.89	TECTEH			21H00030	600UL
1234	70	25	0.89	85	INR	6	04C	+20.46	TECTEH			21H00030	600UL
1235			0.96	86	INR	6	03C	+34.65	TECTEH			21H00030	600UL
1236					INF		03C	+39.09	TECTEH	HR		21H00030	600UL
1237	72	25							TECTEH			21H00030	600UL
1238	74	25							TECTEH			21H00030	600UL
1239	76	25							TECTEH			21H00030	600UL
1240	78	25							TECTEH			21H00030	600UL
1241	80	25	0.47	69	INR	6	07H	+9.05	TECTEH			21H00030	600UL
1242	82	25							TECTEH			21H00038	600UL
1243	84	25							TECTEH			21H00038	600UL
1244	86	25	0.36	76	INR	6	04H	+20.48	TECTEH			21H00037	600UL
1245			0.31	88	INR	6	02C	+5.29	TECTEH			21H00037	600UL
1246	88	25			INF		05H	+15.76	TECTEH	HR		21H00038	600UL
1247			0.45	129	INR	3	05H	+31.48	TECTEH			21H00038	600UL
1248			0.36	126	INR	3	02C	+7.50	TECTEH			21H00038	600UL
1249	90	25			INF		04H	+11.28	TECTEH	HR		21H00037	600UL
1250			0.20	63	INR	6	04H	+18.14	TECTEH			21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1251	92	25							TECTEH			21H00038	600UL
1252	94	25							TECTEH			21H00037	600UL
1253	96	25			INF		02H	+27.29	TECTEH	HR		21H00038	600UL
1254			0.36	135	INR	3	04C	+6.75	TECTEH			21H00038	600UL
1255	98	25							TECTEH			21H00037	600UL
1256	1	26							TECTEH			21H00028	600UL
1257	3	26							TECTEH			21H00028	600UL
1258	5	26	0.51	69	INR	6	05H	+21.53	TECTEH			21H00010	600UL
1259	7	26							TECTEH			21H00009	600UL
1260	9	26							TECTEH			21H00010	600UL
1261	11	26							TECTEH			21H00009	600UL
1262	13	26	0.76	77	INR	6	03H	+16.55	TECTEH			21H00010	600UL
1263					INF		06H	+36.05	TECTEH	HR		21H00010	600UL
1264			0.37	117	INR	3	06H	+38.42	TECTEH			21H00010	600UL
1265	15	26	0.41	85	INR	6	03H	+30.08	TECTEH			21H00009	600UL
1266			0.40	46	INR	6	05H	+5.26	TECTEH			21H00009	600UL
1267			0.21	121	INR	3	06H	+16.32	TECTEH			21H00009	600UL
1268			0.69	85	INR	6	TSC	+11.34	TECTEH			21H00009	600UL
1269	17	26	0.36	76	INR	6	01H	+23.75	TECTEH			21H00010	600UL
1270			0.36	83	INR	6	01H	+28.14	TECTEH			21H00010	600UL
1271			0.45	78	INR	6	03C	+38.92	TECTEH			21H00010	600UL
1272			0.33	71	INR	6	02C	+3.89	TECTEH			21H00010	600UL
1273	19	26							TECTEH			21H00009	600UL
1274	21	26	0.74	66	INR	6	05C	+6.54	TECTEH			21H00010	600UL
1275	23	26	4.65	187	DNT	P1	F05	+0.70	TECTEH			21H00009	600UL
1276	25	26							TECTEH			21H00018	600UL
1277	27	26							TECTEH			21H00017	600UL
1278	29	26							TECTEH			21H00018	600UL
1279	31	26	0.36	99	NQH	3	03C	+26.82	TECTEH			21H00017	600UL
1280	33	26							TECTEH			21H00018	600UL
1281	35	26	0.33	77	INR	6	05C	+38.10	TECTEH			21H00017	600UL
1282			0.39	65	INR	6	03C	+24.31	TECTEH			21H00017	600UL
1283	37	26	4.42	182	DNG	1	F04	+2.69	TECTEH			21H00018	600UL
1284	39	26							TECTEH			21H00017	600UL
1285	41	26							TECTEH			21H00018	600UL
1286	43	26							TECTEH			21H00017	600UL
1287	45	26							TECTEH			21H00018	600UL
1288	47	26							TECTEH			21H00017	600UL
1289	49	26							TECTEH			21H00017	600UL
1290	51	26	0.44	76	INR	6	04C	+23.42	TECTEH			21H00032	600UL
1291	53	26	0.28	59	INR	6	06H	+26.90	TECTEH			21H00031	600UL
1292	55	26	0.36	83	INR	6	02C	+37.79	TECTEH			21H00032	600UL
1293	57	26							TECTEH			21H00031	600UL
1294	59	26							TECTEH			21H00030	600UL
1295	61	26							TECTEH			21H00030	600UL
1296	63	26	0.61	75	NQH	3	F05	+4.56	TECTEH			21H00030	600UL
1297			0.92	161	INR	6	F10	-0.68	TECTEH			21H00030	600UL
1298					INF		F10	+0.71	TECTEH	HR		21H00030	600UL
1299			0.49	104	INR	6	03C	+33.51	TECTEH			21H00030	600UL
1300	65	26							TECTEH			21H00030	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1301	67	26							TECTEH			21H00030	600UL
1302	69	26	0.38	94	INR	6	F08	+7.70	TECTEH			21H00030	600UL
1303					INF		F09	+5.22	TECTEH	HR		21H00030	600UL
1304	71	26	0.30	94	INR	6	F03	+10.92	TECTEH			21H00030	600UL
1305			0.47	78	INR	6	F06	+12.04	TECTEH			21H00030	600UL
1306					INF		F07	+1.48	TECTEH	HR		21H00030	600UL
1307	73	26							TECTEH			21H00030	600UL
1308	75	26							TECTEH			21H00030	600UL
1309	77	26	0.36	83	INR	6	01H	+21.74	TECTEH			21H00030	600UL
1310	79	26	0.36	66	INR	6	04H	+14.84	TECTEH			21H00030	600UL
1311			0.58	82	INR	6	F05	-0.31	TECTEH			21H00030	600UL
1312			0.36	83	INR	6	01C	+24.78	TECTEH			21H00030	600UL
1313	81	26	0.34	41	INR	6	F02	+3.09	TECTEH			21H00030	600UL
1314	83	26	0.26	135	INR	3	04H	+7.02	TECTEH			21H00038	600UL
1315			0.23	161	INR	3	F06	+2.49	TECTEH			21H00038	600UL
1316			0.34	127	INR	3	03C	+19.65	TECTEH			21H00038	600UL
1317	85	26							TECTEH			21H00037	600UL
1318	87	26	0.71	171	INR	3	F04	+11.83	TECTEH			21H00038	600UL
1319			0.33	147	INR	3	02C	+23.86	TECTEH			21H00038	600UL
1320	89	26							TECTEH			21H00037	600UL
1321	91	26							TECTEH			21H00038	600UL
1322	93	26							TECTEH			21H00037	600UL
1323	95	26							TECTEH			21H00038	600UL
1324	97	26							TECTEH			21H00037	600UL
1325	99	26			INF		F06	+11.00	TECTEH	HR		21H00037	600UL
1326			0.88	83	INR	6	F06	+12.91	TECTEH			21H00037	600UL
1327					INF		F07	+1.50	TECTEH	HR		21H00037	600UL
1328	2	27							TECTEH			21H00028	600UL
1329	4	27							TECTEH			21H00011	600UL
1330	6	27							TECTEH			21H00010	600UL
1331	8	27							TECTEH			21H00009	600UL
1332	10	27	0.72	70	INR	6	05H	+27.97	TECTEH			21H00010	600UL
1333			0.39	78	INR	6	05H	+38.78	TECTEH			21H00010	600UL
1334			0.53	81	INR	6	03C	+19.09	TECTEH			21H00010	600UL
1335			0.55	60	INR	6	02C	+38.90	TECTEH			21H00010	600UL
1336	12	27							TECTEH			21H00009	600UL
1337	14	27							TECTEH			21H00010	600UL
1338	16	27							TECTEH			21H00009	600UL
1339	18	27							TECTEH			21H00010	600UL
1340	20	27							TECTEH			21H00009	600UL
1341	22	27	4.60	182	DNT	P1	F05	+1.09	TECTEH			21H00010	600UL
1342					INF		F05	+5.71	TECTEH	HR		21H00010	600UL
1343			0.46	70	INR	6	06C	+36.79	TECTEH			21H00010	600UL
1344	24	27	4.44	187	DNT	P1	F05	-0.70	TECTEH			21H00009	600UL
1345			0.70	68	INR	6	F07	+0.70	TECTEH			21H00009	600UL
1346			0.68	72	INR	6	05C	+35.33	TECTEH			21H00009	600UL
1347					INF		01C	+14.12	TECTEH	HR		21H00009	600UL
1348			0.80	79	INR	6	01C	+15.20	TECTEH			21H00009	600UL
1349					INF		01C	+16.37	TECTEH	HR		21H00009	600UL
1350	26	27	0.33	128	INR	3	05H	+6.33	TECTEH			21H00018	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1351			0.73	129	INR	3	04C	+16.72	TECTEH			21H00018	600UL
1352	28	27	0.46	68	INR	6	06C	+17.15	TECTEH			21H00017	600UL
1353			0.43	65	INR	6	01C	+25.67	TECTEH			21H00017	600UL
1354	30	27	0.36	127	INR	3	05H	+18.33	TECTEH			21H00018	600UL
1355			0.28	107	INR	3	06H	+36.31	TECTEH			21H00018	600UL
1356			0.62	147	INR	3	F07	+5.47	TECTEH			21H00018	600UL
1357					INF		F08	+4.61	TECTEH	HR		21H00018	600UL
1358					INF		F08	+5.82	TECTEH	HR		21H00018	600UL
1359			0.48	135	INR	3	06C	+10.54	TECTEH			21H00018	600UL
1360			0.32	127	INR	3	04C	+13.33	TECTEH			21H00018	600UL
1361	32	27	0.58	84	INR	6	03C	+35.29	TECTEH			21H00017	600UL
1362	34	27							TECTEH			21H00018	600UL
1363	36	27							TECTEH			21H00017	600UL
1364	38	27	0.39	158	INR	3	05C	+32.04	TECTEH			21H00018	600UL
1365	40	27							TECTEH			21H00017	600UL
1366	42	27							TECTEH			21H00018	600UL
1367	44	27							TECTEH			21H00017	600UL
1368	46	27	0.28	142	INR	3	TSH	+20.07	TECTEH			21H00018	600UL
1369			0.28	119	INR	3	06H	+33.69	TECTEH			21H00018	600UL
1370	48	27			INF		06H	+21.24	TECTEH	HR		21H00017	600UL
1371	50	27							TECTEH			21H00032	600UL
1372	52	27							TECTEH			21H00031	600UL
1373	54	27							TECTEH			21H00032	600UL
1374	56	27	0.38	118	INR	6	F07	+2.84	TECTEH			21H00031	600UL
1375					INF		F08	+8.19	TECTEH	HR		21H00031	600UL
1376			0.21	94	INR	3	03C	+14.37	TECTEH			21H00031	600UL
1377	58	27	0.38	106	INR	6	F07	+4.06	TECTEH			21H00032	600UL
1378					INF		F08	+7.14	TECTEH	HR		21H00032	600UL
1379	60	27							TECTEH			21H00031	600UL
1380	62	27	0.34	63	INR	6	01H	+30.65	TECTEH			21H00032	600UL
1381			0.65	79	INR	6	03H	+22.78	TECTEH			21H00032	600UL
1382					INF		04H	+12.76	TECTEH	HR		21H00032	600UL
1383			0.41	79	INR	6	04H	+14.23	TECTEH			21H00032	600UL
1384	64	27							TECTEH			21H00031	600UL
1385	66	27	1.42	37	INR	6	04C	+1.94	TECTEH			21H00032	600UL
1386	68	27							TECTEH			21H00031	600UL
1387	70	27	0.28	98	INR	6	03H	+37.42	TECTEH			21H00032	600UL
1388			0.52	96	INR	6	F09	+7.39	TECTEH			21H00032	600UL
1389					INF		F10	+4.83	TECTEH	HR		21H00032	600UL
1390			0.57	87	INR	6	04C	+25.46	TECTEH			21H00032	600UL
1391			0.52	95	NQH	3	01C	+13.86	TECTEH			21H00032	600UL
1392	72	27							TECTEH			21H00031	600UL
1393	74	27							TECTEH			21H00032	600UL
1394	76	27							TECTEH			21H00031	600UL
1395	78	27							TECTEH			21H00032	600UL
1396	80	27	0.41	83	INR	6	05C	+12.97	TECTEH			21H00031	600UL
1397	82	27	0.34	93	INR	3	F03	+5.14	TECTEH			21H00038	600UL
1398	84	27							TECTEH			21H00038	600UL
1399	86	27	0.41	67	INR	6	04H	+33.68	TECTEH			21H00037	600UL
1400			0.36	77	INR	6	04H	+38.07	TECTEH			21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1401			0.34	86	INR	6	06C	+14.89	TECTEH			21H00037	600UL
1402			0.34	84	INR	6	02C	+12.91	TECTEH			21H00037	600UL
1403	88	27	0.26	130	INR	3	02C	+9.96	TECTEH			21H00038	600UL
1404	90	27							TECTEH			21H00037	600UL
1405	92	27	0.95	128	INR	3	04C	+9.79	TECTEH			21H00038	600UL
1406	94	27	0.27	104	INR	6	03H	+1.96	TECTEH			21H00037	600UL
1407			0.76	34	INR	6	F02	+9.54	TECTEH			21H00037	600UL
1408	96	27							TECTEH			21H00038	600UL
1409	98	27	0.49	40	INR	6	F03	-1.68	TECTEH			21H00037	600UL
1410	100	27	0.47	143	INR	3	F12	+6.22	TECTEH			21H00038	600UL
1411			0.36	134	INR	3	F12	+11.79	TECTEH			21H00038	600UL
1412					INF		07C	+3.73	TECTEH	HR		21H00038	600UL
1413					INF		07C	+8.53	TECTEH	HR		21H00038	600UL
1414	102	27							TECTEH			21H00037	600UL
1415	1	28							TECTEH			21H00028	600UL
1416	3	28							TECTEH			21H00028	600UL
1417	5	28	0.28	87	INR	6	02H	+35.28	TECTEH			21H00011	600UL
1418	7	28	0.45	91	INR	6	02C	+39.05	TECTEH			21H00012	600UL
1419	9	28							TECTEH			21H00010	600UL
1420	11	28							TECTEH			21H00009	600UL
1421	13	28	0.39	121	INR	3	05H	+2.64	TECTEH			21H00010	600UL
1422	15	28							TECTEH			21H00009	600UL
1423	17	28							TECTEH			21H00010	600UL
1424	19	28							TECTEH			21H00009	600UL
1425	21	28			INF		F01	+5.40	TECTEH	HR		21H00010	600UL
1426			4.27	183	INR	P1	F01	+7.84	TECTEH			21H00010	600UL
1427					INF		F05	+5.40	TECTEH	HR		21H00010	600UL
1428	23	28							TECTEH			21H00009	600UL
1429	25	28	0.34	129	INR	3	06C	+15.48	TECTEH			21H00018	600UL
1430	27	28							TECTEH			21H00017	600UL
1431	29	28							TECTEH			21H00018	600UL
1432	31	28							TECTEH			21H00017	600UL
1433	33	28			INF		07H	+0.99	TECTEH	HR		21H00018	600UL
1434			1.04	119	INR	3	07H	+2.10	TECTEH			21H00018	600UL
1435	35	28	0.37	69	INR	6	01H	+23.41	TECTEH			21H00017	600UL
1436			0.42	72	INR	6	05H	+23.51	TECTEH			21H00017	600UL
1437			0.82	82	INR	6	05C	+34.26	TECTEH			21H00017	600UL
1438	37	28							TECTEH			21H00018	600UL
1439	39	28							TECTEH			21H00017	600UL
1440	41	28							TECTEH			21H00018	600UL
1441	43	28							TECTEH			21H00017	600UL
1442	45	28							TECTEH			21H00018	600UL
1443	47	28							TECTEH			21H00017	600UL
1444	49	28							TECTEH			21H00017	600UL
1445	51	28							TECTEH			21H00032	600UL
1446	53	28							TECTEH			21H00031	600UL
1447	55	28	0.44	72	INR	6	06H	+20.14	TECTEH			21H00032	600UL
1448	57	28	0.48	54	INR	6	03H	+39.73	TECTEH			21H00031	600UL
1449			0.37	51	NQH	6	F05	+7.33	TECTEH			21H00031	600UL
1450	59	28							TECTEH			21H00032	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1451	61	28	0.20	81	NQH	3	02H	+24.54	TECTEH			21H00031	600UL
1452			0.36	78	INR	6	05C	+12.31	TECTEH			21H00031	600UL
1453			0.50	74	INR	6	01C	+24.34	TECTEH			21H00031	600UL
1454	63	28							TECTEH			21H00032	600UL
1455	65	28	0.46	78	INR	6	03H	+4.29	TECTEH			21H00031	600UL
1456			0.84	85	INR	6	04C	+39.13	TECTEH			21H00031	600UL
1457	67	28	0.47	74	INR	6	02H	+27.87	TECTEH			21H00032	600UL
1458	69	28							TECTEH			21H00031	600UL
1459	71	28							TECTEH			21H00032	600UL
1460	73	28							TECTEH			21H00031	600UL
1461	75	28							TECTEH			21H00032	600UL
1462	77	28							TECTEH			21H00031	600UL
1463	79	28							TECTEH			21H00032	600UL
1464	81	28	0.60	74	INR	6	02C	+12.48	TECTEH			21H00031	600UL
1465					INF		02C	+14.81	TECTEH	HR		21H00031	600UL
1466	83	28							TECTEH			21H00038	600UL
1467	85	28	0.41	93	NQH	3	F03	+10.68	TECTEH			21H00037	600UL
1468			0.49	64	INR	6	01C	+27.91	TECTEH			21H00037	600UL
1469	87	28							TECTEH			21H00038	600UL
1470	89	28							TECTEH			21H00037	600UL
1471	91	28							TECTEH			21H00038	600UL
1472	93	28	0.52	89	INR	6	06H	+33.73	TECTEH			21H00037	600UL
1473			0.41	73	INR	6	01C	+13.64	TECTEH			21H00037	600UL
1474	95	28							TECTEH			21H00038	600UL
1475	97	28	1.38	36	INR	6	F11	+0.67	TECTEH			21H00037	600UL
1476					INF		F12	+6.33	TECTEH	HR		21H00037	600UL
1477	99	28							TECTEH			21H00038	600UL
1478	101	28							TECTEH			21H00037	600UL
1479	103	28	0.35	76	INR	6	03H	+10.49	TECTEH			21H00037	600UL
1480					INF		06C	+7.90	TECTEH	HR		21H00037	600UL
1481			0.29	65	INR	6	06C	+8.99	TECTEH			21H00037	600UL
1482	2	29							TECTEH			21H00028	600UL
1483	4	29							TECTEH			21H00010	600UL
1484	6	29	0.61	70	INR	6	03H	+2.90	TECTEH			21H00010	600UL
1485	8	29							TECTEH			21H00009	600UL
1486	10	29	0.57	87	INR	6	TSH	+13.97	TECTEH			21H00010	600UL
1487	12	29							TECTEH			21H00009	600UL
1488	14	29	0.86	79	INR	6	02C	+16.89	TECTEH			21H00010	600UL
1489	16	29							TECTEH			21H00009	600UL
1490	18	29							TECTEH			21H00010	600UL
1491	20	29							TECTEH			21H00009	600UL
1492	22	29	5.51	186	DNT	P1	F05	+1.54	TECTEH			21H00010	600UL
1493			0.26	84	INR	3	06C	+16.02	TECTEH			21H00010	600UL
1494			0.36	61	INR	6	02C	+32.46	TECTEH			21H00010	600UL
1495	24	29	0.40	44	INR	6	05H	+29.90	TECTEH			21H00009	600UL
1496			1.37	73	INR	6	06C	+18.41	TECTEH			21H00009	600UL
1497	26	29							TECTEH			21H00017	600UL
1498	28	29	0.29	139	INR	3	TSH	+4.31	TECTEH			21H00018	600UL
1499	30	29							TECTEH			21H00017	600UL
1500	32	29							TECTEH			21H00017	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1501	34	29							TECTEH			21H00018	600UL
1502	36	29							TECTEH			21H00017	600UL
1503	38	29	1.21	130	INR	3	TSH	+16.70	TECTEH			21H00018	600UL
1504			0.48	145	INR	3	02H	+8.60	TECTEH			21H00018	600UL
1505			0.39	63	INR	6	06C	+35.02	TECTEH			21H00018	600UL
1506	40	29	0.28	54	INR	6	05H	+31.01	TECTEH			21H00017	600UL
1507	42	29							TECTEH			21H00018	600UL
1508	44	29							TECTEH			21H00017	600UL
1509	46	29	1.07	124	INR	3	01C	+31.59	TECTEH			21H00018	600UL
1510	48	29	0.35	80	INR	6	01C	+28.67	TECTEH			21H00017	600UL
1511	50	29	0.42	70	INR	6	01H	+22.92	TECTEH			21H00032	600UL
1512			0.29	98	INR	6	01H	+26.27	TECTEH			21H00032	600UL
1513			0.36	84	INR	6	01C	+4.02	TECTEH			21H00032	600UL
1514	52	29							TECTEH			21H00031	600UL
1515	54	29							TECTEH			21H00032	600UL
1516	56	29	0.25	81	INR	6	TSH	+17.90	TECTEH			21H00031	600UL
1517			0.67	114	NQH	3	05H	+31.99	TECTEH			21H00031	600UL
1518			0.44	70	INR	6	01C	+31.29	TECTEH			21H00031	600UL
1519	58	29							TECTEH			21H00032	600UL
1520	60	29	0.37	82	INR	6	06C	+13.91	TECTEH			21H00031	600UL
1521			0.52	80	INR	6	03C	+28.45	TECTEH			21H00031	600UL
1522			0.24	102	INR	3	02C	+24.13	TECTEH			21H00031	600UL
1523	62	29							TECTEH			21H00032	600UL
1524	64	29	0.36	84	INR	6	05C	+38.87	TECTEH			21H00031	600UL
1525			0.39	88	INR	6	01C	+9.96	TECTEH			21H00031	600UL
1526	66	29							TECTEH			21H00032	600UL
1527	68	29	0.35	82	INR	6	02H	+6.46	TECTEH			21H00031	600UL
1528			0.50	71	INR	6	F12	+7.62	TECTEH			21H00031	600UL
1529					INF		07C	+3.70	TECTEH	HR		21H00031	600UL
1530			0.51	82	INR	6	01C	+15.12	TECTEH			21H00031	600UL
1531	70	29			INF		02H	+18.18	TECTEH	HR		21H00032	600UL
1532			0.88	80	INR	6	02H	+19.36	TECTEH			21H00032	600UL
1533			0.41	73	INR	6	04H	+6.05	TECTEH			21H00032	600UL
1534			0.71	73	INR	6	F04	+11.93	TECTEH			21H00032	600UL
1535	72	29							TECTEH			21H00031	600UL
1536	74	29							TECTEH			21H00032	600UL
1537	76	29	0.28	85	INR	6	06H	+29.03	TECTEH			21H00031	600UL
1538			0.50	87	INR	6	04C	+9.64	TECTEH			21H00031	600UL
1539	78	29							TECTEH			21H00032	600UL
1540	80	29							TECTEH			21H00031	600UL
1541	82	29							TECTEH			21H00038	600UL
1542	84	29							TECTEH			21H00037	600UL
1543	86	29							TECTEH			21H00038	600UL
1544	88	29							TECTEH			21H00037	600UL
1545	90	29							TECTEH			21H00038	600UL
1546	92	29	0.49	77	INR	6	TSH	+6.29	TECTEH			21H00037	600UL
1547	94	29	0.22	135	INR	3	02C	+29.56	TECTEH			21H00038	600UL
1548	96	29							TECTEH			21H00037	600UL
1549	98	29							TECTEH			21H00038	600UL
1550	100	29							TECTEH			21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1551	102	29	0.70	159	INR	3	F05	+11.32	TECTEH			21H00038	600UL
1552	104	29							TECTEH			21H00037	600UL
1553	1	30							TECTEH			21H00028	600UL
1554	3	30							TECTEH			21H00028	600UL
1555	5	30							TECTEH			21H00026	600UL
1556	7	30	0.48	81	INR	6	02H	+35.18	TECTEH			21H00026	600UL
1557	9	30	0.50	88	INR	6	01C	+5.01	TECTEH			21H00019	600UL
1558	11	30							TECTEH			21H00019	600UL
1559	13	30	0.43	59	INR	6	05H	+31.22	TECTEH			21H00019	600UL
1560	15	30	0.29	91	INR	6	05H	+28.65	TECTEH			21H00019	600UL
1561	17	30							TECTEH			21H00019	600UL
1562	19	30	0.32	67	INR	6	05H	+7.43	TECTEH			21H00019	600UL
1563			0.46	87	INR	6	05C	+18.31	TECTEH			21H00019	600UL
1564			0.33	83	INR	6	05C	+37.13	TECTEH			21H00019	600UL
1565					INF		04C	+25.92	TECTEH	HR		21H00019	600UL
1566			0.38	86	INR	6	04C	+27.37	TECTEH			21H00019	600UL
1567			0.56	80	INR	6	03C	+8.99	TECTEH			21H00019	600UL
1568					INF		03C	+11.44	TECTEH	HR		21H00019	600UL
1569			0.45	76	INR	6	03C	+31.75	TECTEH			21H00019	600UL
1570			0.22	65	INR	6	03C	+36.64	TECTEH			21H00019	600UL
1571			0.70	71	INR	6	02C	+3.25	TECTEH			21H00019	600UL
1572	21	30	4.11	183	INR	1	F01	+5.87	TECTEH			21H00019	600UL
1573					INF		F05	+5.35	TECTEH	HR		21H00019	600UL
1574	23	30	0.56	78	INR	6	TSH	+5.27	TECTEH			21H00019	600UL
1575	25	30	0.42	96	INR	3	02H	+19.64	TECTEH			21H00018	600UL
1576			0.60	114	INR	3	05H	+34.28	TECTEH			21H00018	600UL
1577			0.72	113	INR	3	06C	+19.84	TECTEH			21H00018	600UL
1578	27	30							TECTEH			21H00017	600UL
1579	29	30			INF		01H	+15.04	TECTEH	HR		21H00018	600UL
1580			0.39	142	INR	3	01H	+16.17	TECTEH			21H00018	600UL
1581			0.56	125	INR	3	04H	+2.53	TECTEH			21H00018	600UL
1582					INF		07H	+60.08	TECTEH	HR		21H00018	600UL
1583			1.00	131	INR	3	F08	+3.04	TECTEH			21H00018	600UL
1584					INF		F12	+6.70	TECTEH	HR		21H00018	600UL
1585			0.33	129	INR	3	03C	+2.49	TECTEH			21H00018	600UL
1586			0.51	120	INR	3	TSC	+2.03	TECTEH			21H00018	600UL
1587	31	30	0.39	69	INR	6	TSH	+9.63	TECTEH			21H00017	600UL
1588	33	30							TECTEH			21H00018	600UL
1589	35	30	0.49	77	INR	6	F06	+2.97	TECTEH			21H00017	600UL
1590	37	30	1.98	180	INR	1	F04	+4.39	TECTEH			21H00018	600UL
1591	39	30	0.39	78	INR	6	F05	+7.69	TECTEH			21H00017	600UL
1592	41	30							TECTEH			21H00018	600UL
1593	43	30							TECTEH			21H00017	600UL
1594	45	30							TECTEH			21H00018	600UL
1595	47	30							TECTEH			21H00017	600UL
1596	49	30	0.45	75	INR	6	01C	+8.53	TECTEH			21H00017	600UL
1597	51	30	0.45	91	INR	6	02C	+9.33	TECTEH			21H00032	600UL
1598	53	30							TECTEH			21H00031	600UL
1599	55	30	0.51	79	INR	6	01H	+27.28	TECTEH			21H00032	600UL
1600			0.72	79	INR	6	03C	+3.32	TECTEH			21H00032	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1601			0.45	77	INR	6	TSC	+5.44	TECTEH			21H00032	600UL
1602	57	30							TECTEH			21H00031	600UL
1603	59	30	0.53	74	INR	6	06C	+27.19	TECTEH			21H00032	600UL
1604	61	30	1.04	75	INR	6	04H	+30.66	TECTEH			21H00031	600UL
1605			0.42	78	INR	6	02C	+28.22	TECTEH			21H00031	600UL
1606	63	30	0.85	79	INR	6	01C	+31.65	TECTEH			21H00032	600UL
1607	65	30							TECTEH			21H00031	600UL
1608	67	30	0.31	76	INR	6	06H	+32.25	TECTEH			21H00032	600UL
1609	69	30	0.39	75	INR	6	01H	+10.05	TECTEH			21H00031	600UL
1610	71	30	0.45	83	INR	6	06C	+27.61	TECTEH			21H00032	600UL
1611	73	30							TECTEH			21H00031	600UL
1612	75	30							TECTEH			21H00032	600UL
1613	77	30							TECTEH			21H00031	600UL
1614	79	30							TECTEH			21H00032	600UL
1615	81	30	0.96	83	INR	6	01H	+3.57	TECTEH			21H00031	600UL
1616			0.33	75	INR	6	05H	+10.93	TECTEH			21H00031	600UL
1617			0.55	86	INR	6	F04	+12.00	TECTEH			21H00031	600UL
1618	83	30							TECTEH			21H00038	600UL
1619	85	30							TECTEH			21H00037	600UL
1620	87	30	0.31	132	INR	3	F12	+5.73	TECTEH			21H00038	600UL
1621					INF		07C	+9.09	TECTEH	HR		21H00038	600UL
1622			0.30	139	INR	3	01C	+6.98	TECTEH			21H00038	600UL
1623			0.40	152	INR	3	01C	+19.75	TECTEH			21H00038	600UL
1624	89	30							TECTEH			21H00037	600UL
1625	91	30							TECTEH			21H00038	600UL
1626	93	30							TECTEH			21H00037	600UL
1627	95	30							TECTEH			21H00038	600UL
1628	97	30							TECTEH			21H00037	600UL
1629	99	30	0.47	156	INR	3	04H	+17.09	TECTEH			21H00038	600UL
1630			0.33	161	INR	3	04H	+21.47	TECTEH			21H00038	600UL
1631			0.40	52	INR	3	05H	+30.36	TECTEH			21H00038	600UL
1632	101	30							TECTEH			21H00037	600UL
1633	103	30							TECTEH			21H00038	600UL
1634	105	30							TECTEH			21H00037	600UL
1635	107	30			INF		F04	+8.14	TECTEH	HR		21H00037	600UL
1636			0.28	84	INR	6	F04	+10.47	TECTEH			21H00037	600UL
1637			0.38	78	INR	6	02C	+11.39	TECTEH			21H00037	600UL
1638	2	31							TECTEH			21H00028	600UL
1639	4	31							TECTEH			21H00026	600UL
1640	6	31							TECTEH			21H00026	600UL
1641	8	31							TECTEH			21H00021	600UL
1642	10	31							TECTEH			21H00022	600UL
1643	12	31	0.65	77	INR	6	04H	+19.25	TECTEH			21H00021	600UL
1644			0.50	76	INR	6	04H	+22.32	TECTEH			21H00021	600UL
1645	14	31							TECTEH			21H00022	600UL
1646	16	31							TECTEH			21H00021	600UL
1647	18	31							TECTEH			21H00022	600UL
1648	20	31							TECTEH			21H00021	600UL
1649	22	31	5.13	185	INR	P1	F05	+2.07	TECTEH			21H00022	600UL
1650	24	31							TECTEH			21H00021	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1651	26	31	0.49	121	INR	3	TSH	+18.93	TECTEH			21H00018	600UL
1652			0.35	123	INR	3	04H	+19.38	TECTEH			21H00018	600UL
1653			0.27	130	INR	3	05H	+21.73	TECTEH			21H00018	600UL
1654			0.62	129	INR	3	06C	+9.43	TECTEH			21H00018	600UL
1655					INF		02C	+11.13	TECTEH	HR		21H00018	600UL
1656			0.50	122	INR	3	02C	+12.39	TECTEH			21H00018	600UL
1657	28	31	0.46	92	NQH	3	01H	+8.75	TECTEH			21H00017	600UL
1658	30	31			INF		07H	+15.35	TECTEH	HR		21H00018	600UL
1659			0.50	76	INR	6	F05	+0.00	TECTEH			21H00018	600UL
1660	32	31							TECTEH			21H00017	600UL
1661	34	31							TECTEH			21H00018	600UL
1662	36	31							TECTEH			21H00017	600UL
1663	38	31							TECTEH			21H00018	600UL
1664	40	31							TECTEH			21H00017	600UL
1665	42	31							TECTEH			21H00018	600UL
1666	44	31	0.33	100	INR	6	01C	+17.23	TECTEH			21H00017	600UL
1667	46	31							TECTEH			21H00018	600UL
1668	48	31							TECTEH			21H00017	600UL
1669	50	31							TECTEH			21H00032	600UL
1670	52	31	0.36	77	INR	6	TSH	+6.90	TECTEH			21H00031	600UL
1671			0.23	107	INR	6	F06	+0.00	TECTEH			21H00031	600UL
1672			0.29	111	INR	3	F09	+4.98	TECTEH			21H00031	600UL
1673					INF		F10	+0.00	TECTEH	HR		21H00031	600UL
1674					INF		F10	+5.70	TECTEH	HR		21H00031	600UL
1675	54	31	0.39	78	INR	6	04C	+13.67	TECTEH			21H00032	600UL
1676			0.98	74	INR	6	01C	+4.09	TECTEH			21H00032	600UL
1677	56	31	0.42	81	INR	6	06H	+27.80	TECTEH			21H00031	600UL
1678			0.43	75	INR	6	06H	+34.21	TECTEH			21H00031	600UL
1679			0.71	56	INR	6	04C	+2.34	TECTEH			21H00031	600UL
1680			0.44	73	INR	6	04C	+4.44	TECTEH			21H00031	600UL
1681	58	31							TECTEH			21H00032	600UL
1682	60	31							TECTEH			21H00031	600UL
1683	62	31	0.64	101	INR	6	02H	+3.22	TECTEH			21H00032	600UL
1684			0.62	153	INR	6	F09	+0.00	TECTEH			21H00032	600UL
1685			0.67	140	INR	6	F10	-0.65	TECTEH			21H00032	600UL
1686					INF		F10	+2.24	TECTEH	HR		21H00032	600UL
1687			0.55	80	INR	6	02C	+37.86	TECTEH			21H00032	600UL
1688	64	31							TECTEH			21H00031	600UL
1689	66	31							TECTEH			21H00032	600UL
1690	68	31							TECTEH			21H00031	600UL
1691	70	31			INF		02H	+28.15	TECTEH	HR		21H00032	600UL
1692			0.43	74	INR	6	02H	+30.37	TECTEH			21H00032	600UL
1693			0.50	74	INR	6	04H	+3.78	TECTEH			21H00032	600UL
1694			1.52	26	INR	6	F07	+0.55	TECTEH			21H00032	600UL
1695	72	31							TECTEH			21H00031	600UL
1696	74	31							TECTEH			21H00032	600UL
1697	76	31							TECTEH			21H00031	600UL
1698	78	31	0.66	74	INR	6	03C	+27.61	TECTEH			21H00032	600UL
1699	80	31	0.22	23	INR	3	07H	+0.00	TECTEH			21H00031	600UL
1700			5.11	6	BLG	P1	07H	+1.85	TECTEH			21H00031	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1701					NDF	3	07H	+1.85	07H07H			21H00051	610PP
1702	82	31							TECTEH			21H00038	600UL
1703	84	31							TECTEH			21H00037	600UL
1704	86	31							TECTEH			21H00038	600UL
1705	88	31							TECTEH			21H00037	600UL
1706	90	31	0.30	141	INR	3	01C	+9.93	TECTEH			21H00038	600UL
1707	92	31							TECTEH			21H00037	600UL
1708	94	31							TECTEH			21H00038	600UL
1709	96	31							TECTEH			21H00037	600UL
1710	98	31							TECTEH			21H00038	600UL
1711	100	31							TECTEH			21H00037	600UL
1712	102	31							TECTEH			21H00038	600UL
1713	104	31							TECTEH			21H00037	600UL
1714	106	31	0.29	93	INR	3	02H	+4.37	TECTEH			21H00038	600UL
1715			0.67	124	INR	3	04H	+29.81	TECTEH			21H00038	600UL
1716	108	31							TECTEH			21H00037	600UL
1717	1	32							TECTEH			21H00028	600UL
1718	3	32							TECTEH			21H00028	600UL
1719	5	32	0.73	57	INR	6	01H	+32.48	TECTEH			21H00026	600UL
1720			0.43	82	INR	6	02H	+34.83	TECTEH			21H00026	600UL
1721	7	32							TECTEH			21H00026	600UL
1722	9	32							TECTEH			21H00022	600UL
1723	11	32							TECTEH			21H00021	600UL
1724	13	32							TECTEH			21H00022	600UL
1725	15	32							TECTEH			21H00021	600UL
1726	17	32							TECTEH			21H00022	600UL
1727	19	32	0.32	80	INR	6	02C	+22.30	TECTEH			21H00021	600UL
1728	21	32	0.61	75	INR	6	03H	+29.18	TECTEH			21H00022	600UL
1729			4.42	184	INR	3	F01	+6.45	TECTEH			21H00022	600UL
1730					INF		F05	+3.51	TECTEH	HR		21H00022	600UL
1731			0.60	75	INR	6	06C	+17.99	TECTEH			21H00022	600UL
1732			0.43	67	INR	6	04C	+9.38	TECTEH			21H00022	600UL
1733			0.87	77	INR	6	04C	+13.81	TECTEH			21H00022	600UL
1734			0.46	81	INR	6	04C	+22.53	TECTEH			21H00022	600UL
1735			0.54	72	INR	6	01C	+14.00	TECTEH			21H00022	600UL
1736	23	32							TECTEH			21H00021	600UL
1737	25	32	0.44	119	INR	3	02C	+9.56	TECTEH			21H00018	600UL
1738			0.32	128	INR	3	02C	+11.93	TECTEH			21H00018	600UL
1739	27	32							TECTEH			21H00017	600UL
1740	29	32							TECTEH			21H00018	600UL
1741	31	32							TECTEH			21H00017	600UL
1742	33	32							TECTEH			21H00018	600UL
1743	35	32	0.51	78	INR	6	03C	+19.51	TECTEH			21H00017	600UL
1744			0.49	77	INR	6	02C	+9.62	TECTEH			21H00017	600UL
1745	37	32							TECTEH			21H00018	600UL
1746	39	32	0.34	86	INR	6	F04	+3.24	TECTEH			21H00017	600UL
1747					INF		F04	+10.24	TECTEH	HR		21H00017	600UL
1748			0.27	82	INR	6	F06	+2.94	TECTEH			21H00017	600UL
1749			0.55	76	INR	6	03C	+23.67	TECTEH			21H00017	600UL
1750			0.38	74	INR	6	03C	+30.17	TECTEH			21H00017	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1751			0.42	70	INR	6	02C	+3.75	TECTEH			21H00017	600UL
1752			0.53	81	INR	6	02C	+29.75	TECTEH			21H00017	600UL
1753	41	32							TECTEH			21H00018	600UL
1754	43	32							TECTEH			21H00017	600UL
1755	45	32	0.25	115	INR	3	05C	+29.10	TECTEH			21H00018	600UL
1756	47	32							TECTEH			21H00017	600UL
1757	49	32	0.38	74	INR	6	04C	+22.36	TECTEH			21H00017	600UL
1758	51	32							TECTEH			21H00032	600UL
1759	53	32							TECTEH			21H00031	600UL
1760	55	32	0.45	83	INR	6	05H	+30.46	TECTEH			21H00032	600UL
1761			0.47	76	INR	6	06H	+30.06	TECTEH			21H00032	600UL
1762			0.54	86	INR	6	02C	+31.43	TECTEH			21H00032	600UL
1763	57	32							TECTEH			21H00031	600UL
1764	59	32							TECTEH			21H00032	600UL
1765	61	32	0.36	80	INR	6	F04	+3.68 TO+6.95	TECTEH			21H00031	600UL
1766			0.43	71	INR	6	06C	+19.92	TECTEH			21H00031	600UL
1767			0.39	80	INR	6	02C	+7.37	TECTEH			21H00031	600UL
1768	63	32							TECTEH			21H00032	600UL
1769	65	32							TECTEH			21H00031	600UL
1770	67	32	0.42	71	INR	6	02H	+18.31	TECTEH			21H00032	600UL
1771			0.37	109	INR	6	F05	+8.66	TECTEH			21H00032	600UL
1772	69	32							TECTEH			21H00031	600UL
1773	71	32			INF		02H	+3.43	TECTEH	HR		21H00032	600UL
1774			0.51	71	INR	6	02H	+10.76	TECTEH			21H00032	600UL
1775					INF		04H	-0.38	TECTEH	HR		21H00032	600UL
1776					INF		04H	+14.59	TECTEH	HR		21H00032	600UL
1777			1.16	54	INR	6	F04	+5.01	TECTEH			21H00032	600UL
1778			0.50	82	INR	6	F10	+6.63	TECTEH			21H00032	600UL
1779					INF		F11	+1.36	TECTEH	HR		21H00032	600UL
1780			0.42	88	INR	6	03C	+6.50	TECTEH			21H00032	600UL
1781			0.69	80	INR	6	01C	+20.72	TECTEH			21H00032	600UL
1782			0.72	80	INR	6	TSC	+4.57	TECTEH			21H00032	600UL
1783	73	32	0.36	70	INR	6	TSH	+21.11	TECTEH			21H00031	600UL
1784	75	32							TECTEH			21H00032	600UL
1785	77	32							TECTEH			21H00031	600UL
1786	79	32	0.81	42	INR	6	06H	+26.74 TO+35.95	TECTEH			21H00032	600UL
1787	81	32							TECTEH			21H00031	600UL
1788	83	32							TECTEH			21H00038	600UL
1789	85	32	0.30	97	INR	6	F07	+11.15	TECTEH			21H00037	600UL
1790					INF		F08	+4.96	TECTEH	HR		21H00037	600UL
1791	87	32	0.35	129	INR	3	02H	+2.39	TECTEH			21H00038	600UL
1792	89	32	0.63	68	INR	6	F05	+10.12	TECTEH			21H00037	600UL
1793	91	32	0.28	142	INR	3	05C	+27.34	TECTEH			21H00038	600UL
1794			0.31	166	INR	3	02C	+8.11	TECTEH			21H00038	600UL
1795			0.24	125	INR	3	02C	+20.05	TECTEH			21H00038	600UL
1796	93	32							TECTEH			21H00037	600UL
1797	95	32							TECTEH			21H00038	600UL
1798	97	32							TECTEH			21H00037	600UL
1799	99	32							TECTEH			21H00038	600UL
1800	101	32			INF		01C	+27.47	TECTEH	HR		21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1801			0.40	57	INR	6	01C	+29.12	TECTEH			21H00037	600UL
1802	103	32							TECTEH			21H00038	600UL
1803	105	32							TECTEH			21H00037	600UL
1804	107	32							TECTEH			21H00038	600UL
1805	109	32							TECTEH			21H00037	600UL
1806	2	33							TECTEH			21H00028	600UL
1807	4	33							TECTEH			21H00026	600UL
1808	6	33	0.32	86	INR	6	TSC	+13.86	TECTEH			21H00026	600UL
1809	8	33							TECTEH			21H00022	600UL
1810	10	33	0.48	65	INR	6	02C	+13.19	TECTEH			21H00021	600UL
1811	12	33	0.74	71	INR	6	04H	+24.43	TECTEH			21H00022	600UL
1812			0.47	78	INR	6	03C	+34.71	TECTEH			21H00022	600UL
1813			0.83	75	INR	6	01C	+12.39	TECTEH			21H00022	600UL
1814			0.79	77	INR	6	01C	+15.04	TECTEH			21H00022	600UL
1815	14	33							TECTEH			21H00021	600UL
1816	16	33							TECTEH			21H00022	600UL
1817	18	33	0.39	81	INR	6	04H	+8.50	TECTEH			21H00021	600UL
1818	20	33	0.23	87	INR	6	05H	+27.28	TECTEH			21H00022	600UL
1819			0.53	35	INR	6	F01	+9.61	TECTEH			21H00022	600UL
1820					INF		F05	+6.72	TECTEH	HR		21H00022	600UL
1821	22	33	4.35	188	INR	1	F05	+2.27	TECTEH			21H00021	600UL
1822			0.25	90	INR	6	01C	+26.53	TECTEH			21H00021	600UL
1823			0.27	86	INR	6	01C	+28.14	TECTEH			21H00021	600UL
1824			0.34	91	INR	6	TSC	+10.88	TECTEH			21H00021	600UL
1825			0.44	83	INR	6	TSC	+21.68	TECTEH			21H00021	600UL
1826	24	33	0.38	79	INR	6	01H	+2.22	TECTEH			21H00021	600UL
1827			0.32	76	INR	6	01C	+9.75	TECTEH			21H00021	600UL
1828	26	33							TECTEH			21H00018	600UL
1829	28	33							TECTEH			21H00017	600UL
1830	30	33	0.54	32	INR	3	F06	+6.73	TECTEH			21H00018	600UL
1831					INF		F07	+5.04	TECTEH	HR		21H00018	600UL
1832			0.22	119	INR	3	02C	+35.98	TECTEH			21H00018	600UL
1833	32	33							TECTEH			21H00017	600UL
1834	34	33							TECTEH			21H00018	600UL
1835	36	33	0.40	91	INR	6	03H	+19.15	TECTEH			21H00017	600UL
1836	38	33	0.41	50	INR	6	06C	+29.36	TECTEH			21H00018	600UL
1837	40	33							TECTEH			21H00017	600UL
1838	42	33							TECTEH			21H00018	600UL
1839	44	33	0.57	82	INR	6	05H	+11.32	TECTEH			21H00017	600UL
1840	46	33	0.52	143	INR	3	01C	+18.26	TECTEH			21H00018	600UL
1841	48	33							TECTEH			21H00017	600UL
1842	50	33	0.36	69	INR	6	05H	+21.94	TECTEH			21H00032	600UL
1843	52	33	0.40	61	INR	6	F12	+5.56	TECTEH			21H00031	600UL
1844					INF		07C	+2.78	TECTEH	HR		21H00031	600UL
1845	54	33	0.38	65	INR	6	TSH	+15.90	TECTEH			21H00032	600UL
1846			4.03	178	DNT	P1	07H	-0.13	TECTEH			21H00032	600UL
1847					NDF	3	07H	-0.13	07H07H			21H00051	610PP
1848	56	33	0.25	92	INR	3	02H	+25.81	TECTEH			21H00031	600UL
1849	58	33							TECTEH			21H00032	600UL
1850	60	33							TECTEH			21H00031	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1851	62	33	0.69	79	INR	6	05H	+18.03	TECTEH			21H00032	600UL
1852	64	33	0.39	96	INR	6	02C	+9.59	TECTEH			21H00031	600UL
1853			0.60	85	INR	6	02C	+32.53	TECTEH			21H00031	600UL
1854			0.47	69	INR	6	01C	+5.30	TECTEH			21H00031	600UL
1855			0.41	82	INR	6	TSC	+15.30	TECTEH			21H00031	600UL
1856	66	33			INF		03C	+2.93	TECTEH	HR		21H00032	600UL
1857			0.79	71	INR	6	03C	+5.84	TECTEH			21H00032	600UL
1858	68	33							TECTEH			21H00031	600UL
1859	70	33	0.51	66	INR	6	02H	+18.23	TECTEH			21H00032	600UL
1860			0.42	85	INR	6	02H	+20.27	TECTEH			21H00032	600UL
1861			0.34	143	INR	3	04H	+2.83	TECTEH			21H00032	600UL
1862	72	33							TECTEH			21H00031	600UL
1863	74	33	0.50	84	INR	6	01H	+9.74	TECTEH			21H00032	600UL
1864			0.91	64	INR	6	F03	+5.49	TECTEH			21H00032	600UL
1865			0.22	69	INR	6	F05	+6.04	TECTEH			21H00032	600UL
1866					INF		F06	+8.74	TECTEH	HR		21H00032	600UL
1867			0.30	119	INR	6	F06	+9.02	TECTEH			21H00032	600UL
1868					INF		F07	+4.30	TECTEH	HR		21H00032	600UL
1869	76	33							TECTEH			21H00031	600UL
1870	78	33							TECTEH			21H00032	600UL
1871	80	33							TECTEH			21H00031	600UL
1872	82	33	0.45	133	INR	3	06H	+36.94	TECTEH			21H00038	600UL
1873			0.43	99	INR	3	F06	+13.31	TECTEH			21H00038	600UL
1874					INF		F07	+1.60	TECTEH	HR		21H00038	600UL
1875			0.34	132	INR	3	F07	+11.65	TECTEH			21H00038	600UL
1876			0.43	87	INR	3	F08	+0.17	TECTEH			21H00038	600UL
1877					INF		F08	+1.36	TECTEH	HR		21H00038	600UL
1878	84	33	0.33	134	INR	3	01C	+18.70	TECTEH			21H00038	600UL
1879	86	33							TECTEH			21H00037	600UL
1880	88	33							TECTEH			21H00038	600UL
1881	90	33			INF		05C	+19.29	TECTEH	HR		21H00037	600UL
1882			0.31	86	INR	6	05C	+22.44	TECTEH			21H00037	600UL
1883	92	33							TECTEH			21H00038	600UL
1884	94	33	0.24	94	INR	6	F02	+0.00	TECTEH			21H00037	600UL
1885	96	33							TECTEH			21H00038	600UL
1886	98	33			INF		F11	-0.71	TECTEH	HR		21H00037	600UL
1887			0.70	108	INR	6	F11	+0.59	TECTEH			21H00037	600UL
1888			0.37	73	INR	6	06C	+13.38	TECTEH			21H00037	600UL
1889	100	33							TECTEH			21H00038	600UL
1890	102	33							TECTEH			21H00037	600UL
1891	104	33	0.33	153	INR	3	02C	+6.62	TECTEH			21H00038	600UL
1892	106	33							TECTEH			21H00037	600UL
1893	108	33	0.34	133	INR	3	05C	+5.03	TECTEH			21H00038	600UL
1894			0.27	104	INR	3	03C	+33.44	TECTEH			21H00038	600UL
1895	110	33	0.71	110	INR	6	F08	+0.46	TECTEH			21H00037	600UL
1896	1	34	0.75	42	INR	6	03H	+22.23 TO+34.32	TECTEH			21H00028	600UL
1897	3	34							TECTEH			21H00028	600UL
1898	5	34							TECTEH			21H00026	600UL
1899	7	34							TECTEH			21H00026	600UL
1900	9	34	0.33	63	INR	6	06H	+15.62	TECTEH			21H00022	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1901	11	34	0.34	76	INR	6	06C	+19.63	TECTEH			21H00021	600UL
1902	13	34							TECTEH			21H00022	600UL
1903	15	34							TECTEH			21H00021	600UL
1904					NDF	3	TSH	-1.03	TSHTSH			21H00051	610PP
1905	17	34							TECTEH			21H00022	600UL
1906	19	34	0.28	94	INR	6	03H	+27.31	TECTEH			21H00021	600UL
1907	21	34	0.42	42	INR	6	05H	+9.56	TECTEH			21H00022	600UL
1908			4.62	184	INR	3	F01	+7.29	TECTEH			21H00022	600UL
1909					INF		F05	+5.69	TECTEH	HR		21H00022	600UL
1910	23	34			INF		F05	+4.09	TECTEH	HR		21H00021	600UL
1911			0.67	102	INR	6	F05	+6.82	TECTEH			21H00021	600UL
1912	25	34	0.30	130	INR	3	TSH	+12.99	TECTEH			21H00018	600UL
1913			0.30	129	INR	3	TSH	+16.82	TECTEH			21H00018	600UL
1914			0.27	101	INR	3	01H	+4.29	TECTEH			21H00018	600UL
1915			0.48	122	INR	3	01H	+10.31	TECTEH			21H00018	600UL
1916			0.23	124	INR	3	02H	+14.68	TECTEH			21H00018	600UL
1917			0.26	132	INR	3	02H	+33.31	TECTEH			21H00018	600UL
1918			0.21	145	INR	3	03H	+9.25	TECTEH			21H00018	600UL
1919			0.16	136	INR	3	03H	+14.68	TECTEH			21H00018	600UL
1920			0.28	101	INR	3	04H	+25.73	TECTEH			21H00018	600UL
1921			0.29	113	INR	3	05H	+5.41	TECTEH			21H00018	600UL
1922			0.17	122	INR	3	06H	+31.97	TECTEH			21H00018	600UL
1923					INF		F04	+5.15	TECTEH	HR		21H00018	600UL
1924			0.34	107	INR	3	F05	+9.35	TECTEH			21H00018	600UL
1925			0.41	153	INR	3	F06	+9.48	TECTEH			21H00018	600UL
1926			0.89	29	INR	6	F12	+6.85	TECTEH			21H00018	600UL
1927			0.55	132	INR	3	F12	+6.90	TECTEH			21H00018	600UL
1928					INF		07C	+0.74	TECTEH	HR		21H00018	600UL
1929			0.21	106	INR	3	06C	+33.51	TECTEH			21H00018	600UL
1930			0.33	111	INR	3	06C	+35.83	TECTEH			21H00018	600UL
1931			0.27	133	INR	3	05C	+8.65	TECTEH			21H00018	600UL
1932	27	34	0.41	99	INR	6	04C	+38.40	TECTEH			21H00017	600UL
1933	29	34	0.39	79	INR	3	F12	+0.25	TECTEH			21H00018	600UL
1934	31	34							TECTEH			21H00017	600UL
1935	33	34	0.30	141	INR	3	TSH	+16.03	TECTEH			21H00018	600UL
1936			0.32	146	INR	3	03H	+8.89	TECTEH			21H00018	600UL
1937			0.28	144	INR	3	05H	+10.67	TECTEH			21H00018	600UL
1938			0.33	158	INR	3	TSC	+14.75	TECTEH			21H00018	600UL
1939	35	34	0.43	59	INR	6	05H	+36.75	TECTEH			21H00017	600UL
1940			0.45	40	INR	6	06H	+33.35	TECTEH			21H00017	600UL
1941			0.35	29	INR	6	F04	+7.18	TECTEH			21H00017	600UL
1942			0.30	74	INR	6	06C	+3.88	TECTEH			21H00017	600UL
1943			0.54	66	INR	6	06C	+20.88	TECTEH			21H00017	600UL
1944			0.41	82	INR	6	03C	+24.99	TECTEH			21H00017	600UL
1945			0.34	81	INR	6	02C	+18.80	TECTEH			21H00017	600UL
1946			0.42	80	INR	6	01C	+16.47	TECTEH			21H00017	600UL
1947			0.52	71	INR	6	TSC	+5.60	TECTEH			21H00017	600UL
1948			0.78	92	INR	6	TSC	+12.97	TECTEH			21H00017	600UL
1949			0.78	81	INR	6	TSC	+13.55	TECTEH			21H00017	600UL
1950	37	34							TECTEH			21H00018	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
1951	39	34								TECTEH			21H00017	600UL
1952	41	34								TECTEH			21H00018	600UL
1953	43	34	0.27	73	INR	6	05H	+30.85		TECTEH			21H00017	600UL
1954	45	34	0.32	176	INR	3	03H	+13.66		TECTEH			21H00018	600UL
1955			0.29	155	INR	3	05H	+17.39		TECTEH			21H00018	600UL
1956			0.28	142	INR	3	05C	+10.69		TECTEH			21H00018	600UL
1957	47	34								TECTEH			21H00017	600UL
1958	49	34								TECTEH			21H00017	600UL
1959	51	34	0.47	67	INR	6	04H	+7.99		TECTEH			21H00032	600UL
1960			0.36	160	INR	6	F03	+5.70		TECTEH			21H00032	600UL
1961					INF		F05	+4.72		TECTEH	HR		21H00032	600UL
1962			0.78	54	INR	6	F05	+6.04		TECTEH			21H00032	600UL
1963			0.42	73	INR	6	03C	+5.57		TECTEH			21H00032	600UL
1964			0.26	81	INR	3	01C	+25.21		TECTEH			21H00032	600UL
1965	53	34	0.74	75	INR	6	TSH	+5.93		TECTEH			21H00031	600UL
1966			0.42	117	INR	3	07H	+9.02		TECTEH			21H00031	600UL
1967			0.32	75	INR	6	F04	+6.74		TECTEH			21H00031	600UL
1968	55	34	0.20	38	INR	6	06H	+5.49	TO+17.20	TECTEH			21H00032	600UL
1969	57	34								TECTEH			21H00031	600UL
1970	59	34	0.48	134	INR	6	F03	+6.85		TECTEH			21H00032	600UL
1971					INF		F03	+9.43		TECTEH	HR		21H00032	600UL
1972			0.34	76	INR	6	03C	+18.38		TECTEH			21H00032	600UL
1973	61	34	0.38	77	INR	6	03H	+17.19		TECTEH			21H00031	600UL
1974			0.48	66	INR	6	01C	+31.46		TECTEH			21H00031	600UL
1975	63	34	0.45	86	INR	6	04H	+18.87		TECTEH			21H00032	600UL
1976	65	34	0.33	81	INR	6	01H	+3.12		TECTEH			21H00031	600UL
1977			0.43	79	INR	6	01H	+15.00		TECTEH			21H00031	600UL
1978			0.26	85	INR	6	03H	+12.80		TECTEH			21H00031	600UL
1979			0.42	73	INR	6	04H	+20.56		TECTEH			21H00031	600UL
1980			0.30	54	INR	6	06H	+29.17		TECTEH			21H00031	600UL
1981			0.38	71	INR	6	F07	+5.39		TECTEH			21H00031	600UL
1982			0.35	97	INR	6	F08	+7.09		TECTEH			21H00031	600UL
1983			0.23	49	INR	6	F09	+5.14		TECTEH			21H00031	600UL
1984			0.33	60	INR	6	F09	+8.19		TECTEH			21H00031	600UL
1985			0.40	71	NQH	3	F10	-0.23		TECTEH			21H00031	600UL
1986					INF		F10	+1.42		TECTEH	HR		21H00031	600UL
1987					INF		F10	+2.87		TECTEH	HR		21H00031	600UL
1988					INF		F10	+8.61		TECTEH	HR		21H00031	600UL
1989					INF		F11	+5.93		TECTEH	HR		21H00031	600UL
1990			0.31	55	INR	6	F12	+9.37		TECTEH			21H00031	600UL
1991					INF		F12	+10.60		TECTEH	HR		21H00031	600UL
1992			0.41	67	INR	6	03C	+23.53		TECTEH			21H00031	600UL
1993	67	34	0.32	74	INR	6	05H	+33.19		TECTEH			21H00032	600UL
1994			0.47	79	INR	6	F12	+6.17		TECTEH			21H00032	600UL
1995					INF		07C	+5.00		TECTEH	HR		21H00032	600UL
1996			0.44	67	INR	6	04C	+32.42		TECTEH			21H00032	600UL
1997					INF		04C	+36.55		TECTEH	HR		21H00032	600UL
1998			0.42	88	INR	6	03C	+22.41		TECTEH			21H00032	600UL
1999	69	34								TECTEH			21H00031	600UL
2000	71	34	0.41	66	INR	6	F10	+4.39		TECTEH			21H00032	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2001					INF		F11	+4.10	TECTEH	HR		21H00032	600UL
2002	73	34	0.34	81	INR	6	F12	+7.82	TECTEH			21H00031	600UL
2003					INF		07C	+2.86	TECTEH	HR		21H00031	600UL
2004	75	34							TECTEH			21H00032	600UL
2005	77	34							TECTEH			21H00031	600UL
2006	79	34	1.38	41	INR	6	F04	+12.78	TECTEH			21H00032	600UL
2007			0.63	82	INR	6	02C	+29.29	TECTEH			21H00032	600UL
2008	81	34							TECTEH			21H00031	600UL
2009	83	34	0.29	139	INR	3	07H	+12.14	TECTEH			21H00038	600UL
2010			0.31	148	INR	3	04C	+31.44	TECTEH			21H00038	600UL
2011	85	34							TECTEH			21H00037	600UL
2012	87	34			INF		07H	+56.84	TECTEH	HR		21H00038	600UL
2013			0.68	48	INR	3	F04	+6.85	TECTEH			21H00038	600UL
2014	89	34							TECTEH			21H00037	600UL
2015	91	34	0.34	145	INR	3	07H	+9.91	TECTEH			21H00038	600UL
2016	93	34	0.32	86	INR	6	04C	+6.72	TECTEH			21H00037	600UL
2017			0.45	78	INR	6	03C	+14.90	TECTEH			21H00037	600UL
2018			0.39	75	INR	6	02C	+13.71	TECTEH			21H00037	600UL
2019	95	34							TECTEH			21H00038	600UL
2020	97	34							TECTEH			21H00037	600UL
2021	99	34							TECTEH			21H00038	600UL
2022	101	34							TECTEH			21H00037	600UL
2023	103	34							TECTEH			21H00038	600UL
2024	105	34							TECTEH			21H00037	600UL
2025	107	34							TECTEH			21H00038	600UL
2026	109	34							TECTEH			21H00037	600UL
2027	111	34							TECTEH			21H00037	600UL
2028	2	35	1.30	45	INR	6	03H	+15.32 TO+32.62	TECTEH			21H00028	600UL
2029	4	35							TECTEH			21H00026	600UL
2030	6	35							TECTEH			21H00026	600UL
2031	8	35							TECTEH			21H00022	600UL
2032	10	35	0.35	81	INR	6	02H	+12.58	TECTEH			21H00021	600UL
2033			0.50	75	INR	6	04C	+23.02	TECTEH			21H00021	600UL
2034			0.45	72	INR	6	01C	+28.14	TECTEH			21H00021	600UL
2035	12	35	0.75	67	INR	6	05H	+39.18	TECTEH			21H00022	600UL
2036	14	35	0.53	85	INR	6	04C	+9.43	TECTEH			21H00021	600UL
2037			0.39	91	INR	6	02C	+11.40	TECTEH			21H00021	600UL
2038			0.51	84	INR	6	02C	+14.89	TECTEH			21H00021	600UL
2039	16	35							TECTEH			21H00022	600UL
2040	18	35	0.52	83	INR	6	04C	+9.52	TECTEH			21H00021	600UL
2041	20	35							TECTEH			21H00022	600UL
2042	22	35	0.40	82	INR	6	04C	+8.34	TECTEH			21H00021	600UL
2043	24	35							TECTEH			21H00021	600UL
2044	26	35	0.41	69	INR	6	02H	+31.94	TECTEH			21H00017	600UL
2045	28	35							TECTEH			21H00018	600UL
2046	30	35							TECTEH			21H00017	600UL
2047	32	35							TECTEH			21H00017	600UL
2048	34	35							TECTEH			21H00018	600UL
2049	36	35							TECTEH			21H00017	600UL
2050	38	35	0.60	123	INR	3	01C	+7.12	TECTEH			21H00018	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2051	40	35							TECTEH			21H00017	600UL
2052	42	35	0.73	103	INR	3	06H	+22.79	TECTEH			21H00018	600UL
2053			0.47	123	INR	3	06C	+16.01	TECTEH			21H00018	600UL
2054	44	35	0.60	79	INR	6	01H	+24.23	TECTEH			21H00017	600UL
2055			0.46	75	INR	6	03H	+30.55	TECTEH			21H00017	600UL
2056	46	35							TECTEH			21H00018	600UL
2057	48	35							TECTEH			21H00017	600UL
2058	50	35	0.33	74	INR	6	01C	+25.14	TECTEH			21H00032	600UL
2059	52	35	0.43	69	INR	6	06H	+23.95	TECTEH			21H00031	600UL
2060			0.40	73	INR	6	05C	+7.16	TECTEH			21H00031	600UL
2061	54	35							TECTEH			21H00032	600UL
2062	56	35							TECTEH			21H00031	600UL
2063	58	35							TECTEH			21H00032	600UL
2064	60	35	0.67	69	INR	6	02C	+5.40	TECTEH			21H00031	600UL
2065	62	35							TECTEH			21H00032	600UL
2066	64	35	0.21	86	NQH	3	03C	+38.42	TECTEH			21H00031	600UL
2067	66	35							TECTEH			21H00032	600UL
2068	68	35							TECTEH			21H00031	600UL
2069	70	35	0.73	83	INR	6	04C	+10.61	TECTEH			21H00032	600UL
2070	72	35							TECTEH			21H00031	600UL
2071	74	35							TECTEH			21H00032	600UL
2072	76	35							TECTEH			21H00031	600UL
2073	78	35							TECTEH			21H00032	600UL
2074	80	35	0.56	82	INR	6	03C	+38.06	TECTEH			21H00031	600UL
2075					INF		03C	+41.82	TECTEH	HR		21H00031	600UL
2076	82	35							TECTEH			21H00038	600UL
2077	84	35	0.43	73	INR	6	03C	+13.50	TECTEH			21H00037	600UL
2078	86	35							TECTEH			21H00038	600UL
2079	88	35							TECTEH			21H00037	600UL
2080	90	35							TECTEH			21H00038	600UL
2081	92	35							TECTEH			21H00037	600UL
2082	94	35							TECTEH			21H00038	600UL
2083	96	35							TECTEH			21H00037	600UL
2084	98	35	0.99	174	INR	3	04C	+18.80	TECTEH			21H00038	600UL
2085	100	35							TECTEH			21H00037	600UL
2086	102	35							TECTEH			21H00038	600UL
2087	104	35							TECTEH			21H00037	600UL
2088	106	35							TECTEH			21H00038	600UL
2089	108	35							TECTEH			21H00037	600UL
2090	110	35							TECTEH			21H00038	600UL
2091	112	35	0.47	77	INR	6	TSH	+13.03	TECTEH			21H00037	600UL
2092			0.40	85	INR	6	02H	+14.37	TECTEH			21H00037	600UL
2093					INF		F07	+0.00	TECTEH	HR		21H00037	600UL
2094			0.59	58	INR	6	F09	+0.15	TECTEH			21H00037	600UL
2095	1	36							TECTEH			21H00028	600UL
2096	3	36							TECTEH			21H00028	600UL
2097	5	36							TECTEH			21H00026	600UL
2098	7	36							TECTEH			21H00026	600UL
2099	9	36							TECTEH			21H00022	600UL
2100	11	36							TECTEH			21H00021	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2101	13	36							TECTEH			21H00022	600UL
2102	15	36							TECTEH			21H00021	600UL
2103	17	36							TECTEH			21H00022	600UL
2104	19	36	0.84	73	INR	6	04H	+26.47	TECTEH			21H00021	600UL
2105	21	36	2.86	184	INR	3	F01	+8.07	TECTEH			21H00022	600UL
2106					INF		F05	+5.92	TECTEH	HR		21H00022	600UL
2107	23	36							TECTEH			21H00021	600UL
2108	25	36							TECTEH			21H00018	600UL
2109	27	36							TECTEH			21H00017	600UL
2110	29	36			NDF	3	TEH	+17.46	TEHTSH			21H00051	610PP
2111					NDF	3	TEH	+19.51	TEHTSH			21H00051	610PP
2112			0.50	76	INR	6	F12	+5.62	TECTEH			21H00018	600UL
2113					INF		07C	+0.34	TECTEH	HR		21H00018	600UL
2114			0.18	126	INR	3	06C	+9.23	TECTEH			21H00018	600UL
2115			0.37	141	INR	3	04C	+36.71	TECTEH			21H00018	600UL
2116			0.47	124	INR	3	02C	+4.75	TECTEH			21H00018	600UL
2117			0.47	125	INR	3	02C	+36.41	TECTEH			21H00018	600UL
2118	31	36	0.88	76	INR	6	02C	+4.89	TECTEH			21H00017	600UL
2119			0.48	92	INR	6	02C	+22.06	TECTEH			21H00017	600UL
2120			0.66	73	INR	6	01C	+3.78	TECTEH			21H00017	600UL
2121			0.45	93	INR	6	01C	+24.07	TECTEH			21H00017	600UL
2122	33	36							TECTEH			21H00018	600UL
2123	35	36							TECTEH			21H00017	600UL
2124	37	36							TECTEH			21H00018	600UL
2125	39	36	0.77	88	INR	6	03C	+17.61	TECTEH			21H00017	600UL
2126	41	36							TECTEH			21H00018	600UL
2127	43	36							TECTEH			21H00017	600UL
2128	45	36	0.36	113	INR	3	F08	+2.58	TECTEH			21H00018	600UL
2129					INF		F09	+9.57	TECTEH	HR		21H00018	600UL
2130	47	36	0.53	80	INR	6	TSH	+3.11	TECTEH			21H00017	600UL
2131			0.47	80	INR	6	TSH	+5.36	TECTEH			21H00017	600UL
2132	49	36							TECTEH			21H00017	600UL
2133	51	36							TECTEH			21H00032	600UL
2134	53	36							TECTEH			21H00031	600UL
2135					NDF	3	TSH	-1.19	TSHTSH			21H00051	610PP
2136	55	36							TECTEH			21H00032	600UL
2137	57	36	0.31	97	NQH	3	06H	+12.43	TECTEH			21H00031	600UL
2138	59	36							TECTEH			21H00032	600UL
2139	61	36							TECTEH			21H00031	600UL
2140	63	36	0.27	67	INR	6	TSH	+17.51	TECTEH			21H00032	600UL
2141	65	36	0.31	109	NQH	3	01C	+15.27	TECTEH			21H00031	600UL
2142	67	36	0.52	102	NQH	3	F06	+6.89	TECTEH			21H00032	600UL
2143			0.66	158	INR	3	F07	+11.91	TECTEH			21H00032	600UL
2144			0.28	88	INR	6	F08	+5.86	TECTEH			21H00032	600UL
2145					INF		F08	+8.77	TECTEH	HR		21H00032	600UL
2146					INF		F09	+3.30	TECTEH	HR		21H00032	600UL
2147			0.57	68	INR	6	TSC	+2.54	TECTEH			21H00032	600UL
2148	69	36	0.44	74	INR	6	01H	+14.07	TECTEH			21H00031	600UL
2149	71	36							TECTEH			21H00032	600UL
2150	73	36							TECTEH			21H00031	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2151	75	36	1.10	108	INR	6	F08	+1.70	TO+18.01	TECTEH			21H00032	600UL
2152					INF		F09	+0.00	TO+5.04	TECTEH	HR		21H00032	600UL
2153	77	36								TECTEH			21H00031	600UL
2154	79	36								TECTEH			21H00032	600UL
2155	81	36								TECTEH			21H00031	600UL
2156	83	36								TECTEH			21H00038	600UL
2157	85	36								TECTEH			21H00037	600UL
2158	87	36	0.46	133	INR	3	02H	+20.67		TECTEH			21H00038	600UL
2159	89	36								TECTEH			21H00037	600UL
2160	91	36								TECTEH			21H00038	600UL
2161	93	36								TECTEH			21H00037	600UL
2162	95	36	0.24	91	INR	3	04C	+4.28		TECTEH			21H00038	600UL
2163	97	36								TECTEH			21H00037	600UL
2164	99	36								TECTEH			21H00038	600UL
2165	101	36								TECTEH			21H00037	600UL
2166	103	36								TECTEH			21H00038	600UL
2167	105	36								TECTEH			21H00037	600UL
2168	107	36	0.38	134	INR	3	01H	+13.63		TECTEH			21H00038	600UL
2169			0.41	140	INR	3	06H	+18.80		TECTEH			21H00038	600UL
2170			1.08	112	INR	3	F10	+3.96		TECTEH			21H00038	600UL
2171					INF		F11	+12.37		TECTEH	HR		21H00038	600UL
2172			0.50	119	INR	3	06C	+38.88		TECTEH			21H00038	600UL
2173			0.61	137	INR	3	05C	+22.10		TECTEH			21H00038	600UL
2174	109	36	0.37	112	NQH	3	04H	+12.11		TECTEH			21H00037	600UL
2175			0.35	79	INR	6	05H	+27.09		TECTEH			21H00037	600UL
2176			0.72	64	INR	6	F06	+7.45		TECTEH			21H00037	600UL
2177			1.04	79	INR	6	06C	+11.07		TECTEH			21H00037	600UL
2178			0.87	77	INR	6	01C	+14.69		TECTEH			21H00037	600UL
2179	111	36	0.60	145	INR	3	F05	+5.15		TECTEH			21H00038	600UL
2180			0.31	170	INR	3	F05	+6.46		TECTEH			21H00038	600UL
2181			0.38	90	INR	3	F08	+16.56		TECTEH			21H00038	600UL
2182					INF		F09	+2.32		TECTEH	HR		21H00038	600UL
2183	113	36								TECTEH			21H00037	600UL
2184	115	36								TECTEH			21H00037	600UL
2185	2	37								TECTEH			21H00028	600UL
2186	4	37	0.67	74	INR	6	01C	+30.85		TECTEH			21H00026	600UL
2187	6	37								TECTEH			21H00026	600UL
2188	8	37								TECTEH			21H00022	600UL
2189	10	37								TECTEH			21H00021	600UL
2190	12	37								TECTEH			21H00022	600UL
2191	14	37	0.38	68	INR	6	06C	+38.32		TECTEH			21H00021	600UL
2192	16	37								TECTEH			21H00022	600UL
2193	18	37								TECTEH			21H00021	600UL
2194	20	37								TECTEH			21H00022	600UL
2195	22	37	4.32	187	INR	1	F05	+2.68		TECTEH			21H00021	600UL
2196	24	37								TECTEH			21H00021	600UL
2197	26	37								TECTEH			21H00018	600UL
2198	28	37								TECTEH			21H00017	600UL
2199	30	37	0.45	145	INR	3	06H	+9.67		TECTEH			21H00018	600UL
2200	32	37								TECTEH			21H00017	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2201	34	37							TECTEH			21H00018	600UL
2202	36	37							TECTEH			21H00017	600UL
2203	38	37							TECTEH			21H00018	600UL
2204	40	37	0.80	68	INR	6	02H	-0.26	TECTEH			21H00017	600UL
2205	42	37							TECTEH			21H00018	600UL
2206	44	37							TECTEH			21H00017	600UL
2207	46	37							TECTEH			21H00018	600UL
2208	48	37							TECTEH			21H00017	600UL
2209	50	37							TECTEH			21H00032	600UL
2210	52	37	0.46	79	INR	6	03H	+20.75	TECTEH			21H00031	600UL
2211	54	37							TECTEH			21H00032	600UL
2212	56	37	0.48	61	INR	6	07H	+5.92	TECTEH			21H00031	600UL
2213	58	37							TECTEH			21H00032	600UL
2214	60	37							TECTEH			21H00031	600UL
2215	62	37	0.41	51	INR	6	04C	+27.76	TECTEH			21H00032	600UL
2216			0.46	79	INR	6	03C	+27.66	TECTEH			21H00032	600UL
2217	64	37							TECTEH			21H00031	600UL
2218	66	37			INF		02C	+26.39	TECTEH	HR		21H00032	600UL
2219			0.53	63	INR	6	02C	+28.04	TECTEH			21H00032	600UL
2220	68	37							TECTEH			21H00031	600UL
2221	70	37	0.44	74	INR	6	TSH	+16.84	TECTEH			21H00032	600UL
2222			0.59	82	INR	6	06C	+12.05	TECTEH			21H00032	600UL
2223			0.79	79	INR	6	04C	+38.26	TECTEH			21H00032	600UL
2224			0.56	81	INR	6	TSC	+2.68	TECTEH			21H00032	600UL
2225	72	37							TECTEH			21H00031	600UL
2226	74	37							TECTEH			21H00032	600UL
2227	76	37							TECTEH			21H00031	600UL
2228	78	37							TECTEH			21H00032	600UL
2229	80	37							TECTEH			21H00031	600UL
2230	82	37	0.54	124	INR	3	01H	+32.15	TECTEH			21H00038	600UL
2231	84	37							TECTEH			21H00037	600UL
2232	86	37							TECTEH			21H00038	600UL
2233	88	37							TECTEH			21H00037	600UL
2234	90	37							TECTEH			21H00038	600UL
2235	92	37	0.77	62	INR	6	F08	+12.50	TECTEH			21H00037	600UL
2236					INF		F09	+4.44	TECTEH	HR		21H00037	600UL
2237					INF		F09	+9.52	TECTEH	HR		21H00037	600UL
2238	94	37							TECTEH			21H00038	600UL
2239	96	37							TECTEH			21H00037	600UL
2240	98	37							TECTEH			21H00038	600UL
2241	100	37	0.37	81	INR	6	TSH	+17.57	TECTEH			21H00037	600UL
2242	102	37							TECTEH			21H00038	600UL
2243	104	37	0.42	73	INR	6	04H	+38.66	TECTEH			21H00037	600UL
2244			0.42	79	INR	6	05H	+16.28	TECTEH			21H00037	600UL
2245			0.50	85	INR	6	05H	+29.07	TECTEH			21H00037	600UL
2246			0.58	106	INR	6	F09	+0.00	TECTEH			21H00037	600UL
2247			0.71	76	INR	6	06C	+21.13	TECTEH			21H00037	600UL
2248			0.35	84	INR	6	02C	+37.41	TECTEH			21H00037	600UL
2249	106	37	0.88	132	INR	3	02C	+33.19	TECTEH			21H00038	600UL
2250	108	37							TECTEH			21H00037	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2251	110	37								TECTEH			21H00038	600UL
2252	112	37	0.32	84	INR	6	F04	+3.00		TECTEH			21H00037	600UL
2253	114	37								TECTEH			21H00038	600UL
2254	116	37	0.40	68	INR	6	TSC	+2.64		TECTEH			21H00037	600UL
2255	1	38								TECTEH			21H00028	600UL
2256	3	38								TECTEH			21H00028	600UL
2257	5	38	0.65	75	INR	6	03C	+4.48		TECTEH			21H00026	600UL
2258	7	38								TECTEH			21H00026	600UL
2259	9	38								TECTEH			21H00022	600UL
2260	11	38	0.43	77	INR	6	05H	+12.07		TECTEH			21H00021	600UL
2261			0.53	87	INR	6	TSC	+11.65		TECTEH			21H00021	600UL
2262			0.96	76	INR	6	TSC	+12.98		TECTEH			21H00021	600UL
2263			1.05	86	INR	6	TSC	+15.94		TECTEH			21H00021	600UL
2264	13	38								TECTEH			21H00022	600UL
2265	15	38								TECTEH			21H00021	600UL
2266	17	38	0.50	88	INR	6	03C	+37.53		TECTEH			21H00022	600UL
2267	19	38								TECTEH			21H00021	600UL
2268	21	38			INF		07H	+5.54		TECTEH	HR		21H00022	600UL
2269					INF		07H	+8.08		TECTEH	HR		21H00022	600UL
2270	23	38								TECTEH			21H00021	600UL
2271	25	38	0.35	109	INR	3	06C	+31.14		TECTEH			21H00018	600UL
2272	27	38	0.45	77	INR	6	01H	+13.42		TECTEH			21H00017	600UL
2273	29	38								TECTEH			21H00018	600UL
2274	31	38	2.68		ADS	6	05H	+5.00	TO+21.57	TECTEH			21H00017	600UL
2275	33	38								TECTEH			21H00018	600UL
2276	35	38								TECTEH			21H00017	600UL
2277	37	38								TECTEH			21H00018	600UL
2278	39	38								TECTEH			21H00017	600UL
2279	41	38								TECTEH			21H00018	600UL
2280	43	38								TECTEH			21H00017	600UL
2281	45	38								TECTEH			21H00018	600UL
2282	47	38								TECTEH			21H00017	600UL
2283	49	38								TECTEH			21H00017	600UL
2284	51	38								TECTEH			21H00032	600UL
2285	53	38								TECTEH			21H00031	600UL
2286	55	38	1.06	81	INR	6	TSC	+3.68		TECTEH			21H00032	600UL
2287	57	38								TECTEH			21H00031	600UL
2288	59	38	0.62	82	INR	6	04C	+15.10		TECTEH			21H00032	600UL
2289	61	38								TECTEH			21H00031	600UL
2290	63	38								TECTEH			21H00032	600UL
2291	65	38								TECTEH			21H00031	600UL
2292	67	38								TECTEH			21H00032	600UL
2293	69	38	1.97	184	INR	1	02C	+1.16		TECTEH			21H00031	600UL
2294	71	38	0.59	69	INR	6	05C	+5.29		TECTEH			21H00032	600UL
2295	73	38								TECTEH			21H00031	600UL
2296	75	38								TECTEH			21H00032	600UL
2297	77	38								TECTEH			21H00031	600UL
2298	79	38								TECTEH			21H00032	600UL
2299	81	38								TECTEH			21H00031	600UL
2300	83	38								TECTEH			21H00038	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2301	85	38							TECTEH			21H00037	600UL
2302	87	38	0.44	141	INR	3	05H	+28.39	TECTEH			21H00038	600UL
2303	89	38							TECTEH			21H00037	600UL
2304	91	38							TECTEH			21H00038	600UL
2305	93	38							TECTEH			21H00037	600UL
2306	95	38							TECTEH			21H00038	600UL
2307	97	38							TECTEH			21H00037	600UL
2308	99	38							TECTEH			21H00038	600UL
2309	101	38							TECTEH			21H00037	600UL
2310	103	38							TECTEH			21H00038	600UL
2311	105	38							TECTEH			21H00037	600UL
2312	107	38	0.50	157	INR	3	F08	+9.57	TECTEH			21H00038	600UL
2313					INF		F09	+5.55	TECTEH	HR		21H00038	600UL
2314	109	38							TECTEH			21H00037	600UL
2315	111	38	0.44	39	INR	3	F08	+13.79	TECTEH			21H00038	600UL
2316					INF		F09	+1.99	TECTEH	HR		21H00038	600UL
2317	113	38							TECTEH			21H00037	600UL
2318	115	38							TECTEH			21H00038	600UL
2319	117	38	0.63	76	INR	6	06H	+20.54	TECTEH			21H00037	600UL
2320	2	39							TECTEH			21H00028	600UL
2321	4	39							TECTEH			21H00026	600UL
2322	6	39							TECTEH			21H00026	600UL
2323	8	39							TECTEH			21H00022	600UL
2324	10	39							TECTEH			21H00021	600UL
2325	12	39							TECTEH			21H00022	600UL
2326	14	39							TECTEH			21H00021	600UL
2327	16	39							TECTEH			21H00022	600UL
2328	18	39							TECTEH			21H00021	600UL
2329	20	39							TECTEH			21H00022	600UL
2330	22	39	4.29	186	INR	1	F05	+1.87	TECTEH			21H00021	600UL
2331	24	39	0.39	78	INR	6	02H	+4.16	TECTEH			21H00021	600UL
2332	26	39	0.49	124	INR	3	05H	+34.90	TECTEH			21H00018	600UL
2333	28	39							TECTEH			21H00017	600UL
2334	30	39	0.51	163	INR	3	F06	+10.31	TECTEH			21H00018	600UL
2335					INF		F07	+3.65	TECTEH	HR		21H00018	600UL
2336	32	39							TECTEH			21H00017	600UL
2337	34	39							TECTEH			21H00018	600UL
2338	36	39							TECTEH			21H00017	600UL
2339	38	39							TECTEH			21H00018	600UL
2340	40	39							TECTEH			21H00017	600UL
2341	42	39							TECTEH			21H00018	600UL
2342	44	39			INF		F02	+6.89	TECTEH	HR		21H00017	600UL
2343			0.60	72	INR	6	F04	+7.07	TECTEH			21H00017	600UL
2344			0.38	78	INR	6	01C	+24.83	TECTEH			21H00017	600UL
2345	46	39							TECTEH			21H00018	600UL
2346	48	39							TECTEH			21H00017	600UL
2347	50	39							TECTEH			21H00032	600UL
2348	52	39	0.46	71	INR	6	07H	+7.94	TECTEH			21H00031	600UL
2349			0.74	74	INR	6	04C	+24.05	TECTEH			21H00031	600UL
2350	54	39							TECTEH			21H00032	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2351	56	39	0.59	71	INR	6	F06	+9.15	TECTEH			21H00031	600UL
2352					INF		F07	+6.15	TECTEH	HR		21H00031	600UL
2353			0.37	78	INR	6	06C	+37.91	TECTEH			21H00031	600UL
2354			0.40	102	INR	3	03C	+30.30	TECTEH			21H00031	600UL
2355	58	39	1.44	82	INR	6	02H	+38.09	TECTEH			21H00032	600UL
2356	60	39	0.39	76	INR	6	03H	+26.89	TECTEH			21H00031	600UL
2357			0.43	77	INR	6	04H	+22.78	TECTEH			21H00031	600UL
2358			0.50	75	INR	6	05H	+8.97	TECTEH			21H00031	600UL
2359			0.42	70	INR	6	TSC	+20.36	TECTEH			21H00031	600UL
2360	62	39							TECTEH			21H00032	600UL
2361	64	39	0.75	76	INR	6	06C	+30.30	TECTEH			21H00031	600UL
2362	66	39							TECTEH			21H00032	600UL
2363	68	39	0.23	138	INR	3	05C	+12.96	TECTEH			21H00031	600UL
2364			0.50	105	INR	6	05C	+18.44	TECTEH			21H00031	600UL
2365			0.49	72	INR	6	03C	+17.90	TECTEH			21H00031	600UL
2366	70	39							TECTEH			21H00032	600UL
2367	72	39							TECTEH			21H00031	600UL
2368	74	39							TECTEH			21H00032	600UL
2369	76	39							TECTEH			21H00031	600UL
2370	78	39							TECTEH			21H00032	600UL
2371	80	39							TECTEH			21H00031	600UL
2372	82	39	0.25	118	INR	3	06C	+18.82	TECTEH			21H00038	600UL
2373			0.64	128	INR	3	01C	+31.87	TECTEH			21H00038	600UL
2374	84	39							TECTEH			21H00038	600UL
2375	86	39							TECTEH			21H00037	600UL
2376	88	39	0.30	121	INR	3	01H	+17.22	TECTEH			21H00038	600UL
2377	90	39							TECTEH			21H00037	600UL
2378	92	39							TECTEH			21H00038	600UL
2379	94	39							TECTEH			21H00037	600UL
2380	96	39	0.39	131	INR	3	01H	+18.36	TECTEH			21H00038	600UL
2381			0.37	122	INR	3	06C	+2.75	TECTEH			21H00038	600UL
2382			0.36	136	INR	3	02C	+13.16	TECTEH			21H00038	600UL
2383			0.49	134	INR	3	02C	+30.36	TECTEH			21H00038	600UL
2384	98	39	0.38	58	INR	6	04H	+34.91	TECTEH			21H00037	600UL
2385			1.27	63	INR	6	F03	+0.43	TECTEH			21H00037	600UL
2386	100	39							TECTEH			21H00038	600UL
2387	102	39							TECTEH			21H00037	600UL
2388	104	39							TECTEH			21H00038	600UL
2389	106	39			INF		F03	+3.80	TECTEH	HR		21H00037	600UL
2390			1.16	58	INR	6	F03	+4.88	TECTEH			21H00037	600UL
2391	108	39	0.27	113	INR	3	06H	+2.53	TECTEH			21H00038	600UL
2392	110	39							TECTEH			21H00037	600UL
2393	112	39							TECTEH			21H00038	600UL
2394	114	39							TECTEH			21H00037	600UL
2395	116	39							TECTEH			21H00038	600UL
2396	118	39							TECTEH			21H00037	600UL
2397	1	40							TECTEH			21H00028	600UL
2398	3	40							TECTEH			21H00028	600UL
2399	5	40	0.44	86	INR	6	04H	+34.38	TECTEH			21H00026	600UL
2400	7	40							TECTEH			21H00026	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2401	9	40							TECTEH			21H00022	600UL
2402	11	40							TECTEH			21H00021	600UL
2403	13	40							TECTEH			21H00022	600UL
2404	15	40							TECTEH			21H00021	600UL
2405	17	40							TECTEH			21H00022	600UL
2406	19	40							TECTEH			21H00021	600UL
2407	21	40	4.78	183	INR	3	F01	+8.05	TECTEH			21H00022	600UL
2408					INF		F05	+6.02	TECTEH	HR		21H00022	600UL
2409	23	40	0.34	47	INR	6	06H	+3.68	TECTEH			21H00021	600UL
2410	25	40							TECTEH			21H00018	600UL
2411	27	40	0.37	79	INR	6	01C	+9.56	TECTEH			21H00017	600UL
2412	29	40							TECTEH			21H00018	600UL
2413	31	40							TECTEH			21H00017	600UL
2414	33	40							TECTEH			21H00018	600UL
2415	35	40							TECTEH			21H00017	600UL
2416	37	40	0.28	100	INR	3	04C	+36.08	TECTEH			21H00018	600UL
2417	39	40							TECTEH			21H00017	600UL
2418	41	40							TECTEH			21H00018	600UL
2419	43	40							TECTEH			21H00017	600UL
2420	45	40	0.21	151	INR	3	01H	+23.28	TECTEH			21H00018	600UL
2421	47	40							TECTEH			21H00017	600UL
2422	49	40							TECTEH			21H00017	600UL
2423	51	40	0.54	83	INR	6	04C	+23.30	TECTEH			21H00034	600UL
2424	53	40	0.44	84	INR	6	03H	+23.41	TECTEH			21H00033	600UL
2425			0.37	78	INR	6	04H	+20.47	TECTEH			21H00033	600UL
2426			0.37	69	INR	6	06H	+2.91	TECTEH			21H00033	600UL
2427			0.44	80	INR	6	06H	+11.06	TECTEH			21H00033	600UL
2428			0.53	85	INR	6	F07	+8.27	TECTEH			21H00033	600UL
2429					INF		F08	+4.84	TECTEH	HR		21H00033	600UL
2430	55	40							TECTEH			21H00034	600UL
2431	57	40	0.39	70	INR	6	04H	+36.51	TECTEH			21H00033	600UL
2432					INF		F05	+6.31	TECTEH	HR		21H00033	600UL
2433			0.57	82	INR	6	F07	+7.21	TECTEH			21H00033	600UL
2434			0.43	63	INR	6	05C	+17.88	TECTEH			21H00033	600UL
2435			0.59	84	INR	6	03C	+6.31	TECTEH			21H00033	600UL
2436	59	40							TECTEH			21H00034	600UL
2437	61	40							TECTEH			21H00033	600UL
2438	63	40							TECTEH			21H00034	600UL
2439	65	40							TECTEH			21H00033	600UL
2440	67	40	0.42	45	INR	6	F06	+12.23	TECTEH			21H00034	600UL
2441					INF		F07	+0.05	TECTEH	HR		21H00034	600UL
2442	69	40	0.42	65	INR	6	06C	+33.02	TECTEH			21H00033	600UL
2443	71	40							TECTEH			21H00032	600UL
2444	73	40							TECTEH			21H00031	600UL
2445	75	40							TECTEH			21H00032	600UL
2446	77	40	0.67	72	INR	6	01C	+23.62	TECTEH			21H00031	600UL
2447	79	40							TECTEH			21H00032	600UL
2448	81	40							TECTEH			21H00031	600UL
2449	83	40							TECTEH			21H00036	600UL
2450	85	40							TECTEH			21H00035	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2451	87	40							TECTEH			21H00036	600UL
2452	89	40							TECTEH			21H00035	600UL
2453	91	40							TECTEH			21H00036	600UL
2454	93	40							TECTEH			21H00035	600UL
2455	95	40							TECTEH			21H00038	600UL
2456	97	40							TECTEH			21H00037	600UL
2457	99	40							TECTEH			21H00038	600UL
2458	101	40							TECTEH			21H00037	600UL
2459	103	40	0.40	131	INR	3	03H	+35.90	TECTEH			21H00038	600UL
2460			0.33	105	INR	3	03H	+37.05	TECTEH			21H00038	600UL
2461			0.29	75	INR	3	04H	+14.91	TECTEH			21H00038	600UL
2462			0.38	127	INR	3	06C	+35.16	TECTEH			21H00038	600UL
2463			0.47	122	INR	3	02C	+9.26	TECTEH			21H00038	600UL
2464	105	40							TECTEH			21H00037	600UL
2465	107	40							TECTEH			21H00038	600UL
2466	109	40							TECTEH			21H00037	600UL
2467	111	40							TECTEH			21H00038	600UL
2468	113	40							TECTEH			21H00037	600UL
2469	115	40							TECTEH			21H00038	600UL
2470	117	40							TECTEH			21H00037	600UL
2471	119	40							TECTEH			21H00037	600UL
2472	2	41							TECTEH			21H00028	600UL
2473	4	41							TECTEH			21H00026	600UL
2474	6	41							TECTEH			21H00026	600UL
2475	8	41							TECTEH			21H00022	600UL
2476	10	41							TECTEH			21H00021	600UL
2477	12	41							TECTEH			21H00022	600UL
2478	14	41	0.44	37	INR	6	F07	+0.00	TECTEH			21H00021	600UL
2479	16	41	0.70	72	INR	6	TSC	+4.55	TECTEH			21H00022	600UL
2480	18	41							TECTEH			21H00021	600UL
2481	20	41	2.69	184	INR	3	F01	+7.92	TECTEH			21H00022	600UL
2482					INF		F05	+5.69	TECTEH	HR		21H00022	600UL
2483	22	41							TECTEH			21H00021	600UL
2484	24	41	0.44	135	INR	3	03H	+34.02	TECTEH			21H00018	600UL
2485			0.37	91	INR	6	03H	+35.02	TECTEH	IDOK		21H00021	600UL
2486			4.04	185	INR	P1	F05	-0.36	TECTEH	IDOK		21H00021	600UL
2487			4.25	181	INR	P1	F05	-0.27	TECTEH			21H00018	600UL
2488					INF		F05	+1.55	TECTEH	HR		21H00021	600UL
2489					INF		F05	+1.55	TECTEH	HR		21H00018	600UL
2490	26	41							TECTEH			21H00017	600UL
2491	28	41	0.24	101	INR	3	02H	+4.88	TECTEH			21H00018	600UL
2492	30	41							TECTEH			21H00017	600UL
2493	34	41							TECTEH			21H00018	600UL
2494	36	41							TECTEH			21H00017	600UL
2495	38	41							TECTEH			21H00018	600UL
2496	40	41							TECTEH			21H00017	600UL
2497	42	41	0.40	130	INR	3	06C	+7.42	TECTEH			21H00018	600UL
2498	44	41							TECTEH			21H00017	600UL
2499	46	41							TECTEH			21H00018	600UL
2500	48	41	2.25		ADS	6	01H	+23.43 TO+32.26	TECTEH			21H00017	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2501	50	41	0.71	83	INR	6	03H	+14.70	TECTEH			21H00034	600UL
2502	52	41							TECTEH			21H00033	600UL
2503	54	41	0.92	70	INR	6	04H	+21.96	TECTEH			21H00034	600UL
2504	56	41			INF		02H	+22.14	TECTEH	HR		21H00033	600UL
2505			0.19	55	INR	6	02H	+34.93	TECTEH			21H00033	600UL
2506					INF		03H	+11.34	TECTEH	HR		21H00033	600UL
2507			1.37	78	INR	6	04H	+17.92 TO+26.90	TECTEH			21H00033	600UL
2508			0.48	44	INR	6	F09	+7.85	TECTEH			21H00033	600UL
2509					INF		F10	+0.00	TECTEH	HR		21H00033	600UL
2510			1.01	78	INR	6	03C	+11.06	TECTEH			21H00033	600UL
2511			0.74	78	INR	6	02C	+25.27	TECTEH			21H00033	600UL
2512	58	41	0.62	58	INR	6	06H	+28.56	TECTEH			21H00034	600UL
2513	60	41	0.63	80	INR	6	TSC	+4.26	TECTEH			21H00033	600UL
2514	64	41	0.49	73	INR	6	02H	+20.31	TECTEH			21H00034	600UL
2515	66	41	0.39	63	INR	6	F06	+2.83	TECTEH			21H00033	600UL
2516					INF		F07	+3.00	TECTEH	HR		21H00033	600UL
2517	68	41							TECTEH			21H00034	600UL
2518	70	41							TECTEH			21H00033	600UL
2519	72	41							TECTEH			21H00034	600UL
2520	74	41			INF		06C	+33.75	TECTEH	HR		21H00033	600UL
2521			0.39	81	INR	6	06C	+37.55	TECTEH			21H00033	600UL
2522	76	41							TECTEH			21H00034	600UL
2523	78	41							TECTEH			21H00033	600UL
2524	80	41							TECTEH			21H00033	600UL
2525	82	41							TECTEH			21H00036	600UL
2526	84	41							TECTEH			21H00036	600UL
2527	86	41							TECTEH			21H00035	600UL
2528	88	41							TECTEH			21H00036	600UL
2529	90	41							TECTEH			21H00035	600UL
2530	94	41							TECTEH			21H00036	600UL
2531	96	41	0.25	143	INR	3	02H	+23.95	TECTEH			21H00035	600UL
2532			0.33	127	INR	3	02H	+25.81	TECTEH			21H00035	600UL
2533			0.40	54	INR	6	F12	+0.00	TECTEH			21H00035	600UL
2534					INF		F12	+2.18	TECTEH	HR		21H00035	600UL
2535			0.21	336	INR	3	02C	+15.38	TECTEH			21H00035	600UL
2536			0.48	135	INR	3	02C	+19.06	TECTEH			21H00035	600UL
2537	98	41							TECTEH			21H00036	600UL
2538	100	41							TECTEH			21H00035	600UL
2539	102	41							TECTEH			21H00036	600UL
2540	104	41							TECTEH			21H00035	600UL
2541	106	41							TECTEH			21H00036	600UL
2542	108	41							TECTEH			21H00035	600UL
2543	110	41							TECTEH			21H00036	600UL
2544	112	41							TECTEH			21H00035	600UL
2545	114	41							TECTEH			21H00036	600UL
2546	116	41							TECTEH			21H00035	600UL
2547	118	41							TECTEH			21H00036	600UL
2548	120	41							TECTEH			21H00035	600UL
2549	1	42							TECTEH			21H00028	600UL
2550	3	42							TECTEH			21H00028	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2551	5	42	0.27	108	INR	3	06C	+20.28	TECTEH			21H00026	600UL
2552			0.57	71	INR	6	01C	+32.70	TECTEH			21H00026	600UL
2553	7	42	0.46	73	INR	6	06C	+7.75	TECTEH			21H00026	600UL
2554			0.81	83	INR	6	03C	+13.87	TECTEH			21H00026	600UL
2555			0.37	81	INR	6	03C	+16.23	TECTEH			21H00026	600UL
2556	9	42	0.37	80	INR	6	01C	+7.68	TECTEH			21H00022	600UL
2557	11	42							TECTEH			21H00021	600UL
2558	13	42	0.58	77	INR	6	02H	+19.78	TECTEH			21H00022	600UL
2559	15	42							TECTEH			21H00021	600UL
2560	17	42							TECTEH			21H00022	600UL
2561	19	42							TECTEH			21H00021	600UL
2562	21	42			INF		02C	+15.55	TECTEH	PVI		21H00022	600UL
2563	23	42	4.15	187	INR	1	F05	+1.25	TECTEH			21H00021	600UL
2564			0.55	89	INR	6	06C	+32.02	TECTEH			21H00021	600UL
2565	25	42							TECTEH			21H00018	600UL
2566	27	42	1.16	19	INR	6	F06	+0.08	TECTEH			21H00017	600UL
2567	29	42							TECTEH			21H00017	600UL
2568	33	42	1.23	127	INR	3	TSH	+4.02	TECTEH			21H00018	600UL
2569			0.39	125	INR	3	TSH	+8.23	TECTEH			21H00018	600UL
2570			0.39	136	INR	3	TSH	+10.53	TECTEH			21H00018	600UL
2571			0.71	125	INR	3	02H	+12.56	TECTEH			21H00018	600UL
2572			0.57	132	INR	3	05H	+26.13	TECTEH			21H00018	600UL
2573	35	42							TECTEH			21H00017	600UL
2574	37	42							TECTEH			21H00018	600UL
2575	39	42	0.43	66	INR	6	05H	+28.92	TECTEH			21H00017	600UL
2576	41	42							TECTEH			21H00018	600UL
2577	43	42							TECTEH			21H00017	600UL
2578	45	42							TECTEH			21H00018	600UL
2579	47	42							TECTEH			21H00017	600UL
2580	49	42							TECTEH			21H00017	600UL
2581	51	42							TECTEH			21H00034	600UL
2582	53	42	0.76	76	INR	6	01C	+5.44	TECTEH			21H00034	600UL
2583	55	42							TECTEH			21H00033	600UL
2584	57	42	0.65	61	INR	6	01C	+3.89	TECTEH			21H00034	600UL
2585	59	42	0.55	78	INR	6	01H	+8.11	TECTEH			21H00033	600UL
2586			0.96	72	INR	6	02H	+37.91	TECTEH			21H00033	600UL
2587	63	42							TECTEH			21H00034	600UL
2588	65	42	0.54	60	INR	6	05H	+33.61	TECTEH			21H00033	600UL
2589			0.48	80	INR	6	03C	+19.50	TECTEH			21H00033	600UL
2590	67	42	0.55	72	INR	6	F12	+4.59	TECTEH			21H00034	600UL
2591					INF		07C	+9.08	TECTEH	HR		21H00034	600UL
2592			0.52	77	INR	6	04C	+29.49	TECTEH			21H00034	600UL
2593			0.53	63	INR	6	02C	+16.66	TECTEH			21H00034	600UL
2594	69	42							TECTEH			21H00033	600UL
2595	71	42							TECTEH			21H00034	600UL
2596	73	42							TECTEH			21H00033	600UL
2597	75	42							TECTEH			21H00034	600UL
2598	77	42							TECTEH			21H00033	600UL
2599	79	42	0.57	76	INR	6	03C	+32.40	TECTEH			21H00034	600UL
2600	81	42							TECTEH			21H00033	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2601	83	42	0.34	64	INR	6	02C	+10.68	TECTEH			21H00036	600UL
2602	85	42							TECTEH			21H00035	600UL
2603	87	42							TECTEH			21H00036	600UL
2604	89	42							TECTEH			21H00035	600UL
2605	93	42							TECTEH			21H00036	600UL
2606	95	42							TECTEH			21H00035	600UL
2607	97	42							TECTEH			21H00036	600UL
2608	99	42	0.74	70	INR	6	05H	+37.52	TECTEH			21H00035	600UL
2609	101	42							TECTEH			21H00036	600UL
2610	103	42							TECTEH			21H00035	600UL
2611	105	42							TECTEH			21H00036	600UL
2612	107	42							TECTEH			21H00035	600UL
2613					NDF	3	TSH	-0.34	TSHTSH			21H00051	610PP
2614	109	42	0.58	79	INR	6	F07	+8.50	TECTEH			21H00036	600UL
2615					INF		F08	+8.72	TECTEH	HR		21H00036	600UL
2616	111	42	0.53	58	INR	6	F03	+11.57	TECTEH			21H00035	600UL
2617	113	42	0.49	78	INR	6	TSC	+12.65	TECTEH			21H00036	600UL
2618	115	42							TECTEH			21H00035	600UL
2619	117	42							TECTEH			21H00036	600UL
2620	119	42							TECTEH			21H00035	600UL
2621	121	42							TECTEH			21H00035	600UL
2622	2	43							TECTEH			21H00028	600UL
2623	4	43	0.40	74	INR	6	02H	+14.56	TECTEH			21H00026	600UL
2624	6	43	0.37	74	INR	6	05C	+6.73	TECTEH			21H00026	600UL
2625	8	43							TECTEH			21H00022	600UL
2626	10	43							TECTEH			21H00021	600UL
2627	12	43							TECTEH			21H00022	600UL
2628	14	43							TECTEH			21H00021	600UL
2629	16	43	0.36	103	INR	6	02C	+4.65	TECTEH			21H00022	600UL
2630	18	43	0.30	70	INR	6	06C	+6.39	TECTEH			21H00021	600UL
2631	20	43							TECTEH			21H00022	600UL
2632	22	43	0.39	65	INR	6	06H	+30.10	TECTEH			21H00021	600UL
2633			4.88	186	INR	1	F05	+3.17	TECTEH			21H00021	600UL
2634	24	43							TECTEH			21H00021	600UL
2635	26	43							TECTEH			21H00017	600UL
2636	28	43							TECTEH			21H00018	600UL
2637	30	43							TECTEH			21H00018	600UL
2638	32	43							TECTEH			21H00017	600UL
2639	34	43							TECTEH			21H00018	600UL
2640	36	43							TECTEH			21H00017	600UL
2641	38	43							TECTEH			21H00018	600UL
2642	40	43							TECTEH			21H00017	600UL
2643	42	43							TECTEH			21H00028	600UL
2644					RIC				TSCTEH			21H00018	600UL
2645	44	43	0.44	77	INR	6	06C	+22.41	TECTEH			21H00017	600UL
2646	46	43							TECTEH			21H00018	600UL
2647	48	43	0.43	72	INR	6	06C	+8.10	TECTEH			21H00017	600UL
2648	50	43	0.36	80	INR	6	05C	+31.75	TECTEH			21H00034	600UL
2649	52	43							TECTEH			21H00033	600UL
2650	54	43	0.44	85	INR	6	TSH	+19.56	TECTEH			21H00034	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2651			0.45	76	INR	6	04C	+20.07	TECTEH			21H00034	600UL
2652	56	43	0.37	96	INR	3	06H	+17.63	TECTEH			21H00033	600UL
2653			0.35	72	INR	6	05C	+4.96	TECTEH			21H00033	600UL
2654			0.72	71	INR	6	03C	+12.10	TECTEH			21H00033	600UL
2655			0.54	79	INR	6	01C	+26.80	TECTEH			21H00033	600UL
2656	58	43							TECTEH			21H00034	600UL
2657	60	43							TECTEH			21H00033	600UL
2658	62	43							TECTEH			21H00034	600UL
2659	64	43	0.39	58	INR	6	F01	+0.08	TECTEH			21H00033	600UL
2660			0.37	36	INR	6	F03	+8.00	TECTEH			21H00033	600UL
2661	66	43							TECTEH			21H00034	600UL
2662	68	43							TECTEH			21H00033	600UL
2663	70	43	0.57	66	INR	6	01H	+32.76	TECTEH			21H00034	600UL
2664			0.68	80	INR	6	06C	+14.95	TECTEH			21H00034	600UL
2665			0.60	76	INR	6	TSC	+17.38	TECTEH			21H00034	600UL
2666	72	43							TECTEH			21H00033	600UL
2667	74	43	0.50	77	INR	6	02H	+27.84	TECTEH			21H00034	600UL
2668			0.49	75	INR	6	02C	+13.29	TECTEH			21H00034	600UL
2669			0.50	73	INR	6	01C	+9.28	TECTEH			21H00034	600UL
2670	76	43	0.51	83	INR	6	02C	+14.10	TECTEH			21H00033	600UL
2671	78	43	0.56	82	INR	6	04H	+36.78	TECTEH			21H00034	600UL
2672	80	43	0.54	78	INR	6	05H	+5.62	TECTEH			21H00033	600UL
2673	82	43							TECTEH			21H00036	600UL
2674	84	43	0.52	98	INR	6	F08	+4.32	TECTEH			21H00036	600UL
2675					INF		F09	+4.18	TECTEH	HR		21H00036	600UL
2676	86	43							TECTEH			21H00035	600UL
2677	88	43	0.69	56	INR	6	F04	+13.65	TECTEH			21H00036	600UL
2678	90	43							TECTEH			21H00035	600UL
2679	92	43							TECTEH			21H00036	600UL
2680	94	43	0.42	68	INR	6	01C	+17.38	TECTEH			21H00035	600UL
2681	96	43	0.21	73	INR	6	01C	+4.80	TECTEH			21H00036	600UL
2682	98	43	0.29	79	INR	6	03C	+37.40	TECTEH			21H00035	600UL
2683			0.84	81	INR	6	01C	+7.87	TECTEH			21H00035	600UL
2684	100	43	0.65	76	INR	6	05H	+7.11	TECTEH			21H00036	600UL
2685			1.17	78	INR	6	02C	+20.83	TECTEH			21H00036	600UL
2686	102	43	0.39	81	INR	6	04H	+27.87	TECTEH			21H00035	600UL
2687	104	43							TECTEH			21H00036	600UL
2688	106	43							TECTEH			21H00035	600UL
2689	108	43							TECTEH			21H00036	600UL
2690	110	43							TECTEH			21H00035	600UL
2691	112	43							TECTEH			21H00036	600UL
2692	114	43	0.41	72	INR	6	04C	+17.68	TECTEH			21H00035	600UL
2693	116	43	0.47	75	INR	6	05H	+27.45	TECTEH			21H00036	600UL
2694			0.34	89	INR	6	04C	+3.51	TECTEH			21H00036	600UL
2695	118	43							TECTEH			21H00035	600UL
2696	120	43							TECTEH			21H00036	600UL
2697	122	43							TECTEH			21H00035	600UL
2698	1	44							TECTEH			21H00028	600UL
2699	3	44							TECTEH			21H00028	600UL
2700	5	44							TECTEH			21H00026	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2701	7	44	0.52	72	INR	6	04C	+20.57	TECTEH			21H00026	600UL
2702	9	44							TECTEH			21H00022	600UL
2703	11	44							TECTEH			21H00021	600UL
2704	13	44							TECTEH			21H00022	600UL
2705	15	44							TECTEH			21H00021	600UL
2706	17	44							TECTEH			21H00022	600UL
2707	19	44							TECTEH			21H00021	600UL
2708	21	44	5.33	182	INR	P1	F01	+6.78	TECTEH			21H00022	600UL
2709			5.15	182	INR	P1	F05	+3.11	TECTEH			21H00022	600UL
2710					INF		F05	+5.29	TECTEH	HR		21H00022	600UL
2711	23	44							TECTEH			21H00021	600UL
2712	25	44							TECTEH			21H00018	600UL
2713	27	44							TECTEH			21H00017	600UL
2714	29	44							TECTEH			21H00018	600UL
2715	31	44							TECTEH			21H00017	600UL
2716	33	44							TECTEH			21H00018	600UL
2717	35	44	0.58	67	INR	6	TSH	+7.61	TECTEH			21H00017	600UL
2718	37	44							TECTEH			21H00018	600UL
2719	39	44	0.47	70	INR	6	03H	+11.61	TECTEH			21H00017	600UL
2720			0.48	83	INR	6	05C	+6.28	TECTEH			21H00017	600UL
2721			0.37	74	INR	6	05C	+9.79	TECTEH			21H00017	600UL
2722			0.80	79	INR	6	02C	+10.85	TECTEH			21H00017	600UL
2723			0.68	68	INR	6	TSC	+18.58	TECTEH			21H00017	600UL
2724	41	44							TECTEH			21H00018	600UL
2725	43	44							TECTEH			21H00017	600UL
2726	45	44	0.53	45	INR	6	05H	+8.11	TECTEH			21H00018	600UL
2727			0.70	144	INR	3	F05	+4.52	TECTEH			21H00018	600UL
2728	47	44							TECTEH			21H00017	600UL
2729	49	44							TECTEH			21H00018	600UL
2730	51	44	0.59	81	INR	6	02H	+25.81	TECTEH			21H00034	600UL
2731			0.64	77	INR	6	03H	+24.85	TECTEH			21H00034	600UL
2732	53	44							TECTEH			21H00033	600UL
2733	55	44							TECTEH			21H00034	600UL
2734	57	44	0.40	74	INR	6	04H	+25.41	TECTEH			21H00033	600UL
2735	59	44							TECTEH			21H00034	600UL
2736	61	44							TECTEH			21H00033	600UL
2737	63	44							TECTEH			21H00034	600UL
2738	65	44	1.00	73	INR	6	TSC	+11.70	TECTEH			21H00033	600UL
2739	67	44	16.90	179	DNG	1	TSH	+13.84	TECTEH			21H00034	600UL
2740					NDF	3	TSH	+13.84	TSH01H			21H00051	610PP
2741	69	44	0.42	81	INR	6	02C	+19.06	TECTEH			21H00033	600UL
2742			0.82	82	INR	6	TSC	+2.77	TECTEH			21H00033	600UL
2743	71	44							TECTEH			21H00034	600UL
2744	73	44	0.39	111	INR	3	F06	+2.09	TECTEH			21H00033	600UL
2745			0.42	76	INR	6	01C	+29.11	TECTEH			21H00033	600UL
2746	75	44							TECTEH			21H00034	600UL
2747	77	44			INF		F05	+8.03	TECTEH	HR		21H00033	600UL
2748			0.47	94	INR	6	F05	+9.07	TECTEH			21H00033	600UL
2749	79	44	1.12	73	INR	6	04H	+21.84	TECTEH			21H00034	600UL
2750			0.93	79	INR	6	04H	+24.11	TECTEH			21H00034	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2751			0.42	73	INR	6	06C	+15.83	TECTEH			21H00034	600UL
2752			0.94	71	INR	6	05C	+22.21	TECTEH			21H00034	600UL
2753			0.83	73	INR	6	01C	+33.02	TECTEH			21H00034	600UL
2754					INF		01C	+39.67	TECTEH	HR		21H00034	600UL
2755	81	44							TECTEH			21H00033	600UL
2756	83	44							TECTEH			21H00036	600UL
2757	85	44	0.33	75	INR	6	F12	+8.55	TECTEH			21H00035	600UL
2758					INF		07C	+5.11	TECTEH	HR		21H00035	600UL
2759			0.33	71	INR	6	06C	+8.94	TECTEH			21H00035	600UL
2760	87	44	0.49	81	INR	6	03H	+32.30	TECTEH			21H00036	600UL
2761			0.93	80	INR	6	05H	+30.96	TECTEH			21H00036	600UL
2762			0.74	34	INR	6	F08	+13.18	TECTEH			21H00036	600UL
2763					INF		F09	+0.14	TECTEH	HR		21H00036	600UL
2764	89	44	0.47	73	INR	6	01H	+25.22	TECTEH			21H00035	600UL
2765	91	44							TECTEH			21H00036	600UL
2766	93	44	0.54	81	INR	6	02H	+20.28	TECTEH			21H00035	600UL
2767	95	44	0.42	95	INR	6	F03	-0.18	TECTEH			21H00036	600UL
2768			0.32	88	INR	3	F09	+6.62	TECTEH			21H00036	600UL
2769					INF		F10	+8.41	TECTEH	HR		21H00036	600UL
2770	97	44			INF		04C	+12.06	TECTEH	HR		21H00035	600UL
2771					INF		02C	+29.10	TECTEH	HR		21H00035	600UL
2772	99	44	0.41	73	INR	6	05H	+8.85	TECTEH			21H00036	600UL
2773			0.37	81	INR	6	06H	+7.15	TECTEH			21H00036	600UL
2774			0.46	98	INR	3	06H	+30.88	TECTEH			21H00036	600UL
2775	101	44							TECTEH			21H00035	600UL
2776	103	44							TECTEH			21H00036	600UL
2777	105	44							TECTEH			21H00035	600UL
2778	107	44	0.52	76	INR	6	04C	+13.19	TECTEH			21H00036	600UL
2779	109	44	0.42	75	INR	6	02H	+17.78	TECTEH			21H00035	600UL
2780			0.37	85	INR	6	02H	+21.95	TECTEH			21H00035	600UL
2781	111	44							TECTEH			21H00036	600UL
2782	113	44							TECTEH			21H00035	600UL
2783	115	44	0.53	77	INR	6	05C	+27.38	TECTEH			21H00036	600UL
2784	117	44	0.50	68	INR	6	TSH	+12.30	TECTEH			21H00035	600UL
2785			0.29	78	INR	6	04H	+8.02	TECTEH			21H00035	600UL
2786			0.50	97	INR	6	F10	+7.63	TECTEH			21H00035	600UL
2787					INF		F11	+7.35	TECTEH	HR		21H00035	600UL
2788	119	44							TECTEH			21H00036	600UL
2789	121	44							TECTEH			21H00035	600UL
2790	123	44							TECTEH			21H00035	600UL
2791	2	45							TECTEH			21H00028	600UL
2792	4	45							TECTEH			21H00026	600UL
2793	6	45	0.48	67	INR	6	01C	+27.96	TECTEH			21H00026	600UL
2794	8	45							TECTEH			21H00022	600UL
2795	10	45							TECTEH			21H00021	600UL
2796	12	45							TECTEH			21H00022	600UL
2797	14	45							TECTEH			21H00021	600UL
2798	16	45							TECTEH			21H00022	600UL
2799	18	45							TECTEH			21H00021	600UL
2800	20	45							TECTEH			21H00022	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2801	22	45							TECTEH			21H00021	600UL
2802	24	45							TECTEH			21H00021	600UL
2803	26	45							TECTEH			21H00018	600UL
2804	28	45							TECTEH			21H00017	600UL
2805	30	45							TECTEH			21H00018	600UL
2806	32	45	0.53	77	INR	6	01C	+10.76	TECTEH			21H00017	600UL
2807	34	45							TECTEH			21H00018	600UL
2808	36	45	0.42	70	INR	6	TSH	+20.58	TECTEH			21H00017	600UL
2809					INF		TSH	+37.68	TECTEH	HR		21H00017	600UL
2810	38	45	0.80	67	INR	3	F07	+0.00	TECTEH			21H00018	600UL
2811	40	45							TECTEH			21H00017	600UL
2812	42	45							TECTEH			21H00018	600UL
2813	44	45							TECTEH			21H00017	600UL
2814	46	45							TECTEH			21H00018	600UL
2815	48	45	0.45	77	INR	6	05C	+24.75	TECTEH			21H00017	600UL
2816	50	45							TECTEH			21H00036	600UL
2817	52	45	0.39	76	INR	6	04H	+16.86	TECTEH			21H00035	600UL
2818	54	45	0.53	68	INR	6	05H	+20.26	TECTEH			21H00036	600UL
2819			0.52	68	INR	6	03C	+9.16	TECTEH			21H00036	600UL
2820	56	45	0.43	87	INR	6	02H	+22.38	TECTEH			21H00035	600UL
2821	58	45							TECTEH			21H00036	600UL
2822	60	45							TECTEH			21H00035	600UL
2823	62	45							TECTEH			21H00036	600UL
2824	64	45	0.37	80	INR	6	04C	+7.56	TECTEH			21H00035	600UL
2825	66	45							TECTEH			21H00036	600UL
2826	68	45							TECTEH			21H00035	600UL
2827	70	45							TECTEH			21H00036	600UL
2828	72	45							TECTEH			21H00035	600UL
2829	74	45							TECTEH			21H00036	600UL
2830	76	45							TECTEH			21H00035	600UL
2831	78	45	1.17	78	INR	6	F04	+3.11	TECTEH			21H00036	600UL
2832			0.75	32	INR	6	F10	+0.21	TECTEH			21H00036	600UL
2833			0.41	89	INR	6	02C	+13.95	TECTEH			21H00036	600UL
2834	80	45							TECTEH			21H00035	600UL
2835	82	45							TECTEH			21H00036	600UL
2836	84	45							TECTEH			21H00035	600UL
2837	86	45							TECTEH			21H00036	600UL
2838	88	45							TECTEH			21H00035	600UL
2839	90	45							TECTEH			21H00036	600UL
2840	92	45	0.44	83	INR	6	05H	+16.80	TECTEH			21H00035	600UL
2841			0.33	77	INR	6	05H	+23.36	TECTEH			21H00035	600UL
2842			0.39	81	INR	6	06H	+12.22	TECTEH			21H00035	600UL
2843			0.43	91	INR	6	F07	+9.84	TECTEH			21H00035	600UL
2844					INF		F08	+6.53	TECTEH	HR		21H00035	600UL
2845			0.44	82	INR	6	03C	+36.84	TECTEH			21H00035	600UL
2846					INF		03C	+42.12	TECTEH	HR		21H00035	600UL
2847	94	45							TECTEH			21H00036	600UL
2848	96	45							TECTEH			21H00035	600UL
2849	98	45	0.51	84	INR	6	05C	+21.02	TECTEH			21H00035	600UL
2850					INF		05C	+24.41	TECTEH	HR		21H00035	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2851	100	45							TECTEH			21H00036	600UL
2852	102	45	0.36	71	INR	6	F06	+11.14	TECTEH			21H00035	600UL
2853					INF		F07	+5.46	TECTEH	HR		21H00035	600UL
2854			0.67	83	INR	6	F10	+0.00	TECTEH			21H00035	600UL
2855	104	45							TECTEH			21H00036	600UL
2856	106	45							TECTEH			21H00035	600UL
2857	108	45							TECTEH			21H00036	600UL
2858	110	45							TECTEH			21H00035	600UL
2859	112	45							TECTEH			21H00036	600UL
2860	114	45							TECTEH			21H00035	600UL
2861	116	45	0.34	67	INR	6	F12	+15.62	TECTEH			21H00036	600UL
2862					INF		07C	+3.30	TECTEH	HR		21H00036	600UL
2863	118	45							TECTEH			21H00035	600UL
2864	120	45							TECTEH			21H00036	600UL
2865	122	45							TECTEH			21H00035	600UL
2866	124	45							TECTEH			21H00036	600UL
2867	1	46							TECTEH			21H00028	600UL
2868	3	46							TECTEH			21H00028	600UL
2869	5	46							TECTEH			21H00026	600UL
2870	7	46	0.43	81	INR	6	01H	+13.93	TECTEH			21H00026	600UL
2871			0.50	81	INR	6	02H	+7.84	TECTEH			21H00026	600UL
2872			0.45	70	INR	6	02H	+9.74	TECTEH			21H00026	600UL
2873			0.74	78	INR	6	03H	+28.62	TECTEH			21H00026	600UL
2874	9	46							TECTEH			21H00022	600UL
2875	11	46							TECTEH			21H00021	600UL
2876	13	46							TECTEH			21H00022	600UL
2877	15	46							TECTEH			21H00021	600UL
2878	17	46							TECTEH			21H00022	600UL
2879	19	46							TECTEH			21H00021	600UL
2880	21	46	2.81	184	INR	3	F01	+8.19	TECTEH			21H00022	600UL
2881					INF		F05	+5.44	TECTEH	HR		21H00022	600UL
2882	23	46							TECTEH			21H00021	600UL
2883	25	46							TECTEH			21H00018	600UL
2884	27	46							TECTEH			21H00017	600UL
2885	29	46							TECTEH			21H00018	600UL
2886	31	46							TECTEH			21H00017	600UL
2887	33	46							TECTEH			21H00018	600UL
2888	35	46	0.44	81	INR	6	03C	+17.34	TECTEH			21H00017	600UL
2889	37	46							TECTEH			21H00018	600UL
2890	39	46							TECTEH			21H00017	600UL
2891	41	46	0.33	113	INR	3	TSH	+18.96	TECTEH			21H00018	600UL
2892	43	46	1.27	25	INR	6	F05	+0.00	TECTEH			21H00017	600UL
2893			0.73	79	INR	6	01C	+29.99	TECTEH			21H00017	600UL
2894	45	46							TECTEH			21H00018	600UL
2895	47	46	0.53	82	INR	6	TSC	+19.95	TECTEH			21H00017	600UL
2896	49	46							TECTEH			21H00017	600UL
2897	51	46	0.48	85	INR	6	02H	+4.76	TECTEH			21H00036	600UL
2898			0.46	87	INR	3	F09	+0.00	TECTEH			21H00036	600UL
2899			0.35	83	INR	6	06C	+7.51	TECTEH			21H00036	600UL
2900	53	46	0.33	76	INR	6	02H	+25.69	TECTEH			21H00035	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2901			0.40	84	INR	6	03H	+23.68	TECTEH			21H00035	600UL
2902					INF		F03	+0.00	TECTEH	HR		21H00035	600UL
2903					INF		F03	+2.68	TECTEH	HR		21H00035	600UL
2904			0.30	70	INR	6	F04	+3.09	TECTEH			21H00035	600UL
2905	55	46			INF		F01	+0.00	TECTEH	HR		21H00036	600UL
2906			0.44	67	INR	6	F03	-0.05	TECTEH			21H00036	600UL
2907			0.70	71	INR	6	01C	+9.33	TECTEH			21H00036	600UL
2908			0.48	82	INR	6	TSC	+17.55	TECTEH			21H00036	600UL
2909	57	46	0.35	81	INR	6	F04	+5.99	TECTEH			21H00035	600UL
2910	59	46							TECTEH			21H00036	600UL
2911	61	46	0.54	76	INR	6	06C	+26.28	TECTEH			21H00035	600UL
2912	63	46							TECTEH			21H00036	600UL
2913	65	46							TECTEH			21H00035	600UL
2914	67	46							TECTEH			21H00036	600UL
2915	69	46							TECTEH			21H00035	600UL
2916	71	46							TECTEH			21H00036	600UL
2917	73	46	0.38	86	INR	6	02H	+30.89	TECTEH			21H00035	600UL
2918			0.46	107	INR	6	F06	+7.94	TECTEH			21H00035	600UL
2919			0.32	101	INR	6	F07	+5.10	TECTEH			21H00035	600UL
2920			2.29	69	NQH	6	F10	+7.07	TECTEH			21H00035	600UL
2921					INF		F12	+3.36	TECTEH	HR		21H00035	600UL
2922	75	46	0.55	117	INR	3	05H	+30.58	TECTEH			21H00036	600UL
2923			0.69	73	INR	6	04C	+5.65	TECTEH			21H00036	600UL
2924			0.41	84	INR	6	03C	+30.60	TECTEH			21H00036	600UL
2925	77	46							TECTEH			21H00035	600UL
2926	79	46							TECTEH			21H00036	600UL
2927	81	46							TECTEH			21H00035	600UL
2928	83	46							TECTEH			21H00036	600UL
2929	85	46							TECTEH			21H00035	600UL
2930	87	46	0.90	59	INR	6	F07	+13.68	TECTEH			21H00036	600UL
2931					INF		F08	+0.00	TECTEH	HR		21H00036	600UL
2932			0.46	92	INR	6	03C	+21.25	TECTEH			21H00036	600UL
2933	89	46	0.30	89	INR	6	01C	+19.95	TECTEH			21H00035	600UL
2934	91	46	0.37	76	INR	6	05C	+25.82	TECTEH			21H00036	600UL
2935	93	46							TECTEH			21H00035	600UL
2936	95	46							TECTEH			21H00036	600UL
2937	97	46	0.38	81	INR	6	F11	+5.64	TECTEH			21H00035	600UL
2938					INF		F12	+1.81	TECTEH	HR		21H00035	600UL
2939	99	46	0.46	85	INR	6	F06	+11.56	TECTEH			21H00036	600UL
2940					INF		F07	+4.37	TECTEH	HR		21H00036	600UL
2941			0.57	63	INR	6	F12	+8.01	TECTEH			21H00036	600UL
2942					INF		07C	+8.09	TECTEH	HR		21H00036	600UL
2943	101	46	0.90	78	INR	6	06H	+33.00	TECTEH			21H00035	600UL
2944			0.89	49	INR	6	F01	+6.97	TECTEH			21H00035	600UL
2945			0.45	50	INR	6	F09	+5.10	TECTEH			21H00035	600UL
2946					INF		F10	+11.75	TECTEH	HR		21H00035	600UL
2947			0.49	87	INR	6	06C	+38.03	TECTEH			21H00035	600UL
2948			0.41	85	INR	6	03C	+6.42	TECTEH			21H00035	600UL
2949			0.73	84	INR	6	TSC	+20.39	TECTEH			21H00035	600UL
2950	103	46							TECTEH			21H00036	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
2951	105	46	0.19	84	INR	6	03H	+20.63	TECTEH			21H00035	600UL
2952	107	46							TECTEH			21H00036	600UL
2953	109	46	0.41	56	INR	6	F05	+0.00	TECTEH			21H00035	600UL
2954	111	46	0.34	63	INR	6	04C	+9.18	TECTEH			21H00035	600UL
2955			0.67	77	INR	6	03C	+19.57	TECTEH			21H00035	600UL
2956	113	46	0.51	53	INR	6	F05	+8.55	TECTEH			21H00036	600UL
2957			0.74	80	INR	6	05C	+16.97	TECTEH			21H00036	600UL
2958			0.47	77	INR	6	02C	+16.36	TECTEH			21H00036	600UL
2959			0.55	90	INR	6	TSC	+15.55	TECTEH			21H00036	600UL
2960	115	46							TECTEH			21H00035	600UL
2961	117	46							TECTEH			21H00036	600UL
2962	119	46							TECTEH			21H00035	600UL
2963	121	46	0.48	81	INR	6	01H	+5.49	TECTEH			21H00036	600UL
2964			0.73	72	INR	6	F12	+10.72	TECTEH			21H00036	600UL
2965					INF		07C	+8.38	TECTEH	HR		21H00036	600UL
2966	123	46	0.67	74	INR	6	03H	+33.56	TECTEH			21H00035	600UL
2967			0.62	72	INR	6	01C	+13.63	TECTEH			21H00035	600UL
2968	125	46	0.53	64	INR	6	F04	+16.46	TECTEH			21H00036	600UL
2969			0.27	84	INR	6	03C	+36.16	TECTEH			21H00036	600UL
2970			0.62	72	INR	6	02C	+15.21	TECTEH			21H00036	600UL
2971	2	47							TECTEH			21H00028	600UL
2972	4	47							TECTEH			21H00026	600UL
2973	6	47							TECTEH			21H00026	600UL
2974	8	47							TECTEH			21H00022	600UL
2975	10	47							TECTEH			21H00021	600UL
2976	12	47							TECTEH			21H00022	600UL
2977	14	47							TECTEH			21H00021	600UL
2978	16	47							TECTEH			21H00022	600UL
2979	18	47							TECTEH			21H00021	600UL
2980	20	47	0.43	105	NQH	3	05H	+23.21	TECTEH			21H00022	600UL
2981	22	47	5.08	187	INR	1	F05	+3.58	TECTEH			21H00021	600UL
2982	24	47							TECTEH			21H00026	600UL
2983	26	47							TECTEH			21H00018	600UL
2984	28	47							TECTEH			21H00017	600UL
2985	30	47							TECTEH			21H00018	600UL
2986	32	47							TECTEH			21H00017	600UL
2987	34	47							TECTEH			21H00018	600UL
2988	36	47							TECTEH			21H00017	600UL
2989	38	47	0.61	128	INR	3	05C	+9.03	TECTEH			21H00018	600UL
2990					INF		04C	+28.66	TECTEH	HR		21H00018	600UL
2991			0.75	137	INR	3	04C	+36.23	TECTEH			21H00018	600UL
2992					INF		03C	+36.23	TECTEH	HR		21H00018	600UL
2993	40	47							TECTEH			21H00017	600UL
2994	42	47							TECTEH			21H00018	600UL
2995	44	47							TECTEH			21H00017	600UL
2996	46	47							TECTEH			21H00018	600UL
2997	48	47							TECTEH			21H00017	600UL
2998	50	47	0.56	84	INR	6	01H	+8.98	TECTEH			21H00036	600UL
2999	52	47							TECTEH			21H00035	600UL
3000	54	47	0.43	76	INR	6	02C	+21.47	TECTEH			21H00036	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3001					INF		02C	+22.71	TECTEH	HR		21H00036	600UL
3002	56	47							TECTEH			21H00035	600UL
3003	58	47			INF		F12	+4.84	TECTEH	HR		21H00036	600UL
3004			0.74	75	INR	6	F12	+6.22	TECTEH			21H00036	600UL
3005					INF		07C	+6.52	TECTEH	HR		21H00036	600UL
3006	60	47	0.34	66	INR	6	F07	+5.02	TECTEH			21H00035	600UL
3007					INF		F08	+3.88	TECTEH	HR		21H00035	600UL
3008			0.45	74	INR	6	05C	+18.44	TECTEH			21H00035	600UL
3009			0.43	83	INR	6	05C	+28.96	TECTEH			21H00035	600UL
3010			0.76	81	INR	6	04C	+14.19	TECTEH			21H00035	600UL
3011			0.52	83	INR	6	04C	+38.77	TECTEH			21H00035	600UL
3012			0.41	72	INR	6	01C	+27.92	TECTEH			21H00035	600UL
3013	62	47							TECTEH			21H00036	600UL
3014	64	47							TECTEH			21H00035	600UL
3015	66	47							TECTEH			21H00036	600UL
3016	68	47							TECTEH			21H00035	600UL
3017	70	47							TECTEH			21H00036	600UL
3018	72	47	0.43	84	INR	6	01H	+17.34	TECTEH			21H00035	600UL
3019			0.63	82	INR	6	02H	+29.53	TECTEH			21H00035	600UL
3020	74	47							TECTEH			21H00036	600UL
3021	76	47							TECTEH			21H00035	600UL
3022	78	47							TECTEH			21H00036	600UL
3023	80	47							TECTEH			21H00035	600UL
3024	82	47	0.87	73	INR	6	05H	+37.28	TECTEH			21H00035	600UL
3025	84	47	0.50	91	INR	6	01H	+16.46	TECTEH			21H00036	600UL
3026					INF		04H	+21.86	TECTEH	HR		21H00036	600UL
3027			0.80	79	INR	6	04H	+23.20	TECTEH			21H00036	600UL
3028			0.33	90	INR	6	07H	+10.98	TECTEH			21H00036	600UL
3029	86	47	0.87	172	INR	6	F11	+4.01	TECTEH			21H00035	600UL
3030			0.72	135	INR	6	F12	-0.74	TECTEH			21H00035	600UL
3031					INF		F12	+2.60	TECTEH	HR		21H00035	600UL
3032	88	47							TECTEH			21H00036	600UL
3033	90	47							TECTEH			21H00035	600UL
3034	92	47	0.54	101	INR	3	F05	+13.75	TECTEH			21H00036	600UL
3035			0.58	78	INR	6	03C	+12.87	TECTEH			21H00036	600UL
3036	94	47							TECTEH			21H00035	600UL
3037	96	47	0.60	73	INR	6	04H	+17.22	TECTEH			21H00036	600UL
3038	98	47	0.48	52	INR	6	06C	+17.07	TECTEH			21H00035	600UL
3039	100	47							TECTEH			21H00036	600UL
3040	102	47	0.45	71	INR	6	05C	+18.51	TECTEH			21H00035	600UL
3041	104	47							TECTEH			21H00036	600UL
3042	106	47							TECTEH			21H00035	600UL
3043	108	47							TECTEH			21H00036	600UL
3044	110	47							TECTEH			21H00035	600UL
3045	112	47							TECTEH			21H00036	600UL
3046	114	47	1.16	81	INR	6	02H	+0.00	TECTEH			21H00035	600UL
3047			0.38	73	INR	6	03H	+22.93	TECTEH			21H00035	600UL
3048			0.23	92	INR	6	06H	+25.16	TECTEH			21H00035	600UL
3049	116	47							TECTEH			21H00036	600UL
3050	118	47							TECTEH			21H00035	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3051	120	47	0.66	76	INR	6	01C	+23.57	TECTEH			21H00035	600UL
3052	122	47							TECTEH			21H00036	600UL
3053	124	47							TECTEH			21H00035	600UL
3054	126	47			NDF	3	TEH	+18.34	TEHTSH			21H00051	610PP
3055			1.65	181	INR	1	F04	+10.31	TECTEH			21H00036	600UL
3056	1	48							TECTEH			21H00028	600UL
3057	3	48							TECTEH			21H00028	600UL
3058	5	48							TECTEH			21H00026	600UL
3059	7	48	1.14	71	INR	6	03H	+25.81	TECTEH			21H00026	600UL
3060	9	48							TECTEH			21H00026	600UL
3061	11	48							TECTEH			21H00026	600UL
3062	13	48			INF		06H	+36.59	TECTEH	HR		21H00026	600UL
3063	15	48							TECTEH			21H00026	600UL
3064	17	48							TECTEH			21H00026	600UL
3065	19	48							TECTEH			21H00026	600UL
3066	21	48	4.32	186	INR	1	F01	+6.85	TECTEH			21H00026	600UL
3067					INF		F05	+5.42	TECTEH	HR		21H00026	600UL
3068	23	48							TECTEH			21H00026	600UL
3069	25	48							TECTEH			21H00018	600UL
3070	27	48	0.39	73	INR	6	01H	+10.07	TECTEH			21H00017	600UL
3071					INF		01H	+12.22	TECTEH	HR		21H00017	600UL
3072	29	48							TECTEH			21H00018	600UL
3073	31	48	0.36	73	INR	6	02H	+15.33	TECTEH			21H00017	600UL
3074			0.38	69	INR	6	02H	+17.61	TECTEH			21H00017	600UL
3075	33	48							TECTEH			21H00018	600UL
3076	35	48							TECTEH			21H00017	600UL
3077	37	48							TECTEH			21H00018	600UL
3078	39	48			INF		01C	+23.07	TECTEH	HR		21H00017	600UL
3079			0.44	76	INR	6	01C	+25.69	TECTEH			21H00017	600UL
3080	41	48							TECTEH			21H00018	600UL
3081	43	48							TECTEH			21H00017	600UL
3082	45	48	0.54	135	INR	3	02C	+24.13	TECTEH			21H00018	600UL
3083	47	48	0.94	77	INR	6	TSH	+15.28	TECTEH			21H00017	600UL
3084	49	48	0.87	73	INR	6	02C	+14.13	TECTEH			21H00017	600UL
3085	51	48							TECTEH			21H00036	600UL
3086	53	48							TECTEH			21H00035	600UL
3087	55	48	0.57	89	INR	6	03C	+33.66	TECTEH			21H00036	600UL
3088	57	48							TECTEH			21H00035	600UL
3089	59	48	0.56	73	INR	6	07H	+7.61	TECTEH			21H00036	600UL
3090	61	48							TECTEH			21H00035	600UL
3091	63	48							TECTEH			21H00036	600UL
3092	65	48	1.27	78	INR	6	01C	+21.80	TECTEH			21H00035	600UL
3093	67	48			INF		F09	-1.24	TECTEH	HR		21H00036	600UL
3094					INF		F09	-0.20	TECTEH	HR		21H00036	600UL
3095			0.90	72	INR	6	F09	+1.12	TECTEH			21H00036	600UL
3096			0.54	70	INR	6	06C	+23.61	TECTEH			21H00036	600UL
3097	69	48	1.18	80	INR	6	F07	+0.00	TECTEH			21H00035	600UL
3098	71	48	0.47	70	INR	6	TSH	+2.34	TECTEH			21H00036	600UL
3099			0.46	84	INR	6	06H	+24.27	TECTEH			21H00036	600UL
3100			0.52	80	INR	6	F08	+5.18	TECTEH			21H00036	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3101					INF		F08	+7.93	TECTEH	HR		21H00036	600UL
3102	73	48							TECTEH			21H00035	600UL
3103	75	48							TECTEH			21H00036	600UL
3104	77	48	0.63	56	INR	6	F05	+10.89	TECTEH			21H00035	600UL
3105			0.40	76	INR	6	01C	+9.07	TECTEH			21H00035	600UL
3106	79	48							TECTEH			21H00036	600UL
3107	81	48							TECTEH			21H00035	600UL
3108	83	48							TECTEH			21H00036	600UL
3109	85	48	0.47	75	INR	6	03C	+7.22	TECTEH			21H00035	600UL
3110	87	48							TECTEH			21H00036	600UL
3111	89	48	0.75	64	INR	6	03H	+39.30	TECTEH			21H00035	600UL
3112			0.39	59	INR	6	06H	+10.68	TECTEH			21H00035	600UL
3113					INF		03C	+11.50	TECTEH	HR		21H00035	600UL
3114			0.35	95	INR	6	03C	+15.83	TECTEH			21H00035	600UL
3115	91	48							TECTEH			21H00036	600UL
3116	93	48							TECTEH			21H00035	600UL
3117	95	48	0.48	75	INR	6	06C	+17.97	TECTEH			21H00036	600UL
3118	97	48	0.49	83	INR	6	F08	+5.66	TECTEH			21H00035	600UL
3119					INF		F09	+10.99	TECTEH	HR		21H00035	600UL
3120			0.41	75	INR	6	05C	+14.54	TECTEH			21H00035	600UL
3121	99	48	0.42	81	INR	6	01H	+18.84	TECTEH			21H00036	600UL
3122	101	48							TECTEH			21H00035	600UL
3123	103	48	3.48	187	DNG	1	F06	+4.37	TECTEH			21H00036	600UL
3124	105	48							TECTEH			21H00035	600UL
3125	107	48	0.39	79	INR	6	02H	+21.76	TECTEH			21H00036	600UL
3126			0.56	83	INR	6	04H	+11.51	TECTEH			21H00036	600UL
3127			0.56	76	INR	6	06C	+2.96	TECTEH			21H00036	600UL
3128	109	48	0.27	101	INR	6	F04	+10.59	TECTEH			21H00035	600UL
3129	111	48							TECTEH			21H00036	600UL
3130	113	48	3.05	181	DNT	P1	07H	+1.40	TECTEH			21H00035	600UL
3131	115	48	0.38	69	INR	6	06H	+25.89	TECTEH			21H00036	600UL
3132	117	48							TECTEH			21H00035	600UL
3133	119	48							TECTEH			21H00036	600UL
3134	121	48							TECTEH			21H00035	600UL
3135	123	48							TECTEH			21H00035	600UL
3136	125	48	0.50	72	INR	6	F05	+4.47	TECTEH			21H00036	600UL
3137	127	48	2.37	185	INR	1	F10	+13.77	TECTEH			21H00036	600UL
3138	2	49							TECTEH			21H00028	600UL
3139	4	49							TECTEH			21H00026	600UL
3140	6	49							TECTEH			21H00026	600UL
3141	8	49							TECTEH			21H00026	600UL
3142	10	49							TECTEH			21H00026	600UL
3143	12	49							TECTEH			21H00026	600UL
3144	14	49							TECTEH			21H00026	600UL
3145	16	49							TECTEH			21H00026	600UL
3146	18	49							TECTEH			21H00026	600UL
3147	20	49							TECTEH			21H00026	600UL
3148	22	49	4.20	187	INR	1	F05	+2.01	TECTEH			21H00026	600UL
3149	24	49							TECTEH			21H00026	600UL
3150	26	49							TECTEH			21H00018	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3151	28	49							TECTEH			21H00017	600UL
3152	30	49							TECTEH			21H00018	600UL
3153	32	49							TECTEH			21H00017	600UL
3154	34	49							TECTEH			21H00018	600UL
3155	36	49							TECTEH			21H00017	600UL
3156	38	49			INF		F02	+6.78	TECTEH	HR		21H00018	600UL
3157					INF		F03	+7.87	TECTEH	HR		21H00018	600UL
3158			0.36	15	INR	3	F05	+6.90	TECTEH			21H00018	600UL
3159			0.36	96	INR	3	F06	+7.54	TECTEH			21H00018	600UL
3160			0.37	103	INR	3	03C	+34.91	TECTEH			21H00018	600UL
3161	40	49							TECTEH			21H00017	600UL
3162	42	49	0.44	134	INR	3	03C	+6.37	TECTEH			21H00018	600UL
3163	44	49							TECTEH			21H00017	600UL
3164	46	49							TECTEH			21H00018	600UL
3165	48	49	0.63	67	INR	6	F05	+4.00	TECTEH			21H00017	600UL
3166			0.56	76	INR	6	01C	+5.86	TECTEH			21H00017	600UL
3167	50	49							TECTEH			21H00036	600UL
3168	52	49							TECTEH			21H00035	600UL
3169	54	49	0.54	74	INR	6	05C	+35.06	TECTEH			21H00036	600UL
3170	56	49							TECTEH			21H00035	600UL
3171	58	49	0.78	76	INR	6	01H	+30.35	TECTEH			21H00036	600UL
3172	60	49							TECTEH			21H00035	600UL
3173	62	49							TECTEH			21H00036	600UL
3174	64	49							TECTEH			21H00035	600UL
3175	66	49							TECTEH			21H00036	600UL
3176	68	49							TECTEH			21H00035	600UL
3177	70	49							TECTEH			21H00036	600UL
3178	72	49							TECTEH			21H00035	600UL
3179	74	49							TECTEH			21H00036	600UL
3180	76	49							TECTEH			21H00035	600UL
3181	78	49	0.53	67	INR	6	07H	+10.53	TECTEH			21H00036	600UL
3182			0.65	74	INR	6	07H	+11.64	TECTEH			21H00036	600UL
3183	80	49	0.66	76	INR	6	F09	+2.97	TECTEH			21H00035	600UL
3184					INF		F10	+8.29	TECTEH	HR		21H00035	600UL
3185			0.59	65	INR	6	05C	+2.57	TECTEH			21H00035	600UL
3186			0.78	79	INR	6	02C	+27.63	TECTEH			21H00035	600UL
3187			0.34	76	INR	6	02C	+37.06	TECTEH			21H00035	600UL
3188			0.63	80	INR	6	TSC	+15.78	TECTEH			21H00035	600UL
3189	82	49	0.56	80	INR	6	F06	+13.42	TECTEH			21H00036	600UL
3190					INF		F07	+3.17	TECTEH	HR		21H00036	600UL
3191	84	49	0.54	84	INR	6	F08	+7.09	TECTEH			21H00036	600UL
3192					INF		F09	+5.42	TECTEH	HR		21H00036	600UL
3193	86	49	0.46	67	INR	6	04C	+5.43	TECTEH			21H00035	600UL
3194			0.31	81	INR	6	04C	+37.14	TECTEH			21H00035	600UL
3195			0.62	65	INR	6	01C	+12.48	TECTEH			21H00035	600UL
3196	88	49	0.48	46	INR	3	TSC	+13.93	TECTEH			21H00036	600UL
3197	90	49	0.47	77	INR	6	01H	+21.42	TECTEH			21H00035	600UL
3198	92	49							TECTEH			21H00035	600UL
3199	94	49	0.86	80	INR	6	03H	+24.91	TECTEH			21H00036	600UL
3200			0.61	74	INR	6	F02	+11.17	TECTEH			21H00036	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3201					INF		F03	+32.07	TECTEH	HR		21H00036	600UL
3202			1.07	27	INR	6	F05	+0.39	TECTEH			21H00036	600UL
3203	96	49	0.35	77	INR	6	03H	+27.24	TECTEH			21H00035	600UL
3204	98	49							TECTEH			21H00036	600UL
3205	100	49							TECTEH			21H00035	600UL
3206	102	49							TECTEH			21H00036	600UL
3207	104	49							TECTEH			21H00035	600UL
3208	106	49	0.39	78	INR	6	02H	+25.90	TECTEH			21H00036	600UL
3209	108	49							TECTEH			21H00035	600UL
3210	110	49	0.73	78	INR	6	04H	+9.55	TECTEH			21H00036	600UL
3211			0.49	59	INR	6	06H	+16.77	TECTEH			21H00036	600UL
3212			1.02	74	INR	6	06C	+7.88	TECTEH			21H00036	600UL
3213			0.50	76	INR	6	06C	+12.41	TECTEH			21H00036	600UL
3214			0.46	69	INR	6	04C	+22.61	TECTEH			21H00036	600UL
3215	112	49							TECTEH			21H00035	600UL
3216	114	49	0.86	77	INR	6	06C	+30.87	TECTEH			21H00036	600UL
3217	116	49							TECTEH			21H00035	600UL
3218	118	49							TECTEH			21H00036	600UL
3219	120	49	0.36	81	INR	6	05H	+36.38	TECTEH			21H00035	600UL
3220	122	49							TECTEH			21H00036	600UL
3221	124	49							TECTEH			21H00035	600UL
3222	126	49							TECTEH			21H00036	600UL
3223	1	50							TECTEH			21H00028	600UL
3224	3	50							TECTEH			21H00028	600UL
3225	5	50							TECTEH			21H00026	600UL
3226	7	50							TECTEH			21H00026	600UL
3227	9	50							TECTEH			21H00027	600UL
3228	11	50							TECTEH			21H00026	600UL
3229	13	50							TECTEH			21H00027	600UL
3230	15	50							TECTEH			21H00026	600UL
3231	17	50							TECTEH			21H00027	600UL
3232	19	50							TECTEH			21H00026	600UL
3233	21	50	5.49	183	INR	P1	F01	+6.35	TECTEH			21H00027	600UL
3234					INF		F05	+5.04	TECTEH	HR		21H00027	600UL
3235	23	50							TECTEH			21H00026	600UL
3236	25	50							TECTEH			21H00065	600UL
3237	27	50							TECTEH			21H00064	600UL
3238	29	50							TECTEH			21H00065	600UL
3239	31	50							TECTEH			21H00064	600UL
3240	33	50							TECTEH			21H00065	600UL
3241	35	50							TECTEH			21H00064	600UL
3242	37	50							TECTEH			21H00065	600UL
3243	39	50							TECTEH			21H00064	600UL
3244	41	50							TECTEH			21H00065	600UL
3245	43	50							TECTEH			21H00064	600UL
3246	45	50	0.25	70	INR	6	05H	+16.75	TECTEH			21H00065	600UL
3247	47	50							TECTEH			21H00064	600UL
3248	49	50	0.38	106	INR	3	05H	+15.31	TECTEH			21H00065	600UL
3249	51	50	0.53	72	INR	6	03H	+32.75	TECTEH			21H00064	600UL
3250	53	50							TECTEH			21H00065	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3251	55	50	0.54	81	INR	6	04H	+25.96	TECTEH			21H00064	600UL
3252			0.71	84	INR	6	03C	+19.45	TECTEH			21H00064	600UL
3253	57	50	0.44	81	INR	6	05C	+18.42	TECTEH			21H00065	600UL
3254	59	50	0.41	80	INR	6	05H	+28.56	TECTEH			21H00064	600UL
3255	61	50	0.70	83	INR	6	01H	+29.31	TECTEH			21H00065	600UL
3256					INF		F01	+5.14	TECTEH	HR		21H00065	600UL
3257			0.87	51	INR	6	F03	+0.10	TECTEH			21H00065	600UL
3258			0.57	74	INR	6	F08	+3.77	TECTEH			21H00065	600UL
3259					INF		F08	+10.76	TECTEH	HR		21H00065	600UL
3260	63	50							TECTEH			21H00064	600UL
3261	65	50							TECTEH			21H00065	600UL
3262	67	50							TECTEH			21H00064	600UL
3263	69	50							TECTEH			21H00065	600UL
3264	71	50							TECTEH			21H00064	600UL
3265	73	50							TECTEH			21H00065	600UL
3266	75	50							TECTEH			21H00064	600UL
3267	77	50							TECTEH			21H00065	600UL
3268	79	50							TECTEH			21H00064	600UL
3269	81	50	0.45	100	INR	3	01H	+18.58	TECTEH			21H00064	600UL
3270			0.40	63	INR	6	03H	+32.79	TECTEH			21H00064	600UL
3271			0.41	52	INR	6	05H	+28.41	TECTEH			21H00064	600UL
3272					INF		F02	+0.00	TECTEH	HR		21H00064	600UL
3273	83	50	0.61	104	INR	3	06C	+21.01	TECTEH			21H00042	600UL
3274	85	50							TECTEH			21H00041	600UL
3275	87	50							TECTEH			21H00042	600UL
3276	89	50			INF		07H	+17.75	TECTEH	HR		21H00041	600UL
3277			0.42	63	INR	6	F06	+8.77	TECTEH			21H00041	600UL
3278	91	50							TECTEH			21H00042	600UL
3279	93	50							TECTEH			21H00041	600UL
3280	95	50							TECTEH			21H00042	600UL
3281	97	50	0.39	64	INR	6	03H	+36.07	TECTEH			21H00041	600UL
3282			0.49	71	INR	6	05C	+11.36	TECTEH			21H00041	600UL
3283			0.43	71	INR	6	01C	+22.04	TECTEH			21H00041	600UL
3284			0.67	68	INR	6	01C	+31.15	TECTEH			21H00041	600UL
3285	99	50							TECTEH			21H00042	600UL
3286	101	50							TECTEH			21H00041	600UL
3287	103	50							TECTEH			21H00042	600UL
3288	105	50							TECTEH			21H00041	600UL
3289	107	50							TECTEH			21H00042	600UL
3290	109	50							TECTEH			21H00041	600UL
3291	111	50	0.34	148	INR	3	F08	+0.00	TECTEH			21H00042	600UL
3292	113	50							TECTEH			21H00041	600UL
3293	115	50							TECTEH			21H00042	600UL
3294	117	50	0.35	70	INR	6	06C	+11.93	TECTEH			21H00041	600UL
3295	119	50							TECTEH			21H00042	600UL
3296	121	50							TECTEH			21H00041	600UL
3297	123	50							TECTEH			21H00042	600UL
3298	125	50	0.54	93	INR	6	F06	+4.09	TECTEH			21H00041	600UL
3299			0.47	96	INR	6	F06	+5.54	TECTEH			21H00041	600UL
3300	127	50							TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3301	2	51							TECTEH			21H00028	600UL
3302	4	51							TECTEH			21H00026	600UL
3303	6	51							TECTEH			21H00026	600UL
3304	8	51							TECTEH			21H00026	600UL
3305	10	51							TECTEH			21H00027	600UL
3306	12	51							TECTEH			21H00026	600UL
3307	14	51							TECTEH			21H00027	600UL
3308	16	51							TECTEH			21H00026	600UL
3309	18	51							TECTEH			21H00027	600UL
3310	20	51							TECTEH			21H00026	600UL
3311	22	51	3.90	184	INR	P1	F05	+2.21	TECTEH			21H00027	600UL
3312	24	51							TECTEH			21H00026	600UL
3313	26	51	0.56	67	INR	6	05C	+12.68	TECTEH			21H00065	600UL
3314	28	51							TECTEH			21H00064	600UL
3315	30	51							TECTEH			21H00065	600UL
3316	32	51							TECTEH			21H00064	600UL
3317	34	51							TECTEH			21H00065	600UL
3318	36	51			INF		06H	+26.03	TECTEH	HR		21H00064	600UL
3319			0.47	66	INR	6	06H	+28.36	TECTEH			21H00064	600UL
3320			0.39	82	INR	6	03C	+32.99	TECTEH			21H00064	600UL
3321			0.71	77	INR	6	02C	+28.99	TECTEH			21H00064	600UL
3322	38	51	0.25	86	INR	6	05H	+2.67	TECTEH			21H00065	600UL
3323			0.50	80	INR	6	05C	+11.40	TECTEH			21H00065	600UL
3324	40	51	0.54	77	INR	6	TSH	+12.77	TECTEH			21H00064	600UL
3325			0.42	73	INR	6	06C	+14.35	TECTEH			21H00064	600UL
3326			0.45	79	INR	6	02C	+7.74	TECTEH			21H00064	600UL
3327			0.57	69	INR	6	02C	+14.26	TECTEH			21H00064	600UL
3328	42	51	0.49	93	INR	6	TSC	+1.90	TECTEH			21H00065	600UL
3329	44	51	0.34	66	INR	6	06H	+7.59	TECTEH			21H00064	600UL
3330	46	51							TECTEH			21H00065	600UL
3331	48	51	0.31	55	INR	6	05H	+24.44	TECTEH			21H00064	600UL
3332			1.14	34	INR	6	F06	+12.19	TECTEH			21H00064	600UL
3333					INF		F07	+1.24	TECTEH	HR		21H00064	600UL
3334	50	51							TECTEH			21H00065	600UL
3335	52	51							TECTEH			21H00064	600UL
3336	54	51	0.49	58	INR	6	F05	+8.02	TECTEH			21H00065	600UL
3337			0.58	85	INR	6	01C	+27.45	TECTEH			21H00065	600UL
3338	56	51	0.51	62	INR	6	TSC	+9.91	TECTEH			21H00064	600UL
3339	58	51							TECTEH			21H00065	600UL
3340	60	51	0.31	100	INR	6	F04	+5.67	TECTEH			21H00064	600UL
3341					INF		F05	+4.96	TECTEH	HR		21H00064	600UL
3342	62	51							TECTEH			21H00065	600UL
3343	64	51	0.56	75	INR	6	03H	+8.85	TECTEH			21H00064	600UL
3344	66	51	0.45	85	INR	6	01H	+13.94	TECTEH			21H00065	600UL
3345			0.51	81	INR	6	04H	+16.84	TECTEH			21H00065	600UL
3346			0.64	74	INR	6	04C	+17.19	TECTEH			21H00065	600UL
3347	68	51							TECTEH			21H00064	600UL
3348	70	51							TECTEH			21H00065	600UL
3349	72	51							TECTEH			21H00064	600UL
3350	74	51	0.53	71	INR	6	06H	+15.12	TECTEH			21H00065	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3351	76	51							TECTEH			21H00064	600UL
3352	78	51	1.03	76	INR	6	03C	+27.37	TECTEH			21H00065	600UL
3353	80	51	1.43	60	INR	6	03C	-0.10	TECTEH			21H00064	600UL
3354	82	51	0.54	128	INR	3	F07	+2.93	TECTEH			21H00042	600UL
3355					INF		F08	+12.03	TECTEH	HR		21H00042	600UL
3356	84	51	1.29	86	INR	6	06H	+11.26	TECTEH			21H00041	600UL
3357			0.74	66	INR	6	F03	+5.07	TECTEH			21H00041	600UL
3358			0.51	83	INR	6	TSC	+5.98	TECTEH			21H00041	600UL
3359					INF		TSC	+7.65	TECTEH	HR		21H00041	600UL
3360	86	51							TECTEH			21H00042	600UL
3361	88	51	0.66	79	INR	6	04C	+36.48	TECTEH			21H00041	600UL
3362			0.60	84	INR	6	02C	+13.90	TECTEH			21H00041	600UL
3363	90	51	0.28	80	INR	3	01C	+2.64	TECTEH			21H00042	600UL
3364	92	51							TECTEH			21H00041	600UL
3365	94	51							TECTEH			21H00042	600UL
3366	96	51	0.46	65	INR	6	TSC	+7.70	TECTEH			21H00041	600UL
3367	98	51	0.49	140	INR	3	F08	+7.62	TECTEH			21H00042	600UL
3368					INF		F09	+8.55	TECTEH	HR		21H00042	600UL
3369	100	51	0.33	78	INR	6	TSH	+6.88	TECTEH			21H00041	600UL
3370			0.34	77	INR	6	02H	+7.65	TECTEH			21H00041	600UL
3371			0.50	52	INR	6	F05	+8.01	TECTEH			21H00041	600UL
3372			1.13	82	INR	6	04C	+29.56	TECTEH			21H00041	600UL
3373	102	51							TECTEH			21H00042	600UL
3374	104	51							TECTEH			21H00041	600UL
3375	106	51							TECTEH			21H00042	600UL
3376	108	51							TECTEH			21H00041	600UL
3377	110	51	0.32	135	INR	3	02H	+33.85	TECTEH			21H00042	600UL
3378			0.48	120	INR	3	05H	+29.28	TECTEH			21H00042	600UL
3379			0.27	61	INR	3	F06	+8.95	TECTEH			21H00042	600UL
3380	112	51							TECTEH			21H00041	600UL
3381	114	51	0.52	71	INR	3	F09	-1.98	TECTEH			21H00042	600UL
3382			0.58	100	INR	3	F09	+1.57	TECTEH			21H00042	600UL
3383					INF		F09	+2.29	TECTEH	HR		21H00042	600UL
3384					INF		F10	+16.46	TECTEH	HR		21H00042	600UL
3385			0.39	128	INR	3	06C	+2.45	TECTEH			21H00042	600UL
3386			0.31	133	INR	3	01C	+30.72	TECTEH			21H00042	600UL
3387	116	51	0.53	78	INR	6	04H	+24.53	TECTEH			21H00041	600UL
3388			0.40	99	INR	6	F05	+13.88	TECTEH			21H00041	600UL
3389					INF		F05	+15.91	TECTEH	HR		21H00041	600UL
3390	118	51							TECTEH			21H00042	600UL
3391	120	51							TECTEH			21H00041	600UL
3392	122	51							TECTEH			21H00042	600UL
3393	124	51							TECTEH			21H00041	600UL
3394	126	51							TECTEH			21H00042	600UL
3395	128	51							TECTEH			21H00041	600UL
3396	1	52							TECTEH			21H00028	600UL
3397	3	52	0.36	117	NQH	3	05C	+23.15	TECTEH			21H00028	600UL
3398			0.37	74	INR	6	05C	+27.63	TECTEH			21H00028	600UL
3399	5	52							TECTEH			21H00026	600UL
3400	7	52							TECTEH			21H00026	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3401	9	52							TECTEH			21H00026	600UL
3402	11	52	0.42	75	INR	6	06H	+5.84	TECTEH			21H00026	600UL
3403	13	52							TECTEH			21H00027	600UL
3404	15	52							TECTEH			21H00026	600UL
3405	17	52							TECTEH			21H00027	600UL
3406	19	52							TECTEH			21H00026	600UL
3407	21	52	2.39	183	INR	P1	F01	+3.42	TECTEH			21H00027	600UL
3408					INF		F05	+5.83	TECTEH	HR		21H00027	600UL
3409	23	52							TECTEH			21H00026	600UL
3410	25	52							TECTEH			21H00065	600UL
3411	27	52							TECTEH			21H00064	600UL
3412	29	52							TECTEH			21H00065	600UL
3413					NDF	3	TSH	-0.36	TEHTSH			21H00086	610PP
3414	31	52							TECTEH			21H00064	600UL
3415	33	52							TECTEH			21H00065	600UL
3416	35	52							TECTEH			21H00064	600UL
3417	37	52							TECTEH			21H00065	600UL
3418					NDF	3	TSH	-0.32	TEHTSH			21H00086	610PP
3419	39	52							TECTEH			21H00064	600UL
3420	41	52	0.47	57	INR	6	05H	+24.48	TECTEH			21H00065	600UL
3421	43	52							TECTEH			21H00064	600UL
3422	45	52							TECTEH			21H00065	600UL
3423	47	52	0.85	79	INR	6	05C	+5.53	TECTEH			21H00064	600UL
3424	49	52							TECTEH			21H00065	600UL
3425	51	52	0.29	108	INR	6	02C	+10.09	TECTEH			21H00064	600UL
3426	53	52							TECTEH			21H00065	600UL
3427	55	52	0.33	82	INR	6	03C	+23.81	TECTEH			21H00064	600UL
3428	57	52							TECTEH			21H00065	600UL
3429	59	52							TECTEH			21H00064	600UL
3430	61	52							TECTEH			21H00065	600UL
3431	63	52							TECTEH			21H00064	600UL
3432	65	52							TECTEH			21H00065	600UL
3433	67	52							TECTEH			21H00064	600UL
3434	69	52							TECTEH			21H00065	600UL
3435	71	52	0.41	80	INR	6	02H	+27.01	TECTEH			21H00064	600UL
3436	73	52	0.79	73	INR	6	05H	+11.07	TECTEH			21H00065	600UL
3437	75	52	1.23	65	INR	6	02H	+39.55	TECTEH			21H00064	600UL
3438	77	52	0.52	78	INR	6	01H	+11.42	TECTEH			21H00065	600UL
3439	79	52	0.51	83	INR	6	04C	+37.25	TECTEH			21H00064	600UL
3440	81	52							TECTEH			21H00064	600UL
3441	83	52							TECTEH			21H00042	600UL
3442	85	52							TECTEH			21H00041	600UL
3443	87	52							TECTEH			21H00042	600UL
3444	89	52							TECTEH			21H00041	600UL
3445	91	52	0.41	125	INR	3	04C	+25.14	TECTEH			21H00042	600UL
3446	93	52	1.21	81	INR	6	02H	+4.67	TECTEH			21H00041	600UL
3447	95	52							TECTEH			21H00042	600UL
3448	97	52							TECTEH			21H00041	600UL
3449	99	52	0.36	127	INR	3	04H	+34.09	TECTEH			21H00042	600UL
3450	101	52	0.89	68	INR	6	F08	+10.23	TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3451					INF		F09	+6.09	TECTEH	HR		21H00041	600UL
3452			0.64	74	INR	6	TSC	+18.48	TECTEH			21H00041	600UL
3453	103	52							TECTEH			21H00042	600UL
3454	105	52							TECTEH			21H00041	600UL
3455	107	52							TECTEH			21H00042	600UL
3456	109	52	0.27	77	INR	6	02H	+10.66	TECTEH			21H00041	600UL
3457			0.39	94	INR	6	04H	+2.12	TECTEH			21H00041	600UL
3458	111	52							TECTEH			21H00042	600UL
3459	113	52							TECTEH			21H00041	600UL
3460	115	52							TECTEH			21H00042	600UL
3461	117	52							TECTEH			21H00041	600UL
3462	119	52							TECTEH			21H00042	600UL
3463	121	52							TECTEH			21H00041	600UL
3464	123	52							TECTEH			21H00042	600UL
3465	125	52	0.50	85	INR	6	01H	+4.36	TECTEH			21H00041	600UL
3466			0.44	74	INR	6	05H	+17.60	TECTEH			21H00041	600UL
3467			0.42	62	INR	6	03C	+16.59	TECTEH			21H00041	600UL
3468			0.54	73	INR	6	02C	+28.08	TECTEH			21H00041	600UL
3469			0.42	79	INR	6	02C	+36.99	TECTEH			21H00041	600UL
3470	127	52							TECTEH			21H00042	600UL
3471	129	52	0.45	69	NQH	3	F04	+16.24	TECTEH			21H00041	600UL
3472			0.64	88	INR	6	F04	+17.93	TECTEH			21H00041	600UL
3473			0.39	89	INR	6	F08	+4.37	TECTEH			21H00041	600UL
3474					INF		F09	+15.53	TECTEH	HR		21H00041	600UL
3475			0.51	70	INR	6	F10	+10.64	TECTEH			21H00041	600UL
3476			0.57	73	INR	6	06C	+16.93	TECTEH			21H00041	600UL
3477			0.43	80	INR	6	04C	+27.01	TECTEH			21H00041	600UL
3478			0.39	69	INR	6	02C	+7.07	TECTEH			21H00041	600UL
3479	2	53							TECTEH			21H00028	600UL
3480	4	53							TECTEH			21H00026	600UL
3481	6	53							TECTEH			21H00026	600UL
3482	8	53							TECTEH			21H00026	600UL
3483	10	53							TECTEH			21H00026	600UL
3484	12	53							TECTEH			21H00027	600UL
3485	14	53							TECTEH			21H00026	600UL
3486	16	53							TECTEH			21H00027	600UL
3487	18	53							TECTEH			21H00026	600UL
3488	20	53							TECTEH			21H00027	600UL
3489	22	53	5.11	185	INR	P1	F05	+1.54	TECTEH			21H00026	600UL
3490	24	53							TECTEH			21H00026	600UL
3491	26	53							TECTEH			21H00065	600UL
3492	28	53							TECTEH			21H00064	600UL
3493	30	53							TECTEH			21H00065	600UL
3494	32	53							TECTEH			21H00064	600UL
3495	34	53							TECTEH			21H00065	600UL
3496	36	53	0.46	66	INR	6	TSH	+12.80	TECTEH			21H00064	600UL
3497	38	53	0.41	76	INR	6	01H	+30.22	TECTEH			21H00065	600UL
3498					INF		06H	+28.98	TECTEH	HR		21H00065	600UL
3499			0.56	74	INR	6	06H	+31.43	TECTEH			21H00065	600UL
3500	40	53							TECTEH			21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3501	42	53								TECTEH			21H00065	600UL
3502	44	53	0.42	81	INR	6	03C	+29.86		TECTEH			21H00064	600UL
3503	46	53								TECTEH			21H00065	600UL
3504	48	53								TECTEH			21H00064	600UL
3505	50	53								TECTEH			21H00065	600UL
3506	52	53								TECTEH			21H00064	600UL
3507	54	53								TECTEH			21H00065	600UL
3508	56	53	0.56	85	INR	6	F12	+7.23		TECTEH			21H00064	600UL
3509					INF		07C	+5.58		TECTEH	HR		21H00064	600UL
3510					INF		07C	+6.64		TECTEH	HR		21H00064	600UL
3511	58	53								TECTEH			21H00065	600UL
3512	60	53								TECTEH			21H00064	600UL
3513	62	53								TECTEH			21H00065	600UL
3514	64	53								TECTEH			21H00064	600UL
3515	66	53								TECTEH			21H00065	600UL
3516	68	53	0.45	67	INR	6	06H	+33.08		TECTEH			21H00064	600UL
3517			0.65	41	INR	6	F10	+0.15		TECTEH			21H00064	600UL
3518	70	53								TECTEH			21H00065	600UL
3519	72	53	0.36	79	INR	6	04H	+13.22		TECTEH			21H00064	600UL
3520			0.49	69	INR	6	04H	+37.63		TECTEH			21H00064	600UL
3521	74	53	0.91	75	INR	6	06C	+32.00		TECTEH			21H00065	600UL
3522			0.60	79	INR	6	03C	+26.27		TECTEH			21H00065	600UL
3523			0.54	74	INR	6	01C	+26.38		TECTEH			21H00065	600UL
3524	76	53								TECTEH			21H00064	600UL
3525	78	53	0.52	240	INR	6	04H	+7.00	TO+39.29	TECTEH			21H00065	600UL
3526			0.25	6	INR	6	05H	+0.96	TO+39.96	TECTEH			21H00065	600UL
3527			0.80	52	INR	6	06H	+1.49	TO+57.03	TECTEH			21H00065	600UL
3528	80	53	0.41	50	INR	6	06H	+24.29		TECTEH			21H00064	600UL
3529	82	53								TECTEH			21H00041	600UL
3530	84	53	0.40	105	INR	3	F07	+4.56		TECTEH			21H00042	600UL
3531					INF		F08	+9.60		TECTEH	HR		21H00042	600UL
3532	86	53								TECTEH			21H00041	600UL
3533	88	53	0.44	122	INR	3	04C	+30.48		TECTEH			21H00042	600UL
3534	90	53								TECTEH			21H00041	600UL
3535	92	53	0.31	119	INR	3	04H	+18.66		TECTEH			21H00042	600UL
3536	94	53								TECTEH			21H00041	600UL
3537	96	53	0.35	112	INR	3	04H	+14.38		TECTEH			21H00042	600UL
3538	98	53								TECTEH			21H00041	600UL
3539	100	53	0.98	80	INR	6	04H	+28.01		TECTEH			21H00041	600UL
3540			0.37	84	INR	6	04H	+33.56		TECTEH			21H00041	600UL
3541	102	53	0.44	118	INR	3	01H	+20.68		TECTEH			21H00042	600UL
3542			0.31	130	INR	3	02H	+16.30		TECTEH			21H00042	600UL
3543			1.37	80	INR	6	F12	+0.00		TECTEH			21H00042	600UL
3544			0.37	142	INR	3	02C	+14.52		TECTEH			21H00042	600UL
3545	104	53	0.27	85	INR	6	05H	+8.86		TECTEH			21H00041	600UL
3546	106	53								TECTEH			21H00042	600UL
3547	108	53	0.40	85	INR	6	TSH	+16.36		TECTEH			21H00041	600UL
3548			0.30	85	INR	6	04H	+17.96		TECTEH			21H00041	600UL
3549	110	53	0.34	121	INR	3	02H	+5.55		TECTEH			21H00042	600UL
3550	112	53								TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3551	114	53	0.65	74	INR	6	F08	+0.00		TECTEH			21H00042	600UL
3552	116	53	0.40	99	INR	6	F07	+3.32		TECTEH			21H00041	600UL
3553					INF		F08	+14.93		TECTEH	HR		21H00041	600UL
3554			0.84	74	INR	6	06C	+11.76		TECTEH			21H00041	600UL
3555			0.77	74	INR	6	05C	+26.81		TECTEH			21H00041	600UL
3556			0.34	72	INR	6	04C	+15.20		TECTEH			21H00041	600UL
3557			0.32	85	INR	6	04C	+39.23		TECTEH			21H00041	600UL
3558	118	53								TECTEH			21H00042	600UL
3559	120	53								TECTEH			21H00041	600UL
3560	122	53								TECTEH			21H00042	600UL
3561	124	53								TECTEH			21H00041	600UL
3562	126	53	0.33	119	INR	3	03C	+15.45		TECTEH			21H00042	600UL
3563	128	53								TECTEH			21H00041	600UL
3564	130	53								TECTEH			21H00042	600UL
3565	1	54								TECTEH			21H00028	600UL
3566	3	54								TECTEH			21H00028	600UL
3567	5	54	0.41	72	INR	6	TSH	+17.96		TECTEH			21H00026	600UL
3568	7	54								TECTEH			21H00026	600UL
3569	9	54								TECTEH			21H00026	600UL
3570	11	54								TECTEH			21H00026	600UL
3571	13	54								TECTEH			21H00027	600UL
3572	15	54								TECTEH			21H00026	600UL
3573	17	54								TECTEH			21H00027	600UL
3574	19	54								TECTEH			21H00026	600UL
3575	21	54	0.30	125	INR	3	05H	+13.68		TECTEH			21H00027	600UL
3576					INF		F01	+6.88		TECTEH	HR		21H00027	600UL
3577			6.04	183	INR	P1	F05	+3.43		TECTEH			21H00027	600UL
3578	23	54								TECTEH			21H00026	600UL
3579	25	54								TECTEH			21H00065	600UL
3580	27	54								TECTEH			21H00064	600UL
3581	29	54								TECTEH			21H00065	600UL
3582	31	54								TECTEH			21H00064	600UL
3583	33	54								TECTEH			21H00065	600UL
3584	35	54	0.64	40	INR	6	F07	+0.46	TO+8.23	TECTEH			21H00064	600UL
3585					INF		F07	+3.02		TECTEH	HR		21H00064	600UL
3586					INF		F08	+3.65	TO+11.52	TECTEH	HR		21H00064	600UL
3587	37	54	0.47	60	INR	6	05C	+35.54		TECTEH			21H00065	600UL
3588	39	54								TECTEH			21H00064	600UL
3589	41	54			INF		06C	+24.76		TECTEH	HR		21H00065	600UL
3590			0.47	63	INR	6	06C	+26.09		TECTEH			21H00065	600UL
3591	43	54	0.60	76	INR	6	03C	+29.53		TECTEH			21H00064	600UL
3592	45	54								TECTEH			21H00065	600UL
3593	47	54			INF		06H	+23.52		TECTEH	HR		21H00064	600UL
3594			0.40	68	INR	6	06H	+25.51		TECTEH			21H00064	600UL
3595	49	54								TECTEH			21H00065	600UL
3596	51	54			INF		TSH	+7.50		TECTEH	PVC		21H00064	600UL
3597					INF		TSH	+15.38		TECTEH	PVC		21H00064	600UL
3598					INF		02H	+8.43		TECTEH	PVC		21H00064	600UL
3599					INF		05C	+24.61		TECTEH	PVC		21H00064	600UL
3600					INF		04C	+38.95		TECTEH	PVC		21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3601	53	54							TECTEH			21H00065	600UL
3602	55	54							TECTEH			21H00064	600UL
3603	57	54							TECTEH			21H00065	600UL
3604	59	54	0.35	82	INR	6	04H	+18.31	TECTEH			21H00064	600UL
3605			0.41	72	INR	6	F09	+2.52	TECTEH			21H00064	600UL
3606					INF		F10	+9.53	TECTEH	HR		21H00064	600UL
3607	61	54	0.50	76	INR	6	TSH	+7.95	TECTEH			21H00065	600UL
3608			0.67	77	INR	6	TSH	+15.87	TECTEH			21H00065	600UL
3609			0.56	71	INR	6	02H	+8.25	TECTEH			21H00065	600UL
3610			0.53	87	INR	6	05C	+24.52	TECTEH			21H00065	600UL
3611			0.52	74	INR	6	04C	+39.13	TECTEH			21H00065	600UL
3612	63	54							TECTEH			21H00064	600UL
3613	65	54							TECTEH			21H00065	600UL
3614	67	54							TECTEH			21H00064	600UL
3615	69	54							TECTEH			21H00065	600UL
3616	71	54							TECTEH			21H00064	600UL
3617	73	54	0.88	76	INR	6	02C	+15.84	TECTEH			21H00065	600UL
3618	75	54	0.41	72	INR	6	TSH	+3.99	TECTEH			21H00064	600UL
3619	77	54	0.47	92	INR	6	05H	+2.00	TECTEH			21H00065	600UL
3620			0.46	63	INR	6	06C	+19.53	TECTEH			21H00065	600UL
3621			0.77	71	INR	6	05C	+15.10	TECTEH			21H00065	600UL
3622			0.67	77	INR	6	02C	+14.20	TECTEH			21H00065	600UL
3623	79	54							TECTEH			21H00064	600UL
3624	81	54			INF		06C	+35.10	TECTEH	HR		21H00064	600UL
3625			0.42	66	INR	6	06C	+37.49	TECTEH			21H00064	600UL
3626	83	54							TECTEH			21H00042	600UL
3627	85	54	0.65	83	INR	6	01H	+14.39	TECTEH			21H00041	600UL
3628			0.64	64	INR	6	F04	+13.01	TECTEH			21H00041	600UL
3629	87	54							TECTEH			21H00042	600UL
3630	89	54	0.89	72	INR	6	TSH	+21.52	TECTEH			21H00041	600UL
3631			0.40	77	INR	6	03H	+26.43	TECTEH			21H00041	600UL
3632			0.34	73	INR	6	03C	+23.99	TECTEH			21H00041	600UL
3633	91	54	0.37	112	INR	3	03H	+15.92	TECTEH			21H00042	600UL
3634	93	54							TECTEH			21H00041	600UL
3635	95	54	0.23	122	INR	3	06C	+35.70	TECTEH			21H00042	600UL
3636	97	54							TECTEH			21H00041	600UL
3637	99	54	0.44	137	INR	3	01H	+26.24	TECTEH			21H00042	600UL
3638	101	54	0.48	85	INR	6	TSH	+11.67	TECTEH			21H00041	600UL
3639			0.29	85	INR	6	05H	+6.28	TECTEH			21H00041	600UL
3640			0.48	68	INR	6	05H	+31.11	TECTEH			21H00041	600UL
3641			0.37	65	INR	6	F05	+4.21	TECTEH			21H00041	600UL
3642			0.44	68	INR	6	F06	+5.59	TECTEH			21H00041	600UL
3643			0.43	75	INR	6	02C	+8.47	TECTEH			21H00041	600UL
3644			0.62	88	INR	6	TSC	+9.78	TECTEH			21H00041	600UL
3645	103	54	0.64	130	INR	3	06C	+31.89	TECTEH			21H00042	600UL
3646	105	54							TECTEH			21H00041	600UL
3647	107	54							TECTEH			21H00042	600UL
3648	109	54							TECTEH			21H00041	600UL
3649	111	54	0.46	122	INR	3	05H	+3.50	TECTEH			21H00042	600UL
3650	113	54							TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3651	115	54							TECTEH			21H00042	600UL
3652	117	54	0.42	83	INR	6	F08	+5.60	TECTEH			21H00041	600UL
3653					INF		F09	+10.99	TECTEH	HR		21H00041	600UL
3654			0.40	75	INR	6	03C	+3.31	TECTEH			21H00041	600UL
3655	119	54							TECTEH			21H00042	600UL
3656	121	54							TECTEH			21H00041	600UL
3657	123	54							TECTEH			21H00042	600UL
3658	125	54							TECTEH			21H00041	600UL
3659	127	54							TECTEH			21H00041	600UL
3660	129	54							TECTEH			21H00042	600UL
3661	131	54	0.46	120	INR	3	05H	+3.01	TECTEH			21H00042	600UL
3662			0.27	119	INR	3	06H	+25.38	TECTEH			21H00042	600UL
3663			0.58	114	INR	3	07H	+3.42	TECTEH			21H00042	600UL
3664			1.23	71	INR	3	F04	+11.30	TECTEH			21H00042	600UL
3665			0.56	151	INR	3	F05	+14.65	TECTEH			21H00042	600UL
3666			0.31	70	INR	3	F06	+5.38	TECTEH			21H00042	600UL
3667					INF		F07	+14.13	TECTEH	HR		21H00042	600UL
3668			0.73	76	INR	6	F07	+16.76	TECTEH			21H00042	600UL
3669			0.69	142	INR	3	F07	+17.73	TECTEH			21H00042	600UL
3670					INF		F08	+3.29	TECTEH	HR		21H00042	600UL
3671					INF		F08	+18.36	TECTEH	HR		21H00042	600UL
3672			1.80	213	INR	6	F09	+0.00	TECTEH			21H00042	600UL
3673			0.83	78	INR	6	06C	+34.64	TECTEH			21H00042	600UL
3674			0.80	77	INR	6	06C	+34.72	TECTEH			21H00042	600UL
3675			0.51	119	INR	3	06C	+37.04	TECTEH			21H00042	600UL
3676			0.37	133	INR	3	04C	+3.47	TECTEH			21H00042	600UL
3677			0.33	137	INR	3	04C	+25.37	TECTEH			21H00042	600UL
3678			0.31	118	INR	3	04C	+37.49	TECTEH			21H00042	600UL
3679			0.75	131	INR	3	01C	+25.58	TECTEH			21H00042	600UL
3680	2	55							TECTEH			21H00028	600UL
3681	4	55	0.68	62	INR	6	02C	+0.00	TECTEH			21H00026	600UL
3682	6	55							TECTEH			21H00026	600UL
3683	8	55							TECTEH			21H00026	600UL
3684	10	55							TECTEH			21H00026	600UL
3685	12	55							TECTEH			21H00027	600UL
3686	14	55							TECTEH			21H00026	600UL
3687	16	55							TECTEH			21H00027	600UL
3688	18	55							TECTEH			21H00026	600UL
3689	20	55							TECTEH			21H00027	600UL
3690	22	55							TECTEH			21H00026	600UL
3691	24	55							TECTEH			21H00026	600UL
3692	26	55							TECTEH			21H00065	600UL
3693	28	55							TECTEH			21H00064	600UL
3694	30	55							TECTEH			21H00065	600UL
3695	32	55							TECTEH			21H00064	600UL
3696	34	55							TECTEH			21H00065	600UL
3697	36	55							TECTEH			21H00064	600UL
3698	38	55							TECTEH			21H00065	600UL
3699	40	55							TECTEH			21H00064	600UL
3700	42	55	0.28	85	INR	3	TSH	+19.87	TECTEH			21H00065	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3701	44	55	0.60	85	INR	6	TSC	+10.77	TECTEH			21H00064	600UL
3702	46	55							TECTEH			21H00065	600UL
3703	48	55							TECTEH			21H00064	600UL
3704	50	55							TECTEH			21H00065	600UL
3705	52	55							TECTEH			21H00064	600UL
3706	54	55	0.39	61	INR	6	F09	+8.33	TECTEH			21H00065	600UL
3707					INF		F10	+4.10	TECTEH	HR		21H00065	600UL
3708			0.55	74	INR	6	02C	+25.25	TECTEH			21H00065	600UL
3709			0.61	68	INR	6	02C	+26.00	TECTEH			21H00065	600UL
3710	56	55							TECTEH			21H00064	600UL
3711	58	55							TECTEH			21H00065	600UL
3712	60	55	0.77	81	INR	6	TSC	+15.31	TECTEH			21H00064	600UL
3713	62	55							TECTEH			21H00065	600UL
3714	64	55							TECTEH			21H00064	600UL
3715	66	55							TECTEH			21H00065	600UL
3716	68	55							TECTEH			21H00064	600UL
3717	70	55							TECTEH			21H00065	600UL
3718	72	55							TECTEH			21H00064	600UL
3719	74	55							TECTEH			21H00065	600UL
3720	76	55	0.63	77	INR	6	03H	+13.16	TECTEH			21H00064	600UL
3721	78	55							TECTEH			21H00065	600UL
3722	80	55	0.50	73	INR	6	03C	+38.70	TECTEH			21H00064	600UL
3723	82	55							TECTEH			21H00041	600UL
3724	84	55	0.46	135	INR	3	03H	+6.32	TECTEH			21H00042	600UL
3725			0.62	131	INR	3	03H	+19.42	TECTEH			21H00042	600UL
3726	86	55	0.75	77	INR	6	06H	+29.60	TECTEH			21H00041	600UL
3727	88	55							TECTEH			21H00042	600UL
3728	90	55	0.79	82	INR	6	06C	+7.51	TECTEH			21H00041	600UL
3729	92	55							TECTEH			21H00042	600UL
3730	94	55	0.36	88	INR	6	02H	+10.94	TECTEH			21H00041	600UL
3731			0.48	40	INR	6	F02	+7.54	TECTEH			21H00041	600UL
3732			0.46	78	INR	6	02C	+8.04	TECTEH			21H00041	600UL
3733	96	55	0.37	148	INR	3	TSC	+18.20	TECTEH			21H00042	600UL
3734	98	55							TECTEH			21H00041	600UL
3735	100	55							TECTEH			21H00042	600UL
3736	102	55	0.33	66	INR	6	05H	+12.02	TECTEH			21H00041	600UL
3737			0.43	75	INR	6	07H	+4.57	TECTEH			21H00041	600UL
3738	104	55							TECTEH			21H00042	600UL
3739	106	55	0.34	77	INR	6	TSC	+11.92	TECTEH			21H00041	600UL
3740	108	55							TECTEH			21H00042	600UL
3741	110	55							TECTEH			21H00041	600UL
3742	112	55							TECTEH			21H00042	600UL
3743	114	55	0.42	82	INR	6	TSH	+6.98	TECTEH			21H00041	600UL
3744			0.47	77	INR	6	TSC	+13.15	TECTEH			21H00041	600UL
3745	116	55							TECTEH			21H00042	600UL
3746	118	55							TECTEH			21H00041	600UL
3747	120	55							TECTEH			21H00042	600UL
3748	122	55	0.32	77	INR	6	05H	+36.53	TECTEH			21H00041	600UL
3749	124	55							TECTEH			21H00041	600UL
3750	126	55							TECTEH			21H00042	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3751	128	55	0.42	68	INR	6	01H	+31.54	TECTEH			21H00041	600UL
3752			0.43	55	INR	6	F10	+12.45	TECTEH			21H00041	600UL
3753					INF		F11	+5.79	TECTEH	HR		21H00041	600UL
3754					INF		F11	+12.92	TECTEH	HR		21H00041	600UL
3755	130	55	0.29	113	INR	3	TSH	+6.26	TECTEH			21H00042	600UL
3756			0.28	116	INR	3	TSH	+10.27	TECTEH			21H00042	600UL
3757			0.38	133	INR	3	TSH	+13.24	TECTEH			21H00042	600UL
3758			0.50	124	INR	3	02H	+18.39	TECTEH			21H00042	600UL
3759			0.30	139	INR	3	02H	+24.67	TECTEH			21H00042	600UL
3760			0.21	135	INR	3	05H	+6.25	TECTEH			21H00042	600UL
3761			0.23	108	INR	3	05H	+39.39	TECTEH			21H00042	600UL
3762			0.29	101	INR	3	07H	+14.81	TECTEH			21H00042	600UL
3763			0.35	154	INR	3	F06	+3.54	TECTEH			21H00042	600UL
3764			0.38	87	INR	3	F06	+11.42	TECTEH			21H00042	600UL
3765					INF		F07	+5.58	TECTEH	HR		21H00042	600UL
3766			0.44	149	INR	3	05C	+22.83	TECTEH			21H00042	600UL
3767			0.29	150	INR	3	03C	+12.83	TECTEH			21H00042	600UL
3768			0.28	124	INR	3	01C	+21.14	TECTEH			21H00042	600UL
3769	132	55							TECTEH			21H00040	600UL
3770	1	56							TECTEH			21H00028	600UL
3771	3	56							TECTEH			21H00028	600UL
3772	5	56	0.28	89	INR	6	02H	+26.54	TECTEH			21H00026	600UL
3773			0.49	82	INR	6	04C	+9.60	TECTEH			21H00026	600UL
3774	7	56							TECTEH			21H00026	600UL
3775	9	56							TECTEH			21H00026	600UL
3776	11	56							TECTEH			21H00026	600UL
3777	13	56							TECTEH			21H00027	600UL
3778	15	56							TECTEH			21H00026	600UL
3779	17	56							TECTEH			21H00027	600UL
3780	19	56							TECTEH			21H00026	600UL
3781	21	56			INF		F01	+6.17	TECTEH	HR		21H00027	600UL
3782			5.20	184	INR	P1	F05	+2.57	TECTEH			21H00027	600UL
3783	23	56			INF		F05	+0.31	TECTEH	HR		21H00026	600UL
3784			4.27	184	INR	P1	F05	+2.40	TECTEH			21H00026	600UL
3785	25	56			INF		F01	+8.01	TECTEH	HR		21H00065	600UL
3786			0.60	12	INR	6	F05	+0.84	TECTEH			21H00065	600UL
3787	27	56							TECTEH			21H00064	600UL
3788	29	56							TECTEH			21H00065	600UL
3789	31	56	0.53	41	INR	6	F06	+9.47	TECTEH			21H00064	600UL
3790					INF		F07	+3.11	TECTEH	HR		21H00064	600UL
3791					INF		F07	+8.54	TECTEH	HR		21H00064	600UL
3792	33	56	4.31	181	INR	1	F01	+6.14	TECTEH			21H00065	600UL
3793					INF		F01	+7.83	TECTEH	HR		21H00065	600UL
3794					INF		F04	+5.20	TECTEH	HR		21H00065	600UL
3795	35	56							TECTEH			21H00064	600UL
3796	37	56							TECTEH			21H00065	600UL
3797	39	56	0.68	73	INR	6	03H	+5.40	TECTEH			21H00064	600UL
3798					INF		06H	+13.17	TECTEH	HR		21H00064	600UL
3799			0.55	64	INR	6	06H	+14.83	TECTEH			21H00064	600UL
3800			0.50	72	INR	6	05C	+28.61	TECTEH			21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3801	41	56							TECTEH			21H00065	600UL
3802	43	56	0.50	83	INR	6	05C	+17.57	TECTEH			21H00064	600UL
3803	45	56	0.78	118	INR	6	F09	+5.26	TECTEH			21H00065	600UL
3804					INF		F12	+4.21	TECTEH	HR		21H00065	600UL
3805	47	56	0.33	67	INR	6	04H	+10.42	TECTEH			21H00064	600UL
3806			0.56	74	INR	6	05H	+7.28	TECTEH			21H00064	600UL
3807			0.59	102	INR	6	F08	+5.89	TECTEH			21H00064	600UL
3808					INF		F09	+4.90	TECTEH	HR		21H00064	600UL
3809			0.38	62	INR	6	06C	+13.45	TECTEH			21H00064	600UL
3810	49	56							TECTEH			21H00065	600UL
3811	51	56							TECTEH			21H00064	600UL
3812	53	56	0.77	75	INR	6	TSH	+2.88	TECTEH			21H00065	600UL
3813	55	56	0.42	88	INR	6	03H	+24.58	TECTEH			21H00064	600UL
3814	57	56							TECTEH			21H00065	600UL
3815	59	56							TECTEH			21H00064	600UL
3816	61	56			INF		F01	+3.34	TECTEH	HR		21H00065	600UL
3817					INF		F01	+4.67	TECTEH	HR		21H00065	600UL
3818			10.58	183	DNT	P1	F03	-1.75	TECTEH			21H00065	600UL
3819			0.41	77	INR	6	04C	+10.91	TECTEH			21H00065	600UL
3820					INF		03C	+31.47	TECTEH	HR		21H00065	600UL
3821			0.44	72	INR	6	03C	+33.52	TECTEH			21H00065	600UL
3822					INF		01C	+21.81	TECTEH	HR		21H00065	600UL
3823			0.48	67	INR	6	01C	+23.31	TECTEH			21H00065	600UL
3824	63	56	0.49	78	INR	6	06C	+36.42	TECTEH			21H00064	600UL
3825	65	56							TECTEH			21H00065	600UL
3826	67	56	0.44	79	INR	6	02H	+15.97	TECTEH			21H00064	600UL
3827	69	56	0.37	85	INR	6	02H	+13.75	TECTEH			21H00065	600UL
3828			0.74	70	NQH	3	F04	+11.99	TECTEH			21H00065	600UL
3829			0.75	33	INR	6	F06	+3.94	TECTEH			21H00065	600UL
3830			0.41	71	INR	6	F08	+3.60	TECTEH			21H00065	600UL
3831	71	56	0.67	61	INR	6	F03	+9.95	TECTEH			21H00064	600UL
3832			1.21	81	INR	6	F05	+1.07	TECTEH			21H00064	600UL
3833	73	56							TECTEH			21H00065	600UL
3834	75	56							TECTEH			21H00064	600UL
3835	77	56							TECTEH			21H00065	600UL
3836	79	56							TECTEH			21H00064	600UL
3837	81	56							TECTEH			21H00064	600UL
3838	83	56							TECTEH			21H00042	600UL
3839	85	56							TECTEH			21H00041	600UL
3840	87	56							TECTEH			21H00042	600UL
3841	89	56							TECTEH			21H00041	600UL
3842	91	56	0.29	114	INR	3	05H	+30.64	TECTEH			21H00042	600UL
3843			0.56	122	INR	3	F12	+3.13	TECTEH			21H00042	600UL
3844					INF		07C	+12.31	TECTEH	HR		21H00042	600UL
3845	93	56							TECTEH			21H00041	600UL
3846	95	56							TECTEH			21H00042	600UL
3847	97	56							TECTEH			21H00041	600UL
3848	99	56							TECTEH			21H00042	600UL
3849	101	56	0.33	58	INR	6	F04	+3.48	TECTEH			21H00041	600UL
3850			0.44	78	INR	6	05C	+11.65	TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3851	103	56							TECTEH			21H00042	600UL
3852	105	56							TECTEH			21H00041	600UL
3853	107	56							TECTEH			21H00042	600UL
3854	109	56							TECTEH			21H00041	600UL
3855	111	56	0.29	76	INR	6	TSC	+20.79	TECTEH			21H00042	600UL
3856	113	56	0.59	81	INR	6	06H	+6.29	TECTEH			21H00041	600UL
3857					INF		03C	+24.81	TECTEH	HR		21H00041	600UL
3858			0.31	83	INR	6	03C	+28.21	TECTEH			21H00041	600UL
3859	115	56	0.64	155	INR	3	F10	+3.00	TECTEH			21H00042	600UL
3860					INF		F11	+3.32	TECTEH	HR		21H00042	600UL
3861					INF		F11	+12.98	TECTEH	HR		21H00042	600UL
3862			0.22	87	INR	3	04C	+2.81	TECTEH			21H00042	600UL
3863	117	56							TECTEH			21H00041	600UL
3864	119	56							TECTEH			21H00041	600UL
3865	121	56							TECTEH			21H00042	600UL
3866	123	56							TECTEH			21H00041	600UL
3867	125	56							TECTEH			21H00042	600UL
3868	127	56	0.42	80	INR	6	01H	+29.02	TECTEH			21H00041	600UL
3869			0.59	84	INR	6	02H	+26.69	TECTEH			21H00041	600UL
3870			0.58	82	INR	6	03H	+12.33	TECTEH			21H00041	600UL
3871			0.50	74	INR	6	03H	+17.70	TECTEH			21H00041	600UL
3872			0.28	82	INR	6	03H	+25.74	TECTEH			21H00041	600UL
3873			0.41	84	INR	6	04H	+28.93	TECTEH			21H00041	600UL
3874			0.36	67	INR	6	05H	+23.30	TECTEH			21H00041	600UL
3875			0.34	66	INR	6	05H	+28.55	TECTEH			21H00041	600UL
3876			0.24	64	INR	6	F05	+16.00	TECTEH			21H00041	600UL
3877			0.50	88	INR	6	F07	+13.78	TECTEH			21H00041	600UL
3878					INF		F08	+5.20	TECTEH	HR		21H00041	600UL
3879	129	56	0.23	129	INR	3	01H	+27.38	TECTEH			21H00042	600UL
3880			0.32	135	INR	3	04H	+17.42	TECTEH			21H00042	600UL
3881			0.35	37	INR	3	F08	+8.46	TECTEH			21H00042	600UL
3882					INF		F09	+10.10	TECTEH	HR		21H00042	600UL
3883			0.33	115	INR	3	03C	+33.50	TECTEH			21H00042	600UL
3884			0.33	139	INR	3	02C	+9.01	TECTEH			21H00042	600UL
3885			0.30	136	INR	3	01C	+9.85	TECTEH			21H00042	600UL
3886	131	56							TECTEH			21H00042	600UL
3887	2	57							TECTEH			21H00028	600UL
3888	4	57							TECTEH			21H00026	600UL
3889	6	57							TECTEH			21H00026	600UL
3890	8	57							TECTEH			21H00026	600UL
3891	10	57							TECTEH			21H00027	600UL
3892	12	57							TECTEH			21H00026	600UL
3893	14	57	0.32	75	INR	6	05C	+15.90	TECTEH			21H00027	600UL
3894	16	57							TECTEH			21H00026	600UL
3895	18	57							TECTEH			21H00027	600UL
3896	20	57							TECTEH			21H00026	600UL
3897	22	57			INF		F05	+1.90	TECTEH	HR		21H00027	600UL
3898	24	57							TECTEH			21H00026	600UL
3899	26	57							TECTEH			21H00065	600UL
3900	28	57							TECTEH			21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3901	30	57							TECTEH			21H00065	600UL
3902	32	57							TECTEH			21H00064	600UL
3903	34	57							TECTEH			21H00065	600UL
3904	36	57							TECTEH			21H00064	600UL
3905	38	57							TECTEH			21H00065	600UL
3906	40	57	0.46	80	INR	6	02H	+31.48	TECTEH			21H00064	600UL
3907			0.57	70	INR	6	04H	+7.04	TECTEH			21H00064	600UL
3908	42	57	0.47	63	INR	6	F06	+10.70	TECTEH			21H00065	600UL
3909					INF		F07	+1.17	TECTEH	HR		21H00065	600UL
3910	44	57	0.38	77	INR	6	03C	+25.02	TECTEH			21H00064	600UL
3911			0.28	81	INR	6	01C	+26.16	TECTEH			21H00064	600UL
3912	46	57							TECTEH			21H00065	600UL
3913	48	57	0.52	43	INR	6	05H	+16.74	TECTEH			21H00064	600UL
3914	50	57							TECTEH			21H00065	600UL
3915	52	57			INF		02C	+32.77	TECTEH	HR		21H00064	600UL
3916			0.42	72	INR	6	02C	+34.63	TECTEH			21H00064	600UL
3917	54	57			INF		TSH	+2.70	TECTEH	HR		21H00065	600UL
3918					INF		01H	+9.88	TECTEH	HR		21H00065	600UL
3919			0.53	76	INR	6	03H	+36.52	TECTEH			21H00065	600UL
3920			0.99	76	INR	6	04H	+8.00	TECTEH			21H00065	600UL
3921					INF		F09	+5.08	TECTEH	HR		21H00065	600UL
3922			0.63	76	INR	6	05C	+3.34	TECTEH			21H00065	600UL
3923	56	57	0.38	68	INR	6	01H	+9.51	TECTEH			21H00064	600UL
3924			0.45	80	INR	6	01H	+11.76	TECTEH			21H00064	600UL
3925			0.41	89	INR	6	04H	+8.69	TECTEH			21H00064	600UL
3926	58	57	0.29	83	INR	6	01H	+3.77	TECTEH			21H00065	600UL
3927					INF		F08	+7.96	TECTEH	HR		21H00065	600UL
3928			0.41	134	INR	6	F09	+5.92	TECTEH			21H00065	600UL
3929					INF		F10	+8.86	TECTEH	HR		21H00065	600UL
3930	60	57	0.38	80	INR	6	01H	+16.70	TECTEH			21H00064	600UL
3931			0.40	64	INR	6	02H	+9.66	TECTEH			21H00064	600UL
3932	62	57							TECTEH			21H00065	600UL
3933	64	57							TECTEH			21H00064	600UL
3934	66	57							TECTEH			21H00065	600UL
3935	68	57	0.56	133	INR	6	F08	+2.04	TECTEH			21H00064	600UL
3936					INF		F09	+1.88	TECTEH	HR		21H00064	600UL
3937					INF		F09	+9.25	TECTEH	HR		21H00064	600UL
3938	70	57	0.42	74	INR	6	04C	+10.44	TECTEH			21H00065	600UL
3939			0.35	91	INR	6	02C	+16.09	TECTEH			21H00065	600UL
3940	72	57							TECTEH			21H00064	600UL
3941	74	57	0.49	77	INR	6	F02	+4.52	TECTEH			21H00065	600UL
3942					INF		F02	+6.15	TECTEH	HR		21H00065	600UL
3943	76	57	0.45	74	INR	6	02H	+27.36	TECTEH			21H00064	600UL
3944			0.50	79	INR	6	06C	+26.85	TECTEH			21H00064	600UL
3945	78	57	0.41	76	INR	6	05H	+10.94	TECTEH			21H00065	600UL
3946	80	57							TECTEH			21H00064	600UL
3947	82	57	0.42	167	INR	3	F06	+12.59	TECTEH			21H00042	600UL
3948					INF		F07	+1.53	TECTEH	HR		21H00042	600UL
3949			0.35	128	INR	3	03C	+38.33	TECTEH			21H00042	600UL
3950	84	57	0.30	126	INR	3	04H	+9.68	TECTEH			21H00042	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
3951			0.33	140	INR	3	04H	+14.44	TECTEH			21H00042	600UL
3952			0.44	141	INR	3	F01	+3.95	TECTEH			21H00042	600UL
3953			1.07	149	INR	3	F05	+12.64	TECTEH			21H00042	600UL
3954	86	57	0.41	69	INR	6	05H	+27.02	TECTEH			21H00041	600UL
3955	88	57							TECTEH			21H00042	600UL
3956	90	57	0.45	68	INR	6	F03	+11.01	TECTEH			21H00041	600UL
3957					INF		F03	+13.33	TECTEH	HR		21H00041	600UL
3958			0.42	114	INR	6	F03	+15.25	TECTEH			21H00041	600UL
3959			1.28	72	INR	6	05C	+33.54	TECTEH			21H00041	600UL
3960	92	57							TECTEH			21H00042	600UL
3961	94	57	0.32	67	INR	6	05C	+18.53	TECTEH			21H00041	600UL
3962			0.35	68	INR	6	04C	+14.35	TECTEH			21H00041	600UL
3963			0.39	72	INR	6	02C	+29.74	TECTEH			21H00041	600UL
3964	96	57							TECTEH			21H00042	600UL
3965	98	57							TECTEH			21H00041	600UL
3966	100	57							TECTEH			21H00042	600UL
3967	102	57							TECTEH			21H00041	600UL
3968	104	57							TECTEH			21H00042	600UL
3969	106	57	0.62	81	INR	6	02H	+3.78	TECTEH			21H00041	600UL
3970			1.04	78	INR	6	02C	+2.24	TECTEH			21H00041	600UL
3971			0.28	81	INR	6	02C	+5.06	TECTEH			21H00041	600UL
3972			0.82	79	INR	6	02C	+9.00	TECTEH			21H00041	600UL
3973			0.40	76	INR	6	02C	+11.15	TECTEH			21H00041	600UL
3974			0.19	90	INR	6	02C	+37.02	TECTEH			21H00041	600UL
3975	108	57	2.36	203	INR	6	04C	+0.05	TECTEH			21H00042	600UL
3976	110	57	0.34	127	INR	6	F06	+5.24	TECTEH			21H00041	600UL
3977	112	57							TECTEH			21H00042	600UL
3978	114	57							TECTEH			21H00041	600UL
3979	116	57							TECTEH			21H00042	600UL
3980	118	57							TECTEH			21H00041	600UL
3981	120	57							TECTEH			21H00041	600UL
3982	122	57							TECTEH			21H00042	600UL
3983	124	57							TECTEH			21H00041	600UL
3984	126	57	0.55	139	INR	3	02H	+21.42	TECTEH			21H00042	600UL
3985	128	57							TECTEH			21H00041	600UL
3986	130	57							TECTEH			21H00042	600UL
3987	132	57							TECTEH			21H00040	600UL
3988	1	58							TECTEH			21H00028	600UL
3989	3	58							TECTEH			21H00028	600UL
3990	5	58							TECTEH			21H00027	600UL
3991	7	58							TECTEH			21H00026	600UL
3992	9	58							TECTEH			21H00027	600UL
3993	11	58							TECTEH			21H00026	600UL
3994	13	58							TECTEH			21H00027	600UL
3995	15	58	0.29	46	INR	6	04H	+8.57	TECTEH			21H00026	600UL
3996	17	58							TECTEH			21H00027	600UL
3997	19	58							TECTEH			21H00026	600UL
3998	21	58			INF		F01	+6.95	TECTEH	HR		21H00027	600UL
3999					INF		F05	+4.35	TECTEH	HR		21H00027	600UL
4000	23	58							TECTEH			21H00026	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4001	25	58							TECTEH			21H00065	600UL
4002	27	58							TECTEH			21H00064	600UL
4003	29	58							TECTEH			21H00065	600UL
4004	31	58							TECTEH			21H00064	600UL
4005	33	58							TECTEH			21H00065	600UL
4006	35	58							TECTEH			21H00064	600UL
4007	37	58	0.50	72	INR	6	02C	+3.99	TECTEH			21H00065	600UL
4008	39	58	0.44	68	INR	6	02C	+34.62	TECTEH			21H00064	600UL
4009	41	58							TECTEH			21H00065	600UL
4010	43	58	0.33	73	INR	6	02H	+16.47	TECTEH			21H00064	600UL
4011			0.46	60	INR	6	06C	+30.42	TECTEH			21H00064	600UL
4012			0.48	92	INR	6	03C	+18.13	TECTEH			21H00064	600UL
4013	45	58							TECTEH			21H00065	600UL
4014	47	58							TECTEH			21H00064	600UL
4015	49	58	0.38	86	INR	6	01C	+28.15	TECTEH			21H00065	600UL
4016	51	58							TECTEH			21H00064	600UL
4017	53	58	0.36	105	NQH	3	06H	+5.67	TECTEH			21H00065	600UL
4018	55	58	0.38	74	INR	6	04C	+30.36	TECTEH			21H00064	600UL
4019			0.47	76	INR	6	03C	+36.10	TECTEH			21H00064	600UL
4020	57	58	0.64	116	INR	6	F03	+5.67	TECTEH			21H00065	600UL
4021	59	58							TECTEH			21H00064	600UL
4022	61	58	0.67	59	INR	6	F07	+5.63	TECTEH			21H00065	600UL
4023					INF		F08	+6.40	TECTEH	HR		21H00065	600UL
4024	63	58							TECTEH			21H00064	600UL
4025	65	58							TECTEH			21H00065	600UL
4026	67	58							TECTEH			21H00064	600UL
4027	69	58							TECTEH			21H00065	600UL
4028	71	58	1.16	79	INR	6	03H	+9.08	TECTEH			21H00064	600UL
4029	73	58	0.40	81	INR	6	TSH	+20.41	TECTEH			21H00065	600UL
4030			0.45	76	INR	6	03H	+11.21	TECTEH			21H00065	600UL
4031			0.37	69	INR	6	04H	+6.44	TECTEH			21H00065	600UL
4032			0.50	70	INR	6	05H	+10.70	TECTEH			21H00065	600UL
4033			0.42	58	INR	6	02C	+19.22	TECTEH			21H00065	600UL
4034			0.38	78	INR	6	02C	+24.39	TECTEH			21H00065	600UL
4035	75	58							TECTEH			21H00064	600UL
4036	77	58							TECTEH			21H00065	600UL
4037	79	58							TECTEH			21H00064	600UL
4038	81	58							TECTEH			21H00064	600UL
4039	83	58							TECTEH			21H00042	600UL
4040	85	58							TECTEH			21H00041	600UL
4041	87	58							TECTEH			21H00042	600UL
4042	89	58	0.39	84	INR	6	03C	+17.19	TECTEH			21H00041	600UL
4043			0.64	78	INR	6	02C	+29.45	TECTEH			21H00041	600UL
4044	91	58	0.19	130	INR	3	04C	+18.47	TECTEH			21H00042	600UL
4045					INF		03C	+17.19	TECTEH	PVI		21H00042	600UL
4046					INF		02C	+29.45	TECTEH	PVI		21H00042	600UL
4047	93	58	1.18	84	INR	6	04H	+34.40	TECTEH			21H00041	600UL
4048					INF		04C	+18.47	TECTEH	PVI		21H00041	600UL
4049	95	58			INF		04H	+38.00	TECTEH	PVI		21H00042	600UL
4050	97	58							TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4051	99	58							TECTEH			21H00042	600UL
4052	101	58	0.78	71	INR	6	05C	+8.10	TECTEH			21H00041	600UL
4053	103	58			INF		05C	+8.10	TECTEH	PVI		21H00042	600UL
4054	105	58							TECTEH			21H00041	600UL
4055	107	58							TECTEH			21H00042	600UL
4056	109	58							TECTEH			21H00041	600UL
4057	111	58	0.27	140	INR	3	F02	+8.93	TECTEH			21H00042	600UL
4058			0.35	38	INR	3	F03	+2.25	TECTEH			21H00042	600UL
4059			0.33	115	INR	3	F06	+14.45	TECTEH			21H00042	600UL
4060					INF		F07	+2.98	TECTEH	HR		21H00042	600UL
4061	113	58			INF		F02	+8.93	TECTEH	PVI		21H00041	600UL
4062					INF		F03	+2.25	TECTEH	PVI		21H00041	600UL
4063					INF		F07	+2.98	TECTEH	PVI		21H00041	600UL
4064	115	58							TECTEH			21H00042	600UL
4065	117	58	0.29	98	INR	6	05C	+20.93	TECTEH			21H00041	600UL
4066	119	58			INF		05C	+20.93	TECTEH	PVI		21H00041	600UL
4067	121	58							TECTEH			21H00042	600UL
4068	123	58							TECTEH			21H00041	600UL
4069	125	58							TECTEH			21H00042	600UL
4070	127	58	2.58		ADS	6	F05	+11.75 TO+24.05	TECTEH			21H00041	600UL
4071			0.90	74	INR	6	F08	+6.70	TECTEH			21H00041	600UL
4072					INF		F09	+6.54	TECTEH	HR		21H00041	600UL
4073					INF		F09	+12.19	TECTEH	HR		21H00041	600UL
4074	129	58	0.33	134	INR	3	01H	+20.77	TECTEH			21H00042	600UL
4075			0.28	115	INR	3	02H	+32.01	TECTEH			21H00042	600UL
4076			0.28	116	INR	3	03H	+29.01	TECTEH			21H00042	600UL
4077			0.55	120	INR	3	04H	+16.17	TECTEH			21H00042	600UL
4078			0.33	92	INR	3	06H	+13.12	TECTEH			21H00042	600UL
4079			0.19	100	INR	3	06C	+32.78	TECTEH			21H00042	600UL
4080	131	58							TECTEH			21H00041	600UL
4081	133	58	0.78	50	INR	6	02C	+1.96	TECTEH			21H00040	600UL
4082	2	59							TECTEH			21H00028	600UL
4083	4	59							TECTEH			21H00026	600UL
4084	6	59							TECTEH			21H00027	600UL
4085	8	59							TECTEH			21H00026	600UL
4086	10	59							TECTEH			21H00027	600UL
4087	12	59							TECTEH			21H00026	600UL
4088	14	59							TECTEH			21H00027	600UL
4089	16	59							TECTEH			21H00026	600UL
4090	18	59							TECTEH			21H00027	600UL
4091	20	59							TECTEH			21H00026	600UL
4092	22	59	0.50	72	INR	6	05H	+19.00	TECTEH			21H00027	600UL
4093			5.26	183	INR	P1	F05	-1.82	TECTEH			21H00027	600UL
4094					INF		F05	+1.13	TECTEH	HR		21H00027	600UL
4095			0.40	71	INR	6	03C	+4.63	TECTEH			21H00027	600UL
4096	24	59	0.32	83	INR	6	04H	+38.70	TECTEH			21H00027	600UL
4097	26	59							TECTEH			21H00065	600UL
4098	28	59							TECTEH			21H00064	600UL
4099	30	59							TECTEH			21H00065	600UL
4100	32	59	0.49	63	INR	6	05H	+4.39	TECTEH			21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4101	34	59							TECTEH			21H00065	600UL
4102	36	59							TECTEH			21H00064	600UL
4103	38	59	0.40	75	INR	6	02H	+15.04	TECTEH			21H00065	600UL
4104	40	59	0.68	90	INR	6	01H	+3.13	TECTEH			21H00064	600UL
4105			0.39	31	INR	6	05H	+23.98	TECTEH			21H00064	600UL
4106	42	59							TECTEH			21H00065	600UL
4107	44	59	0.39	69	INR	6	05H	+7.48	TECTEH			21H00064	600UL
4108			0.46	93	INR	6	02C	+17.83	TECTEH			21H00064	600UL
4109			0.42	89	INR	6	02C	+20.66	TECTEH			21H00064	600UL
4110	46	59							TECTEH			21H00065	600UL
4111	48	59							TECTEH			21H00064	600UL
4112	50	59	0.46	39	INR	6	06H	+35.05	TECTEH			21H00065	600UL
4113	52	59							TECTEH			21H00064	600UL
4114	54	59	0.44	75	INR	6	02H	+7.72	TECTEH			21H00065	600UL
4115			0.50	69	INR	6	03C	+21.56	TECTEH			21H00065	600UL
4116	56	59			INF		TSC	+20.27	TECTEH	HR		21H00064	600UL
4117			0.43	106	INR	6	TSC	+21.62	TECTEH			21H00064	600UL
4118	58	59	0.36	67	INR	6	F04	+3.78	TECTEH			21H00065	600UL
4119					INF		F04	+6.06	TECTEH	HR		21H00065	600UL
4120			0.81	96	INR	6	02C	+15.75	TECTEH			21H00065	600UL
4121			0.35	97	INR	6	02C	+39.64	TECTEH			21H00065	600UL
4122	60	59	0.66	84	INR	6	04H	+4.24	TECTEH			21H00064	600UL
4123	62	59							TECTEH			21H00065	600UL
4124	64	59	0.39	81	INR	6	01H	+26.81	TECTEH			21H00064	600UL
4125			0.43	82	INR	6	01C	+20.28	TECTEH			21H00064	600UL
4126	66	59							TECTEH			21H00065	600UL
4127	68	59							TECTEH			21H00064	600UL
4128	70	59							TECTEH			21H00065	600UL
4129	72	59							TECTEH			21H00064	600UL
4130	74	59							TECTEH			21H00065	600UL
4131	76	59							TECTEH			21H00064	600UL
4132	78	59	0.43	68	INR	6	04H	+4.82	TECTEH			21H00065	600UL
4133			0.80	57	INR	6	03C	-0.90	TECTEH			21H00065	600UL
4134	80	59							TECTEH			21H00064	600UL
4135	82	59							TECTEH			21H00041	600UL
4136	84	59							TECTEH			21H00042	600UL
4137	86	59	0.33	81	INR	6	06H	+38.89	TECTEH			21H00041	600UL
4138			0.30	85	INR	6	03C	+34.07	TECTEH			21H00041	600UL
4139	88	59							TECTEH			21H00042	600UL
4140	90	59							TECTEH			21H00041	600UL
4141	92	59							TECTEH			21H00042	600UL
4142	94	59	0.39	74	INR	6	02H	+27.59	TECTEH			21H00041	600UL
4143			0.69	79	INR	6	04H	+34.16	TECTEH			21H00041	600UL
4144	96	59							TECTEH			21H00042	600UL
4145	98	59	0.61	69	INR	6	TSH	+17.39	TECTEH			21H00041	600UL
4146			0.54	71	INR	6	05H	+20.13	TECTEH			21H00041	600UL
4147	100	59	0.36	134	INR	3	06C	+32.87	TECTEH			21H00042	600UL
4148			0.36	152	INR	3	05C	+18.75	TECTEH			21H00042	600UL
4149			0.34	137	INR	3	01C	+11.85	TECTEH			21H00042	600UL
4150			0.36	141	INR	3	TSC	+13.89	TECTEH			21H00042	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4151	102	59	0.41	71	INR	6	TSC	+4.00	TECTEH			21H00041	600UL
4152	104	59	0.54	123	INR	3	TSH	+18.95	TECTEH			21H00042	600UL
4153	106	59	0.41	112	INR	6	F03	+6.33	TECTEH			21H00041	600UL
4154	108	59							TECTEH			21H00042	600UL
4155	110	59	0.40	86	INR	6	03H	+22.96	TECTEH			21H00041	600UL
4156	112	59							TECTEH			21H00041	600UL
4157	114	59	0.33	122	INR	3	02C	+29.68	TECTEH			21H00042	600UL
4158			0.37	122	INR	3	01C	+5.10	TECTEH			21H00042	600UL
4159	116	59							TECTEH			21H00041	600UL
4160	118	59							TECTEH			21H00042	600UL
4161	120	59							TECTEH			21H00041	600UL
4162	122	59							TECTEH			21H00042	600UL
4163	124	59	0.51	77	INR	6	06C	+10.42	TECTEH			21H00041	600UL
4164	126	59	0.59	166	INR	3	F07	+14.37	TECTEH			21H00042	600UL
4165					INF		F08	+5.24	TECTEH	HR		21H00042	600UL
4166			0.52	123	INR	3	01C	+26.53	TECTEH			21H00042	600UL
4167	128	59	0.43	82	INR	6	TSH	+15.30	TECTEH			21H00041	600UL
4168			0.93	74	INR	6	07H	+16.01	TECTEH			21H00041	600UL
4169			1.22	56	INR	6	F05	+16.95	TECTEH			21H00041	600UL
4170					INF		F06	-1.01	TECTEH	HR		21H00041	600UL
4171			0.41	69	INR	6	06C	+25.74	TECTEH			21H00041	600UL
4172	130	59	0.53	182	INR	3	01C	+10.31	TECTEH			21H00042	600UL
4173	132	59							TECTEH			21H00039	600UL
4174	134	59							TECTEH			21H00040	600UL
4175	1	60	0.34	84	INR	6	05H	+20.37	TECTEH			21H00028	600UL
4176	3	60							TECTEH			21H00028	600UL
4177	5	60							TECTEH			21H00026	600UL
4178	7	60							TECTEH			21H00026	600UL
4179	9	60							TECTEH			21H00027	600UL
4180	11	60							TECTEH			21H00027	600UL
4181	13	60							TECTEH			21H00027	600UL
4182	15	60							TECTEH			21H00027	600UL
4183	17	60							TECTEH			21H00027	600UL
4184	19	60							TECTEH			21H00027	600UL
4185	21	60	0.59	108	INR	6	01H	+31.57	TECTEH			21H00027	600UL
4186	23	60							TECTEH			21H00027	600UL
4187	25	60							TECTEH			21H00065	600UL
4188	27	60							TECTEH			21H00064	600UL
4189	29	60							TECTEH			21H00065	600UL
4190	31	60							TECTEH			21H00064	600UL
4191	33	60							TECTEH			21H00065	600UL
4192	35	60	0.86	75	INR	6	02C	+3.46	TECTEH			21H00064	600UL
4193			0.70	71	INR	6	TSC	+11.07	TECTEH			21H00064	600UL
4194			0.39	80	INR	6	TSC	+15.48	TECTEH			21H00064	600UL
4195	37	60							TECTEH			21H00065	600UL
4196	39	60	0.34	78	INR	6	01C	+3.09	TECTEH			21H00064	600UL
4197	41	60	0.42	35	INR	6	F12	+4.72	TECTEH			21H00065	600UL
4198					INF		07C	+3.75	TECTEH	HR		21H00065	600UL
4199	43	60	0.37	83	INR	6	01H	+7.12	TECTEH			21H00064	600UL
4200			0.37	84	INR	6	01H	+12.99	TECTEH			21H00064	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4201			0.38	51	INR	6	04H	+32.96	TECTEH			21H00064	600UL
4202			0.67	160	INR	6	F06	+0.00	TECTEH			21H00064	600UL
4203	45	60							TECTEH			21H00065	600UL
4204	47	60							TECTEH			21H00064	600UL
4205	49	60	0.32	75	INR	6	05C	+7.63	TECTEH			21H00065	600UL
4206	51	60	0.35	71	INR	6	05H	+19.10	TECTEH			21H00064	600UL
4207			0.39	74	INR	6	06C	+20.48	TECTEH			21H00064	600UL
4208	53	60							TECTEH			21H00065	600UL
4209	55	60	0.35	78	INR	6	TSC	+15.46	TECTEH			21H00064	600UL
4210	57	60	0.35	31	INR	6	04H	+39.79	TECTEH			21H00065	600UL
4211			0.43	71	INR	6	05C	+4.21	TECTEH			21H00065	600UL
4212			0.28	70	INR	6	04C	+6.68	TECTEH			21H00065	600UL
4213	59	60							TECTEH			21H00064	600UL
4214	61	60							TECTEH			21H00065	600UL
4215	63	60							TECTEH			21H00064	600UL
4216	65	60	1.56	76	INR	6	02C	+3.83	TECTEH			21H00065	600UL
4217	67	60	0.31	79	INR	6	02C	+23.60	TECTEH			21H00064	600UL
4218	69	60							TECTEH			21H00065	600UL
4219	71	60	0.70	72	INR	6	03C	+5.87	TECTEH			21H00064	600UL
4220	73	60	1.56	66	INR	6	02C	-0.28	TECTEH			21H00065	600UL
4221	75	60							TECTEH			21H00064	600UL
4222	77	60	0.47	92	INR	6	F08	+3.63	TECTEH			21H00065	600UL
4223					INF		F09	+9.02	TECTEH	HR		21H00065	600UL
4224			0.49	82	INR	6	04C	+28.71	TECTEH			21H00065	600UL
4225			0.39	123	INR	6	01C	+32.86	TECTEH			21H00065	600UL
4226	79	60			INF		F10	+8.80	TECTEH	HR		21H00064	600UL
4227			0.91	55	INR	6	F10	+10.10	TECTEH			21H00064	600UL
4228					INF		F11	+2.46	TECTEH	HR		21H00064	600UL
4229	81	60	0.28	86	INR	6	05H	+36.87	TECTEH			21H00064	600UL
4230	83	60							TECTEH			21H00042	600UL
4231	85	60	0.26	79	INR	6	04H	+27.48	TECTEH			21H00041	600UL
4232	87	60							TECTEH			21H00042	600UL
4233	89	60	0.92	69	INR	6	F01	+2.36	TECTEH			21H00041	600UL
4234			0.53	78	INR	6	03C	+2.92	TECTEH			21H00041	600UL
4235			0.46	122	NQH	3	TSC	+20.77	TECTEH			21H00041	600UL
4236	91	60							TECTEH			21H00042	600UL
4237	93	60							TECTEH			21H00041	600UL
4238	95	60							TECTEH			21H00042	600UL
4239	97	60							TECTEH			21H00041	600UL
4240	99	60	0.25	60	INR	3	04C	+10.04	TECTEH			21H00042	600UL
4241	101	60							TECTEH			21H00041	600UL
4242	103	60							TECTEH			21H00042	600UL
4243	105	60							TECTEH			21H00041	600UL
4244	107	60							TECTEH			21H00042	600UL
4245	109	60	0.40	67	INR	6	F04	+5.90	TECTEH			21H00041	600UL
4246			0.56	82	INR	6	F08	+3.99	TECTEH			21H00041	600UL
4247					INF		F09	+13.88	TECTEH	HR		21H00041	600UL
4248	111	60	0.47	117	INR	3	TSH	+19.32	TECTEH			21H00042	600UL
4249	113	60							TECTEH			21H00041	600UL
4250	115	60	0.34	61	INR	6	02C	+11.39	TECTEH			21H00041	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4251			0.51	75	INR	6	01C	+15.36	TECTEH			21H00041	600UL
4252	117	60							TECTEH			21H00042	600UL
4253	119	60							TECTEH			21H00041	600UL
4254	121	60							TECTEH			21H00042	600UL
4255	123	60							TECTEH			21H00041	600UL
4256	125	60			INF		TSH	+9.99	TECTEH	HR		21H00042	600UL
4257	127	60	0.51	77	INR	6	02H	+16.35	TECTEH			21H00041	600UL
4258	129	60							TECTEH			21H00042	600UL
4259	131	60							TECTEH			21H00042	600UL
4260	133	60	0.63	103	INR	6	F04	+0.00	TECTEH			21H00039	600UL
4261	135	60	0.54	134	INR	3	TSH	+19.88	TECTEH			21H00040	600UL
4262			0.21	73	INR	3	07H	+13.47	TECTEH			21H00040	600UL
4263			0.26	129	INR	3	TSC	+5.71	TECTEH			21H00040	600UL
4264	4	61	6.96	183	DNG	1	F01	+11.48	TECTEH			21H00026	600UL
4265	6	61							TECTEH			21H00026	600UL
4266	8	61							TECTEH			21H00026	600UL
4267	10	61							TECTEH			21H00027	600UL
4268	12	61							TECTEH			21H00027	600UL
4269	14	61							TECTEH			21H00027	600UL
4270	16	61							TECTEH			21H00027	600UL
4271	18	61							TECTEH			21H00027	600UL
4272	20	61							TECTEH			21H00027	600UL
4273	22	61	5.16	183	INR	P1	F05	+2.02	TECTEH			21H00027	600UL
4274	24	61	1.77	43	INR	6	03H	+17.12 TO+36.51	TECTEH			21H00027	600UL
4275	26	61							TECTEH			21H00067	600UL
4276	28	61							TECTEH			21H00066	600UL
4277	30	61							TECTEH			21H00067	600UL
4278	32	61							TECTEH			21H00066	600UL
4279	34	61							TECTEH			21H00067	600UL
4280	36	61	0.45	81	INR	6	01H	+2.95	TECTEH			21H00066	600UL
4281	38	61	0.32	80	INR	6	02H	+25.57	TECTEH			21H00067	600UL
4282	40	61	0.56	77	INR	6	06H	+22.89	TECTEH			21H00066	600UL
4283	42	61							TECTEH			21H00067	600UL
4284	44	61	0.56	84	INR	6	TSH	+12.36	TECTEH			21H00066	600UL
4285	46	61							TECTEH			21H00067	600UL
4286	48	61							TECTEH			21H00066	600UL
4287	50	61							TECTEH			21H00067	600UL
4288	52	61	0.42	76	INR	6	05C	+31.43	TECTEH			21H00066	600UL
4289	54	61	0.16	40	INR	6	TSH	+16.04 TO+0.87	TECTEH			21H00067	600UL
4290			0.33	194	INR	6	F08	+0.00	TECTEH			21H00067	600UL
4291			0.66	79	INR	6	03C	+23.01	TECTEH			21H00067	600UL
4292	56	61	0.44	85	INR	6	02H	+13.37	TECTEH			21H00066	600UL
4293			0.44	71	INR	6	03H	+3.20	TECTEH			21H00066	600UL
4294			0.90	65	INR	6	07C	-0.13	TECTEH			21H00066	600UL
4295			0.99	62	INR	6	05C	-0.13	TECTEH			21H00066	600UL
4296	58	61							TECTEH			21H00067	600UL
4297	60	61							TECTEH			21H00066	600UL
4298	62	61							TECTEH			21H00067	600UL
4299	64	61							TECTEH			21H00066	600UL
4300	66	61							TECTEH			21H00067	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4301	68	61	0.43	69	INR	6	06H	+21.94	TECTEH			21H00066	600UL
4302			0.28	64	INR	6	F12	+3.01	TECTEH			21H00066	600UL
4303					INF		07C	+10.38	TECTEH	HR		21H00066	600UL
4304	70	61							TECTEH			21H00067	600UL
4305	72	61							TECTEH			21H00066	600UL
4306	74	61							TECTEH			21H00067	600UL
4307	76	61							TECTEH			21H00066	600UL
4308	78	61	0.55	85	INR	6	02C	+11.66	TECTEH			21H00067	600UL
4309	80	61							TECTEH			21H00066	600UL
4310	82	61							TECTEH			21H00044	600UL
4311	84	61							TECTEH			21H00044	600UL
4312	86	61							TECTEH			21H00043	600UL
4313	88	61	0.59	102	INR	6	01C	+32.75	TECTEH			21H00043	600UL
4314	90	61							TECTEH			21H00044	600UL
4315	92	61	1.00	81	INR	6	F07	+11.76	TECTEH			21H00043	600UL
4316					INF		F08	+3.35	TECTEH	HR		21H00043	600UL
4317			0.41	98	INR	6	04C	+15.71	TECTEH			21H00043	600UL
4318	94	61							TECTEH			21H00044	600UL
4319	96	61			INF		F10	+0.00	TECTEH	HR		21H00043	600UL
4320			0.34	97	INR	6	F10	+4.78	TECTEH			21H00043	600UL
4321	98	61							TECTEH			21H00044	600UL
4322	100	61	0.51	72	INR	6	04C	+28.12	TECTEH			21H00043	600UL
4323	102	61							TECTEH			21H00044	600UL
4324	104	61							TECTEH			21H00043	600UL
4325	106	61	0.29	74	INR	6	02C	+10.35	TECTEH			21H00044	600UL
4326	108	61							TECTEH			21H00043	600UL
4327	110	61	0.44	74	INR	6	03H	+7.41	TECTEH			21H00044	600UL
4328			0.41	79	INR	6	03H	+15.30	TECTEH			21H00044	600UL
4329			0.54	62	INR	6	F10	+5.61	TECTEH			21H00044	600UL
4330					INF		F11	+8.49	TECTEH	HR		21H00044	600UL
4331			0.36	73	INR	6	02C	+24.42	TECTEH			21H00044	600UL
4332			0.50	70	INR	6	02C	+35.13	TECTEH			21H00044	600UL
4333			0.53	75	INR	6	01C	+21.63	TECTEH			21H00044	600UL
4334	112	61							TECTEH			21H00043	600UL
4335	114	61	0.56	75	INR	6	04H	+30.55	TECTEH			21H00044	600UL
4336			0.63	68	INR	6	F02	+9.91	TECTEH			21H00044	600UL
4337			0.38	76	INR	6	03C	+23.61	TECTEH			21H00044	600UL
4338	116	61							TECTEH			21H00043	600UL
4339	118	61	0.57	75	INR	6	TSC	+6.87	TECTEH			21H00044	600UL
4340	120	61							TECTEH			21H00043	600UL
4341	122	61							TECTEH			21H00044	600UL
4342	124	61							TECTEH			21H00043	600UL
4343	126	61	0.58	78	INR	6	02C	+12.75	TECTEH			21H00044	600UL
4344			0.46	84	INR	6	01C	+22.79	TECTEH			21H00044	600UL
4345	128	61	0.33	88	INR	6	03C	+35.44	TECTEH			21H00043	600UL
4346	130	61							TECTEH			21H00044	600UL
4347	132	61	0.62	84	INR	6	04H	+22.75	TECTEH			21H00039	600UL
4348			0.60	72	INR	6	F04	+10.88	TECTEH			21H00039	600UL
4349					INF		F04	+11.97	TECTEH	HR		21H00039	600UL
4350			0.36	62	INR	6	F07	+0.00	TECTEH			21H00039	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4351			0.33	77	INR	6	04C	+27.21	TECTEH			21H00039	600UL
4352	134	61							TECTEH			21H00040	600UL
4353	11	62	0.41	61	INR	6	06H	+18.29	TECTEH			21H00027	600UL
4354	13	62	0.63	83	INR	6	TSH	+18.21	TECTEH			21H00027	600UL
4355	15	62							TECTEH			21H00027	600UL
4356	17	62							TECTEH			21H00027	600UL
4357	19	62							TECTEH			21H00027	600UL
4358	21	62							TECTEH			21H00027	600UL
4359	23	62	0.54	76	INR	6	TSC	+6.80	TECTEH			21H00027	600UL
4360	25	62							TECTEH			21H00067	600UL
4361	27	62							TECTEH			21H00066	600UL
4362	29	62							TECTEH			21H00067	600UL
4363	31	62							TECTEH			21H00066	600UL
4364	33	62							TECTEH			21H00067	600UL
4365	35	62	0.87	73	INR	6	05C	+2.37	TECTEH			21H00066	600UL
4366	37	62							TECTEH			21H00067	600UL
4367	39	62	0.53	74	INR	6	06C	+9.46	TECTEH			21H00066	600UL
4368			0.64	86	INR	6	02C	+2.85	TECTEH			21H00066	600UL
4369	41	62	0.47	79	INR	6	06C	+26.96	TECTEH			21H00067	600UL
4370	43	62	0.64	15	INR	6	04H	+29.14	TECTEH			21H00066	600UL
4371			0.39	80	INR	6	05H	+30.03	TECTEH			21H00066	600UL
4372			0.65	37	INR	6	05H	+31.73	TECTEH			21H00066	600UL
4373			0.39	74	INR	6	04C	+34.62	TECTEH			21H00066	600UL
4374			0.46	73	INR	6	01C	+15.58	TECTEH			21H00066	600UL
4375			0.26	59	INR	6	01C	+32.66	TECTEH			21H00066	600UL
4376	45	62	0.47	86	INR	6	01H	+2.74	TECTEH			21H00067	600UL
4377	47	62	0.89	80	INR	6	01H	+17.72	TECTEH			21H00066	600UL
4378			0.47	73	INR	6	03H	+12.44	TECTEH			21H00066	600UL
4379			3.15	183	INR	1	F01	+6.10	TECTEH			21H00066	600UL
4380			0.81	81	INR	6	04C	+8.21	TECTEH			21H00066	600UL
4381			0.57	76	INR	6	03C	+35.28	TECTEH			21H00066	600UL
4382			0.46	75	INR	6	02C	+18.23	TECTEH			21H00066	600UL
4383	49	62	0.26	66	INR	6	05C	+16.14	TECTEH			21H00067	600UL
4384	51	62	1.16	77	INR	6	03H	+17.87	TECTEH			21H00066	600UL
4385	53	62	0.37	60	INR	6	05H	+5.94	TECTEH			21H00067	600UL
4386	55	62	0.36	76	INR	6	02H	+23.30	TECTEH			21H00066	600UL
4387			0.58	77	INR	6	01C	+23.29	TECTEH			21H00066	600UL
4388	57	62							TECTEH			21H00067	600UL
4389	59	62							TECTEH			21H00066	600UL
4390	61	62	3.80	8	INR	1	F01	+1.96	TECTEH			21H00067	600UL
4391					INF		F02	+2.56	TECTEH	HR		21H00067	600UL
4392			0.84	57	INR	6	F06	+0.00	TECTEH			21H00067	600UL
4393	63	62							TECTEH			21H00066	600UL
4394	65	62							TECTEH			21H00067	600UL
4395	67	62	0.62	77	INR	6	02H	+20.27	TECTEH			21H00066	600UL
4396			0.77	36	INR	6	F03	+0.21	TECTEH			21H00066	600UL
4397	69	62							TECTEH			21H00067	600UL
4398	71	62							TECTEH			21H00066	600UL
4399	73	62							TECTEH			21H00067	600UL
4400	75	62							TECTEH			21H00066	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4401	77	62							TECTEH			21H00067	600UL
4402	79	62	0.50	77	INR	6	04C	+30.76	TECTEH			21H00066	600UL
4403			0.37	83	INR	6	03C	+39.31	TECTEH			21H00066	600UL
4404			0.67	86	INR	6	TSC	+0.97	TECTEH			21H00066	600UL
4405	81	62							TECTEH			21H00066	600UL
4406	83	62							TECTEH			21H00044	600UL
4407	85	62							TECTEH			21H00043	600UL
4408	87	62							TECTEH			21H00044	600UL
4409	89	62							TECTEH			21H00043	600UL
4410	91	62							TECTEH			21H00044	600UL
4411	93	62	0.57	70	INR	6	02C	+4.29	TECTEH			21H00043	600UL
4412	95	62							TECTEH			21H00044	600UL
4413	97	62			INF		F06	+0.00	TECTEH	HR		21H00043	600UL
4414	99	62							TECTEH			21H00044	600UL
4415	101	62	0.30	57	INR	6	06H	+4.53	TECTEH			21H00043	600UL
4416	103	62	0.49	61	INR	6	F03	+7.41	TECTEH			21H00044	600UL
4417	105	62							TECTEH			21H00043	600UL
4418	107	62	0.32	111	INR	6	02H	+5.71	TECTEH			21H00044	600UL
4419	109	62			INF		07H	+7.75	TECTEH	HR		21H00043	600UL
4420			0.50	77	INR	6	07H	+15.25	TECTEH			21H00043	600UL
4421			0.51	92	NQH	3	F04	+5.10	TECTEH			21H00043	600UL
4422			0.39	66	NQH	3	F11	+5.10	TECTEH			21H00043	600UL
4423					INF		F12	+7.18	TECTEH	HR		21H00043	600UL
4424			0.57	66	INR	6	F12	+9.54	TECTEH			21H00043	600UL
4425					INF		07C	+7.75	TECTEH	HR		21H00043	600UL
4426	111	62	0.32	91	INR	6	F06	+10.46	TECTEH			21H00044	600UL
4427			0.33	62	INR	6	04C	+25.75	TECTEH			21H00044	600UL
4428			0.56	75	INR	6	TSC	+2.93	TECTEH			21H00044	600UL
4429	113	62							TECTEH			21H00043	600UL
4430	115	62							TECTEH			21H00043	600UL
4431	117	62							TECTEH			21H00044	600UL
4432	119	62							TECTEH			21H00043	600UL
4433	121	62							TECTEH			21H00044	600UL
4434	123	62							TECTEH			21H00043	600UL
4435	125	62			INF		F07	+0.00	TECTEH	HR		21H00044	600UL
4436			0.46	72	INR	6	F07	+3.23	TECTEH			21H00044	600UL
4437	127	62							TECTEH			21H00043	600UL
4438	129	62	0.42	70	INR	6	05C	+30.77	TECTEH			21H00044	600UL
4439	131	62	0.68	81	INR	6	04H	+2.41	TECTEH			21H00043	600UL
4440			0.51	85	INR	6	02C	+20.70	TECTEH			21H00043	600UL
4441	133	62							TECTEH			21H00039	600UL
4442	135	62	0.33	141	INR	3	F12	+8.45	TECTEH			21H00040	600UL
4443					INF		07C	+14.87	TECTEH	HR		21H00040	600UL
4444	14	63							TECTEH			21H00027	600UL
4445	16	63							TECTEH			21H00027	600UL
4446	18	63							TECTEH			21H00027	600UL
4447	20	63							TECTEH			21H00027	600UL
4448	22	63							TECTEH			21H00027	600UL
4449	24	63							TECTEH			21H00027	600UL
4450	26	63							TECTEH			21H00067	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4451	28	63							TECTEH			21H00066	600UL
4452	30	63							TECTEH			21H00067	600UL
4453	32	63							TECTEH			21H00066	600UL
4454	34	63							TECTEH			21H00067	600UL
4455	36	63	1.04	68	INR	6	04H	+0.03	TECTEH			21H00066	600UL
4456	38	63							TECTEH			21H00067	600UL
4457	40	63							TECTEH			21H00066	600UL
4458	42	63							TECTEH			21H00067	600UL
4459	44	63							TECTEH			21H00066	600UL
4460	46	63	0.42	79	INR	6	03H	+25.90	TECTEH			21H00067	600UL
4461	48	63	0.55	75	INR	6	02H	+33.48	TECTEH			21H00066	600UL
4462	50	63							TECTEH			21H00067	600UL
4463	52	63							TECTEH			21H00066	600UL
4464	54	63			INF		05H	+27.05	TECTEH	HR		21H00067	600UL
4465					INF		07H	+2.97	TECTEH	HR		21H00067	600UL
4466					INF		07H	+8.10	TECTEH	HR		21H00067	600UL
4467			0.81	71	INR	6	07H	+9.74	TECTEH			21H00067	600UL
4468	56	63							TECTEH			21H00066	600UL
4469	58	63							TECTEH			21H00067	600UL
4470	60	63							TECTEH			21H00066	600UL
4471	62	63							TECTEH			21H00067	600UL
4472	64	63	0.64	79	INR	6	F10	+3.81	TECTEH			21H00066	600UL
4473	66	63							TECTEH			21H00067	600UL
4474	68	63							TECTEH			21H00066	600UL
4475	70	63	0.67	78	INR	6	02H	+33.97	TECTEH			21H00067	600UL
4476	72	63							TECTEH			21H00066	600UL
4477	74	63							TECTEH			21H00067	600UL
4478	76	63							TECTEH			21H00066	600UL
4479	78	63	0.31	83	INR	6	04H	+14.67	TECTEH			21H00067	600UL
4480	80	63	0.45	63	INR	6	02H	+16.40	TECTEH			21H00066	600UL
4481			0.41	83	INR	6	02H	+34.72	TECTEH			21H00066	600UL
4482			0.96	75	INR	6	07H	+7.15	TECTEH			21H00066	600UL
4483			0.43	106	INR	6	F06	+4.89	TECTEH			21H00066	600UL
4484	82	63							TECTEH			21H00043	600UL
4485	84	63							TECTEH			21H00044	600UL
4486	86	63							TECTEH			21H00043	600UL
4487	88	63	1.11	80	INR	6	04H	+19.33	TECTEH			21H00043	600UL
4488			0.43	67	NQH	3	F05	+9.17	TECTEH			21H00043	600UL
4489	90	63	0.42	52	INR	6	F05	+0.00	TECTEH			21H00044	600UL
4490	92	63							TECTEH			21H00043	600UL
4491	94	63	0.39	100	NQH	3	F01	+3.10	TECTEH			21H00044	600UL
4492			0.33	66	INR	6	05C	+20.76	TECTEH			21H00044	600UL
4493			0.39	72	INR	6	05C	+35.58	TECTEH			21H00044	600UL
4494			0.31	68	INR	6	05C	+37.18	TECTEH			21H00044	600UL
4495			0.53	82	INR	6	04C	+28.27	TECTEH			21H00044	600UL
4496	96	63	0.27	86	INR	6	01H	+31.99	TECTEH			21H00043	600UL
4497			0.57	76	INR	6	05H	+16.08	TECTEH			21H00043	600UL
4498					INF		F07	+0.00	TECTEH	HR		21H00043	600UL
4499			0.28	95	INR	6	F07	+3.72	TECTEH			21H00043	600UL
4500			1.14	81	INR	6	01C	+19.55	TECTEH			21H00043	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4501	98	63	0.57	52	INR	6	F04	+5.98	TECTEH			21H00044	600UL
4502			0.37	72	INR	6	F12	+9.40	TECTEH			21H00044	600UL
4503					INF		07C	+5.67	TECTEH	HR		21H00044	600UL
4504			0.67	79	INR	6	05C	+39.05	TECTEH			21H00044	600UL
4505					INF		05C	+42.73	TECTEH	HR		21H00044	600UL
4506			0.52	65	INR	6	04C	+23.99	TECTEH			21H00044	600UL
4507			0.32	90	INR	6	03C	+30.58	TECTEH			21H00044	600UL
4508	100	63							TECTEH			21H00043	600UL
4509	102	63	0.82	72	INR	6	05C	+18.51	TECTEH			21H00044	600UL
4510			0.56	69	INR	6	04C	+23.12	TECTEH			21H00044	600UL
4511	104	63							TECTEH			21H00043	600UL
4512	106	63	0.55	93	INR	6	F05	+9.30	TECTEH			21H00044	600UL
4513	108	63							TECTEH			21H00043	600UL
4514	110	63	0.31	65	INR	6	F04	+10.68	TECTEH			21H00044	600UL
4515	112	63	0.33	80	INR	6	02C	+17.65	TECTEH			21H00043	600UL
4516	114	63	0.40	40	INR	6	F03	+0.00	TECTEH			21H00044	600UL
4517	116	63	0.46	92	INR	6	TSH	+7.76	TECTEH			21H00043	600UL
4518			0.58	81	INR	6	04C	+6.58	TECTEH			21H00043	600UL
4519	118	63							TECTEH			21H00044	600UL
4520	120	63	0.30	83	INR	6	02H	+20.55	TECTEH			21H00043	600UL
4521	122	63							TECTEH			21H00044	600UL
4522	124	63							TECTEH			21H00043	600UL
4523	126	63							TECTEH			21H00044	600UL
4524	128	63	0.39	61	INR	6	05H	+17.55	TECTEH			21H00043	600UL
4525			0.38	86	NQH	3	F03	+0.49	TECTEH			21H00043	600UL
4526	130	63							TECTEH			21H00044	600UL
4527	132	63							TECTEH			21H00039	600UL
4528	134	63							TECTEH			21H00039	600UL
4529	136	63	0.28	118	INR	3	01H	+12.09	TECTEH			21H00040	600UL
4530			0.35	98	INR	3	F10	+8.22	TECTEH			21H00040	600UL
4531					INF		F11	+8.22	TECTEH	HR		21H00040	600UL
4532					INF		F11	+9.81	TECTEH	HR		21H00040	600UL
4533			0.48	139	INR	3	TSC	+6.59	TECTEH			21H00040	600UL
4534	17	64							TECTEH			21H00027	600UL
4535	19	64							TECTEH			21H00027	600UL
4536	21	64							TECTEH			21H00027	600UL
4537	23	64	0.44	83	INR	6	01C	+29.10	TECTEH			21H00027	600UL
4538	25	64							TECTEH			21H00067	600UL
4539	27	64							TECTEH			21H00066	600UL
4540	29	64							TECTEH			21H00067	600UL
4541	31	64	0.37	81	INR	6	TSH	+17.43	TECTEH			21H00066	600UL
4542			0.77	72	INR	6	01H	+15.88	TECTEH			21H00066	600UL
4543	33	64							TECTEH			21H00067	600UL
4544	35	64	0.55	76	INR	6	01H	+10.46	TECTEH			21H00066	600UL
4545			0.48	66	INR	6	06H	+7.16	TECTEH			21H00066	600UL
4546					INF		TSC	+14.92	TECTEH	HR		21H00066	600UL
4547	37	64	0.45	72	INR	6	01H	+30.02	TECTEH			21H00067	600UL
4548			0.24	75	INR	6	F09	+0.00	TECTEH			21H00067	600UL
4549			0.63	75	INR	6	04C	+24.52	TECTEH			21H00067	600UL
4550					INF		04C	+27.09	TECTEH	HR		21H00067	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4551					INF		04C	+27.86	TECTEH	HR		21H00067	600UL
4552					INF		04C	+27.86	TECTEH	HR		21H00067	600UL
4553					INF		02C	+16.12	TECTEH	HR		21H00067	600UL
4554			0.63	69	INR	6	02C	+17.81	TECTEH			21H00067	600UL
4555			0.69	75	INR	6	01C	+31.34	TECTEH			21H00067	600UL
4556	39	64	0.48	80	INR	6	03C	+7.93	TECTEH			21H00066	600UL
4557	41	64							TECTEH			21H00067	600UL
4558	43	64							TECTEH			21H00066	600UL
4559	45	64							TECTEH			21H00067	600UL
4560	47	64	0.67	78	INR	6	05C	+24.06	TECTEH			21H00066	600UL
4561	49	64	0.45	94	INR	6	F05	+3.63	TECTEH			21H00067	600UL
4562	51	64							TECTEH			21H00066	600UL
4563	53	64							TECTEH			21H00067	600UL
4564	55	64	0.34	83	INR	6	06H	+30.00	TECTEH			21H00066	600UL
4565	57	64	0.45	88	INR	6	TSC	+17.82	TECTEH			21H00067	600UL
4566	59	64							TECTEH			21H00066	600UL
4567	61	64							TECTEH			21H00067	600UL
4568	63	64	0.55	81	INR	6	04H	+30.03	TECTEH			21H00066	600UL
4569	65	64	0.47	73	INR	6	01H	+27.13	TECTEH			21H00067	600UL
4570	67	64	0.45	79	INR	6	TSH	+6.57	TECTEH			21H00066	600UL
4571	69	64							TECTEH			21H00067	600UL
4572	71	64							TECTEH			21H00066	600UL
4573	73	64							TECTEH			21H00067	600UL
4574	75	64	0.90	76	INR	6	02C	+11.46	TECTEH			21H00066	600UL
4575			0.48	78	INR	6	02C	+13.10	TECTEH			21H00066	600UL
4576	77	64							TECTEH			21H00067	600UL
4577	79	64	0.53	74	INR	6	04H	+7.10	TECTEH			21H00066	600UL
4578	81	64							TECTEH			21H00066	600UL
4579	83	64	0.70	57	INR	6	05C	+0.00	TECTEH			21H00044	600UL
4580			0.43	73	INR	6	03C	+15.00	TECTEH			21H00044	600UL
4581			0.42	84	INR	6	02C	+16.50	TECTEH			21H00044	600UL
4582	85	64	0.47	72	INR	6	04H	+6.72	TECTEH			21H00043	600UL
4583	87	64							TECTEH			21H00044	600UL
4584	89	64	0.43	73	INR	6	04H	+34.19	TECTEH			21H00043	600UL
4585			0.83	66	INR	6	F02	+10.07	TECTEH			21H00043	600UL
4586			0.41	87	INR	6	03C	+20.17	TECTEH			21H00043	600UL
4587			0.70	71	INR	6	03C	+30.19	TECTEH			21H00043	600UL
4588	91	64	0.40	76	INR	6	05H	+12.09	TECTEH			21H00044	600UL
4589			0.40	75	INR	6	05C	+6.49	TECTEH			21H00044	600UL
4590	93	64							TECTEH			21H00043	600UL
4591	95	64							TECTEH			21H00044	600UL
4592	97	64	1.01	81	INR	6	03H	+30.90	TECTEH			21H00043	600UL
4593	99	64	0.39	77	INR	6	06H	+28.01	TECTEH			21H00044	600UL
4594			0.48	51	INR	6	F08	+7.56	TECTEH			21H00044	600UL
4595			0.52	75	INR	6	F08	+8.79	TECTEH			21H00044	600UL
4596					INF		F09	+7.78	TECTEH	HR		21H00044	600UL
4597					INF		F09	+9.04	TECTEH	HR		21H00044	600UL
4598			1.27	77	INR	6	04C	+34.42	TECTEH			21H00044	600UL
4599			0.39	77	INR	6	03C	+0.27	TECTEH			21H00044	600UL
4600			0.72	77	INR	6	TSC	+5.00	TECTEH			21H00044	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4601	101	64	0.46	78	INR	6	01H	+27.50	TECTEH			21H00043	600UL
4602			0.40	80	INR	6	TSC	+17.63	TECTEH			21H00043	600UL
4603	103	64							TECTEH			21H00044	600UL
4604	105	64	1.05	35	INR	6	F06	+0.13	TECTEH			21H00043	600UL
4605			0.54	72	INR	6	F06	+9.28	TECTEH			21H00043	600UL
4606					INF		F07	+8.32	TECTEH	HR		21H00043	600UL
4607			0.46	75	INR	6	04C	+19.72	TECTEH			21H00043	600UL
4608			0.80	64	INR	6	01C	+14.99	TECTEH			21H00043	600UL
4609			0.46	85	INR	6	01C	+30.00	TECTEH			21H00043	600UL
4610			0.49	88	INR	6	TSC	+6.50	TECTEH			21H00043	600UL
4611	107	64							TECTEH			21H00044	600UL
4612	109	64	0.45	84	NQH	3	F04	+3.14	TECTEH			21H00043	600UL
4613			0.46	97	NQH	3	F04	+4.70	TECTEH			21H00043	600UL
4614			0.64	76	INR	6	05C	+11.83	TECTEH			21H00043	600UL
4615	111	64	0.34	82	INR	6	TSH	+17.14	TECTEH			21H00043	600UL
4616			0.47	79	INR	6	01H	+14.66	TECTEH			21H00043	600UL
4617					INF		F10	+9.04	TECTEH	HR		21H00043	600UL
4618			0.29	42	INR	6	TSC	+14.20	TECTEH			21H00043	600UL
4619	113	64							TECTEH			21H00044	600UL
4620	115	64	0.69	88	NQH	3	F04	+16.07	TECTEH			21H00043	600UL
4621					INF		03C	+0.00	TECTEH	HR		21H00043	600UL
4622	117	64	0.59	72	INR	6	F09	+13.11	TECTEH			21H00044	600UL
4623					INF		F10	+4.78	TECTEH	HR		21H00044	600UL
4624			0.44	66	INR	6	05C	+26.12	TECTEH			21H00044	600UL
4625			1.09	78	INR	6	03C	+14.38	TECTEH			21H00044	600UL
4626			0.78	75	INR	6	01C	+25.13	TECTEH			21H00044	600UL
4627			0.44	73	INR	6	TSC	+3.22	TECTEH			21H00044	600UL
4628			0.49	79	INR	6	TSC	+20.59	TECTEH			21H00044	600UL
4629	119	64							TECTEH			21H00043	600UL
4630	121	64							TECTEH			21H00044	600UL
4631	123	64							TECTEH			21H00043	600UL
4632	125	64							TECTEH			21H00044	600UL
4633	127	64			INF		F04	+6.10	TECTEH	HR		21H00043	600UL
4634			0.43	52	INR	6	F04	+7.56	TECTEH			21H00043	600UL
4635			0.35	138	INR	3	05C	+18.46	TECTEH			21H00043	600UL
4636					INF		05C	+20.60	TECTEH	HR		21H00043	600UL
4637	129	64	0.30	86	INR	6	06C	+4.10	TECTEH			21H00044	600UL
4638	131	64	0.80	66	INR	6	F07	+5.25	TECTEH			21H00044	600UL
4639					INF		F08	+14.05	TECTEH	HR		21H00044	600UL
4640	133	64	0.29	74	INR	6	07H	+11.43	TECTEH			21H00039	600UL
4641			0.71	76	NQH	3	F01	+9.14	TECTEH			21H00039	600UL
4642			0.40	81	INR	6	F07	+12.01	TECTEH			21H00039	600UL
4643					INF		F08	+7.66	TECTEH	HR		21H00039	600UL
4644	135	64							TECTEH			21H00040	600UL
4645	137	64	0.35	126	INR	3	06C	+32.06	TECTEH			21H00040	600UL
4646			0.39	143	INR	3	04C	+27.73	TECTEH			21H00040	600UL
4647			0.36	155	INR	3	02C	+10.74	TECTEH			21H00040	600UL
4648	20	65							TECTEH			21H00027	600UL
4649	22	65	4.89	183	INR	P1	F05	+0.48	TECTEH			21H00027	600UL
4650	24	65							TECTEH			21H00027	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4651	26	65	1.88	45	INR	6	03H	+25.55 TO+35.48	TECTEH			21H00067	600UL
4652	28	65							TECTEH			21H00066	600UL
4653	30	65	0.37	75	INR	6	02C	+7.55	TECTEH			21H00067	600UL
4654	32	65	0.55	68	INR	6	01C	+16.11	TECTEH			21H00066	600UL
4655	34	65	1.62	62	INR	6	F06	+0.41 TO+6.83	TECTEH			21H00067	600UL
4656	36	65	0.42	69	INR	6	TSH	+17.02	TECTEH			21H00066	600UL
4657			0.21	66	INR	6	05H	+14.99	TECTEH			21H00066	600UL
4658	38	65							TECTEH			21H00067	600UL
4659	40	65							TECTEH			21H00066	600UL
4660	42	65	0.32	70	INR	6	01H	+4.39	TECTEH			21H00067	600UL
4661	44	65							TECTEH			21H00066	600UL
4662	46	65							TECTEH			21H00067	600UL
4663	48	65							TECTEH			21H00066	600UL
4664	50	65							TECTEH			21H00067	600UL
4665	52	65							TECTEH			21H00066	600UL
4666	54	65							TECTEH			21H00067	600UL
4667	56	65	0.47	76	INR	6	01H	+23.00	TECTEH			21H00066	600UL
4668	58	65							TECTEH			21H00067	600UL
4669	60	65							TECTEH			21H00066	600UL
4670	62	65	1.03	62	INR	6	TSH	+21.99	TECTEH			21H00067	600UL
4671			0.42	75	INR	6	03H	+15.31	TECTEH			21H00067	600UL
4672	64	65	0.52	71	INR	6	01H	+4.27	TECTEH			21H00066	600UL
4673	66	65							TECTEH			21H00067	600UL
4674	68	65							TECTEH			21H00066	600UL
4675	70	65	0.47	56	INR	6	06H	+36.12	TECTEH			21H00067	600UL
4676			0.81	99	INR	6	F04	+4.87	TECTEH			21H00067	600UL
4677					INF		F06	+35.96	TECTEH	HR		21H00067	600UL
4678	72	65	0.90	50	INR	6	F01	+0.23	TECTEH			21H00066	600UL
4679					INF		F02	+0.00	TECTEH	HR		21H00066	600UL
4680			0.92	79	INR	6	TSC	+8.09	TECTEH			21H00066	600UL
4681	74	65	0.58	73	INR	6	04C	+22.31	TECTEH			21H00067	600UL
4682			1.03	76	INR	6	03C	+24.92	TECTEH			21H00067	600UL
4683	76	65							TECTEH			21H00066	600UL
4684	78	65	0.49	46	INR	6	07H	+4.69	TECTEH			21H00067	600UL
4685	80	65	0.67	81	INR	6	F07	+12.40	TECTEH			21H00066	600UL
4686					INF		F08	+2.57	TECTEH	HR		21H00066	600UL
4687			0.40	79	INR	6	06C	+26.22	TECTEH			21H00066	600UL
4688	82	65							TECTEH			21H00043	600UL
4689	84	65	0.52	61	INR	6	06H	+22.67	TECTEH			21H00043	600UL
4690			0.56	86	INR	6	02C	+36.01	TECTEH			21H00043	600UL
4691	86	65	0.46	154	INR	3	02H	+31.34	TECTEH			21H00044	600UL
4692	88	65							TECTEH			21H00043	600UL
4693	90	65							TECTEH			21H00044	600UL
4694	92	65	0.41	86	INR	6	04C	+32.95	TECTEH			21H00043	600UL
4695	94	65	0.45	78	INR	6	01H	+10.57	TECTEH			21H00044	600UL
4696			0.40	75	INR	6	06C	+28.45	TECTEH			21H00044	600UL
4697			0.49	70	INR	6	05C	+12.69	TECTEH			21H00044	600UL
4698	96	65							TECTEH			21H00043	600UL
4699	98	65	0.39	71	INR	6	01H	+5.29	TECTEH			21H00044	600UL
4700			0.27	78	INR	6	04C	+13.88	TECTEH			21H00044	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4701	100	65	1.87	95	INR	6	F07	+16.28	TECTEH			21H00043	600UL
4702			2.01	91	INR	6	F08	-0.10	TECTEH			21H00043	600UL
4703	102	65							TECTEH			21H00044	600UL
4704	104	65							TECTEH			21H00043	600UL
4705	106	65							TECTEH			21H00044	600UL
4706	108	65							TECTEH			21H00043	600UL
4707	110	65	0.41	73	INR	6	05C	+24.51	TECTEH			21H00044	600UL
4708	112	65							TECTEH			21H00043	600UL
4709	114	65	0.45	78	INR	6	03H	+2.28	TECTEH			21H00044	600UL
4710			0.39	77	INR	6	04H	+38.03	TECTEH			21H00044	600UL
4711			0.33	74	INR	6	F07	+0.25	TECTEH			21H00044	600UL
4712	116	65	0.33	139	INR	6	F06	+2.01	TECTEH			21H00043	600UL
4713					INF		F08	+1.75	TECTEH	HR		21H00043	600UL
4714			0.36	56	INR	6	06C	+13.51	TECTEH			21H00043	600UL
4715			0.42	111	INR	3	05C	+18.77	TECTEH			21H00043	600UL
4716	118	65							TECTEH			21H00044	600UL
4717	120	65							TECTEH			21H00043	600UL
4718	122	65							TECTEH			21H00044	600UL
4719	124	65	0.31	88	INR	6	06H	+7.41	TECTEH			21H00043	600UL
4720	126	65	0.24	130	INR	3	03C	+5.43	TECTEH			21H00044	600UL
4721			0.45	129	INR	3	02C	+5.39	TECTEH			21H00044	600UL
4722	128	65	0.44	72	INR	6	02C	+8.55	TECTEH			21H00043	600UL
4723	130	65	0.46	104	INR	3	TSC	+8.59	TECTEH			21H00044	600UL
4724	132	65							TECTEH			21H00039	600UL
4725	134	65	0.43	78	INR	6	01H	+29.30	TECTEH			21H00039	600UL
4726	136	65							TECTEH			21H00040	600UL
4727	23	66							TECTEH			21H00027	600UL
4728	25	66							TECTEH			21H00067	600UL
4729	27	66							TECTEH			21H00066	600UL
4730	29	66							TECTEH			21H00067	600UL
4731	31	66							TECTEH			21H00066	600UL
4732	33	66							TECTEH			21H00067	600UL
4733	35	66							TECTEH			21H00066	600UL
4734	37	66							TECTEH			21H00067	600UL
4735	39	66			INF		05C	+15.79	TECTEH	HR		21H00066	600UL
4736			0.61	78	INR	6	05C	+18.10	TECTEH			21H00066	600UL
4737			1.06	71	INR	6	02C	+29.83	TECTEH			21H00066	600UL
4738	41	66	0.43	74	INR	6	01C	+15.06	TECTEH			21H00067	600UL
4739	43	66							TECTEH			21H00066	600UL
4740	45	66							TECTEH			21H00067	600UL
4741	47	66							TECTEH			21H00066	600UL
4742	49	66							TECTEH			21H00067	600UL
4743	51	66							TECTEH			21H00066	600UL
4744	53	66			NDF	3	TEH	+17.91	TEHTSH			21H00086	610PP
4745			0.31	67	INR	6	01H	+29.90	TECTEH			21H00067	600UL
4746			0.32	86	INR	6	05C	+17.81	TECTEH			21H00067	600UL
4747			0.42	90	INR	6	TSC	+18.17	TECTEH			21H00067	600UL
4748	55	66	0.45	76	INR	6	03H	+4.67	TECTEH			21H00066	600UL
4749			0.48	75	INR	6	03H	+4.72	TECTEH			21H00066	600UL
4750			0.65	83	INR	6	F08	-0.15	TECTEH			21H00066	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4751					INF		07C	+0.00	TECTEH	HR		21H00066	600UL
4752			0.19	113	INR	6	03C	+7.72	TECTEH			21H00066	600UL
4753			0.96	50	INR	6	02C	+1.79	TECTEH			21H00066	600UL
4754	57	66							TECTEH			21H00067	600UL
4755	59	66							TECTEH			21H00066	600UL
4756	61	66	1.53	73	INR	6	F12	+1.05	TECTEH			21H00067	600UL
4757					INF		F12	+6.00	TECTEH	HR		21H00067	600UL
4758			0.51	81	INR	6	F12	+7.66	TECTEH			21H00067	600UL
4759					INF		F12	+13.00	TECTEH	HR		21H00067	600UL
4760					INF		07C	+10.50	TECTEH	HR		21H00067	600UL
4761			0.40	77	INR	6	01C	+6.93	TECTEH			21H00067	600UL
4762	63	66							TECTEH			21H00066	600UL
4763	65	66			INF		04H	+18.68	TECTEH	HR		21H00067	600UL
4764			0.43	77	INR	6	04H	+20.14	TECTEH			21H00067	600UL
4765	67	66							TECTEH			21H00066	600UL
4766	69	66							TECTEH			21H00067	600UL
4767	71	66							TECTEH			21H00066	600UL
4768	73	66							TECTEH			21H00067	600UL
4769	75	66	0.40	56	INR	6	06H	+13.82	TECTEH			21H00066	600UL
4770			0.50	60	INR	6	F07	+3.66	TECTEH			21H00066	600UL
4771					INF		F08	+9.86	TECTEH	HR		21H00066	600UL
4772	77	66							TECTEH			21H00067	600UL
4773	79	66	0.37	70	INR	6	02H	+17.10	TECTEH			21H00066	600UL
4774			0.37	78	INR	6	03H	+12.38	TECTEH			21H00066	600UL
4775	81	66							TECTEH			21H00066	600UL
4776	83	66	0.33	75	INR	6	TSH	+6.05	TECTEH			21H00043	600UL
4777	85	66							TECTEH			21H00044	600UL
4778	87	66							TECTEH			21H00043	600UL
4779	89	66							TECTEH			21H00044	600UL
4780	91	66			INF		F05	+5.60	TECTEH	HR		21H00043	600UL
4781			0.62	68	NQH	3	F05	+6.72	TECTEH			21H00043	600UL
4782			0.50	74	INR	6	05C	+4.83	TECTEH			21H00043	600UL
4783			0.58	78	INR	6	02C	+32.87	TECTEH			21H00043	600UL
4784	93	66	0.36	70	INR	6	02C	+27.02	TECTEH			21H00044	600UL
4785	95	66	4.41	183	DNT	P1	07C	+1.62	TECTEH			21H00043	600UL
4786			1.24	80	INR	6	02C	+2.03	TECTEH			21H00043	600UL
4787	97	66	0.25	119	INR	3	03H	+31.78	TECTEH			21H00044	600UL
4788			0.32	148	INR	3	06C	+34.38	TECTEH			21H00044	600UL
4789	99	66	0.56	74	INR	6	02H	+10.43	TECTEH			21H00043	600UL
4790			0.59	80	INR	6	04H	+34.64	TECTEH			21H00043	600UL
4791			0.37	74	INR	6	TSC	+11.92	TECTEH			21H00043	600UL
4792			0.40	82	INR	6	TSC	+14.88	TECTEH			21H00043	600UL
4793	101	66	0.35	124	INR	3	05H	+7.96	TECTEH			21H00044	600UL
4794			0.40	109	NQH	3	06C	+17.66	TECTEH			21H00044	600UL
4795			0.47	115	INR	3	05C	+6.46	TECTEH			21H00044	600UL
4796	103	66							TECTEH			21H00043	600UL
4797	105	66							TECTEH			21H00044	600UL
4798	107	66	0.33	75	INR	6	01C	+22.20	TECTEH			21H00043	600UL
4799	109	66	0.29	142	INR	3	02C	+14.32	TECTEH			21H00044	600UL
4800	111	66							TECTEH			21H00043	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4801	113	66							TECTEH			21H00044	600UL
4802	115	66	0.33	62	INR	6	02H	+38.97	TECTEH			21H00043	600UL
4803	117	66	0.45	80	INR	6	01H	+15.92	TECTEH			21H00044	600UL
4804	119	66							TECTEH			21H00043	600UL
4805	121	66							TECTEH			21H00044	600UL
4806	123	66							TECTEH			21H00043	600UL
4807	125	66							TECTEH			21H00044	600UL
4808	127	66	0.38	72	INR	6	02H	+9.28	TECTEH			21H00043	600UL
4809			0.54	76	INR	6	05H	+8.31	TECTEH			21H00043	600UL
4810					INF		F10	+13.27	TECTEH	HR		21H00043	600UL
4811			0.35	48	INR	6	06C	+6.03	TECTEH			21H00043	600UL
4812	129	66	0.62	67	INR	6	05H	+32.98	TECTEH			21H00044	600UL
4813			0.53	78	INR	6	01C	+21.63	TECTEH			21H00044	600UL
4814	131	66							TECTEH			21H00044	600UL
4815	133	66	0.32	70	INR	6	03C	+31.47	TECTEH			21H00039	600UL
4816	135	66	0.18	108	INR	3	03H	+33.40	TECTEH			21H00040	600UL
4817	137	66	0.57	113	INR	3	04H	+31.39	TECTEH			21H00040	600UL
4818			0.57	145	INR	3	04H	+32.70	TECTEH			21H00040	600UL
4819			0.45	138	INR	3	06H	+7.68	TECTEH			21H00040	600UL
4820	24	67							TECTEH			21H00027	600UL
4821	26	67							TECTEH			21H00067	600UL
4822	28	67							TECTEH			21H00066	600UL
4823	30	67							TECTEH			21H00067	600UL
4824	32	67							TECTEH			21H00066	600UL
4825	34	67							TECTEH			21H00067	600UL
4826	36	67	0.69	71	INR	6	05H	+25.59	TECTEH			21H00066	600UL
4827			0.53	47	INR	6	06H	+35.69	TECTEH			21H00066	600UL
4828			0.88	76	INR	6	F07	-0.05	TECTEH			21H00066	600UL
4829	38	67							TECTEH			21H00067	600UL
4830	40	67	0.68	77	INR	6	01H	+2.85	TECTEH			21H00066	600UL
4831					INF		06C	+18.77	TECTEH	HR		21H00066	600UL
4832			0.36	73	INR	6	06C	+21.13	TECTEH			21H00066	600UL
4833	42	67							TECTEH			21H00067	600UL
4834	44	67							TECTEH			21H00066	600UL
4835	46	67	0.42	60	INR	6	05H	+12.75	TECTEH			21H00067	600UL
4836	48	67	0.49	79	INR	6	TSH	+18.38	TECTEH			21H00066	600UL
4837			0.61	76	INR	6	04H	+25.86	TECTEH			21H00066	600UL
4838					INF		05C	+22.21	TECTEH	HR		21H00066	600UL
4839			0.96	79	INR	6	05C	+25.28	TECTEH			21H00066	600UL
4840			0.47	76	INR	6	04C	+36.90	TECTEH			21H00066	600UL
4841			0.58	71	INR	6	01C	+4.77	TECTEH			21H00066	600UL
4842			0.49	71	INR	6	TSC	+20.83	TECTEH			21H00066	600UL
4843	50	67							TECTEH			21H00067	600UL
4844	52	67	0.48	59	INR	6	F04	+5.98	TECTEH			21H00066	600UL
4845					INF		F05	+6.00	TECTEH	HR		21H00066	600UL
4846	54	67							TECTEH			21H00067	600UL
4847	56	67	0.89	117	NQH	3	07H	+3.74	TECTEH			21H00066	600UL
4848	58	67	0.42	67	INR	6	TSC	+8.71	TECTEH			21H00067	600UL
4849	60	67							TECTEH			21H00066	600UL
4850	62	67	0.94	77	INR	6	02H	+18.63	TECTEH			21H00067	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4851	64	67							TECTEH			21H00066	600UL
4852	66	67							TECTEH			21H00067	600UL
4853	68	67	0.51	70	INR	6	04C	+14.42	TECTEH			21H00066	600UL
4854					INF		04C	+28.04	TECTEH	HR		21H00066	600UL
4855	70	67							TECTEH			21H00067	600UL
4856	72	67	0.54	74	INR	6	02H	+3.72	TECTEH			21H00066	600UL
4857			0.50	80	INR	6	02H	+25.86	TECTEH			21H00066	600UL
4858	74	67							TECTEH			21H00067	600UL
4859	76	67	0.69	82	INR	6	02C	+24.94	TECTEH			21H00066	600UL
4860	78	67	0.61	82	INR	6	03C	+7.75	TECTEH			21H00067	600UL
4861			0.53	71	INR	6	02C	+2.74	TECTEH			21H00067	600UL
4862			0.82	82	INR	6	01C	+13.03	TECTEH			21H00067	600UL
4863			0.39	71	INR	6	TSC	+14.03	TECTEH			21H00067	600UL
4864	80	67	0.46	72	INR	6	04H	+39.08	TECTEH			21H00066	600UL
4865			0.42	80	INR	6	F04	+5.57	TECTEH			21H00066	600UL
4866					INF		F04	+6.72	TECTEH	HR		21H00066	600UL
4867			0.46	58	INR	6	F07	+3.65	TECTEH			21H00066	600UL
4868					INF		F08	+11.41	TECTEH	HR		21H00066	600UL
4869					INF		F12	+0.00	TECTEH	HR		21H00066	600UL
4870			0.47	67	INR	6	F12	+7.36	TECTEH			21H00066	600UL
4871					INF		F12	+11.39	TECTEH	HR		21H00066	600UL
4872					INF		07C	+1.16	TECTEH	HR		21H00066	600UL
4873					INF		07C	+6.22	TECTEH	HR		21H00066	600UL
4874			0.72	74	INR	6	05C	+37.91	TECTEH			21H00066	600UL
4875	82	67							TECTEH			21H00043	600UL
4876	84	67							TECTEH			21H00043	600UL
4877	86	67							TECTEH			21H00044	600UL
4878	88	67	0.38	67	INR	6	04C	+17.05	TECTEH			21H00043	600UL
4879	90	67							TECTEH			21H00044	600UL
4880	92	67							TECTEH			21H00043	600UL
4881	94	67	0.38	126	INR	3	03H	+18.07	TECTEH			21H00044	600UL
4882			0.34	116	INR	3	06C	+6.30	TECTEH			21H00044	600UL
4883	96	67							TECTEH			21H00043	600UL
4884	98	67							TECTEH			21H00044	600UL
4885	100	67							TECTEH			21H00043	600UL
4886	102	67	0.28	130	INR	3	05H	+9.58	TECTEH			21H00044	600UL
4887	104	67	0.54	86	INR	6	05H	+5.67	TECTEH			21H00043	600UL
4888	106	67							TECTEH			21H00044	600UL
4889	108	67							TECTEH			21H00043	600UL
4890	110	67							TECTEH			21H00044	600UL
4891	112	67							TECTEH			21H00043	600UL
4892	114	67							TECTEH			21H00044	600UL
4893	116	67	0.32	77	INR	6	02H	+35.11	TECTEH			21H00043	600UL
4894	118	67							TECTEH			21H00044	600UL
4895	120	67							TECTEH			21H00043	600UL
4896	122	67	0.49	127	INR	3	06H	+17.07	TECTEH			21H00044	600UL
4897	124	67	0.52	60	INR	6	F04	+10.77	TECTEH			21H00043	600UL
4898	126	67							TECTEH			21H00044	600UL
4899	128	67	0.46	158	INR	6	05H	+7.07	TECTEH			21H00043	600UL
4900	130	67	0.45	80	INR	6	F11	+12.84	TECTEH			21H00044	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4901					INF		F12	+3.78	TECTEH	HR		21H00044	600UL
4902	132	67							TECTEH			21H00039	600UL
4903	134	67							TECTEH			21H00040	600UL
4904	136	67							TECTEH			21H00039	600UL
4905	138	67							TECTEH			21H00040	600UL
4906	27	68							TECTEH			21H00067	600UL
4907	29	68							TECTEH			21H00066	600UL
4908	31	68							TECTEH			21H00067	600UL
4909	33	68							TECTEH			21H00066	600UL
4910	35	68							TECTEH			21H00067	600UL
4911	37	68							TECTEH			21H00066	600UL
4912	39	68	0.47	53	INR	6	05H	+35.68	TECTEH			21H00067	600UL
4913	41	68							TECTEH			21H00066	600UL
4914	43	68							TECTEH			21H00067	600UL
4915	45	68							TECTEH			21H00066	600UL
4916	47	68			INF		03C	+20.08	TECTEH	HR		21H00067	600UL
4917			0.47	74	INR	6	03C	+24.86	TECTEH			21H00067	600UL
4918	49	68							TECTEH			21H00066	600UL
4919	51	68							TECTEH			21H00067	600UL
4920	53	68	0.55	78	INR	6	TSH	+6.58	TECTEH			21H00066	600UL
4921			0.41	77	INR	6	02H	+30.29	TECTEH			21H00066	600UL
4922			0.58	77	INR	6	03H	+33.78	TECTEH			21H00066	600UL
4923			0.27	50	INR	6	05H	+20.53	TECTEH			21H00066	600UL
4924			0.61	69	INR	6	04C	+15.94	TECTEH			21H00066	600UL
4925			1.36	73	INR	6	03C	+11.87	TECTEH			21H00066	600UL
4926			0.40	80	INR	6	01C	+4.70	TECTEH			21H00066	600UL
4927	55	68							TECTEH			21H00067	600UL
4928	57	68	0.29	64	INR	6	F03	+7.90	TECTEH			21H00066	600UL
4929					INF		F03	+9.44	TECTEH	HR		21H00066	600UL
4930			0.39	87	INR	6	04C	+8.50	TECTEH			21H00066	600UL
4931	59	68							TECTEH			21H00067	600UL
4932	61	68							TECTEH			21H00066	600UL
4933	63	68							TECTEH			21H00067	600UL
4934	65	68			INF		F04	+0.00	TECTEH	HR		21H00066	600UL
4935			0.92	39	INR	6	F05	+0.18	TECTEH			21H00066	600UL
4936			0.34	75	INR	6	06C	+27.52	TECTEH			21H00066	600UL
4937	67	68							TECTEH			21H00067	600UL
4938	69	68	0.32	62	INR	6	07H	+6.07	TECTEH			21H00066	600UL
4939			0.36	82	INR	6	03C	+13.14	TECTEH			21H00066	600UL
4940			0.56	74	INR	6	01C	+31.28	TECTEH			21H00066	600UL
4941	71	68	0.34	73	INR	6	01C	+22.19	TECTEH			21H00067	600UL
4942	73	68							TECTEH			21H00066	600UL
4943	75	68	0.47	70	INR	6	06C	+21.48	TECTEH			21H00067	600UL
4944	77	68							TECTEH			21H00066	600UL
4945	79	68							TECTEH			21H00067	600UL
4946	81	68	0.65	72	INR	6	02C	+4.30	TECTEH			21H00066	600UL
4947	83	68	0.18	85	INR	6	01H	+16.02	TECTEH			21H00043	600UL
4948	85	68							TECTEH			21H00044	600UL
4949	87	68							TECTEH			21H00043	600UL
4950	89	68	0.21	91	INR	6	F02	-0.03	TECTEH			21H00044	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
4951			0.23	73	INR	6	F03	+2.89	TECTEH			21H00044	600UL
4952			0.88	81	INR	6	F05	+10.21	TECTEH			21H00044	600UL
4953	91	68	0.50	76	INR	6	05C	+31.55	TECTEH			21H00043	600UL
4954	93	68							TECTEH			21H00044	600UL
4955	95	68							TECTEH			21H00043	600UL
4956	97	68	0.27	78	INR	3	03H	+34.79	TECTEH			21H00044	600UL
4957			0.32	144	INR	3	05H	+23.24	TECTEH			21H00044	600UL
4958			0.50	139	INR	3	06H	+8.92	TECTEH			21H00044	600UL
4959			0.46	139	INR	3	03C	+6.14	TECTEH			21H00044	600UL
4960	99	68	0.43	75	INR	6	01H	+4.59	TECTEH			21H00043	600UL
4961	101	68	0.33	58	INR	6	06H	+6.04	TECTEH			21H00044	600UL
4962	103	68	0.65	72	INR	6	F06	+14.93	TECTEH			21H00043	600UL
4963					INF		F07	+3.12	TECTEH	HR		21H00043	600UL
4964			0.63	84	INR	6	02C	+20.24	TECTEH			21H00043	600UL
4965	105	68							TECTEH			21H00044	600UL
4966	107	68							TECTEH			21H00043	600UL
4967	109	68	0.29	108	INR	3	TSH	+20.89	TECTEH			21H00044	600UL
4968			0.40	171	INR	3	F03	+8.53	TECTEH			21H00044	600UL
4969			1.69	217	INR	6	F07	+0.00	TECTEH			21H00044	600UL
4970			0.31	164	INR	3	04C	+32.07	TECTEH			21H00044	600UL
4971			0.32	147	INR	3	03C	+34.91	TECTEH			21H00044	600UL
4972	111	68							TECTEH			21H00043	600UL
4973	113	68	0.40	71	INR	6	F05	+9.72	TECTEH			21H00044	600UL
4974	115	68							TECTEH			21H00043	600UL
4975	117	68							TECTEH			21H00044	600UL
4976	119	68							TECTEH			21H00043	600UL
4977	121	68							TECTEH			21H00044	600UL
4978	123	68							TECTEH			21H00043	600UL
4979	125	68							TECTEH			21H00044	600UL
4980	127	68							TECTEH			21H00043	600UL
4981	129	68							TECTEH			21H00044	600UL
4982	131	68							TECTEH			21H00044	600UL
4983	133	68							TECTEH			21H00039	600UL
4984	135	68							TECTEH			21H00040	600UL
4985	137	68	0.38	144	INR	3	03H	+2.21	TECTEH			21H00040	600UL
4986			0.43	103	INR	3	05C	+28.34	TECTEH			21H00040	600UL
4987			0.34	131	INR	3	01C	+19.88	TECTEH			21H00040	600UL
4988	28	69							TECTEH			21H00067	600UL
4989	30	69							TECTEH			21H00067	600UL
4990	32	69							TECTEH			21H00066	600UL
4991	34	69							TECTEH			21H00067	600UL
4992	36	69	0.42	75	INR	6	04C	+9.08	TECTEH			21H00066	600UL
4993	38	69							TECTEH			21H00067	600UL
4994	40	69	0.84	80	INR	6	01H	+5.75	TECTEH			21H00066	600UL
4995					INF		03H	+24.33	TECTEH	HR		21H00066	600UL
4996			0.79	80	INR	6	03H	+26.58	TECTEH			21H00066	600UL
4997			0.23	59	INR	6	05H	+2.93	TECTEH			21H00066	600UL
4998			0.61	85	INR	6	06C	+24.99	TECTEH			21H00066	600UL
4999	42	69	0.67	76	INR	6	05C	+26.78	TECTEH			21H00067	600UL
5000	44	69							TECTEH			21H00066	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5001	46	69			INF		01H	+7.52		TECTEH	HR		21H00067	600UL
5002			0.32	81	INR	6	01H	+9.81		TECTEH			21H00067	600UL
5003			0.43	61	INR	6	06H	+2.99		TECTEH			21H00067	600UL
5004			0.59	59	INR	6	F01	+7.21		TECTEH			21H00067	600UL
5005					INF		F03	+6.54		TECTEH	HR		21H00067	600UL
5006	48	69								TECTEH			21H00066	600UL
5007	50	69	0.39	70	INR	6	06C	+14.86		TECTEH			21H00067	600UL
5008			0.57	79	INR	6	06C	+23.33		TECTEH			21H00067	600UL
5009	52	69	0.40	57	INR	6	04H	+37.87		TECTEH			21H00066	600UL
5010	54	69	0.39	71	INR	6	04C	+23.88		TECTEH			21H00067	600UL
5011	56	69								TECTEH			21H00066	600UL
5012	58	69								TECTEH			21H00067	600UL
5013	60	69	0.39	78	INR	6	05H	+31.37		TECTEH			21H00066	600UL
5014			0.44	75	INR	6	05C	+8.20		TECTEH			21H00066	600UL
5015	62	69								TECTEH			21H00067	600UL
5016	64	69								TECTEH			21H00066	600UL
5017	66	69								TECTEH			21H00067	600UL
5018	68	69								TECTEH			21H00066	600UL
5019	70	69								TECTEH			21H00067	600UL
5020	72	69								TECTEH			21H00066	600UL
5021	74	69	0.36	68	INR	6	06C	+5.51		TECTEH			21H00067	600UL
5022	76	69								TECTEH			21H00066	600UL
5023	78	69								TECTEH			21H00067	600UL
5024	80	69	0.34	68	INR	6	TSH	+16.19		TECTEH			21H00066	600UL
5025			0.85	73	INR	6	TSC	+11.06		TECTEH			21H00066	600UL
5026	82	69								TECTEH			21H00043	600UL
5027	84	69								TECTEH			21H00043	600UL
5028	86	69	0.37	126	INR	3	02C	+29.86		TECTEH			21H00044	600UL
5029	88	69								TECTEH			21H00043	600UL
5030	90	69								TECTEH			21H00044	600UL
5031	92	69								TECTEH			21H00043	600UL
5032	94	69	0.60	126	INR	3	07H	+3.34		TECTEH			21H00044	600UL
5033			0.57	241	INR	6	F07	+0.05		TECTEH			21H00044	600UL
5034			0.54	121	INR	3	06C	+26.72		TECTEH			21H00044	600UL
5035	96	69								TECTEH			21H00043	600UL
5036	98	69	0.31	135	INR	3	01C	+18.96		TECTEH			21H00044	600UL
5037	100	69								TECTEH			21H00043	600UL
5038	102	69								TECTEH			21H00044	600UL
5039	104	69	0.43	76	INR	6	02H	+7.69		TECTEH			21H00043	600UL
5040	106	69	0.26	131	INR	3	02C	+4.40		TECTEH			21H00044	600UL
5041	108	69								TECTEH			21H00043	600UL
5042	110	69								TECTEH			21H00044	600UL
5043	112	69								TECTEH			21H00043	600UL
5044	114	69								TECTEH			21H00044	600UL
5045	116	69	0.53	76	INR	6	02H	+31.66		TECTEH			21H00043	600UL
5046			0.67	84	INR	6	06H	+38.56		TECTEH			21H00043	600UL
5047			2.07	34	INR	6	F07	+6.33	TO+19.63	TECTEH			21H00043	600UL
5048			0.72	76	INR	6	04C	+25.38		TECTEH			21H00043	600UL
5049	118	69								TECTEH			21H00044	600UL
5050	120	69								TECTEH			21H00043	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5051	122	69							TECTEH			21H00044	600UL
5052	124	69							TECTEH			21H00043	600UL
5053	126	69							TECTEH			21H00044	600UL
5054	128	69							TECTEH			21H00043	600UL
5055	130	69	0.62	159	INR	3	F06	+13.24	TECTEH			21H00044	600UL
5056	132	69	0.40	77	INR	6	05H	+31.00	TECTEH			21H00039	600UL
5057	134	69							TECTEH			21H00040	600UL
5058	136	69	0.36	77	INR	6	03H	+3.81	TECTEH			21H00039	600UL
5059			0.55	95	INR	6	F01	+5.35	TECTEH			21H00039	600UL
5060					INF		F07	+2.13	TECTEH	HR		21H00039	600UL
5061			0.61	93	INR	6	F08	+3.10	TECTEH			21H00039	600UL
5062					INF		F09	+14.53	TECTEH	HR		21H00039	600UL
5063			0.63	78	INR	6	03C	+33.36	TECTEH			21H00039	600UL
5064	138	69							TECTEH			21H00040	600UL
5065	29	70							TECTEH			21H00067	600UL
5066	31	70	3.33	184	INR	1	F01	+6.43	TECTEH			21H00066	600UL
5067	33	70							TECTEH			21H00067	600UL
5068	35	70	0.57	87	INR	6	01C	+13.61	TECTEH			21H00066	600UL
5069			0.43	80	INR	6	TSC	+3.08	TECTEH			21H00066	600UL
5070	37	70							TECTEH			21H00067	600UL
5071	39	70							TECTEH			21H00066	600UL
5072	41	70							TECTEH			21H00067	600UL
5073	43	70			INF		TSH	+9.50	TECTEH	HR		21H00066	600UL
5074			0.44	92	INR	6	TSH	+11.70	TECTEH			21H00066	600UL
5075	45	70	0.44	79	INR	6	04C	+34.25	TECTEH			21H00067	600UL
5076			0.67	82	INR	6	01C	+26.17	TECTEH			21H00067	600UL
5077	47	70			INF		04C	+23.06	TECTEH	HR		21H00066	600UL
5078			0.43	81	INR	6	04C	+28.02	TECTEH			21H00066	600UL
5079	49	70	0.50	52	INR	6	06H	+7.99	TECTEH			21H00067	600UL
5080			0.78	46	INR	6	F04	+3.47	TECTEH			21H00067	600UL
5081	51	70							TECTEH			21H00066	600UL
5082	53	70	0.46	75	INR	6	01C	+5.95	TECTEH			21H00067	600UL
5083					INF		01C	+7.71	TECTEH	HR		21H00067	600UL
5084	55	70			INF		04C	+20.47	TECTEH	HR		21H00066	600UL
5085			0.47	78	INR	6	04C	+23.51	TECTEH			21H00066	600UL
5086	57	70							TECTEH			21H00067	600UL
5087	59	70	0.37	41	INR	6	05H	+29.54	TECTEH			21H00066	600UL
5088			0.45	79	INR	6	04C	+8.60	TECTEH			21H00066	600UL
5089	61	70							TECTEH			21H00067	600UL
5090	63	70							TECTEH			21H00066	600UL
5091	65	70	0.73	73	INR	6	02H	+8.70	TECTEH			21H00067	600UL
5092			0.38	72	INR	6	07H	+10.58	TECTEH			21H00067	600UL
5093	67	70							TECTEH			21H00066	600UL
5094	69	70	1.02	81	INR	6	03H	+9.82	TECTEH			21H00067	600UL
5095	71	70	0.40	83	INR	6	02H	+8.31	TECTEH			21H00066	600UL
5096	73	70			INF		F01	+4.19	TECTEH	HR		21H00067	600UL
5097			0.76	45	INR	6	F01	+6.40	TECTEH			21H00067	600UL
5098			1.20	69	INR	6	F08	+11.01	TECTEH			21H00067	600UL
5099					INF		F08	+11.05	TECTEH	HR		21H00067	600UL
5100					INF		F09	+3.45	TECTEH	HR		21H00067	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5101	75	70	0.60	78	INR	6	06C	+18.69	TECTEH			21H00066	600UL
5102	77	70							TECTEH			21H00067	600UL
5103	79	70							TECTEH			21H00066	600UL
5104	81	70							TECTEH			21H00066	600UL
5105	83	70							TECTEH			21H00043	600UL
5106	85	70							TECTEH			21H00044	600UL
5107	87	70							TECTEH			21H00043	600UL
5108	89	70	0.36	112	INR	3	05H	+31.78	TECTEH			21H00044	600UL
5109					INF		F04	+13.05	TECTEH	HR		21H00044	600UL
5110					INF		F05	+3.21	TECTEH	HR		21H00044	600UL
5111	91	70							TECTEH			21H00043	600UL
5112	93	70							TECTEH			21H00044	600UL
5113	95	70							TECTEH			21H00043	600UL
5114	97	70	0.39	139	INR	3	03H	+35.41	TECTEH			21H00044	600UL
5115			0.42	130	INR	3	04H	+17.61	TECTEH			21H00044	600UL
5116			0.44	121	INR	3	06C	+14.13	TECTEH			21H00044	600UL
5117	99	70							TECTEH			21H00043	600UL
5118	101	70	0.33	116	INR	3	01H	+2.39	TECTEH			21H00044	600UL
5119			0.30	105	INR	3	03H	+3.39	TECTEH			21H00044	600UL
5120			0.47	129	INR	3	03H	+30.13	TECTEH			21H00044	600UL
5121			0.44	46	INR	3	F11	+3.71	TECTEH			21H00044	600UL
5122					INF		F12	+3.48	TECTEH	HR		21H00044	600UL
5123			0.35	118	INR	3	01C	+22.46	TECTEH			21H00044	600UL
5124			0.25	139	INR	3	TSC	+13.10	TECTEH			21H00044	600UL
5125	103	70							TECTEH			21H00043	600UL
5126	105	70	0.59	75	INR	6	F12	+11.60	TECTEH			21H00044	600UL
5127					INF		07C	+2.23	TECTEH	HR		21H00044	600UL
5128	107	70	0.44	78	INR	6	04H	+27.35	TECTEH			21H00043	600UL
5129	109	70							TECTEH			21H00044	600UL
5130	111	70							TECTEH			21H00043	600UL
5131	113	70							TECTEH			21H00044	600UL
5132	115	70							TECTEH			21H00043	600UL
5133	117	70	0.29	127	INR	3	03H	+8.11	TECTEH			21H00044	600UL
5134	119	70							TECTEH			21H00043	600UL
5135	121	70							TECTEH			21H00044	600UL
5136	123	70							TECTEH			21H00043	600UL
5137	125	70	0.51	85	INR	3	F03	+2.51	TECTEH			21H00044	600UL
5138			0.33	128	INR	3	F12	+11.35	TECTEH			21H00044	600UL
5139					INF		07C	+7.09	TECTEH	HR		21H00044	600UL
5140			0.41	117	INR	3	01C	+10.75	TECTEH			21H00044	600UL
5141	127	70							TECTEH			21H00043	600UL
5142	129	70	0.35	124	INR	3	04H	+12.16	TECTEH			21H00044	600UL
5143			0.45	124	INR	3	05H	+4.74	TECTEH			21H00044	600UL
5144			0.41	118	INR	3	05H	+10.19	TECTEH			21H00044	600UL
5145			0.36	125	INR	3	01C	+20.14	TECTEH			21H00044	600UL
5146	131	70							TECTEH			21H00044	600UL
5147	133	70							TECTEH			21H00039	600UL
5148	135	70	0.94	78	INR	3	F06	+9.86	TECTEH			21H00040	600UL
5149	137	70	0.34	82	INR	6	04H	+29.69	TECTEH			21H00039	600UL
5150	139	70	0.58	146	INR	3	F11	+13.25	TECTEH			21H00040	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5151					INF		F12	+6.92	TECTEH	HR		21H00040	600UL
5152	30	71							TECTEH			21H00069	600UL
5153	32	71							TECTEH			21H00068	600UL
5154	34	71							TECTEH			21H00069	600UL
5155	36	71	0.41	80	INR	6	06C	+17.50	TECTEH			21H00068	600UL
5156			0.22	78	INR	6	03C	+9.74	TECTEH			21H00068	600UL
5157			0.43	77	INR	6	03C	+15.71	TECTEH			21H00068	600UL
5158			0.62	127	INR	3	03C	+37.51	TECTEH			21H00068	600UL
5159	38	71							TECTEH			21H00069	600UL
5160	40	71	0.24	62	INR	6	03H	+38.24	TECTEH			21H00068	600UL
5161			1.21	37	INR	6	F06	+11.81	TECTEH			21H00068	600UL
5162					INF		F07	+2.03	TECTEH	HR		21H00068	600UL
5163	42	71							TECTEH			21H00069	600UL
5164	44	71							TECTEH			21H00068	600UL
5165	46	71							TECTEH			21H00069	600UL
5166	48	71	0.45	133	INR	3	01H	+32.37	TECTEH			21H00068	600UL
5167			0.43	129	INR	3	01H	+32.45	TECTEH			21H00068	600UL
5168			0.89	79	INR	6	05C	+11.47	TECTEH			21H00068	600UL
5169	50	71							TECTEH			21H00069	600UL
5170	52	71	0.48	71	INR	6	F08	+4.24	TECTEH			21H00068	600UL
5171					INF		F09	+0.03	TECTEH	HR		21H00068	600UL
5172					INF		F09	+7.00	TECTEH	HR		21H00068	600UL
5173			0.49	81	INR	6	02C	+6.36	TECTEH			21H00068	600UL
5174			0.38	77	INR	6	01C	+21.02	TECTEH			21H00068	600UL
5175			0.45	81	INR	6	01C	+27.15	TECTEH			21H00068	600UL
5176	54	71	0.62	77	INR	6	01H	+15.72	TECTEH			21H00069	600UL
5177			0.66	76	INR	6	03H	+26.53	TECTEH			21H00069	600UL
5178			0.52	78	INR	6	04H	+29.91	TECTEH			21H00069	600UL
5179			0.53	79	INR	6	02C	+22.69	TECTEH			21H00069	600UL
5180	56	71	0.31	75	INR	6	01H	+26.03	TECTEH			21H00068	600UL
5181			0.45	82	INR	6	01H	+26.24	TECTEH			21H00068	600UL
5182					INF		06C	+29.67	TECTEH	HR		21H00068	600UL
5183			0.34	130	INR	3	06C	+33.62	TECTEH			21H00068	600UL
5184	58	71	0.56	70	INR	6	04H	+38.88	TECTEH			21H00069	600UL
5185					INF		F03	+5.97	TECTEH	HR		21H00069	600UL
5186			0.67	98	INR	6	F03	+7.99	TECTEH			21H00069	600UL
5187	60	71							TECTEH			21H00068	600UL
5188	62	71	0.52	70	INR	6	05C	+6.66	TECTEH			21H00069	600UL
5189	64	71							TECTEH			21H00068	600UL
5190	66	71							TECTEH			21H00067	600UL
5191	68	71							TECTEH			21H00066	600UL
5192	70	71	0.48	79	INR	6	02H	+11.08	TECTEH			21H00067	600UL
5193			0.46	81	INR	6	03C	+38.68	TECTEH			21H00067	600UL
5194	72	71							TECTEH			21H00066	600UL
5195	74	71							TECTEH			21H00067	600UL
5196	76	71	0.33	72	INR	6	03H	+36.96	TECTEH			21H00066	600UL
5197			0.44	70	INR	6	F07	+10.72	TECTEH			21H00066	600UL
5198					INF		F08	+2.01	TECTEH	HR		21H00066	600UL
5199			0.25	40	INR	6	F08	+8.28	TECTEH			21H00066	600UL
5200			1.11	62	INR	6	04C	+2.21	TECTEH			21H00066	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5201	78	71								TECTEH			21H00067	600UL
5202	80	71								TECTEH			21H00066	600UL
5203	82	71								TECTEH			21H00045	600UL
5204	84	71			INF		TSC	+18.40		TECTEH	HR		21H00045	600UL
5205			0.42	68	INR	6	TSC	+19.23		TECTEH			21H00045	600UL
5206	86	71								TECTEH			21H00046	600UL
5207	88	71	1.52	58	INR	6	F01	+2.87	TO+12.19	TECTEH			21H00045	600UL
5208			0.38	94	INR	6	F07	+5.52		TECTEH			21H00045	600UL
5209					INF		F08	+9.99		TECTEH	HR		21H00045	600UL
5210	90	71								TECTEH			21H00046	600UL
5211	92	71								TECTEH			21H00045	600UL
5212	94	71	0.44	82	INR	6	03H	+16.39		TECTEH			21H00046	600UL
5213					INF		F08	+65.49		TECTEH	HR		21H00046	600UL
5214			0.49	81	INR	6	F12	+12.09		TECTEH			21H00046	600UL
5215					INF		07C	+3.60		TECTEH	HR		21H00046	600UL
5216	96	71								TECTEH			21H00045	600UL
5217	98	71								TECTEH			21H00046	600UL
5218	100	71	0.42	80	INR	6	F06	+3.59		TECTEH			21H00045	600UL
5219			0.45	73	INR	6	05C	+6.03		TECTEH			21H00045	600UL
5220	102	71								TECTEH			21H00046	600UL
5221	104	71								TECTEH			21H00045	600UL
5222	106	71								TECTEH			21H00046	600UL
5223	108	71	0.27	80	INR	6	TSH	+17.43		TECTEH			21H00045	600UL
5224	110	71								TECTEH			21H00046	600UL
5225	112	71								TECTEH			21H00045	600UL
5226	114	71								TECTEH			21H00046	600UL
5227	116	71	0.27	66	NQH	3	04H	+29.01		TECTEH			21H00045	600UL
5228	118	71								TECTEH			21H00046	600UL
5229	120	71								TECTEH			21H00045	600UL
5230	122	71								TECTEH			21H00046	600UL
5231	124	71								TECTEH			21H00045	600UL
5232	126	71								TECTEH			21H00046	600UL
5233	128	71								TECTEH			21H00045	600UL
5234	130	71								TECTEH			21H00046	600UL
5235	132	71								TECTEH			21H00039	600UL
5236	134	71	0.36	129	INR	3	TSC	+4.12		TECTEH			21H00040	600UL
5237	136	71	0.43	68	INR	6	F10	+6.96		TECTEH			21H00039	600UL
5238					INF		F11	+10.84		TECTEH	HR		21H00039	600UL
5239			0.62	77	INR	6	03C	+28.76		TECTEH			21H00039	600UL
5240	138	71								TECTEH			21H00040	600UL
5241	31	72								TECTEH			21H00069	600UL
5242	33	72								TECTEH			21H00068	600UL
5243	35	72								TECTEH			21H00069	600UL
5244	37	72	0.37	82	INR	6	TSH	+5.90		TECTEH			21H00068	600UL
5245			0.35	79	INR	6	04C	+13.06		TECTEH			21H00068	600UL
5246	39	72								TECTEH			21H00069	600UL
5247	41	72								TECTEH			21H00068	600UL
5248	43	72	0.56	73	INR	6	04H	+33.35		TECTEH			21H00069	600UL
5249			0.34	74	INR	6	01C	+6.64		TECTEH			21H00069	600UL
5250	45	72								TECTEH			21H00068	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5251	47	72	0.75	51	INR	6	06H	+23.17	TECTEH			21H00069	600UL
5252			0.52	67	INR	6	05C	+20.13	TECTEH			21H00069	600UL
5253	49	72							TECTEH			21H00068	600UL
5254	51	72							TECTEH			21H00069	600UL
5255	53	72							TECTEH			21H00068	600UL
5256	55	72	0.32	95	INR	3	06H	+10.79	TECTEH			21H00069	600UL
5257	57	72	0.59	73	INR	6	06H	+27.34	TECTEH			21H00068	600UL
5258	59	72							TECTEH			21H00069	600UL
5259	61	72	1.53	27	INR	6	07C	-0.36	TECTEH			21H00068	600UL
5260	63	72							TECTEH			21H00069	600UL
5261	65	72							TECTEH			21H00068	600UL
5262	67	72	0.55	83	INR	6	F06	+7.21	TECTEH			21H00069	600UL
5263					INF		F07	+5.85	TECTEH	HR		21H00069	600UL
5264			0.46	75	INR	6	06C	+10.08	TECTEH			21H00069	600UL
5265	69	72							TECTEH			21H00068	600UL
5266	71	72	0.49	87	INR	6	04C	+5.85	TECTEH			21H00069	600UL
5267	73	72							TECTEH			21H00068	600UL
5268	75	72	0.49	75	INR	6	TSC	+13.32	TECTEH			21H00069	600UL
5269	77	72	1.88	98	INR	6	F11	+1.50	TECTEH			21H00068	600UL
5270					INF		F12	-0.17	TECTEH	HR		21H00068	600UL
5271					INF		F12	+1.40	TECTEH	HR		21H00068	600UL
5272	79	72							TECTEH			21H00069	600UL
5273	81	72							TECTEH			21H00068	600UL
5274	83	72							TECTEH			21H00045	600UL
5275	85	72							TECTEH			21H00046	600UL
5276	87	72	0.82	32	INR	6	F11	+0.77	TECTEH			21H00045	600UL
5277			1.11	78	INR	6	01C	+13.49	TECTEH			21H00045	600UL
5278	89	72	0.47	69	INR	6	05H	+3.46	TECTEH			21H00046	600UL
5279			1.22	84	INR	6	F03	+10.16	TECTEH			21H00046	600UL
5280			1.97	80	INR	6	06C	+25.95	TECTEH			21H00046	600UL
5281	91	72							TECTEH			21H00045	600UL
5282	93	72	0.49	81	INR	6	02H	+29.46	TECTEH			21H00046	600UL
5283	95	72							TECTEH			21H00045	600UL
5284	97	72	0.37	83	INR	6	01H	+10.43	TECTEH			21H00046	600UL
5285			0.63	65	INR	6	F02	+9.25	TECTEH			21H00046	600UL
5286			2.03	83	INR	6	TSC	+20.39	TECTEH			21H00046	600UL
5287	99	72	0.39	86	INR	6	02C	+17.41	TECTEH			21H00045	600UL
5288	101	72	0.53	101	INR	6	TSH	+14.16	TECTEH			21H00046	600UL
5289	103	72							TECTEH			21H00045	600UL
5290	105	72	0.37	70	INR	6	04C	+34.68	TECTEH			21H00046	600UL
5291	107	72	0.37	72	INR	6	06H	+17.53	TECTEH			21H00045	600UL
5292			0.41	77	INR	6	F03	+6.60	TECTEH			21H00045	600UL
5293	109	72							TECTEH			21H00046	600UL
5294	111	72							TECTEH			21H00045	600UL
5295	113	72	0.79	76	INR	6	02H	+20.58	TECTEH			21H00046	600UL
5296			0.45	62	INR	6	05C	+19.32	TECTEH			21H00046	600UL
5297	115	72	0.57	59	INR	6	03H	+19.72	TECTEH			21H00045	600UL
5298			0.41	89	INR	6	05H	+26.55	TECTEH			21H00045	600UL
5299			0.33	59	INR	6	F01	+4.29	TECTEH			21H00045	600UL
5300			1.08	29	INR	6	F03	+16.34	TECTEH			21H00045	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5301			0.28	75	INR	6	F04	+13.59	TECTEH			21H00045	600UL
5302			0.62	81	INR	6	F05	+2.54	TECTEH			21H00045	600UL
5303			0.45	43	INR	6	05C	+20.40	TECTEH			21H00045	600UL
5304			0.34	85	INR	6	04C	+28.89	TECTEH			21H00045	600UL
5305			0.28	98	NQH	3	02C	+2.63	TECTEH			21H00045	600UL
5306			0.51	87	INR	6	02C	+38.51	TECTEH			21H00045	600UL
5307	117	72	0.67	80	INR	6	03C	+34.44	TECTEH			21H00046	600UL
5308	119	72	0.45	68	INR	6	03C	+20.73	TECTEH			21H00045	600UL
5309	121	72							TECTEH			21H00046	600UL
5310	123	72							TECTEH			21H00045	600UL
5311	125	72							TECTEH			21H00046	600UL
5312	127	72							TECTEH			21H00045	600UL
5313	129	72							TECTEH			21H00046	600UL
5314	131	72							TECTEH			21H00046	600UL
5315	133	72							TECTEH			21H00039	600UL
5316	135	72							TECTEH			21H00040	600UL
5317	137	72	0.44	73	INR	6	F06	+5.06	TECTEH			21H00039	600UL
5318					INF		F06	+6.34	TECTEH	HR		21H00039	600UL
5319			0.41	73	INR	6	05C	+25.50	TECTEH			21H00039	600UL
5320			0.44	78	INR	6	02C	+26.00	TECTEH			21H00039	600UL
5321	139	72							TECTEH			21H00040	600UL
5322	32	73							TECTEH			21H00069	600UL
5323	34	73							TECTEH			21H00069	600UL
5324	36	73							TECTEH			21H00068	600UL
5325	38	73							TECTEH			21H00069	600UL
5326	40	73	0.44	78	INR	6	01H	+23.48	TECTEH			21H00068	600UL
5327			0.40	86	INR	6	02C	+17.00	TECTEH			21H00068	600UL
5328	42	73	0.49	70	INR	6	05H	+5.04	TECTEH			21H00069	600UL
5329			0.44	72	INR	6	05H	+18.55	TECTEH			21H00069	600UL
5330			0.64	68	INR	6	F05	+4.70	TECTEH			21H00069	600UL
5331			0.45	75	INR	6	06C	+7.79	TECTEH			21H00069	600UL
5332	44	73							TECTEH			21H00068	600UL
5333	46	73							TECTEH			21H00069	600UL
5334	48	73							TECTEH			21H00068	600UL
5335	50	73							TECTEH			21H00069	600UL
5336	52	73							TECTEH			21H00068	600UL
5337	54	73							TECTEH			21H00069	600UL
5338	56	73							TECTEH			21H00068	600UL
5339	58	73	0.58	68	INR	6	04H	+16.21	TECTEH			21H00069	600UL
5340	60	73	0.41	74	INR	6	03C	+36.22	TECTEH			21H00068	600UL
5341	62	73							TECTEH			21H00069	600UL
5342	64	73							TECTEH			21H00068	600UL
5343	66	73							TECTEH			21H00069	600UL
5344	68	73	0.41	81	INR	6	01C	+27.82	TECTEH			21H00068	600UL
5345	70	73	1.00	71	INR	6	06H	+36.16	TECTEH			21H00069	600UL
5346	72	73	0.16	79	INR	6	01H	+16.05	TECTEH			21H00068	600UL
5347	74	73	0.46	66	INR	6	F12	+4.45	TECTEH			21H00069	600UL
5348					INF		07C	+9.12	TECTEH	HR		21H00069	600UL
5349	76	73							TECTEH			21H00068	600UL
5350	78	73							TECTEH			21H00069	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5351	80	73							TECTEH			21H00068	600UL
5352	82	73							TECTEH			21H00045	600UL
5353	84	73	0.41	74	INR	6	01C	+32.02	TECTEH			21H00045	600UL
5354			0.39	81	INR	6	TSC	+6.92	TECTEH			21H00045	600UL
5355	86	73							TECTEH			21H00046	600UL
5356	88	73							TECTEH			21H00045	600UL
5357	90	73	0.61	79	INR	6	04C	+34.15	TECTEH			21H00046	600UL
5358	92	73	0.54	89	NQH	3	F02	+11.58	TECTEH			21H00045	600UL
5359			0.47	86	INR	6	04C	+16.16	TECTEH			21H00045	600UL
5360	94	73	0.59	78	INR	6	05C	+20.85	TECTEH			21H00046	600UL
5361	96	73	0.57	82	INR	6	01C	+6.68	TECTEH			21H00045	600UL
5362			0.47	102	INR	6	TSC	+21.91	TECTEH			21H00045	600UL
5363	98	73							TECTEH			21H00046	600UL
5364	100	73	0.31	89	INR	6	TSH	+7.18	TECTEH			21H00045	600UL
5365	102	73	0.30	74	INR	6	04C	+27.28	TECTEH			21H00046	600UL
5366	104	73	0.95	74	INR	6	04C	+14.36	TECTEH			21H00045	600UL
5367			0.65	69	INR	6	TSC	+14.60	TECTEH			21H00045	600UL
5368	106	73							TECTEH			21H00046	600UL
5369	108	73							TECTEH			21H00045	600UL
5370	110	73	0.51	46	INR	6	F01	+6.46	TECTEH			21H00046	600UL
5371	112	73							TECTEH			21H00045	600UL
5372	114	73	0.53	73	INR	6	01H	+15.97	TECTEH			21H00046	600UL
5373	116	73							TECTEH			21H00045	600UL
5374	118	73							TECTEH			21H00046	600UL
5375	120	73							TECTEH			21H00045	600UL
5376	122	73							TECTEH			21H00046	600UL
5377	124	73							TECTEH			21H00045	600UL
5378	126	73							TECTEH			21H00046	600UL
5379	128	73	0.36	78	NQH	3	F04	+6.66	TECTEH			21H00045	600UL
5380	130	73							TECTEH			21H00046	600UL
5381	132	73							TECTEH			21H00039	600UL
5382	134	73	0.53	137	INR	3	F01	+7.24	TECTEH			21H00040	600UL
5383	136	73							TECTEH			21H00039	600UL
5384	138	73							TECTEH			21H00040	600UL
5385	33	74							TECTEH			21H00069	600UL
5386	35	74							TECTEH			21H00068	600UL
5387	37	74							TECTEH			21H00069	600UL
5388	39	74	0.18	64	INR	6	01H	+13.49	TECTEH			21H00068	600UL
5389			0.48	72	INR	6	02H	+24.63	TECTEH			21H00068	600UL
5390			0.41	74	INR	6	05C	+25.23	TECTEH			21H00068	600UL
5391			0.28	69	INR	6	04C	+33.53	TECTEH			21H00068	600UL
5392	41	74	0.48	85	INR	6	F08	+3.12	TECTEH			21H00069	600UL
5393					INF		F09	+8.06	TECTEH	HR		21H00069	600UL
5394			0.63	70	INR	6	05C	+2.56	TECTEH			21H00069	600UL
5395	43	74	0.41	75	INR	6	TSH	+9.64	TECTEH			21H00068	600UL
5396			0.30	38	INR	6	F07	+9.21	TECTEH			21H00068	600UL
5397					INF		F08	+2.46	TECTEH	HR		21H00068	600UL
5398			0.44	114	INR	6	F08	+3.15	TECTEH			21H00068	600UL
5399					INF		F09	+7.91	TECTEH	HR		21H00068	600UL
5400	45	74							TECTEH			21H00069	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5401	47	74	0.30	66	INR	6	01H	+32.68	TECTEH			21H00068	600UL
5402			0.61	77	INR	6	03C	+32.48	TECTEH			21H00068	600UL
5403	49	74							TECTEH			21H00069	600UL
5404	51	74							TECTEH			21H00068	600UL
5405	53	74	0.54	61	INR	6	05H	+38.62	TECTEH			21H00069	600UL
5406					INF		07H	+17.50	TECTEH	HR		21H00069	600UL
5407			2.13	182	INR	1	F03	+2.46	TECTEH			21H00069	600UL
5408					INF		F03	+2.47	TECTEH	HR		21H00069	600UL
5409			0.71	84	INR	6	F07	+3.81	TECTEH			21H00069	600UL
5410					INF		F08	+6.37	TECTEH	HR		21H00069	600UL
5411			0.55	98	INR	6	F08	+6.50	TECTEH			21H00069	600UL
5412			0.84	68	INR	6	F09	+4.86	TECTEH			21H00069	600UL
5413					INF		F10	+7.60	TECTEH	HR		21H00069	600UL
5414			0.44	79	INR	6	05C	+4.35	TECTEH			21H00069	600UL
5415			0.42	81	INR	6	04C	+21.03	TECTEH			21H00069	600UL
5416	55	74							TECTEH			21H00068	600UL
5417	57	74	0.26	117	INR	3	04H	+17.18	TECTEH			21H00069	600UL
5418			0.45	66	INR	6	06H	+11.36	TECTEH			21H00069	600UL
5419			0.58	71	INR	6	06C	+30.10	TECTEH			21H00069	600UL
5420	59	74							TECTEH			21H00068	600UL
5421	61	74	0.46	75	INR	6	07H	+6.37	TECTEH			21H00069	600UL
5422			0.55	64	INR	6	F05	+7.25	TECTEH			21H00069	600UL
5423			0.61	65	INR	6	06C	+2.18	TECTEH			21H00069	600UL
5424			0.57	95	INR	6	05C	+26.36	TECTEH			21H00069	600UL
5425	63	74							TECTEH			21H00068	600UL
5426	65	74							TECTEH			21H00069	600UL
5427	67	74							TECTEH			21H00068	600UL
5428	69	74	0.67	69	INR	6	F12	+3.31	TECTEH			21H00069	600UL
5429					INF		07C	+8.90	TECTEH	HR		21H00069	600UL
5430			0.68	78	INR	6	03C	+24.07	TECTEH			21H00069	600UL
5431	71	74	0.62	79	INR	6	04C	+19.07	TECTEH			21H00068	600UL
5432	73	74			INF		F09	+0.00	TECTEH	HR		21H00069	600UL
5433			0.27	80	INR	6	F09	+3.37	TECTEH			21H00069	600UL
5434	75	74	0.52	84	INR	6	01C	+30.32	TECTEH			21H00068	600UL
5435	77	74							TECTEH			21H00069	600UL
5436	79	74	0.29	73	INR	6	01H	+12.70	TECTEH			21H00068	600UL
5437			0.50	76	INR	6	06H	+25.77	TECTEH			21H00068	600UL
5438			0.33	73	INR	6	06C	+24.00	TECTEH			21H00068	600UL
5439	81	74							TECTEH			21H00068	600UL
5440	83	74							TECTEH			21H00045	600UL
5441	85	74							TECTEH			21H00046	600UL
5442	87	74							TECTEH			21H00045	600UL
5443	89	74	0.16	78	INR	6	F06	+0.08	TECTEH			21H00046	600UL
5444	91	74	0.34	82	INR	6	05H	+5.52	TECTEH			21H00045	600UL
5445			0.45	83	INR	6	03C	+24.81	TECTEH			21H00045	600UL
5446			0.37	75	INR	6	01C	+27.28	TECTEH			21H00045	600UL
5447	93	74							TECTEH			21H00046	600UL
5448	95	74							TECTEH			21H00045	600UL
5449	97	74	0.34	39	INR	6	F03	+2.69	TECTEH			21H00046	600UL
5450	99	74	0.22	110	INR	3	04H	+18.29	TECTEH			21H00045	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5451			0.63	91	INR	6	F11	+2.88	TECTEH			21H00045	600UL
5452					INF		F12	+6.47	TECTEH	HR		21H00045	600UL
5453			0.44	82	INR	6	05C	+5.50	TECTEH			21H00045	600UL
5454			0.44	75	INR	6	03C	+36.56	TECTEH			21H00045	600UL
5455			0.49	83	INR	6	TSC	+11.00	TECTEH			21H00045	600UL
5456	101	74	0.39	75	INR	6	05H	+7.08	TECTEH			21H00046	600UL
5457					INF		F05	+10.45	TECTEH	HR		21H00046	600UL
5458			0.28	83	INR	6	F05	+11.64	TECTEH			21H00046	600UL
5459			0.44	70	INR	6	05C	+4.98	TECTEH			21H00046	600UL
5460			0.98	77	INR	6	TSC	+14.66	TECTEH			21H00046	600UL
5461			0.20	126	INR	3	TSC	+17.11	TECTEH			21H00046	600UL
5462	103	74							TECTEH			21H00045	600UL
5463	105	74	0.34	75	INR	6	04C	+8.09	TECTEH			21H00046	600UL
5464	107	74	0.50	83	INR	6	01H	+11.14	TECTEH			21H00045	600UL
5465	109	74							TECTEH			21H00046	600UL
5466	111	74							TECTEH			21H00045	600UL
5467	113	74	0.31	65	INR	6	F10	+11.70	TECTEH			21H00046	600UL
5468					INF		F10	+13.09	TECTEH	HR		21H00046	600UL
5469					INF		F11	+13.41	TECTEH	HR		21H00046	600UL
5470	115	74							TECTEH			21H00045	600UL
5471	117	74							TECTEH			21H00046	600UL
5472	119	74							TECTEH			21H00045	600UL
5473	121	74							TECTEH			21H00046	600UL
5474	123	74	0.69	74	INR	6	01C	+15.70	TECTEH			21H00045	600UL
5475	125	74	0.65	77	INR	6	TSC	+7.58	TECTEH			21H00046	600UL
5476	127	74							TECTEH			21H00045	600UL
5477	129	74							TECTEH			21H00046	600UL
5478	131	74	0.39	74	INR	6	04C	+34.76	TECTEH			21H00046	600UL
5479	133	74							TECTEH			21H00039	600UL
5480	135	74	0.28	97	INR	3	05H	+27.98	TECTEH			21H00040	600UL
5481			0.24	146	INR	3	07H	+4.60	TECTEH			21H00040	600UL
5482	137	74	0.50	76	INR	6	TSC	+5.78	TECTEH			21H00039	600UL
5483	139	74							TECTEH			21H00040	600UL
5484	34	75							TECTEH			21H00069	600UL
5485	36	75							TECTEH			21H00068	600UL
5486	38	75							TECTEH			21H00069	600UL
5487	40	75	0.35	40	INR	6	04H	+38.64	TECTEH			21H00068	600UL
5488	42	75							TECTEH			21H00069	600UL
5489	44	75							TECTEH			21H00068	600UL
5490	46	75							TECTEH			21H00069	600UL
5491	48	75	0.40	73	INR	6	TSH	+18.27	TECTEH			21H00068	600UL
5492	50	75							TECTEH			21H00069	600UL
5493	52	75	0.35	82	INR	6	06C	+16.79	TECTEH			21H00068	600UL
5494	54	75	0.56	75	INR	6	05C	+4.11	TECTEH			21H00069	600UL
5495	56	75							TECTEH			21H00068	600UL
5496	58	75	0.39	80	INR	6	01H	+3.31	TECTEH			21H00069	600UL
5497			0.49	67	INR	6	05H	+16.14	TECTEH			21H00069	600UL
5498	60	75							TECTEH			21H00068	600UL
5499	62	75							TECTEH			21H00069	600UL
5500	64	75							TECTEH			21H00068	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5501	66	75	0.63	47	INR	6	F06	+3.10	TECTEH			21H00069	600UL
5502	68	75							TECTEH			21H00068	600UL
5503	70	75							TECTEH			21H00069	600UL
5504	72	75	0.94	78	INR	6	F09	+6.21	TECTEH			21H00068	600UL
5505					INF		F10	+7.09	TECTEH	HR		21H00068	600UL
5506			0.36	78	INR	6	06C	+26.07	TECTEH			21H00068	600UL
5507	74	75							TECTEH			21H00069	600UL
5508	76	75							TECTEH			21H00068	600UL
5509	78	75							TECTEH			21H00069	600UL
5510	80	75	0.77	51	INR	6	F09	+0.23	TECTEH			21H00068	600UL
5511			0.34	80	INR	6	02C	+2.46	TECTEH			21H00068	600UL
5512	82	75	1.27	78	INR	6	TSH	+20.11	TECTEH			21H00045	600UL
5513	84	75							TECTEH			21H00045	600UL
5514	86	75	0.26	59	INR	6	F06	+4.39	TECTEH			21H00046	600UL
5515	88	75							TECTEH			21H00045	600UL
5516	90	75							TECTEH			21H00046	600UL
5517	92	75							TECTEH			21H00045	600UL
5518	94	75							TECTEH			21H00046	600UL
5519	96	75	0.29	72	INR	6	04H	+19.10	TECTEH			21H00045	600UL
5520	98	75			INF		F01	+2.24	TECTEH	HR		21H00046	600UL
5521			0.42	102	INR	6	F06	+14.06	TECTEH			21H00046	600UL
5522					INF		F07	+0.00	TECTEH	HR		21H00046	600UL
5523			2.10	24	INR	6	03C	+1.67	TECTEH			21H00046	600UL
5524	100	75	0.64	77	INR	6	F05	+14.54	TECTEH			21H00045	600UL
5525	102	75							TECTEH			21H00046	600UL
5526	104	75	0.39	75	INR	6	04H	+26.92	TECTEH			21H00045	600UL
5527			0.53	69	INR	6	07H	+13.86	TECTEH			21H00045	600UL
5528			0.56	75	INR	6	04C	+14.51	TECTEH			21H00045	600UL
5529			0.68	86	INR	6	04C	+16.89	TECTEH			21H00045	600UL
5530			0.58	86	INR	6	04C	+27.46	TECTEH			21H00045	600UL
5531	106	75	0.37	76	INR	6	05C	+33.39	TECTEH			21H00046	600UL
5532	108	75							TECTEH			21H00045	600UL
5533	110	75	0.57	74	INR	6	05C	+6.64	TECTEH			21H00046	600UL
5534			0.45	69	INR	6	02C	+7.78	TECTEH			21H00046	600UL
5535	112	75	0.35	81	INR	6	05H	+8.84	TECTEH			21H00045	600UL
5536			0.52	79	INR	6	F12	+11.83	TECTEH			21H00045	600UL
5537					INF		F12	+13.07	TECTEH	HR		21H00045	600UL
5538			0.70	75	INR	6	F12	+15.63	TECTEH			21H00045	600UL
5539					INF		F12	+16.75	TECTEH	HR		21H00045	600UL
5540			0.76	73	INR	6	07C	+1.98	TECTEH			21H00045	600UL
5541					INF		07C	+5.65	TECTEH	HR		21H00045	600UL
5542			0.82	76	INR	6	03C	+20.29	TECTEH			21H00045	600UL
5543	114	75							TECTEH			21H00046	600UL
5544	116	75							TECTEH			21H00045	600UL
5545	118	75							TECTEH			21H00046	600UL
5546	120	75							TECTEH			21H00045	600UL
5547	122	75							TECTEH			21H00046	600UL
5548	124	75							TECTEH			21H00045	600UL
5549	126	75	0.79	80	INR	6	F10	+2.52	TECTEH			21H00046	600UL
5550					INF		F11	+16.13	TECTEH	HR		21H00046	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5551	128	75							TECTEH			21H00045	600UL
5552	130	75							TECTEH			21H00046	600UL
5553	132	75							TECTEH			21H00039	600UL
5554	134	75							TECTEH			21H00039	600UL
5555	136	75	0.34	100	INR	3	TSC	+15.04	TECTEH			21H00040	600UL
5556	138	75							TECTEH			21H00039	600UL
5557	140	75							TECTEH			21H00040	600UL
5558	35	76							TECTEH			21H00069	600UL
5559	37	76	0.23	81	INR	6	TSC	+3.51	TECTEH			21H00068	600UL
5560	39	76	0.49	70	INR	6	04H	+22.69	TECTEH			21H00069	600UL
5561	41	76							TECTEH			21H00068	600UL
5562	43	76	0.61	67	INR	6	04C	+5.44	TECTEH			21H00069	600UL
5563	45	76	0.26	84	INR	6	01H	+24.42	TECTEH			21H00068	600UL
5564	47	76							TECTEH			21H00069	600UL
5565	49	76							TECTEH			21H00068	600UL
5566	51	76							TECTEH			21H00069	600UL
5567	53	76	0.34	79	INR	6	03H	+12.91	TECTEH			21H00068	600UL
5568			0.47	77	INR	6	F06	+2.02	TECTEH			21H00068	600UL
5569	55	76	0.63	75	INR	6	02H	+19.09	TECTEH			21H00069	600UL
5570			0.33	133	INR	3	04H	+19.48	TECTEH			21H00069	600UL
5571			0.80	76	INR	6	06C	+21.62	TECTEH			21H00069	600UL
5572	57	76							TECTEH			21H00068	600UL
5573	59	76	0.81	48	INR	6	F01	+0.24	TECTEH			21H00069	600UL
5574	61	76							TECTEH			21H00068	600UL
5575	63	76	0.47	80	INR	6	03H	+8.46	TECTEH			21H00069	600UL
5576			0.85	80	INR	6	04H	+21.82	TECTEH			21H00069	600UL
5577			0.88	63	INR	6	06H	+16.24	TECTEH			21H00069	600UL
5578	65	76	0.47	74	INR	6	03C	+28.95	TECTEH			21H00068	600UL
5579	67	76	0.32	72	INR	6	04H	+17.01	TECTEH			21H00069	600UL
5580	69	76							TECTEH			21H00068	600UL
5581	71	76							TECTEH			21H00069	600UL
5582	73	76	0.37	80	INR	6	TSH	+3.26	TECTEH			21H00068	600UL
5583	75	76							TECTEH			21H00069	600UL
5584	77	76							TECTEH			21H00068	600UL
5585	79	76	0.69	75	INR	6	04H	+35.10	TECTEH			21H00069	600UL
5586			0.62	80	INR	6	04C	+24.59	TECTEH			21H00069	600UL
5587	81	76							TECTEH			21H00068	600UL
5588	83	76							TECTEH			21H00045	600UL
5589	85	76							TECTEH			21H00046	600UL
5590	87	76							TECTEH			21H00045	600UL
5591	89	76							TECTEH			21H00046	600UL
5592	91	76	0.55	75	INR	6	F06	+12.64	TECTEH			21H00045	600UL
5593					INF		F07	+3.96	TECTEH	HR		21H00045	600UL
5594	93	76							TECTEH			21H00046	600UL
5595	95	76							TECTEH			21H00045	600UL
5596	97	76							TECTEH			21H00046	600UL
5597	99	76	0.42	77	INR	6	02H	+35.59	TECTEH			21H00045	600UL
5598	101	76							TECTEH			21H00046	600UL
5599	103	76							TECTEH			21H00045	600UL
5600	105	76			INF		01C	+32.18	TECTEH	HR		21H00046	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5601	107	76	0.72	54	NQH	3	F04	+10.02	TECTEH			21H00045	600UL
5602			0.84	92	INR	6	F08	+14.46	TECTEH			21H00045	600UL
5603			0.40	40	INR	6	F09	+0.00	TECTEH			21H00045	600UL
5604			0.40	67	INR	6	05C	+9.05	TECTEH			21H00045	600UL
5605			0.72	74	INR	6	01C	+16.90	TECTEH			21H00045	600UL
5606	109	76	0.63	68	INR	6	02H	+39.35	TECTEH			21H00046	600UL
5607	111	76							TECTEH			21H00045	600UL
5608	113	76							TECTEH			21H00046	600UL
5609	115	76							TECTEH			21H00045	600UL
5610	117	76	1.06	27	INR	6	F05	+0.39	TECTEH			21H00046	600UL
5611	119	76							TECTEH			21H00045	600UL
5612	121	76							TECTEH			21H00046	600UL
5613	123	76							TECTEH			21H00045	600UL
5614	125	76							TECTEH			21H00046	600UL
5615	127	76	0.38	78	INR	6	02C	+7.23	TECTEH			21H00045	600UL
5616			0.34	82	INR	6	02C	+8.76	TECTEH			21H00045	600UL
5617	129	76	0.35	64	INR	6	01H	+9.77	TECTEH			21H00046	600UL
5618			0.38	81	INR	6	01H	+23.72	TECTEH			21H00046	600UL
5619			0.49	78	INR	6	02H	+2.99	TECTEH			21H00046	600UL
5620			0.39	83	INR	6	04H	+15.20	TECTEH			21H00046	600UL
5621			0.35	77	INR	6	04H	+25.72	TECTEH			21H00046	600UL
5622			0.17	77	INR	6	05H	+12.86	TECTEH			21H00046	600UL
5623			0.04	243	INR	6	06H	+0.00	TECTEH			21H00046	600UL
5624			0.42	93	INR	6	F05	+4.54	TECTEH			21H00046	600UL
5625			0.34	80	INR	6	F05	+9.02	TECTEH			21H00046	600UL
5626			0.26	76	INR	6	F06	+9.13	TECTEH			21H00046	600UL
5627			0.99	70	INR	6	F06	+12.46	TECTEH			21H00046	600UL
5628					INF		F07	+6.75	TECTEH	HR		21H00046	600UL
5629					INF		F07	+9.94	TECTEH	HR		21H00046	600UL
5630			0.90	65	INR	6	02C	+1.97	TECTEH			21H00046	600UL
5631					INF		02C	+3.16	TECTEH	HR		21H00046	600UL
5632			0.48	75	INR	6	01C	+6.60	TECTEH			21H00046	600UL
5633			0.39	88	INR	6	01C	+19.25	TECTEH			21H00046	600UL
5634			0.32	60	INR	6	TSC	+16.48	TECTEH			21H00046	600UL
5635	131	76	0.22	82	INR	6	01H	+3.73	TECTEH			21H00046	600UL
5636	133	76	0.47	85	INR	6	06H	+31.00	TECTEH			21H00039	600UL
5637	135	76							TECTEH			21H00040	600UL
5638	137	76	0.71	52	INR	6	F05	+0.00	TECTEH			21H00039	600UL
5639	139	76	0.59	126	INR	3	06H	+16.18	TECTEH			21H00040	600UL
5640	36	77							TECTEH			21H00069	600UL
5641	38	77	0.45	73	INR	6	04C	+11.69	TECTEH			21H00069	600UL
5642	40	77							TECTEH			21H00068	600UL
5643	42	77							TECTEH			21H00069	600UL
5644	44	77							TECTEH			21H00068	600UL
5645	46	77	0.59	74	INR	6	05C	+21.10	TECTEH			21H00069	600UL
5646			0.49	89	INR	6	01C	+15.67	TECTEH			21H00069	600UL
5647	48	77	0.43	79	INR	6	05C	+37.04	TECTEH			21H00068	600UL
5648			0.45	79	INR	6	04C	+13.30	TECTEH			21H00068	600UL
5649			0.40	85	INR	6	02C	+12.33	TECTEH			21H00068	600UL
5650			0.38	77	INR	6	TSC	+21.16	TECTEH			21H00068	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5651	50	77							TECTEH			21H00069	600UL
5652	52	77							TECTEH			21H00068	600UL
5653	54	77	0.40	76	INR	6	03C	+13.38	TECTEH			21H00069	600UL
5654					INF		02C	+17.73	TECTEH	HR		21H00069	600UL
5655			0.55	75	INR	6	02C	+30.35	TECTEH			21H00069	600UL
5656	56	77							TECTEH			21H00068	600UL
5657	58	77	0.69	55	INR	6	F09	+6.22	TECTEH			21H00069	600UL
5658					INF		F10	+5.37	TECTEH	HR		21H00069	600UL
5659	60	77	0.53	66	INR	6	F03	+2.07	TECTEH			21H00068	600UL
5660	62	77	0.61	67	INR	6	05H	+38.47	TECTEH			21H00069	600UL
5661	64	77							TECTEH			21H00068	600UL
5662	66	77							TECTEH			21H00069	600UL
5663	68	77							TECTEH			21H00068	600UL
5664	70	77			INF		F02	+7.05	TECTEH	HR		21H00069	600UL
5665			0.80	52	INR	6	F03	+7.52	TECTEH			21H00069	600UL
5666	72	77							TECTEH			21H00068	600UL
5667	74	77							TECTEH			21H00069	600UL
5668	76	77	0.37	65	INR	6	06H	+31.47	TECTEH			21H00068	600UL
5669	78	77	1.22	76	INR	6	02H	+16.05	TECTEH			21H00069	600UL
5670	80	77							TECTEH			21H00068	600UL
5671	82	77							TECTEH			21H00045	600UL
5672	84	77	0.44	73	INR	6	04H	+32.92	TECTEH			21H00045	600UL
5673			1.43	24	INR	6	F01	-0.10	TECTEH			21H00045	600UL
5674			0.42	80	INR	6	02C	+33.67	TECTEH			21H00045	600UL
5675	86	77	1.10	41	INR	6	TSC	+11.95 TO+21.99	TECTEH			21H00046	600UL
5676	88	77							TECTEH			21H00045	600UL
5677	90	77							TECTEH			21H00046	600UL
5678	92	77							TECTEH			21H00045	600UL
5679	94	77	0.30	68	INR	6	04H	+12.37	TECTEH			21H00046	600UL
5680	96	77							TECTEH			21H00045	600UL
5681	98	77	0.47	85	INR	6	TSC	+19.92	TECTEH			21H00046	600UL
5682	100	77							TECTEH			21H00045	600UL
5683	102	77							TECTEH			21H00046	600UL
5684	104	77							TECTEH			21H00045	600UL
5685	106	77							TECTEH			21H00046	600UL
5686	108	77							TECTEH			21H00045	600UL
5687	110	77	0.22	65	INR	6	06C	+38.60	TECTEH			21H00046	600UL
5688	112	77							TECTEH			21H00045	600UL
5689	114	77	0.16	66	INR	6	05C	+4.84	TECTEH			21H00046	600UL
5690	116	77	0.45	78	INR	6	F04	+12.60	TECTEH			21H00045	600UL
5691	118	77							TECTEH			21H00046	600UL
5692	120	77							TECTEH			21H00045	600UL
5693	122	77							TECTEH			21H00046	600UL
5694	124	77	0.47	85	INR	6	03C	+18.22	TECTEH			21H00045	600UL
5695	126	77							TECTEH			21H00046	600UL
5696	128	77	0.56	72	INR	6	01H	+30.77	TECTEH			21H00045	600UL
5697			0.35	93	INR	6	05H	+9.61	TECTEH			21H00045	600UL
5698			0.41	78	INR	6	05H	+11.88	TECTEH			21H00045	600UL
5699			0.84	70	INR	6	F06	+4.29	TECTEH			21H00045	600UL
5700					INF		F06	+5.63	TECTEH	HR		21H00045	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5701			0.49	81	INR	6	04C	+38.04	TECTEH			21H00045	600UL
5702			0.49	103	INR	6	TSC	+15.47	TECTEH			21H00045	600UL
5703	130	77	0.10	264	INR	6	F06	+0.00	TECTEH			21H00046	600UL
5704	132	77							TECTEH			21H00039	600UL
5705	134	77	0.38	117	INR	3	06H	+33.42	TECTEH			21H00040	600UL
5706	136	77	0.49	78	INR	6	TSH	+19.62	TECTEH			21H00039	600UL
5707			0.44	82	INR	6	05C	+12.61	TECTEH			21H00039	600UL
5708	138	77							TECTEH			21H00040	600UL
5709	140	77							TECTEH			21H00040	600UL
5710	35	78							TECTEH			21H00069	600UL
5711	37	78							TECTEH			21H00068	600UL
5712	39	78							TECTEH			21H00069	600UL
5713	41	78							TECTEH			21H00068	600UL
5714	43	78	0.53	79	INR	6	05C	+38.87	TECTEH			21H00069	600UL
5715	45	78							TECTEH			21H00068	600UL
5716	47	78							TECTEH			21H00069	600UL
5717	49	78							TECTEH			21H00068	600UL
5718	51	78							TECTEH			21H00069	600UL
5719	53	78							TECTEH			21H00068	600UL
5720	55	78							TECTEH			21H00069	600UL
5721	57	78							TECTEH			21H00068	600UL
5722	59	78							TECTEH			21H00069	600UL
5723	61	78	0.41	80	INR	6	TSC	+1.82	TECTEH			21H00068	600UL
5724	63	78	0.44	84	INR	6	TSH	+7.26	TECTEH			21H00069	600UL
5725			1.04	76	INR	6	06C	+25.24	TECTEH			21H00069	600UL
5726			0.56	79	INR	6	02C	+38.31	TECTEH			21H00069	600UL
5727	65	78							TECTEH			21H00068	600UL
5728	67	78							TECTEH			21H00069	600UL
5729	69	78							TECTEH			21H00068	600UL
5730	71	78							TECTEH			21H00069	600UL
5731	73	78							TECTEH			21H00068	600UL
5732	75	78							TECTEH			21H00069	600UL
5733	77	78							TECTEH			21H00068	600UL
5734	79	78							TECTEH			21H00069	600UL
5735	81	78							TECTEH			21H00068	600UL
5736	83	78							TECTEH			21H00045	600UL
5737	85	78							TECTEH			21H00046	600UL
5738	87	78							TECTEH			21H00045	600UL
5739	89	78	0.26	78	INR	6	01H	+25.23	TECTEH			21H00046	600UL
5740			0.34	91	INR	6	02H	+31.20	TECTEH			21H00046	600UL
5741			0.45	78	INR	6	05H	+13.45	TECTEH			21H00046	600UL
5742			0.50	49	INR	6	F09	+5.55	TECTEH			21H00046	600UL
5743					INF		F10	+10.61	TECTEH	HR		21H00046	600UL
5744			0.37	76	INR	6	02C	+9.79	TECTEH			21H00046	600UL
5745	91	78	0.60	78	INR	6	02C	+7.47	TECTEH			21H00045	600UL
5746			0.58	72	INR	6	01C	+20.84	TECTEH			21H00045	600UL
5747	93	78			INF		07C	-2.66	TECTEH	HR		21H00046	600UL
5748			0.31	78	INR	6	06C	+38.89	TECTEH			21H00046	600UL
5749					INF		06C	+38.94	TECTEH	HR		21H00046	600UL
5750	95	78	0.34	88	INR	6	03H	+21.00	TECTEH			21H00045	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5751			0.38	87	INR	6	04H	+27.28	TECTEH			21H00045	600UL
5752	97	78							TECTEH			21H00046	600UL
5753	99	78	0.41	77	INR	6	05C	+2.93	TECTEH			21H00045	600UL
5754			0.34	83	INR	6	05C	+13.78	TECTEH			21H00045	600UL
5755	101	78	0.31	84	INR	6	04H	+11.35	TECTEH			21H00046	600UL
5756			0.23	73	INR	6	04H	+14.76	TECTEH			21H00046	600UL
5757			0.29	77	INR	6	06C	+36.77	TECTEH			21H00046	600UL
5758	103	78	0.47	86	INR	6	01H	+5.56	TECTEH			21H00045	600UL
5759	105	78	0.30	79	INR	6	01H	+17.53	TECTEH			21H00046	600UL
5760			0.52	52	INR	6	F02	+9.19	TECTEH			21H00046	600UL
5761			0.65	88	INR	6	TSC	+8.87	TECTEH			21H00046	600UL
5762	107	78	0.54	71	INR	6	TSH	+20.88	TECTEH			21H00045	600UL
5763			0.41	84	INR	6	01C	+20.07	TECTEH			21H00045	600UL
5764			0.54	62	INR	6	01C	+27.29	TECTEH			21H00045	600UL
5765	109	78							TECTEH			21H00046	600UL
5766	111	78							TECTEH			21H00045	600UL
5767	113	78							TECTEH			21H00046	600UL
5768	115	78							TECTEH			21H00045	600UL
5769	117	78							TECTEH			21H00046	600UL
5770	119	78							TECTEH			21H00045	600UL
5771	121	78	0.30	87	INR	6	06C	+28.20	TECTEH			21H00046	600UL
5772	123	78	0.43	72	NQH	3	F02	+14.66	TECTEH			21H00045	600UL
5773	125	78							TECTEH			21H00046	600UL
5774	127	78							TECTEH			21H00045	600UL
5775	129	78	0.41	91	INR	3	F04	+13.74	TECTEH			21H00046	600UL
5776	131	78	0.42	84	INR	6	F10	+14.83	TECTEH			21H00046	600UL
5777			0.30	66	INR	6	03C	+4.14	TECTEH			21H00046	600UL
5778			0.32	66	INR	6	03C	+17.16	TECTEH			21H00046	600UL
5779			0.40	71	INR	6	01C	+25.85	TECTEH			21H00046	600UL
5780	133	78	0.32	95	INR	6	04H	+36.85	TECTEH			21H00039	600UL
5781			0.62	78	INR	6	03C	+17.03	TECTEH			21H00039	600UL
5782			0.72	69	INR	6	02C	+23.24	TECTEH			21H00039	600UL
5783	135	78	0.33	115	INR	3	06C	+28.09	TECTEH			21H00040	600UL
5784	137	78	0.34	78	INR	6	06C	+19.62	TECTEH			21H00039	600UL
5785	139	78							TECTEH			21H00040	600UL
5786	36	79							TECTEH			21H00069	600UL
5787	38	79							TECTEH			21H00069	600UL
5788	40	79	0.60	45	INR	6	F09	+0.00	TECTEH			21H00068	600UL
5789					INF		F10	+2.93	TECTEH	HR		21H00068	600UL
5790	42	79							TECTEH			21H00069	600UL
5791	44	79							TECTEH			21H00068	600UL
5792	46	79	0.44	80	INR	6	02C	+17.73	TECTEH			21H00069	600UL
5793			0.51	85	INR	6	02C	+26.60	TECTEH			21H00069	600UL
5794	48	79							TECTEH			21H00068	600UL
5795	50	79	4.83	180	DNG	1	04H	+31.06	TECTEH			21H00069	600UL
5796					NDF	3	04H	+31.06	04H05H			21H00086	610PP
5797	52	79							TECTEH			21H00068	600UL
5798	54	79							TECTEH			21H00069	600UL
5799	56	79							TECTEH			21H00068	600UL
5800	58	79							TECTEH			21H00069	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5801	60	79							TECTEH			21H00068	600UL
5802	62	79							TECTEH			21H00069	600UL
5803	64	79	0.40	50	INR	6	05H	+24.52	TECTEH			21H00068	600UL
5804			0.41	103	INR	6	F07	+8.48	TECTEH			21H00068	600UL
5805					INF		F08	+5.22	TECTEH	HR		21H00068	600UL
5806	66	79							TECTEH			21H00069	600UL
5807	68	79	0.50	90	INR	6	F09	+8.76	TECTEH			21H00068	600UL
5808					INF		F10	+5.21	TECTEH	HR		21H00068	600UL
5809			0.18	173	INR	6	F10	+7.09	TECTEH			21H00068	600UL
5810	70	79							TECTEH			21H00069	600UL
5811	72	79							TECTEH			21H00068	600UL
5812	74	79	0.43	75	INR	6	02H	+17.32	TECTEH			21H00069	600UL
5813			0.79	66	INR	6	F03	+8.42	TECTEH			21H00069	600UL
5814	76	79							TECTEH			21H00068	600UL
5815	78	79							TECTEH			21H00069	600UL
5816	80	79							TECTEH			21H00068	600UL
5817	82	79							TECTEH			21H00045	600UL
5818	84	79							TECTEH			21H00045	600UL
5819	86	79	0.49	81	INR	6	06C	+7.09	TECTEH			21H00046	600UL
5820	88	79							TECTEH			21H00045	600UL
5821	90	79							TECTEH			21H00046	600UL
5822	92	79	3.69	177	DNG	1	04C	+33.68	TECTEH			21H00045	600UL
5823	94	79	0.37	69	INR	6	03H	+7.51	TECTEH			21H00046	600UL
5824	96	79	0.42	91	INR	6	01H	+22.09	TECTEH			21H00045	600UL
5825	98	79	0.32	64	INR	6	06C	+10.88	TECTEH			21H00046	600UL
5826	100	79							TECTEH			21H00045	600UL
5827	102	79							TECTEH			21H00046	600UL
5828	104	79							TECTEH			21H00045	600UL
5829	106	79	0.36	82	INR	6	05H	+4.14	TECTEH			21H00046	600UL
5830			0.66	80	INR	6	06H	+8.68	TECTEH			21H00046	600UL
5831			0.26	77	INR	6	05C	+28.17	TECTEH			21H00046	600UL
5832	108	79	0.52	68	INR	6	TSC	+15.05	TECTEH			21H00045	600UL
5833	110	79							TECTEH			21H00046	600UL
5834	112	79	0.56	78	INR	6	TSH	+14.31	TECTEH			21H00045	600UL
5835			0.54	76	INR	6	05H	+21.68	TECTEH			21H00045	600UL
5836			0.40	85	INR	6	05H	+28.40	TECTEH			21H00045	600UL
5837					INF		07H	+25.00	TECTEH	HR		21H00045	600UL
5838			0.37	97	INR	6	F05	+13.59	TECTEH			21H00045	600UL
5839					INF		F10	+6.73	TECTEH	HR		21H00045	600UL
5840			0.36	77	NQH	3	F10	+10.57	TECTEH			21H00045	600UL
5841			0.39	118	INR	3	F11	+6.12	TECTEH			21H00045	600UL
5842			0.20	46	INR	6	F12	+7.62	TECTEH			21H00045	600UL
5843			0.79	74	INR	6	06C	+18.09	TECTEH			21H00045	600UL
5844	114	79							TECTEH			21H00046	600UL
5845	116	79							TECTEH			21H00045	600UL
5846	118	79							TECTEH			21H00046	600UL
5847	120	79							TECTEH			21H00045	600UL
5848	122	79							TECTEH			21H00046	600UL
5849	124	79							TECTEH			21H00045	600UL
5850	126	79	0.57	77	INR	6	05H	+23.22	TECTEH			21H00046	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	PLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5851			0.52	48	INR	6	F06	+14.61	TECTEH			21H00046	600UL
5852					INF		F07	+0.00	TECTEH	HR		21H00046	600UL
5853	128	79							TECTEH			21H00045	600UL
5854	130	79							TECTEH			21H00046	600UL
5855	132	79	0.35	81	INR	6	TSH	+13.08	TECTEH			21H00039	600UL
5856			0.48	20	INR	6	F08	-1.69	TECTEH			21H00039	600UL
5857					INF		F08	+2.40	TECTEH	HR		21H00039	600UL
5858	134	79							TECTEH			21H00040	600UL
5859	136	79							TECTEH			21H00039	600UL
5860	138	79							TECTEH			21H00040	600UL
5861	140	79							TECTEH			21H00040	600UL
5862	37	80							TECTEH			21H00069	600UL
5863	39	80	0.37	67	INR	6	05C	+23.06	TECTEH			21H00068	600UL
5864	41	80	0.46	73	INR	6	03C	+6.21	TECTEH			21H00069	600UL
5865	43	80							TECTEH			21H00068	600UL
5866	45	80							TECTEH			21H00069	600UL
5867	47	80							TECTEH			21H00068	600UL
5868	49	80							TECTEH			21H00069	600UL
5869	51	80							TECTEH			21H00068	600UL
5870	53	80							TECTEH			21H00069	600UL
5871	55	80							TECTEH			21H00068	600UL
5872	57	80							TECTEH			21H00069	600UL
5873	59	80							TECTEH			21H00068	600UL
5874	61	80							TECTEH			21H00069	600UL
5875	63	80							TECTEH			21H00068	600UL
5876	65	80							TECTEH			21H00069	600UL
5877	67	80							TECTEH			21H00068	600UL
5878	69	80							TECTEH			21H00069	600UL
5879	71	80							TECTEH			21H00068	600UL
5880	73	80							TECTEH			21H00069	600UL
5881	75	80	0.33	73	INR	6	07H	+2.25	TECTEH			21H00068	600UL
5882			0.83	81	INR	6	06C	+24.29	TECTEH			21H00068	600UL
5883	77	80	0.58	98	INR	6	F04	+7.52	TECTEH			21H00069	600UL
5884			0.51	68	INR	6	F06	+3.80	TECTEH			21H00069	600UL
5885	79	80	0.24	78	INR	6	03H	+9.77	TECTEH			21H00068	600UL
5886			0.50	62	INR	6	F08	+4.76	TECTEH			21H00068	600UL
5887					INF		F09	+9.97	TECTEH	HR		21H00068	600UL
5888	81	80	0.36	70	INR	6	03C	+34.06	TECTEH			21H00068	600UL
5889	83	80							TECTEH			21H00045	600UL
5890	85	80	0.33	66	INR	6	03C	+33.49	TECTEH			21H00046	600UL
5891	87	80							TECTEH			21H00045	600UL
5892	89	80							TECTEH			21H00046	600UL
5893	91	80							TECTEH			21H00045	600UL
5894	93	80	0.43	76	INR	6	05C	+37.56	TECTEH			21H00046	600UL
5895	95	80	0.63	80	INR	6	01C	+24.91	TECTEH			21H00045	600UL
5896	97	80							TECTEH			21H00046	600UL
5897	99	80			INF		F09	+8.52	TECTEH	HR		21H00045	600UL
5898			0.45	39	INR	6	F09	+12.02	TECTEH			21H00045	600UL
5899					INF		01C	+30.54	TECTEH	HR		21H00045	600UL
5900			0.42	81	INR	6	01C	+32.51	TECTEH			21H00045	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5901	101	80							TECTEH			21H00046	600UL
5902	103	80	0.46	76	INR	6	06C	+7.07	TECTEH			21H00045	600UL
5903	105	80							TECTEH			21H00046	600UL
5904	107	80	0.43	83	INR	6	02C	+39.12	TECTEH			21H00045	600UL
5905	109	80	0.43	79	INR	6	01C	+24.96	TECTEH			21H00046	600UL
5906	111	80	2.37	79	NQH	6	06C	+7.69	TECTEH			21H00045	600UL
5907	113	80							TECTEH			21H00046	600UL
5908	115	80	0.53	72	INR	6	04H	+12.33	TECTEH			21H00045	600UL
5909	117	80							TECTEH			21H00046	600UL
5910	119	80	0.31	117	INR	3	03C	+35.18	TECTEH			21H00045	600UL
5911	121	80	0.59	46	INR	6	F07	+13.75	TECTEH			21H00046	600UL
5912					INF		F08	+5.27	TECTEH	HR		21H00046	600UL
5913			0.46	67	INR	6	03C	+29.94	TECTEH			21H00046	600UL
5914			0.48	69	INR	6	02C	+21.44	TECTEH			21H00046	600UL
5915	123	80	0.46	83	INR	6	04H	+25.01	TECTEH			21H00045	600UL
5916			0.41	66	INR	6	F03	+9.55	TECTEH			21H00045	600UL
5917	125	80	0.62	72	INR	6	05C	+23.06	TECTEH			21H00046	600UL
5918	127	80	0.87	86	INR	6	06C	+36.04	TECTEH			21H00045	600UL
5919	129	80	0.44	72	INR	6	04H	+24.21	TECTEH			21H00046	600UL
5920	131	80							TECTEH			21H00046	600UL
5921	133	80	0.67	51	INR	6	F12	+18.09	TECTEH			21H00039	600UL
5922					INF		07C	+2.55	TECTEH	HR		21H00039	600UL
5923	135	80	0.45	121	INR	3	06H	+21.09	TECTEH			21H00040	600UL
5924			0.31	109	INR	3	F08	+4.50	TECTEH			21H00040	600UL
5925			0.40	121	INR	3	F09	+13.96	TECTEH			21H00040	600UL
5926					INF		F09	+15.00	TECTEH	HR		21H00040	600UL
5927					INF		F10	+5.56	TECTEH	HR		21H00040	600UL
5928			0.48	136	INR	3	06C	+3.32	TECTEH			21H00040	600UL
5929	137	80	1.00	77	INR	6	05C	+14.24	TECTEH			21H00039	600UL
5930			0.32	67	INR	6	TSC	+7.78	TECTEH			21H00039	600UL
5931	139	80	0.52	70	INR	6	02H	+15.11	TECTEH			21H00039	600UL
5932			0.38	65	INR	6	F05	+12.06	TECTEH			21H00039	600UL
5933			0.76	79	INR	6	F07	+17.97	TECTEH			21H00039	600UL
5934					INF		F08	+2.96	TECTEH	HR		21H00039	600UL
5935			0.33	60	INR	6	05C	+31.76	TECTEH			21H00039	600UL
5936	141	80							TECTEH			21H00040	600UL
5937	38	81							TECTEH			21H00069	600UL
5938	40	81							TECTEH			21H00068	600UL
5939	42	81							TECTEH			21H00069	600UL
5940	44	81							TECTEH			21H00068	600UL
5941	46	81							TECTEH			21H00069	600UL
5942	48	81							TECTEH			21H00068	600UL
5943	50	81							TECTEH			21H00069	600UL
5944	52	81							TECTEH			21H00068	600UL
5945	54	81	0.45	81	INR	6	TSC	+1.46	TECTEH			21H00069	600UL
5946	56	81							TECTEH			21H00068	600UL
5947	58	81							TECTEH			21H00069	600UL
5948	60	81	0.35	75	INR	6	03H	+30.59	TECTEH			21H00068	600UL
5949	62	81			INF		F04	+0.00	TECTEH	HR		21H00069	600UL
5950			0.84	75	INR	6	F04	+1.09	TECTEH			21H00069	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
5951			1.02	58	INR	6	F06	+11.82		TECTEH			21H00069	600UL
5952					INF		F07	+2.88		TECTEH	HR		21H00069	600UL
5953	64	81								TECTEH			21H00068	600UL
5954	66	81			INF		03C	+5.43		TECTEH	HR		21H00069	600UL
5955			0.59	76	INR	6	03C	+6.71		TECTEH			21H00069	600UL
5956	68	81								TECTEH			21H00068	600UL
5957	70	81								TECTEH			21H00069	600UL
5958	72	81								TECTEH			21H00068	600UL
5959	74	81	2.01	40	INR	6	F10	+0.05		TECTEH			21H00069	600UL
5960	76	81	0.44	70	INR	6	03H	+18.95		TECTEH			21H00068	600UL
5961			1.05	41	INR	6	F04	+11.49		TECTEH			21H00068	600UL
5962	78	81								TECTEH			21H00069	600UL
5963	80	81	0.90	66	INR	6	03H	+39.59		TECTEH			21H00068	600UL
5964	82	81	0.56	74	INR	6	F09	+0.13		TECTEH			21H00045	600UL
5965	84	81								TECTEH			21H00045	600UL
5966	86	81	0.34	74	INR	6	04H	+22.05		TECTEH			21H00046	600UL
5967			0.55	87	INR	6	03C	+38.11		TECTEH			21H00046	600UL
5968	88	81								TECTEH			21H00045	600UL
5969	90	81	0.43	76	INR	6	01H	+12.48		TECTEH			21H00046	600UL
5970			0.53	56	INR	6	F06	+2.20		TECTEH			21H00046	600UL
5971	92	81								TECTEH			21H00045	600UL
5972	94	81	0.44	52	INR	6	F03	+6.58		TECTEH			21H00046	600UL
5973	96	81	0.90	80	INR	6	06C	+32.41		TECTEH			21H00045	600UL
5974	98	81								TECTEH			21H00046	600UL
5975	100	81	0.35	72	INR	6	03H	+18.77		TECTEH			21H00045	600UL
5976			0.65	71	INR	6	06H	+4.90		TECTEH			21H00045	600UL
5977			0.38	76	INR	6	F03	+4.28		TECTEH			21H00045	600UL
5978			0.29	68	INR	3	F05	+6.03		TECTEH			21H00045	600UL
5979	102	81	0.27	87	INR	6	06C	+5.01		TECTEH			21H00046	600UL
5980	104	81	0.34	79	INR	6	05H	+4.35		TECTEH			21H00045	600UL
5981			0.30	98	NQH	3	05C	+15.94		TECTEH			21H00045	600UL
5982			0.40	65	INR	6	01C	+8.66		TECTEH			21H00045	600UL
5983	106	81	0.35	69	INR	6	05C	+5.50		TECTEH			21H00046	600UL
5984			0.50	101	INR	6	02C	+30.87		TECTEH			21H00046	600UL
5985			0.76	78	INR	6	01C	+3.13		TECTEH			21H00046	600UL
5986			0.45	65	INR	6	TSC	+15.47		TECTEH			21H00046	600UL
5987	108	81								TECTEH			21H00045	600UL
5988	110	81	0.53	70	INR	6	06H	+36.74		TECTEH			21H00046	600UL
5989	112	81	0.41	72	INR	6	07H	+16.07		TECTEH			21H00045	600UL
5990	114	81								TECTEH			21H00046	600UL
5991	116	81								TECTEH			21H00045	600UL
5992	118	81								TECTEH			21H00046	600UL
5993	120	81								TECTEH			21H00045	600UL
5994	122	81								TECTEH			21H00046	600UL
5995	124	81								TECTEH			21H00045	600UL
5996	126	81	0.47	67	INR	6	06C	+23.39		TECTEH			21H00046	600UL
5997			0.41	73	INR	6	02C	+31.96		TECTEH			21H00046	600UL
5998	128	81								TECTEH			21H00045	600UL
5999	130	81								TECTEH			21H00046	600UL
6000	132	81	1.50	29	INR	6	F07	+6.44	TO+16.53	TECTEH			21H00039	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6001					INF		F08	+4.25 TO+9.04	TECTEH	HR		21H00039	600UL
6002	134	81							TECTEH			21H00040	600UL
6003	136	81	0.32	76	INR	6	05H	+33.95	TECTEH			21H00039	600UL
6004			0.45	67	INR	6	F03	+6.44	TECTEH			21H00039	600UL
6005			0.30	84	INR	6	03C	+14.32	TECTEH			21H00039	600UL
6006			0.73	79	INR	6	TSC	+5.58	TECTEH			21H00039	600UL
6007			0.39	74	INR	6	TSC	+10.88	TECTEH			21H00039	600UL
6008	138	81	0.31	114	INR	3	05H	+25.94	TECTEH			21H00040	600UL
6009			0.47	135	INR	3	07H	+8.65	TECTEH			21H00040	600UL
6010					INF		07H	+10.06	TECTEH	HR		21H00040	600UL
6011	140	81							TECTEH			21H00040	600UL
6012	37	82							TECTEH			21H00002	600UL
6013	39	82							TECTEH			21H00001	600UL
6014	41	82							TECTEH			21H00002	600UL
6015	43	82							TECTEH			21H00001	600UL
6016	45	82							TECTEH			21H00002	600UL
6017	47	82	0.29	131	INR	3	TSH	+15.61	TECTEH			21H00001	600UL
6018			0.29	132	INR	3	01H	+14.54	TECTEH			21H00001	600UL
6019			0.23	128	INR	3	01H	+16.47	TECTEH			21H00001	600UL
6020			0.34	139	INR	3	02H	+22.94	TECTEH			21H00001	600UL
6021			0.48	125	INR	3	05C	+29.08	TECTEH			21H00001	600UL
6022	49	82							TECTEH			21H00002	600UL
6023	51	82							TECTEH			21H00001	600UL
6024	53	82							TECTEH			21H00002	600UL
6025	55	82							TECTEH			21H00001	600UL
6026	57	82							TECTEH			21H00002	600UL
6027	59	82	0.21	104	INR	3	01C	+14.01	TECTEH			21H00001	600UL
6028	61	82							TECTEH			21H00002	600UL
6029	63	82	0.34	121	INR	3	03H	+10.06	TECTEH			21H00001	600UL
6030					INF		F04	+11.45	TECTEH	HR		21H00001	600UL
6031			0.69	56	INR	3	F05	-1.98	TECTEH			21H00001	600UL
6032			0.31	91	INR	3	F08	+1.98	TECTEH			21H00001	600UL
6033					INF		F09	+11.45	TECTEH	HR		21H00001	600UL
6034	65	82							TECTEH			21H00002	600UL
6035	67	82							TECTEH			21H00001	600UL
6036	69	82	0.33	112	INR	3	03C	+7.20	TECTEH			21H00002	600UL
6037	71	82							TECTEH			21H00001	600UL
6038	73	82							TECTEH			21H00002	600UL
6039	75	82	0.70	136	INR	3	06C	+28.71	TECTEH			21H00001	600UL
6040	77	82							TECTEH			21H00002	600UL
6041	79	82							TECTEH			21H00001	600UL
6042	81	82							TECTEH			21H00001	600UL
6043	83	82							TECTEH			21H00049	600UL
6044	85	82							TECTEH			21H00050	600UL
6045	87	82							TECTEH			21H00049	600UL
6046	89	82							TECTEH			21H00050	600UL
6047	91	82							TECTEH			21H00049	600UL
6048	93	82	0.68	63	INR	6	03H	+39.51	TECTEH			21H00050	600UL
6049			0.39	67	INR	6	04H	+22.87	TECTEH			21H00050	600UL
6050	95	82	0.27	96	INR	3	06H	+33.56	TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6051	97	82	0.51	72	INR	6	F09	+6.63	TECTEH			21H00050	600UL
6052			0.51	72	INR	6	F09	+6.68	TECTEH			21H00050	600UL
6053					INF		F10	+8.39	TECTEH	HR		21H00050	600UL
6054					INF		F10	+9.58	TECTEH	HR		21H00050	600UL
6055	99	82							TECTEH			21H00049	600UL
6056	101	82	0.68	72	INR	6	04H	+27.00	TECTEH			21H00050	600UL
6057	103	82	0.59	65	INR	6	F07	+14.35	TECTEH			21H00049	600UL
6058					INF		F08	+2.74	TECTEH	HR		21H00049	600UL
6059			0.60	87	INR	6	02C	+15.42	TECTEH			21H00049	600UL
6060	105	82	0.70	80	INR	6	03C	+7.52	TECTEH			21H00050	600UL
6061	107	82							TECTEH			21H00049	600UL
6062	109	82							TECTEH			21H00050	600UL
6063	111	82							TECTEH			21H00049	600UL
6064	113	82							TECTEH			21H00050	600UL
6065	115	82							TECTEH			21H00049	600UL
6066	117	82	0.50	70	INR	6	F06	+4.10	TECTEH			21H00050	600UL
6067	119	82	0.34	85	INR	6	TSC	+2.20	TECTEH			21H00049	600UL
6068	121	82	0.57	78	INR	6	03H	+26.06	TECTEH			21H00050	600UL
6069			0.49	84	INR	6	05C	+28.05	TECTEH			21H00050	600UL
6070	123	82							TECTEH			21H00049	600UL
6071	125	82							TECTEH			21H00049	600UL
6072	127	82							TECTEH			21H00050	600UL
6073	129	82							TECTEH			21H00049	600UL
6074	131	82							TECTEH			21H00050	600UL
6075	133	82	0.45	77	INR	6	04H	+22.34	TECTEH			21H00047	600UL
6076			0.46	88	INR	6	TSC	+9.62	TECTEH			21H00047	600UL
6077	135	82							TECTEH			21H00048	600UL
6078	137	82	0.36	53	INR	6	05H	+12.56	TECTEH			21H00048	600UL
6079	139	82							TECTEH			21H00047	600UL
6080	141	82							TECTEH			21H00048	600UL
6081	38	83							TECTEH			21H00002	600UL
6082	40	83							TECTEH			21H00002	600UL
6083	42	83							TECTEH			21H00001	600UL
6084	44	83							TECTEH			21H00002	600UL
6085	46	83							TECTEH			21H00001	600UL
6086	48	83							TECTEH			21H00002	600UL
6087	50	83							TECTEH			21H00001	600UL
6088	52	83							TECTEH			21H00002	600UL
6089	54	83							TECTEH			21H00001	600UL
6090	56	83							TECTEH			21H00002	600UL
6091	58	83	0.41	80	INR	6	03C	+12.16	TECTEH			21H00001	600UL
6092	62	83							TECTEH			21H00002	600UL
6093	64	83							TECTEH			21H00001	600UL
6094	66	83	0.26	125	INR	3	01H	+7.25	TECTEH			21H00002	600UL
6095			0.22	121	INR	3	02C	+14.83	TECTEH			21H00002	600UL
6096	68	83			INF		03C	+14.56	TECTEH	HR		21H00001	600UL
6097			0.49	86	INR	6	03C	+15.88	TECTEH			21H00001	600UL
6098			0.37	88	INR	6	03C	+28.25	TECTEH			21H00001	600UL
6099	70	83							TECTEH			21H00002	600UL
6100	72	83	0.45	92	INR	6	05C	+35.25	TECTEH			21H00001	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6101			0.32	95	INR	6	04C	+18.41		TECTEH			21H00001	600UL
6102			0.65	77	INR	6	03C	+31.62		TECTEH			21H00001	600UL
6103	74	83	0.62	86	NQH	3	F04	+7.80		TECTEH			21H00002	600UL
6104	76	83	0.36	124	INR	3	03H	+36.11		TECTEH			21H00001	600UL
6105	78	83								TECTEH			21H00002	600UL
6106	80	83								TECTEH			21H00001	600UL
6107	82	83								TECTEH			21H00050	600UL
6108	84	83	0.29	118	INR	3	06H	+4.21		TECTEH			21H00049	600UL
6109			0.72	37	INR	6	F03	+12.51		TECTEH			21H00049	600UL
6110	88	83	0.47	78	INR	6	06C	+5.55		TECTEH			21H00050	600UL
6111	90	83	0.39	58	INR	6	F07	+13.91		TECTEH			21H00049	600UL
6112					INF		F08	+2.21		TECTEH	HR		21H00049	600UL
6113			0.42	95	INR	6	02C	+19.56		TECTEH			21H00049	600UL
6114	92	83	0.39	72	INR	6	03H	+36.58		TECTEH			21H00050	600UL
6115			0.54	67	INR	6	03C	+20.62		TECTEH			21H00050	600UL
6116	94	83								TECTEH			21H00049	600UL
6117	96	83								TECTEH			21H00050	600UL
6118	98	83								TECTEH			21H00049	600UL
6119	100	83								TECTEH			21H00050	600UL
6120	102	83								TECTEH			21H00049	600UL
6121	104	83	0.63	93	INR	6	F06	+12.47		TECTEH			21H00050	600UL
6122					INF		F07	+6.08		TECTEH	HR		21H00050	600UL
6123			0.34	246	INR	6	02C	+28.82		TECTEH			21H00050	600UL
6124	106	83			INF		F04	+8.46		TECTEH	HR		21H00049	600UL
6125			0.46	80	INR	6	F04	+10.52		TECTEH			21H00049	600UL
6126	108	83	0.51	82	INR	6	03H	+10.79		TECTEH			21H00050	600UL
6127			0.53	72	INR	6	F04	+0.00		TECTEH			21H00050	600UL
6128			0.53	84	INR	6	06C	+10.41		TECTEH			21H00050	600UL
6129			0.69	75	INR	6	03C	+33.59		TECTEH			21H00050	600UL
6130	110	83	1.12	84	INR	6	TSH	+11.49		TECTEH			21H00049	600UL
6131	114	83								TECTEH			21H00049	600UL
6132	116	83								TECTEH			21H00050	600UL
6133	118	83	0.65	110	INR	6	F06	+11.74		TECTEH			21H00049	600UL
6134					INF		F07	+5.81		TECTEH	HR		21H00049	600UL
6135	120	83								TECTEH			21H00050	600UL
6136	122	83	0.51	99	INR	6	F07	+4.93		TECTEH			21H00049	600UL
6137					INF		F08	+14.13		TECTEH	HR		21H00049	600UL
6138	124	83								TECTEH			21H00050	600UL
6139	126	83								TECTEH			21H00049	600UL
6140	128	83								TECTEH			21H00050	600UL
6141	130	83								TECTEH			21H00049	600UL
6142	132	83	0.43	79	INR	6	02H	+3.61	TO+5.04	TECTEH			21H00047	600UL
6143			0.33	75	INR	6	F03	+14.82		TECTEH			21H00047	600UL
6144					INF		F03	+15.76		TECTEH	HR		21H00047	600UL
6145			0.69	86	NQH	3	F06	+14.54		TECTEH			21H00047	600UL
6146					INF		F07	+5.22		TECTEH	HR		21H00047	600UL
6147			0.54	82	INR	6	02C	+37.69		TECTEH			21H00047	600UL
6148					INF		02C	+40.05		TECTEH	HR		21H00047	600UL
6149	134	83								TECTEH			21H00047	600UL
6150	136	83	0.48	58	INR	6	F02	+12.77		TECTEH			21H00048	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6151	138	83							TECTEH			21H00047	600UL
6152	140	83							TECTEH			21H00048	600UL
6153	37	84							TECTEH			21H00002	600UL
6154	39	84	0.37	64	INR	6	05H	+6.47	TECTEH			21H00001	600UL
6155	41	84							TECTEH			21H00002	600UL
6156	43	84							TECTEH			21H00001	600UL
6157	45	84							TECTEH			21H00002	600UL
6158	47	84							TECTEH			21H00001	600UL
6159	49	84							TECTEH			21H00002	600UL
6160	51	84							TECTEH			21H00001	600UL
6161	53	84							TECTEH			21H00002	600UL
6162	55	84							TECTEH			21H00001	600UL
6163	57	84	0.18	117	INR	3	06H	+29.83	TECTEH			21H00002	600UL
6164			0.35	120	INR	3	04C	+23.11	TECTEH			21H00002	600UL
6165	59	84	0.44	93	INR	6	TSH	+20.81	TECTEH			21H00001	600UL
6166	63	84							TECTEH			21H00002	600UL
6167	65	84							TECTEH			21H00001	600UL
6168	67	84	0.30	136	INR	3	01H	+30.70	TECTEH			21H00002	600UL
6169	69	84	0.41	83	INR	6	01H	+11.36	TECTEH			21H00001	600UL
6170					INF		F09	+7.96	TECTEH	HR		21H00001	600UL
6171			1.15	35	INR	6	04C	+3.62	TECTEH			21H00001	600UL
6172	71	84			INF		05H	+27.47	TECTEH	HR		21H00002	600UL
6173			0.65	134	INR	3	05H	+28.32	TECTEH			21H00002	600UL
6174			0.76	118	INR	3	06H	+15.01	TECTEH			21H00002	600UL
6175	73	84							TECTEH			21H00001	600UL
6176	75	84							TECTEH			21H00002	600UL
6177	77	84							TECTEH			21H00001	600UL
6178	79	84							TECTEH			21H00002	600UL
6179	81	84	0.52	73	INR	6	TSH	+14.97	TECTEH			21H00001	600UL
6180	83	84							TECTEH			21H00050	600UL
6181	85	84	0.47	87	INR	6	01H	+18.09	TECTEH			21H00049	600UL
6182			0.34	81	INR	6	01H	+21.83	TECTEH			21H00049	600UL
6183	89	84							TECTEH			21H00050	600UL
6184	91	84	0.38	70	INR	6	F12	+6.64	TECTEH			21H00049	600UL
6185					INF		07C	+6.44	TECTEH	HR		21H00049	600UL
6186	93	84	0.40	83	INR	6	04C	+37.67	TECTEH			21H00050	600UL
6187			0.41	103	INR	6	TSC	+3.21	TECTEH			21H00050	600UL
6188	95	84			INF		07H	+11.66	TECTEH	HR		21H00049	600UL
6189			0.36	67	INR	6	07H	+13.52	TECTEH			21H00049	600UL
6190	97	84							TECTEH			21H00050	600UL
6191	99	84	0.52	80	INR	6	04C	+20.71	TECTEH			21H00049	600UL
6192			0.58	78	INR	6	04C	+34.53	TECTEH			21H00049	600UL
6193			0.79	77	INR	6	02C	+6.45	TECTEH			21H00049	600UL
6194			0.43	85	INR	6	02C	+8.41	TECTEH			21H00049	600UL
6195	101	84							TECTEH			21H00050	600UL
6196	103	84	0.38	92	INR	6	06C	+34.10	TECTEH			21H00049	600UL
6197	105	84							TECTEH			21H00050	600UL
6198	107	84							TECTEH			21H00049	600UL
6199	109	84							TECTEH			21H00050	600UL
6200	111	84	0.45	123	INR	3	02H	+16.89	TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6201	115	84							TECTEH			21H00049	600UL
6202	117	84							TECTEH			21H00050	600UL
6203	119	84							TECTEH			21H00049	600UL
6204	121	84	1.02	78	INR	6	F06	+10.23	TECTEH			21H00050	600UL
6205	123	84	0.47	61	INR	6	02H	+14.21	TECTEH			21H00049	600UL
6206	125	84							TECTEH			21H00050	600UL
6207	127	84							TECTEH			21H00049	600UL
6208	129	84							TECTEH			21H00050	600UL
6209	131	84	0.32	82	INR	6	TSH	+3.01	TECTEH			21H00050	600UL
6210			0.45	71	INR	6	02C	+21.93	TECTEH			21H00050	600UL
6211	133	84	0.60	63	INR	6	05H	+36.25 TO+38.55	TECTEH			21H00047	600UL
6212			0.55	86	INR	6	F03	+13.70	TECTEH			21H00047	600UL
6213			0.52	82	INR	6	04C	+4.84	TECTEH			21H00047	600UL
6214			0.45	91	INR	6	04C	+36.15	TECTEH			21H00047	600UL
6215	135	84							TECTEH			21H00048	600UL
6216	137	84							TECTEH			21H00047	600UL
6217	139	84	0.54	90	INR	6	F09	+2.53	TECTEH			21H00048	600UL
6218					INF		F10	+18.76	TECTEH	HR		21H00048	600UL
6219	141	84							TECTEH			21H00048	600UL
6220	38	85							TECTEH			21H00002	600UL
6221	40	85							TECTEH			21H00001	600UL
6222	42	85							TECTEH			21H00002	600UL
6223	44	85	0.52	85	INR	6	04C	+36.34	TECTEH			21H00001	600UL
6224			0.54	74	INR	6	02C	+23.77	TECTEH			21H00001	600UL
6225	46	85							TECTEH			21H00002	600UL
6226	48	85							TECTEH			21H00001	600UL
6227	50	85			INF		F07	-0.23	TECTEH	HR		21H00002	600UL
6228			0.50	78	NQH	3	F07	+3.44	TECTEH			21H00002	600UL
6229			0.31	129	INR	3	03C	+35.22	TECTEH			21H00002	600UL
6230	52	85	0.40	75	INR	6	02H	+29.04	TECTEH			21H00001	600UL
6231	54	85							TECTEH			21H00002	600UL
6232	56	85							TECTEH			21H00001	600UL
6233	58	85							TECTEH			21H00002	600UL
6234	60	85							TECTEH			21H00001	600UL
6235	62	85	0.66	122	INR	3	06H	+38.72	TECTEH			21H00002	600UL
6236			0.41	134	INR	3	02C	+29.32	TECTEH			21H00002	600UL
6237	64	85	0.55	78	INR	6	02H	+26.90	TECTEH			21H00001	600UL
6238			0.48	75	INR	6	07H	+2.98	TECTEH			21H00001	600UL
6239	66	85	0.31	129	INR	3	04H	+2.58	TECTEH			21H00002	600UL
6240	68	85	0.40	73	INR	6	02C	+14.53	TECTEH			21H00001	600UL
6241	70	85	0.35	127	INR	3	06C	+8.59	TECTEH			21H00002	600UL
6242	72	85	0.65	88	INR	6	TSC	+7.14	TECTEH			21H00001	600UL
6243	74	85	0.43	131	INR	3	02C	+3.71	TECTEH			21H00002	600UL
6244	76	85	0.57	84	INR	6	05H	+7.43	TECTEH			21H00001	600UL
6245			0.82	129	INR	3	F09	-1.03	TECTEH			21H00001	600UL
6246					INF		F09	+0.00	TECTEH	HR		21H00001	600UL
6247	78	85							TECTEH			21H00002	600UL
6248	80	85							TECTEH			21H00001	600UL
6249	82	85							TECTEH			21H00050	600UL
6250	84	85	0.42	62	INR	6	05H	+5.57	TECTEH			21H00050	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6251	86	85	0.66	77	INR	6	06C	+15.41	TECTEH			21H00049	600UL
6252			0.39	94	INR	6	03C	+6.86	TECTEH			21H00049	600UL
6253	88	85							TECTEH			21H00050	600UL
6254	90	85	0.47	76	INR	6	05H	+5.62	TECTEH			21H00049	600UL
6255					INF		07H	+12.57	TECTEH	HR		21H00049	600UL
6256			1.37	27	INR	6	07H	+14.72	TECTEH			21H00049	600UL
6257			0.74	88	INR	6	02C	+13.22	TECTEH			21H00049	600UL
6258	92	85	0.65	85	INR	6	02H	+27.86	TECTEH			21H00050	600UL
6259			0.48	39	INR	6	F02	+11.32	TECTEH			21H00050	600UL
6260					INF		F03	+0.00	TECTEH	HR		21H00050	600UL
6261			0.58	59	INR	6	F10	-1.36	TECTEH			21H00050	600UL
6262					INF		F10	+0.00	TECTEH	HR		21H00050	600UL
6263			0.48	89	INR	6	01C	+13.68	TECTEH			21H00050	600UL
6264			0.56	85	INR	6	TSC	+12.23	TECTEH			21H00050	600UL
6265			1.01	75	INR	6	TSC	+17.18	TECTEH			21H00050	600UL
6266	94	85	0.42	71	INR	6	03H	+5.45	TECTEH			21H00049	600UL
6267	96	85	0.32	115	INR	3	01C	+29.26	TECTEH			21H00050	600UL
6268	98	85							TECTEH			21H00049	600UL
6269	100	85							TECTEH			21H00050	600UL
6270	102	85							TECTEH			21H00049	600UL
6271	104	85							TECTEH			21H00050	600UL
6272	106	85							TECTEH			21H00049	600UL
6273	108	85							TECTEH			21H00050	600UL
6274	110	85							TECTEH			21H00049	600UL
6275	112	85	0.33	256	INR	6	01C	+10.07	TECTEH			21H00050	600UL
6276	114	85							TECTEH			21H00049	600UL
6277	116	85	0.53	80	INR	6	02C	+3.19	TECTEH			21H00049	600UL
6278	118	85							TECTEH			21H00050	600UL
6279	120	85	0.44	91	INR	6	F02	+11.49	TECTEH			21H00049	600UL
6280	122	85							TECTEH			21H00050	600UL
6281	124	85							TECTEH			21H00049	600UL
6282	126	85							TECTEH			21H00050	600UL
6283	128	85							TECTEH			21H00049	600UL
6284	130	85							TECTEH			21H00050	600UL
6285	132	85	0.44	84	INR	6	04H	+26.79	TECTEH			21H00047	600UL
6286			0.43	87	INR	6	TSC	+16.89	TECTEH			21H00047	600UL
6287	134	85	0.25	71	INR	6	01H	+8.45	TECTEH			21H00047	600UL
6288			0.38	78	INR	6	05C	+19.16	TECTEH			21H00047	600UL
6289	136	85							TECTEH			21H00048	600UL
6290	138	85	0.42	75	INR	6	05H	+37.85	TECTEH			21H00047	600UL
6291	140	85							TECTEH			21H00048	600UL
6292	37	86							TECTEH			21H00002	600UL
6293	39	86							TECTEH			21H00001	600UL
6294	41	86							TECTEH			21H00002	600UL
6295	43	86							TECTEH			21H00001	600UL
6296	45	86	0.34	136	INR	3	05C	+10.68	TECTEH			21H00002	600UL
6297	47	86	0.57	76	INR	6	TSC	+18.58	TECTEH			21H00001	600UL
6298	49	86							TECTEH			21H00002	600UL
6299	51	86							TECTEH			21H00001	600UL
6300	53	86							TECTEH			21H00002	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6301	55	86							TECTEH			21H00001	600UL
6302	57	86	0.40	113	INR	3	TSC	+7.95	TECTEH			21H00002	600UL
6303			0.39	140	INR	3	TSC	+16.53	TECTEH			21H00002	600UL
6304	59	86	0.35	77	NQH	3	F05	+2.59	TECTEH			21H00001	600UL
6305			0.35	71	NQH	3	F09	+5.98	TECTEH			21H00001	600UL
6306	61	86	0.36	108	INR	3	02H	+4.99	TECTEH			21H00002	600UL
6307			0.22	128	INR	3	03H	+37.50	TECTEH			21H00002	600UL
6308			0.27	141	INR	3	06C	+18.37	TECTEH			21H00002	600UL
6309	63	86							TECTEH			21H00001	600UL
6310	65	86							TECTEH			21H00002	600UL
6311	67	86	0.71	79	INR	6	03H	+30.84	TECTEH			21H00001	600UL
6312			0.60	81	INR	6	03H	+33.90	TECTEH			21H00001	600UL
6313			0.62	82	INR	6	04H	+25.93	TECTEH			21H00001	600UL
6314			0.32	82	INR	6	06H	+6.18	TECTEH			21H00001	600UL
6315			0.37	80	INR	6	06H	+9.62	TECTEH			21H00001	600UL
6316			0.38	79	NQH	3	F05	+4.79	TECTEH			21H00001	600UL
6317			0.36	109	INR	3	04C	+19.98	TECTEH			21H00001	600UL
6318	69	86							TECTEH			21H00002	600UL
6319	71	86							TECTEH			21H00001	600UL
6320	73	86							TECTEH			21H00002	600UL
6321	75	86	0.55	82	INR	6	02H	+21.88	TECTEH			21H00001	600UL
6322			0.46	65	INR	6	06C	+28.37	TECTEH			21H00001	600UL
6323	77	86	0.42	132	INR	3	F10	+5.83	TECTEH			21H00002	600UL
6324	79	86							TECTEH			21H00001	600UL
6325	81	86							TECTEH			21H00001	600UL
6326	83	86							TECTEH			21H00050	600UL
6327	85	86							TECTEH			21H00049	600UL
6328	87	86							TECTEH			21H00050	600UL
6329	89	86							TECTEH			21H00049	600UL
6330	91	86							TECTEH			21H00050	600UL
6331	93	86	0.32	80	INR	6	TSC	+6.29	TECTEH			21H00049	600UL
6332	95	86							TECTEH			21H00050	600UL
6333	97	86							TECTEH			21H00049	600UL
6334	99	86	0.34	77	INR	6	TSH	+10.29	TECTEH			21H00050	600UL
6335			1.12	78	INR	6	05H	+21.77	TECTEH			21H00050	600UL
6336			0.40	83	INR	6	05H	+30.93	TECTEH			21H00050	600UL
6337			0.46	50	INR	6	07H	+7.08	TECTEH			21H00050	600UL
6338					INF		F06	+5.74	TECTEH	HR		21H00050	600UL
6339			0.41	51	INR	6	F06	+6.82	TECTEH			21H00050	600UL
6340					INF		F07	+12.97	TECTEH	HR		21H00050	600UL
6341			0.66	49	INR	6	F07	+14.26	TECTEH			21H00050	600UL
6342					INF		F08	+3.00	TECTEH	HR		21H00050	600UL
6343			0.47	80	INR	6	04C	+36.33	TECTEH			21H00050	600UL
6344			0.70	65	INR	6	03C	+6.40	TECTEH			21H00050	600UL
6345	101	86	0.30	61	INR	6	TSC	+20.70	TECTEH			21H00049	600UL
6346	103	86	0.73	75	INR	6	05H	+3.64	TECTEH			21H00050	600UL
6347			0.44	45	NQH	3	F03	+4.57	TECTEH			21H00050	600UL
6348	105	86							TECTEH			21H00049	600UL
6349	107	86							TECTEH			21H00050	600UL
6350	109	86	0.46	108	INR	6	F05	+16.64	TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6351					INF		F06	+6.40	TECTEH	HR		21H00049	600UL
6352					INF		F06	+7.23	TECTEH	HR		21H00049	600UL
6353			0.68	92	NQH	3	F06	+8.74	TECTEH			21H00049	600UL
6354	111	86							TECTEH			21H00050	600UL
6355	113	86							TECTEH			21H00049	600UL
6356	115	86							TECTEH			21H00050	600UL
6357	117	86							TECTEH			21H00049	600UL
6358	119	86							TECTEH			21H00050	600UL
6359	121	86							TECTEH			21H00049	600UL
6360	123	86	0.42	70	INR	6	04H	+9.74	TECTEH			21H00050	600UL
6361			0.35	76	INR	6	F04	+5.98	TECTEH			21H00050	600UL
6362			0.58	80	INR	6	F08	+11.33	TECTEH			21H00050	600UL
6363					INF		F09	+7.53	TECTEH	HR		21H00050	600UL
6364			0.59	74	INR	6	TSC	+4.59	TECTEH			21H00050	600UL
6365	125	86	0.34	60	INR	6	06H	+30.90	TECTEH			21H00049	600UL
6366	127	86			INF		F01	+2.92	TECTEH	HR		21H00050	600UL
6367			0.50	76	INR	6	F01	+5.04	TECTEH			21H00050	600UL
6368			0.59	77	INR	6	03C	+25.36	TECTEH			21H00050	600UL
6369	129	86							TECTEH			21H00049	600UL
6370	131	86							TECTEH			21H00049	600UL
6371	133	86							TECTEH			21H00047	600UL
6372	135	86							TECTEH			21H00048	600UL
6373	137	86							TECTEH			21H00047	600UL
6374	139	86							TECTEH			21H00048	600UL
6375	141	86							TECTEH			21H00048	600UL
6376	38	87	0.25	102	INR	3	04C	+29.13	TECTEH			21H00002	600UL
6377	40	87							TECTEH			21H00001	600UL
6378	42	87							TECTEH			21H00002	600UL
6379	44	87							TECTEH			21H00001	600UL
6380	46	87							TECTEH			21H00002	600UL
6381	48	87							TECTEH			21H00001	600UL
6382	50	87							TECTEH			21H00002	600UL
6383	52	87							TECTEH			21H00001	600UL
6384	54	87							TECTEH			21H00002	600UL
6385	56	87							TECTEH			21H00001	600UL
6386	58	87							TECTEH			21H00002	600UL
6387	60	87							TECTEH			21H00001	600UL
6388	62	87							TECTEH			21H00002	600UL
6389	64	87	0.42	115	INR	6	07H	+1.83	TECTEH			21H00001	600UL
6390			0.35	91	INR	6	F07	-0.13	TECTEH			21H00001	600UL
6391			0.53	74	INR	6	F08	+5.59	TECTEH			21H00001	600UL
6392					INF		F09	+5.86	TECTEH	HR		21H00001	600UL
6393	66	87							TECTEH			21H00002	600UL
6394	68	87							TECTEH			21H00001	600UL
6395	70	87							TECTEH			21H00002	600UL
6396	72	87							TECTEH			21H00001	600UL
6397	74	87							TECTEH			21H00002	600UL
6398	76	87	0.46	101	INR	6	02C	+7.54	TECTEH			21H00001	600UL
6399	78	87							TECTEH			21H00002	600UL
6400	80	87							TECTEH			21H00001	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6401	82	87							TECTEH			21H00050	600UL
6402	84	87	1.04	70	INR	6	05H	+19.89	TECTEH			21H00050	600UL
6403	86	87							TECTEH			21H00049	600UL
6404	88	87							TECTEH			21H00050	600UL
6405	90	87							TECTEH			21H00049	600UL
6406	92	87							TECTEH			21H00050	600UL
6407	94	87	0.33	87	INR	6	05H	+25.79	TECTEH			21H00049	600UL
6408			0.72	84	INR	6	F04	+3.42	TECTEH			21H00049	600UL
6409					INF		F05	+3.14	TECTEH	HR		21H00049	600UL
6410	96	87							TECTEH			21H00050	600UL
6411	98	87	0.34	104	INR	6	01C	+3.08	TECTEH			21H00049	600UL
6412	100	87	0.46	50	INR	6	06C	+18.36	TECTEH			21H00050	600UL
6413	102	87							TECTEH			21H00049	600UL
6414	104	87	0.75	62	INR	6	F08	+7.89	TECTEH			21H00050	600UL
6415			0.51	89	INR	6	F08	+11.91	TECTEH			21H00050	600UL
6416					INF		F09	+3.86	TECTEH	HR		21H00050	600UL
6417					INF		F09	+8.78	TECTEH	HR		21H00050	600UL
6418	106	87	0.33	85	INR	6	04H	+30.40	TECTEH			21H00049	600UL
6419			0.42	53	INR	6	05H	+39.16	TECTEH			21H00049	600UL
6420			0.58	83	INR	6	F07	+6.56	TECTEH			21H00049	600UL
6421					INF		F08	+11.28	TECTEH	HR		21H00049	600UL
6422			0.40	75	INR	6	TSC	+12.48 TO+14.72	TECTEH			21H00049	600UL
6423	108	87							TECTEH			21H00050	600UL
6424	110	87							TECTEH			21H00049	600UL
6425	112	87							TECTEH			21H00050	600UL
6426	114	87	0.44	108	NQH	3	05C	+32.30	TECTEH			21H00049	600UL
6427	116	87							TECTEH			21H00050	600UL
6428	118	87							TECTEH			21H00049	600UL
6429	120	87							TECTEH			21H00050	600UL
6430	122	87							TECTEH			21H00049	600UL
6431	124	87							TECTEH			21H00050	600UL
6432	126	87							TECTEH			21H00049	600UL
6433	128	87							TECTEH			21H00049	600UL
6434	130	87							TECTEH			21H00050	600UL
6435	132	87							TECTEH			21H00047	600UL
6436	134	87	0.37	79	INR	6	03C	+3.16	TECTEH			21H00047	600UL
6437	136	87	0.46	81	INR	6	F06	+15.25	TECTEH			21H00048	600UL
6438					INF		F07	+3.95	TECTEH	HR		21H00048	600UL
6439			0.54	75	INR	6	F07	+13.00	TECTEH			21H00048	600UL
6440					INF		F08	+7.40	TECTEH	HR		21H00048	600UL
6441					INF		F08	+8.11	TECTEH	HR		21H00048	600UL
6442			0.69	102	NQH	3	02C	+30.70	TECTEH			21H00048	600UL
6443			0.29	82	INR	6	01C	+7.78	TECTEH			21H00048	600UL
6444			0.29	87	INR	6	TSC	+3.81	TECTEH			21H00048	600UL
6445	138	87							TECTEH			21H00047	600UL
6446	140	87	0.86	71	INR	6	F05	+15.98	TECTEH			21H00048	600UL
6447	37	88							TECTEH			21H00002	600UL
6448	39	88							TECTEH			21H00001	600UL
6449	41	88							TECTEH			21H00002	600UL
6450	43	88							TECTEH			21H00001	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6451	45	88							TECTEH			21H00002	600UL
6452	47	88							TECTEH			21H00001	600UL
6453	49	88							TECTEH			21H00002	600UL
6454	51	88							TECTEH			21H00001	600UL
6455	53	88							TECTEH			21H00002	600UL
6456	55	88							TECTEH			21H00001	600UL
6457	57	88	0.33	131	INR	3	03H	+5.22	TECTEH			21H00002	600UL
6458			0.30	141	INR	3	06H	+28.09	TECTEH			21H00002	600UL
6459			0.26	137	INR	3	06H	+35.12	TECTEH			21H00002	600UL
6460			0.43	129	INR	3	06C	+6.59	TECTEH			21H00002	600UL
6461			0.45	125	INR	3	06C	+38.39	TECTEH			21H00002	600UL
6462			0.23	121	INR	3	04C	+6.20	TECTEH			21H00002	600UL
6463			1.17	127	INR	3	01C	+20.85	TECTEH			21H00002	600UL
6464			0.38	114	INR	3	TSC	+19.47	TECTEH			21H00002	600UL
6465	59	88	0.34	67	INR	6	05H	+29.89	TECTEH			21H00001	600UL
6466			0.40	82	INR	6	01C	+22.73	TECTEH			21H00001	600UL
6467	61	88							TECTEH			21H00002	600UL
6468	63	88	0.74	82	INR	6	02H	+14.64	TECTEH			21H00001	600UL
6469			0.33	77	INR	6	05C	+9.35	TECTEH			21H00001	600UL
6470			0.97	68	INR	6	04C	+2.23	TECTEH			21H00001	600UL
6471			0.61	76	INR	6	01C	+30.16	TECTEH			21H00001	600UL
6472	65	88	0.43	133	INR	3	04C	+32.64	TECTEH			21H00002	600UL
6473	67	88	0.69	76	INR	6	05H	+36.55	TECTEH			21H00001	600UL
6474			0.47	74	INR	6	06H	+35.81	TECTEH			21H00001	600UL
6475	69	88							TECTEH			21H00002	600UL
6476	71	88	0.43	83	INR	6	04C	+12.18	TECTEH			21H00001	600UL
6477			0.55	73	INR	6	02C	+5.72	TECTEH			21H00001	600UL
6478			0.34	77	INR	6	02C	+27.63	TECTEH			21H00001	600UL
6479	73	88							TECTEH			21H00002	600UL
6480	75	88	0.28	89	INR	6	02H	+8.14	TECTEH			21H00001	600UL
6481	77	88	0.35	146	INR	3	02C	+9.59	TECTEH			21H00002	600UL
6482	79	88							TECTEH			21H00001	600UL
6483	81	88							TECTEH			21H00001	600UL
6484	83	88							TECTEH			21H00050	600UL
6485	85	88							TECTEH			21H00049	600UL
6486	87	88							TECTEH			21H00050	600UL
6487	89	88							TECTEH			21H00049	600UL
6488	91	88							TECTEH			21H00050	600UL
6489	93	88							TECTEH			21H00049	600UL
6490	95	88	0.63	59	INR	6	F02	+7.51	TECTEH			21H00050	600UL
6491	97	88	0.44	82	INR	6	01H	+8.38	TECTEH			21H00049	600UL
6492			0.46	70	INR	6	01H	+15.04	TECTEH			21H00049	600UL
6493	99	88							TECTEH			21H00050	600UL
6494	101	88	0.52	73	INR	6	04C	+26.71	TECTEH			21H00049	600UL
6495			0.64	71	INR	6	02C	+34.77 TO+36.51	TECTEH			21H00049	600UL
6496	103	88							TECTEH			21H00050	600UL
6497	105	88	0.23	78	INR	6	01H	+2.77	TECTEH			21H00049	600UL
6498	107	88	0.28	230	INR	6	04H	+2.12	TECTEH			21H00050	600UL
6499			0.41	61	NQH	3	F08	+13.48	TECTEH			21H00050	600UL
6500			1.59	81	INR	6	03C	+10.89	TECTEH			21H00050	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6501			0.59	70	INR	6	01C	+18.75	TECTEH			21H00050	600UL
6502	109	88							TECTEH			21H00049	600UL
6503	111	88	1.51	75	INR	6	01H	+7.04	TECTEH			21H00050	600UL
6504			0.71	72	INR	6	01H	+10.63	TECTEH			21H00050	600UL
6505			0.84	73	INR	6	01H	+21.94	TECTEH			21H00050	600UL
6506			0.60	65	INR	6	02H	+12.98	TECTEH			21H00050	600UL
6507			0.44	80	INR	6	02H	+26.15	TECTEH			21H00050	600UL
6508			0.56	69	INR	6	04H	+9.93	TECTEH			21H00050	600UL
6509			0.42	54	INR	6	06H	+22.00	TECTEH			21H00050	600UL
6510			0.69	64	INR	6	07H	+12.56	TECTEH			21H00050	600UL
6511			0.54	40	INR	6	F04	+8.53	TECTEH			21H00050	600UL
6512					INF		F09	+1.66	TECTEH	HR		21H00050	600UL
6513					INF		F09	+2.87	TECTEH	HR		21H00050	600UL
6514			0.65	58	INR	6	F09	+3.16	TECTEH			21H00050	600UL
6515			0.49	44	INR	6	F09	+4.85	TECTEH			21H00050	600UL
6516					INF		F10	+12.20	TECTEH	HR		21H00050	600UL
6517			0.49	69	INR	6	04C	+38.00	TECTEH			21H00050	600UL
6518			0.51	69	INR	6	01C	+28.24	TECTEH			21H00050	600UL
6519	113	88							TECTEH			21H00049	600UL
6520	115	88							TECTEH			21H00050	600UL
6521	117	88							TECTEH			21H00049	600UL
6522	119	88							TECTEH			21H00050	600UL
6523	121	88							TECTEH			21H00049	600UL
6524	123	88	0.43	75	INR	6	04H	+27.56	TECTEH			21H00050	600UL
6525	125	88	0.41	102	INR	6	F04	+9.48	TECTEH			21H00049	600UL
6526					INF		F04	+10.58	TECTEH	HR		21H00049	600UL
6527					INF		F05	+11.46	TECTEH	HR		21H00049	600UL
6528			0.55	93	NQH	3	F08	+14.89	TECTEH			21H00049	600UL
6529					INF		F08	+16.30	TECTEH	HR		21H00049	600UL
6530					INF		F10	+1.21	TECTEH	HR		21H00049	600UL
6531	127	88	0.50	77	INR	6	02C	+12.45	TECTEH			21H00050	600UL
6532	129	88	0.62	86	INR	6	TSH	+11.38	TECTEH			21H00049	600UL
6533	131	88	0.31	83	INR	6	04H	+19.03	TECTEH			21H00049	600UL
6534			0.42	72	INR	6	F03	+13.70	TECTEH			21H00049	600UL
6535			0.22	95	INR	6	F06	+14.75	TECTEH			21H00049	600UL
6536					INF		F07	+2.25	TECTEH	HR		21H00049	600UL
6537	133	88	0.30	100	INR	3	04H	+34.05	TECTEH			21H00047	600UL
6538			0.97	91	INR	6	02C	+30.21	TECTEH			21H00047	600UL
6539	135	88	0.14		INR	6	06C	+37.05 TO+44.36	TECTEH			21H00048	600UL
6540	137	88							TECTEH			21H00047	600UL
6541	139	88	0.64	76	INR	6	F11	+0.03	TECTEH			21H00048	600UL
6542	141	88							TECTEH			21H00048	600UL
6543	36	89							TECTEH			21H00004	600UL
6544	38	89							TECTEH			21H00003	600UL
6545	40	89							TECTEH			21H00004	600UL
6546	42	89							TECTEH			21H00003	600UL
6547	44	89	0.59	125	INR	3	TSH	+16.23	TECTEH			21H00004	600UL
6548			0.45	134	INR	3	02C	+7.02	TECTEH			21H00004	600UL
6549	46	89							TECTEH			21H00003	600UL
6550	48	89							TECTEH			21H00004	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6551	50	89								TECTEH			21H00003	600UL
6552	52	89								TECTEH			21H00004	600UL
6553	54	89								TECTEH			21H00003	600UL
6554	56	89								TECTEH			21H00004	600UL
6555	58	89								TECTEH			21H00003	600UL
6556	60	89								TECTEH			21H00001	600UL
6557	62	89								TECTEH			21H00001	600UL
6558	64	89	0.42	61	INR	6	04H	+38.58		TECTEH			21H00001	600UL
6559			0.79	156	INR	6	F01	-0.46		TECTEH			21H00001	600UL
6560					INF		F02	-0.48		TECTEH	HR		21H00001	600UL
6561	66	89								TECTEH			21H00001	600UL
6562	68	89	1.10	26	INR	6	F05	+0.13		TECTEH			21H00001	600UL
6563	70	89								TECTEH			21H00001	600UL
6564	72	89	0.48	77	INR	6	TSH	+18.86		TECTEH			21H00001	600UL
6565			1.12	184	INR	6	F08	+2.82	TO+13.23	TECTEH			21H00001	600UL
6566	74	89	0.27	99	INR	6	01H	+2.50		TECTEH			21H00001	600UL
6567	76	89								TECTEH			21H00001	600UL
6568	78	89								TECTEH			21H00001	600UL
6569	80	89	0.46	83	INR	6	TSH	+12.92		TECTEH			21H00001	600UL
6570			0.41	86	INR	6	02H	+13.40		TECTEH			21H00001	600UL
6571	82	89	0.42	56	INR	6	02C	+38.08		TECTEH			21H00050	600UL
6572	84	89	0.44	56	INR	6	02C	+8.64		TECTEH			21H00050	600UL
6573	86	89								TECTEH			21H00049	600UL
6574	88	89								TECTEH			21H00050	600UL
6575	90	89	0.51	57	NQH	3	F07	+9.88		TECTEH			21H00049	600UL
6576					INF		F08	+4.08		TECTEH	HR		21H00049	600UL
6577	92	89								TECTEH			21H00050	600UL
6578	94	89								TECTEH			21H00049	600UL
6579	96	89								TECTEH			21H00050	600UL
6580	98	89	0.41	66	INR	6	03C	+23.96		TECTEH			21H00049	600UL
6581	100	89	0.50	87	INR	6	TSH	+11.21		TECTEH			21H00050	600UL
6582			0.34	70	INR	6	01H	+2.97		TECTEH			21H00050	600UL
6583	102	89								TECTEH			21H00049	600UL
6584	104	89	0.61	70	INR	6	06H	+20.83		TECTEH			21H00050	600UL
6585			1.33	22	INR	6	F02	+0.23		TECTEH			21H00050	600UL
6586			0.45	86	INR	6	TSC	+15.66		TECTEH			21H00050	600UL
6587	106	89	0.31	97	INR	6	06H	+7.70		TECTEH			21H00049	600UL
6588			0.61	78	INR	6	01C	+4.89		TECTEH			21H00049	600UL
6589	108	89								TECTEH			21H00050	600UL
6590	110	89								TECTEH			21H00049	600UL
6591	112	89								TECTEH			21H00050	600UL
6592	114	89								TECTEH			21H00049	600UL
6593	116	89								TECTEH			21H00050	600UL
6594	118	89								TECTEH			21H00049	600UL
6595	120	89								TECTEH			21H00050	600UL
6596	122	89	0.45	76	INR	6	01H	+6.78		TECTEH			21H00049	600UL
6597	124	89	1.27	28	INR	6	F06	+16.70		TECTEH			21H00050	600UL
6598					INF		F07	+2.01		TECTEH	HR		21H00050	600UL
6599			0.46	76	INR	6	05C	+27.40		TECTEH			21H00050	600UL
6600	126	89	1.00	169	INR	6	F09	+1.77		TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6601					INF		F10	+16.78	TECTEH	HR		21H00049	600UL
6602	128	89	0.58	63	INR	6	F06	+5.43	TECTEH			21H00050	600UL
6603			0.41	73	INR	6	06C	+32.27	TECTEH			21H00050	600UL
6604			0.61	75	INR	6	05C	+20.03	TECTEH			21H00050	600UL
6605	130	89							TECTEH			21H00049	600UL
6606	132	89	0.63	67	INR	6	F04	+5.96	TECTEH			21H00047	600UL
6607			0.42	116	INR	6	F04	+11.62 TO+13.53	TECTEH			21H00047	600UL
6608	134	89	0.36	70	INR	6	05H	+27.93	TECTEH			21H00047	600UL
6609	136	89							TECTEH			21H00048	600UL
6610	138	89							TECTEH			21H00047	600UL
6611	140	89	0.44	72	INR	6	02H	+28.76	TECTEH			21H00048	600UL
6612	35	90							TECTEH			21H00004	600UL
6613	37	90							TECTEH			21H00003	600UL
6614	39	90							TECTEH			21H00004	600UL
6615	41	90							TECTEH			21H00003	600UL
6616	43	90	0.39	142	INR	3	03H	+33.73	TECTEH			21H00004	600UL
6617	45	90							TECTEH			21H00003	600UL
6618	47	90							TECTEH			21H00004	600UL
6619	49	90							TECTEH			21H00003	600UL
6620	51	90							TECTEH			21H00004	600UL
6621	53	90							TECTEH			21H00003	600UL
6622	55	90							TECTEH			21H00004	600UL
6623	57	90							TECTEH			21H00003	600UL
6624	59	90	0.60	163	INR	3	F05	+7.06	TECTEH			21H00004	600UL
6625	61	90							TECTEH			21H00003	600UL
6626	63	90							TECTEH			21H00004	600UL
6627	65	90							TECTEH			21H00003	600UL
6628	67	90	0.32	136	INR	3	03C	+30.85	TECTEH			21H00004	600UL
6629			0.68	133	INR	3	02C	+16.88	TECTEH			21H00004	600UL
6630	69	90							TECTEH			21H00003	600UL
6631	71	90							TECTEH			21H00004	600UL
6632	73	90	0.51	82	INR	6	02H	+30.44	TECTEH			21H00003	600UL
6633			0.61	76	INR	6	02H	+36.48	TECTEH			21H00003	600UL
6634			0.38	82	INR	6	03H	+27.77	TECTEH			21H00003	600UL
6635			0.73	78	INR	6	05H	+10.06	TECTEH			21H00003	600UL
6636			0.61	80	INR	6	02C	+38.22	TECTEH			21H00003	600UL
6637			0.30	110	INR	3	02C	+39.25	TECTEH			21H00003	600UL
6638	75	90	0.25	101	INR	3	06C	+37.21	TECTEH			21H00004	600UL
6639	77	90							TECTEH			21H00003	600UL
6640	79	90			INF		F08	+12.37	TECTEH	HR		21H00004	600UL
6641	81	90	0.59	76	INR	6	05C	+38.84	TECTEH			21H00003	600UL
6642	83	90							TECTEH			21H00050	600UL
6643	85	90	0.44	85	INR	6	02C	+10.26	TECTEH			21H00049	600UL
6644	87	90							TECTEH			21H00050	600UL
6645	89	90	0.39	92	INR	6	04H	+22.86	TECTEH			21H00049	600UL
6646	91	90	0.41	75	INR	6	02H	+18.32	TECTEH			21H00050	600UL
6647	93	90							TECTEH			21H00049	600UL
6648	95	90							TECTEH			21H00050	600UL
6649	97	90	0.49	85	INR	6	01H	+20.85	TECTEH			21H00049	600UL
6650			0.42	78	INR	6	03H	+33.69	TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6651					INF		F05	+2.03	TECTEH	HR		21H00049	600UL
6652			0.54	81	INR	6	F05	+3.77	TECTEH			21H00049	600UL
6653					INF		F05	+15.32	TECTEH	HR		21H00049	600UL
6654			0.87	86	INR	6	F06	-1.84	TECTEH			21H00049	600UL
6655			0.42	103	INR	3	05C	+20.44	TECTEH			21H00049	600UL
6656	99	90	0.66	79	INR	6	01C	+32.27	TECTEH			21H00050	600UL
6657	101	90	0.39	86	INR	6	01H	+32.24	TECTEH			21H00049	600UL
6658	103	90							TECTEH			21H00050	600UL
6659	105	90							TECTEH			21H00049	600UL
6660	107	90	0.52	85	INR	6	02C	+33.61	TECTEH			21H00050	600UL
6661	109	90	0.38	85	INR	6	02H	+11.69	TECTEH			21H00049	600UL
6662			0.26	59	INR	6	F04	-0.11	TECTEH			21H00049	600UL
6663			0.30	101	INR	6	01C	+33.05	TECTEH			21H00049	600UL
6664	111	90							TECTEH			21H00050	600UL
6665	113	90							TECTEH			21H00049	600UL
6666	115	90							TECTEH			21H00050	600UL
6667	117	90	0.56	96	INR	6	04H	+30.90	TECTEH			21H00049	600UL
6668	119	90	0.62	54	INR	6	F01	+10.07	TECTEH			21H00050	600UL
6669			0.53	91	INR	6	F08	+3.13	TECTEH			21H00050	600UL
6670					INF		F09	+13.23	TECTEH	HR		21H00050	600UL
6671	121	90							TECTEH			21H00049	600UL
6672	123	90	0.42	66	INR	6	02H	+27.31	TECTEH			21H00050	600UL
6673			0.39	71	INR	6	03C	+25.39	TECTEH			21H00050	600UL
6674	125	90	0.36	109	INR	6	F07	+14.84	TECTEH			21H00049	600UL
6675					INF		F08	+2.45	TECTEH	HR		21H00049	600UL
6676			0.40	121	INR	3	06C	+15.90	TECTEH			21H00049	600UL
6677			0.41	95	INR	6	06C	+32.32	TECTEH			21H00049	600UL
6678			0.46	74	INR	6	05C	+35.51	TECTEH			21H00049	600UL
6679			0.56	86	INR	6	04C	+14.61	TECTEH			21H00049	600UL
6680			0.34	99	INR	6	03C	+39.32	TECTEH			21H00049	600UL
6681			0.61	83	INR	6	01C	+13.57	TECTEH			21H00049	600UL
6682	127	90							TECTEH			21H00050	600UL
6683	129	90	0.34	90	INR	6	F03	+5.67	TECTEH			21H00049	600UL
6684	131	90							TECTEH			21H00049	600UL
6685	133	90							TECTEH			21H00047	600UL
6686	135	90							TECTEH			21H00048	600UL
6687	137	90							TECTEH			21H00047	600UL
6688	139	90							TECTEH			21H00048	600UL
6689	36	91							TECTEH			21H00004	600UL
6690	38	91							TECTEH			21H00004	600UL
6691	40	91							TECTEH			21H00003	600UL
6692	42	91	0.20	93	INR	3	05H	+27.37	TECTEH			21H00004	600UL
6693	44	91							TECTEH			21H00003	600UL
6694	46	91							TECTEH			21H00004	600UL
6695	48	91							TECTEH			21H00003	600UL
6696	50	91							TECTEH			21H00004	600UL
6697	52	91							TECTEH			21H00003	600UL
6698	54	91	0.29	140	INR	3	04C	+13.66	TECTEH			21H00004	600UL
6699	56	91							TECTEH			21H00003	600UL
6700	58	91							TECTEH			21H00004	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6701	60	91	0.40	114	INR	6	F08	+10.12	TECTEH			21H00003	600UL
6702					INF		F09	+3.20	TECTEH	HR		21H00003	600UL
6703			0.50	73	INR	6	04C	+21.14	TECTEH			21H00003	600UL
6704	62	91	0.40	125	INR	3	06C	+10.11	TECTEH			21H00004	600UL
6705	64	91	0.80	77	INR	6	05C	+38.85	TECTEH			21H00003	600UL
6706			0.32	109	INR	6	03C	+10.85	TECTEH			21H00003	600UL
6707	66	91							TECTEH			21H00004	600UL
6708	68	91			INF		F04	+3.28	TECTEH	HR		21H00003	600UL
6709			0.84	76	INR	6	F05	+3.97	TECTEH			21H00003	600UL
6710	70	91			INF		F10	+0.00	TECTEH	HR		21H00004	600UL
6711			0.60	130	INR	3	02C	+27.34	TECTEH			21H00004	600UL
6712	72	91	0.25	94	INR	3	02H	+20.74	TECTEH			21H00003	600UL
6713			0.49	83	INR	6	03H	+13.40	TECTEH			21H00003	600UL
6714	74	91	0.82	147	INR	3	F03	+3.06	TECTEH			21H00004	600UL
6715			1.02	128	INR	3	03C	+2.96	TECTEH			21H00004	600UL
6716	76	91	0.35	79	INR	6	02H	+18.36	TECTEH			21H00003	600UL
6717					INF		07H	+72.57	TECTEH	HR		21H00003	600UL
6718			0.14	141	INR	3	F06	+0.08	TECTEH			21H00003	600UL
6719			0.49	79	INR	6	01C	+26.67	TECTEH			21H00003	600UL
6720	78	91	0.39	140	INR	3	06C	+29.17	TECTEH			21H00004	600UL
6721	80	91	0.41	89	INR	6	03C	+13.39	TECTEH			21H00003	600UL
6722	82	91							TECTEH			21H00050	600UL
6723	84	91							TECTEH			21H00050	600UL
6724	86	91			INF		01C	+31.76	TECTEH	HR		21H00049	600UL
6725	88	91							TECTEH			21H00050	600UL
6726	90	91	0.26	83	INR	6	06H	+15.01	TECTEH			21H00049	600UL
6727	92	91	0.32	91	INR	6	02H	+10.66	TECTEH			21H00050	600UL
6728			0.39	44	INR	6	06H	+12.88	TECTEH			21H00050	600UL
6729	94	91							TECTEH			21H00049	600UL
6730	96	91	0.47	76	INR	6	03C	+32.67	TECTEH			21H00050	600UL
6731	98	91	0.77	90	INR	6	F12	+8.95	TECTEH			21H00049	600UL
6732					INF		07C	+8.26	TECTEH	HR		21H00049	600UL
6733			0.27	103	INR	6	TSC	+7.93	TECTEH			21H00049	600UL
6734	100	91							TECTEH			21H00050	600UL
6735	102	91							TECTEH			21H00049	600UL
6736	104	91	1.07	41	INR	6	05H	+0.29	TECTEH			21H00050	600UL
6737			0.50	74	INR	6	F04	+7.99	TECTEH			21H00050	600UL
6738					INF		F10	+12.07	TECTEH	HR		21H00050	600UL
6739			0.34	71	INR	6	F12	+5.33	TECTEH			21H00050	600UL
6740					INF		07C	+13.20	TECTEH	HR		21H00050	600UL
6741	106	91	0.48	118	INR	6	F04	+10.50	TECTEH			21H00049	600UL
6742	108	91	0.25	264	INR	6	01H	+4.97	TECTEH			21H00050	600UL
6743			0.37	74	INR	6	02H	+8.91	TECTEH			21H00050	600UL
6744			0.61	80	INR	6	02H	+27.13	TECTEH			21H00050	600UL
6745			0.53	85	INR	6	F04	+3.60	TECTEH			21H00050	600UL
6746	110	91	0.48	85	INR	6	05H	+4.86	TECTEH			21H00049	600UL
6747	112	91							TECTEH			21H00050	600UL
6748	114	91							TECTEH			21H00049	600UL
6749	116	91							TECTEH			21H00050	600UL
6750	118	91							TECTEH			21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6751	120	91							TECTEH			21H00050	600UL
6752	122	91							TECTEH			21H00049	600UL
6753	124	91	0.92	79	INR	6	02C	+16.21	TECTEH			21H00050	600UL
6754	126	91							TECTEH			21H00049	600UL
6755	128	91	1.42	81	INR	6	F06	+3.81	TECTEH			21H00050	600UL
6756	130	91			INF		F05	+0.00	TECTEH	HR		21H00049	600UL
6757			0.50	107	INR	6	F06	+0.15	TECTEH			21H00049	600UL
6758			0.42	124	INR	3	05C	+19.71	TECTEH			21H00049	600UL
6759	132	91	0.27	90	INR	3	04H	+5.17	TECTEH			21H00047	600UL
6760			0.49	72	INR	6	05H	+15.48	TECTEH			21H00047	600UL
6761			0.39	76	INR	6	06H	+34.60	TECTEH			21H00047	600UL
6762	134	91							TECTEH			21H00047	600UL
6763	136	91							TECTEH			21H00048	600UL
6764	138	91							TECTEH			21H00047	600UL
6765	140	91							TECTEH			21H00048	600UL
6766	35	92							TECTEH			21H00004	600UL
6767	37	92							TECTEH			21H00003	600UL
6768	39	92							TECTEH			21H00004	600UL
6769	41	92	0.48	69	INR	6	02H	+25.51	TECTEH			21H00003	600UL
6770	43	92	0.39	133	INR	3	01C	+7.83	TECTEH			21H00004	600UL
6771	45	92	0.71	63	INR	6	01H	+32.74	TECTEH			21H00003	600UL
6772	47	92							TECTEH			21H00004	600UL
6773	49	92							TECTEH			21H00003	600UL
6774	51	92							TECTEH			21H00004	600UL
6775	53	92							TECTEH			21H00003	600UL
6776	55	92							TECTEH			21H00004	600UL
6777	57	92							TECTEH			21H00003	600UL
6778	59	92	0.27	119	INR	3	TSH	+16.37	TECTEH			21H00004	600UL
6779	61	92							TECTEH			21H00003	600UL
6780	63	92							TECTEH			21H00004	600UL
6781	65	92							TECTEH			21H00003	600UL
6782	67	92	0.37	119	INR	3	F07	+5.74	TECTEH			21H00004	600UL
6783			0.40	155	INR	3	F08	+8.26	TECTEH			21H00004	600UL
6784	69	92	0.45	77	INR	6	05H	+22.94	TECTEH			21H00003	600UL
6785			0.77	23	INR	6	F01	+5.70	TECTEH			21H00003	600UL
6786	71	92							TECTEH			21H00004	600UL
6787	73	92	0.98	80	INR	6	03C	+23.22	TECTEH			21H00003	600UL
6788	75	92							TECTEH			21H00004	600UL
6789	77	92							TECTEH			21H00003	600UL
6790	79	92							TECTEH			21H00004	600UL
6791	81	92							TECTEH			21H00003	600UL
6792	83	92							TECTEH			21H00050	600UL
6793	85	92	0.33	93	INR	6	02H	+10.92	TECTEH			21H00049	600UL
6794			0.53	83	INR	6	02H	+33.51	TECTEH			21H00049	600UL
6795			0.39	114	INR	3	F04	+13.01	TECTEH			21H00049	600UL
6796					INF		F05	+0.00	TECTEH	HR		21H00049	600UL
6797			0.50	51	INR	6	F07	+4.75	TECTEH			21H00049	600UL
6798					INF		F08	+10.66	TECTEH	HR		21H00049	600UL
6799			0.41	87	INR	6	01C	+26.36	TECTEH			21H00049	600UL
6800	87	92							TECTEH			21H00050	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6801	89	92	0.56	96	INR	6	02H	+38.18	TECTEH			21H00049	600UL
6802			0.40	112	INR	3	03H	+28.91	TECTEH			21H00049	600UL
6803	91	92	0.61	78	INR	6	02H	+25.47	TECTEH			21H00050	600UL
6804					INF		F02	+9.14	TECTEH	HR		21H00050	600UL
6805			0.72	76	INR	6	F02	+10.41	TECTEH			21H00050	600UL
6806	93	92							TECTEH			21H00049	600UL
6807	95	92	0.80	76	INR	6	04H	+19.31	TECTEH			21H00050	600UL
6808			0.74	78	INR	6	05H	+18.98	TECTEH			21H00050	600UL
6809			0.75	55	INR	6	F02	+10.98	TECTEH			21H00050	600UL
6810			0.41	90	INR	6	F03	+9.73	TECTEH			21H00050	600UL
6811			0.80	73	INR	6	TSC	+14.90	TECTEH			21H00050	600UL
6812	97	92							TECTEH			21H00049	600UL
6813	99	92							TECTEH			21H00050	600UL
6814	101	92	0.39	96	NQH	3	F03	+13.68	TECTEH			21H00049	600UL
6815			0.43	105	INR	3	05C	+24.08	TECTEH			21H00049	600UL
6816			0.54	88	INR	6	02C	+5.51	TECTEH			21H00049	600UL
6817	103	92							TECTEH			21H00050	600UL
6818	105	92	1.63	45	INR	6	03C	+26.44 TO+38.28	TECTEH			21H00049	600UL
6819	107	92	0.64	75	INR	6	06H	+13.65	TECTEH			21H00050	600UL
6820			0.69	87	INR	6	06C	+34.00	TECTEH			21H00050	600UL
6821			0.67	106	INR	6	03C	+11.46	TECTEH			21H00050	600UL
6822			1.19	79	INR	6	03C	+38.97	TECTEH			21H00050	600UL
6823			0.65	74	INR	6	02C	+37.16	TECTEH			21H00050	600UL
6824	109	92							TECTEH			21H00049	600UL
6825	111	92							TECTEH			21H00050	600UL
6826	113	92							TECTEH			21H00049	600UL
6827	115	92	1.55	50	INR	6	F08	+0.10	TECTEH			21H00050	600UL
6828			0.65	85	INR	6	F10	+6.16	TECTEH			21H00050	600UL
6829					INF		F11	+9.48	TECTEH	HR		21H00050	600UL
6830	117	92							TECTEH			21H00049	600UL
6831	119	92							TECTEH			21H00050	600UL
6832	121	92	0.64	78	INR	6	01H	+20.45	TECTEH			21H00049	600UL
6833	123	92	0.30	218	INR	6	06H	+28.05	TECTEH			21H00050	600UL
6834			0.74	71	INR	6	F11	+10.82	TECTEH			21H00050	600UL
6835					INF		F12	+5.73	TECTEH	HR		21H00050	600UL
6836			2.02	179	INR	P1	07C	+1.46	TECTEH			21H00050	600UL
6837	125	92							TECTEH			21H00049	600UL
6838	127	92							TECTEH			21H00050	600UL
6839	129	92							TECTEH			21H00049	600UL
6840	131	92							TECTEH			21H00049	600UL
6841	133	92	0.52	41	INR	6	F06	+14.45	TECTEH			21H00047	600UL
6842					INF		F07	+4.79	TECTEH	HR		21H00047	600UL
6843			0.42	85	INR	6	06C	+20.62	TECTEH			21H00047	600UL
6844	135	92	0.49	63	INR	6	F02	+8.79	TECTEH			21H00048	600UL
6845	137	92							TECTEH			21H00047	600UL
6846	139	92	0.55	50	INR	6	F07	+9.96	TECTEH			21H00048	600UL
6847			0.32	101	INR	6	F08	+8.57	TECTEH			21H00048	600UL
6848					INF		F08	+10.40	TECTEH	HR		21H00048	600UL
6849	34	93							TECTEH			21H00004	600UL
6850	36	93							TECTEH			21H00003	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6851	38	93							TECTEH			21H00004	600UL
6852	40	93							TECTEH			21H00003	600UL
6853	42	93							TECTEH			21H00004	600UL
6854	44	93	0.66	83	INR	6	02C	+30.28	TECTEH			21H00003	600UL
6855	46	93							TECTEH			21H00004	600UL
6856	48	93							TECTEH			21H00003	600UL
6857	50	93							TECTEH			21H00004	600UL
6858	52	93							TECTEH			21H00003	600UL
6859	54	93							TECTEH			21H00004	600UL
6860	56	93							TECTEH			21H00003	600UL
6861	58	93	0.32	131	INR	3	TSH	+21.09	TECTEH			21H00004	600UL
6862			0.27	132	INR	3	01H	+20.78	TECTEH			21H00004	600UL
6863	60	93	0.52	91	INR	6	TSH	+10.93	TECTEH			21H00003	600UL
6864	62	93							TECTEH			21H00004	600UL
6865	64	93							TECTEH			21H00003	600UL
6866	66	93							TECTEH			21H00004	600UL
6867	68	93							TECTEH			21H00003	600UL
6868	70	93	0.27	137	INR	3	03H	+38.84	TECTEH			21H00004	600UL
6869	72	93							TECTEH			21H00003	600UL
6870	74	93							TECTEH			21H00004	600UL
6871	76	93							TECTEH			21H00003	600UL
6872	78	93							TECTEH			21H00004	600UL
6873	80	93							TECTEH			21H00003	600UL
6874	82	93							TECTEH			21H00050	600UL
6875	84	93							TECTEH			21H00050	600UL
6876	86	93	0.54	71	INR	6	02H	+19.42	TECTEH			21H00049	600UL
6877			0.45	59	INR	6	F10	+1.87	TECTEH			21H00049	600UL
6878					INF		F11	+10.02	TECTEH	HR		21H00049	600UL
6879	88	93							TECTEH			21H00050	600UL
6880	90	93							TECTEH			21H00049	600UL
6881	92	93	0.50	73	INR	6	05C	+21.52	TECTEH			21H00050	600UL
6882			0.53	80	INR	6	01C	+12.68	TECTEH			21H00050	600UL
6883	94	93	0.24	63	INR	6	03H	+14.80	TECTEH			21H00049	600UL
6884			0.52	87	INR	6	03H	+21.40	TECTEH			21H00049	600UL
6885			0.73	80	INR	6	06H	+33.66	TECTEH			21H00049	600UL
6886			0.49	69	INR	6	F03	+9.23	TECTEH			21H00049	600UL
6887			0.50	64	INR	6	F04	+4.69	TECTEH			21H00049	600UL
6888					INF		F04	+7.18	TECTEH	HR		21H00049	600UL
6889			1.49	82	INR	6	06C	+31.53	TECTEH			21H00049	600UL
6890	96	93	0.59	42	INR	6	F09	+10.93	TECTEH			21H00050	600UL
6891					INF		F10	+4.98	TECTEH	HR		21H00050	600UL
6892	98	93							TECTEH			21H00049	600UL
6893	100	93	0.38	101	INR	6	03C	+9.77	TECTEH			21H00050	600UL
6894	102	93							TECTEH			21H00049	600UL
6895	104	93	0.47	82	INR	6	04C	+20.32	TECTEH			21H00050	600UL
6896	106	93							TECTEH			21H00049	600UL
6897	108	93	0.60	66	INR	6	06C	+22.55	TECTEH			21H00050	600UL
6898			0.43	82	INR	6	01C	+5.65	TECTEH			21H00050	600UL
6899	110	93	0.76	95	INR	6	F10	+6.44	TECTEH			21H00049	600UL
6900					INF		F11	+9.76	TECTEH	HR		21H00049	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6901	112	93	0.60	69	INR	6	05H	+29.15	TECTEH			21H00050	600UL
6902			0.46	65	INR	6	F07	+2.76	TECTEH			21H00050	600UL
6903					INF		F08	+15.00	TECTEH	HR		21H00050	600UL
6904			0.30	100	INR	3	06C	+34.65	TECTEH			21H00050	600UL
6905			0.42	33	INR	6	05C	+37.80	TECTEH			21H00050	600UL
6906			0.44	49	INR	6	04C	+34.02	TECTEH			21H00050	600UL
6907	114	93							TECTEH			21H00049	600UL
6908	116	93							TECTEH			21H00050	600UL
6909	118	93							TECTEH			21H00049	600UL
6910	120	93							TECTEH			21H00050	600UL
6911	122	93	0.35	90	INR	3	03H	+18.91	TECTEH			21H00049	600UL
6912			0.30	124	INR	6	F09	+0.95	TECTEH			21H00049	600UL
6913			0.30	104	INR	6	F09	+9.39	TECTEH			21H00049	600UL
6914					INF		F10	+16.36	TECTEH	HR		21H00049	600UL
6915			0.64	87	INR	6	01C	+31.76	TECTEH			21H00049	600UL
6916	124	93							TECTEH			21H00050	600UL
6917	126	93	0.38	68	INR	6	05C	+20.96	TECTEH			21H00049	600UL
6918	128	93	0.87	84	INR	6	02C	+10.23	TECTEH			21H00050	600UL
6919	130	93							TECTEH			21H00049	600UL
6920	132	93	0.51	70	INR	6	F02	+15.38	TECTEH			21H00047	600UL
6921			0.81	79	NQH	3	F11	+6.43	TECTEH			21H00047	600UL
6922					INF		F12	+12.11	TECTEH	HR		21H00047	600UL
6923			0.63	76	INR	6	04C	+34.80	TECTEH			21H00047	600UL
6924			0.64	77	INR	6	04C	+36.46	TECTEH			21H00047	600UL
6925			0.40	74	INR	6	03C	+11.83	TECTEH			21H00047	600UL
6926			1.01	81	INR	6	01C	+3.85	TECTEH			21H00047	600UL
6927	134	93							TECTEH			21H00047	600UL
6928	136	93	0.45	81	INR	6	F12	+12.03	TECTEH			21H00048	600UL
6929					INF		07C	+10.29	TECTEH	HR		21H00048	600UL
6930			0.47	65	INR	6	05C	+35.82	TECTEH			21H00048	600UL
6931			0.36	79	INR	6	04C	+21.38	TECTEH			21H00048	600UL
6932	138	93	0.47	70	INR	6	02C	+13.05	TECTEH			21H00047	600UL
6933			0.45	80	INR	6	01C	+29.85	TECTEH			21H00047	600UL
6934	140	93							TECTEH			21H00048	600UL
6935	33	94							TECTEH			21H00004	600UL
6936	35	94							TECTEH			21H00003	600UL
6937	37	94							TECTEH			21H00004	600UL
6938	39	94							TECTEH			21H00003	600UL
6939	41	94							TECTEH			21H00004	600UL
6940	43	94							TECTEH			21H00003	600UL
6941	45	94							TECTEH			21H00004	600UL
6942	47	94							TECTEH			21H00003	600UL
6943	49	94							TECTEH			21H00004	600UL
6944	51	94							TECTEH			21H00003	600UL
6945	53	94							TECTEH			21H00004	600UL
6946	55	94							TECTEH			21H00003	600UL
6947	57	94							TECTEH			21H00004	600UL
6948	59	94							TECTEH			21H00003	600UL
6949	61	94	1.07	159	INR	3	F07	+2.45	TECTEH			21H00004	600UL
6950					INF		F08	+12.99	TECTEH	HR		21H00004	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
6951	63	94							TECTEH			21H00003	600UL
6952	65	94			INF		F07	+4.99	TECTEH	HR		21H00004	600UL
6953	67	94	0.93	64	INR	6	06H	+38.26	TECTEH			21H00003	600UL
6954	69	94			INF		F08	+7.32	TECTEH	HR		21H00004	600UL
6955			0.41	113	INR	3	01C	+12.73	TECTEH			21H00004	600UL
6956	71	94							TECTEH			21H00003	600UL
6957	73	94							TECTEH			21H00004	600UL
6958	75	94	0.38	81	INR	6	TSH	+5.00	TECTEH			21H00003	600UL
6959	77	94							TECTEH			21H00004	600UL
6960	79	94	0.50	106	INR	6	05C	+39.09	TECTEH			21H00003	600UL
6961	81	94							TECTEH			21H00003	600UL
6962	83	94							TECTEH			21H00053	600UL
6963	85	94							TECTEH			21H00052	600UL
6964	87	94							TECTEH			21H00053	600UL
6965	89	94							TECTEH			21H00052	600UL
6966	91	94							TECTEH			21H00053	600UL
6967	93	94							TECTEH			21H00052	600UL
6968	95	94							TECTEH			21H00053	600UL
6969	97	94							TECTEH			21H00052	600UL
6970	99	94							TECTEH			21H00053	600UL
6971	101	94							TECTEH			21H00052	600UL
6972	103	94							TECTEH			21H00053	600UL
6973	105	94							TECTEH			21H00052	600UL
6974	107	94							TECTEH			21H00053	600UL
6975	109	94	0.23	65	INR	6	F02	+3.20	TECTEH			21H00052	600UL
6976			0.47	60	INR	6	F07	+6.62	TECTEH			21H00052	600UL
6977					INF		F08	+10.73	TECTEH	HR		21H00052	600UL
6978	111	94	0.14	213	INR	6	F06	+0.00	TECTEH			21H00053	600UL
6979			0.59	77	INR	6	06C	+33.43	TECTEH			21H00053	600UL
6980			0.40	75	INR	6	04C	+16.03	TECTEH			21H00053	600UL
6981			0.67	80	INR	6	03C	+23.55	TECTEH			21H00053	600UL
6982	113	94	0.43	122	INR	3	03C	+9.43	TECTEH			21H00052	600UL
6983			0.74	84	INR	6	01C	+30.09	TECTEH			21H00052	600UL
6984	115	94	0.34	81	INR	6	04H	+23.54	TECTEH			21H00053	600UL
6985	117	94	0.36	74	INR	6	02H	+8.00	TECTEH			21H00052	600UL
6986			0.46	60	INR	6	06H	+23.58	TECTEH			21H00052	600UL
6987	119	94							TECTEH			21H00053	600UL
6988	121	94	0.41	85	INR	6	01H	+12.72	TECTEH			21H00052	600UL
6989			0.48	84	INR	6	01H	+24.92	TECTEH			21H00052	600UL
6990			0.44	91	INR	6	01H	+26.62	TECTEH			21H00052	600UL
6991			0.45	73	INR	6	F05	+12.66	TECTEH			21H00052	600UL
6992			0.76	83	INR	6	F12	+2.42	TECTEH			21H00052	600UL
6993			3.49	185	DNT	P1	07C	+1.55	TECTEH			21H00052	600UL
6994					INF		07C	+18.08	TECTEH	HR		21H00052	600UL
6995			0.62	102	INR	6	TSC	+19.23	TECTEH			21H00052	600UL
6996	123	94	1.23	25	INR	6	F09	+16.44	TECTEH			21H00053	600UL
6997					INF		F10	+1.96	TECTEH	HR		21H00053	600UL
6998	125	94							TECTEH			21H00052	600UL
6999	127	94	0.55	83	INR	6	TSH	+4.70	TECTEH			21H00053	600UL
7000	129	94							TECTEH			21H00052	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7001	131	94							TECTEH			21H00052	600UL
7002	133	94	0.41	68	INR	6	F07	+5.22	TECTEH			21H00047	600UL
7003					INF		F08	+14.23	TECTEH	HR		21H00047	600UL
7004			0.40	101	NQH	3	05C	+31.04	TECTEH			21H00047	600UL
7005			0.40	80	INR	6	05C	+38.49	TECTEH			21H00047	600UL
7006			0.43	75	INR	6	03C	+3.70	TECTEH			21H00047	600UL
7007	135	94							TECTEH			21H00048	600UL
7008	137	94	0.40	64	INR	6	F03	+4.77	TECTEH			21H00047	600UL
7009			0.37	64	INR	6	F06	+3.02	TECTEH			21H00047	600UL
7010	139	94	0.49	72	INR	6	06C	+28.91	TECTEH			21H00048	600UL
7011	32	95							TECTEH			21H00004	600UL
7012	34	95							TECTEH			21H00004	600UL
7013	36	95							TECTEH			21H00003	600UL
7014	38	95							TECTEH			21H00004	600UL
7015	40	95							TECTEH			21H00003	600UL
7016	42	95							TECTEH			21H00004	600UL
7017	44	95							TECTEH			21H00003	600UL
7018	46	95							TECTEH			21H00004	600UL
7019	48	95							TECTEH			21H00003	600UL
7020	50	95							TECTEH			21H00004	600UL
7021	52	95							TECTEH			21H00003	600UL
7022	54	95	0.38	144	INR	3	02C	+17.04	TECTEH			21H00004	600UL
7023	56	95	0.67	87	INR	6	F06	+10.33	TECTEH			21H00003	600UL
7024					INF		F07	+4.92	TECTEH	HR		21H00003	600UL
7025			0.45	65	INR	6	TSC	+4.65	TECTEH			21H00003	600UL
7026	58	95							TECTEH			21H00004	600UL
7027	60	95							TECTEH			21H00003	600UL
7028	62	95	0.37	118	INR	3	F06	+8.21	TECTEH			21H00004	600UL
7029			0.28	98	INR	3	05C	+39.22	TECTEH			21H00004	600UL
7030			0.28	110	INR	3	02C	+33.79	TECTEH			21H00004	600UL
7031	64	95	0.51	122	INR	3	03C	+30.37	TECTEH			21H00003	600UL
7032	66	95							TECTEH			21H00004	600UL
7033	68	95	0.54	56	INR	6	F03	+5.27	TECTEH			21H00003	600UL
7034			0.73	84	INR	6	03C	+22.31	TECTEH			21H00003	600UL
7035	70	95	0.46	119	INR	3	06C	+12.98	TECTEH			21H00004	600UL
7036			0.24	163	INR	3	06C	+29.81	TECTEH			21H00004	600UL
7037	72	95							TECTEH			21H00003	600UL
7038	74	95							TECTEH			21H00004	600UL
7039	76	95							TECTEH			21H00003	600UL
7040	78	95							TECTEH			21H00004	600UL
7041	80	95			RRT				TSCTEH			21H00003	600UL
7042			0.41	60	INR	6	F10	+7.58	TECTEH			21H00045	600UL
7043					INF		F12	+2.80	TECTEH	HR		21H00045	600UL
7044	82	95							TECTEH			21H00053	600UL
7045	84	95							TECTEH			21H00053	600UL
7046	86	95							TECTEH			21H00052	600UL
7047	88	95							TECTEH			21H00053	600UL
7048	90	95							TECTEH			21H00052	600UL
7049	92	95	0.61	82	INR	6	02C	+22.22	TECTEH			21H00053	600UL
7050	94	95	0.39	81	INR	6	05H	+20.18	TECTEH			21H00052	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7051			1.33	73	INR	6	F07	+11.01	TECTEH			21H00052	600UL
7052					INF		F08	+5.52	TECTEH	HR		21H00052	600UL
7053			0.69	103	INR	6	F08	+7.86	TECTEH			21H00052	600UL
7054					INF		F08	+11.33	TECTEH	HR		21H00052	600UL
7055					INF		F09	+7.05	TECTEH	HR		21H00052	600UL
7056					INF		F09	+8.42	TECTEH	HR		21H00052	600UL
7057			0.81	76	INR	6	TSC	+19.75	TECTEH			21H00052	600UL
7058	96	95	0.65	75	INR	6	03C	+28.17	TECTEH			21H00053	600UL
7059	98	95							TECTEH			21H00052	600UL
7060	100	95	0.86	76	INR	6	TSH	+2.67	TECTEH			21H00053	600UL
7061			0.45	82	INR	6	04H	+7.58	TECTEH			21H00053	600UL
7062			0.64	84	INR	6	05H	+9.94	TECTEH			21H00053	600UL
7063			0.62	79	INR	6	F03	+2.57	TECTEH			21H00053	600UL
7064			0.34	64	INR	6	F06	+11.80	TECTEH			21H00053	600UL
7065					INF		F07	+5.71	TECTEH	HR		21H00053	600UL
7066	102	95							TECTEH			21H00052	600UL
7067	104	95	0.42	58	INR	6	02C	+3.33	TECTEH			21H00053	600UL
7068			0.53	77	INR	6	01C	+28.29	TECTEH			21H00053	600UL
7069			0.45	72	INR	6	TSC	+7.97	TECTEH			21H00053	600UL
7070	106	95	1.24	40	INR	6	F10	+0.28	TECTEH			21H00052	600UL
7071			0.41	77	INR	6	05C	+3.14	TECTEH			21H00052	600UL
7072			0.50	78	INR	6	03C	+27.72	TECTEH			21H00052	600UL
7073	108	95	0.75	75	INR	6	05C	+11.67	TECTEH			21H00053	600UL
7074			0.90	76	INR	6	01C	+24.48	TECTEH			21H00053	600UL
7075	110	95	1.09	80	INR	6	TSH	+21.57	TECTEH			21H00052	600UL
7076	112	95							TECTEH			21H00053	600UL
7077	114	95							TECTEH			21H00052	600UL
7078	116	95							TECTEH			21H00053	600UL
7079	118	95							TECTEH			21H00052	600UL
7080	120	95	0.51	70	INR	6	03H	+37.01	TECTEH			21H00053	600UL
7081			0.49	77	INR	6	05C	+11.50	TECTEH			21H00053	600UL
7082	122	95			INF		F01	+1.51	TECTEH	HR		21H00052	600UL
7083					INF		F01	+2.67	TECTEH	HR		21H00052	600UL
7084			0.85	54	INR	6	F01	+3.77	TECTEH			21H00052	600UL
7085	124	95							TECTEH			21H00053	600UL
7086	126	95	0.39	67	INR	6	06H	+3.17	TECTEH			21H00052	600UL
7087	128	95	0.58	54	INR	6	F07	+10.08	TECTEH			21H00053	600UL
7088					INF		F08	+9.67	TECTEH	HR		21H00053	600UL
7089	130	95							TECTEH			21H00052	600UL
7090	132	95	0.62	85	INR	6	06H	+5.09	TECTEH			21H00047	600UL
7091			0.57	73	INR	6	06H	+9.10	TECTEH			21H00047	600UL
7092			1.28	79	INR	6	07H	+16.46	TECTEH			21H00047	600UL
7093			0.42	80	INR	6	03C	+36.12	TECTEH			21H00047	600UL
7094	134	95							TECTEH			21H00048	600UL
7095	136	95							TECTEH			21H00047	600UL
7096	138	95							TECTEH			21H00048	600UL
7097	31	96							TECTEH			21H00004	600UL
7098	33	96							TECTEH			21H00003	600UL
7099	35	96							TECTEH			21H00004	600UL
7100	37	96							TECTEH			21H00003	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7101	39	96	0.33	146	INR	3	02C	+29.20	TECTEH			21H00004	600UL
7102	41	96							TECTEH			21H00003	600UL
7103	43	96			INF		F05	+0.00	TECTEH	HR		21H00004	600UL
7104	45	96							TECTEH			21H00003	600UL
7105	47	96							TECTEH			21H00004	600UL
7106	49	96							TECTEH			21H00003	600UL
7107	51	96							TECTEH			21H00004	600UL
7108	53	96							TECTEH			21H00003	600UL
7109	55	96							TECTEH			21H00004	600UL
7110	57	96	0.45	67	INR	6	TSH	+20.93	TECTEH			21H00003	600UL
7111			0.56	73	INR	6	05C	+4.60	TECTEH			21H00003	600UL
7112	59	96	0.31	128	INR	3	04H	+32.84	TECTEH			21H00004	600UL
7113	61	96	0.59	75	INR	6	TSH	+9.27	TECTEH			21H00003	600UL
7114	63	96	0.40	140	INR	3	TSH	+8.47	TECTEH			21H00004	600UL
7115	65	96							TECTEH			21H00003	600UL
7116	67	96							TECTEH			21H00004	600UL
7117	69	96							TECTEH			21H00003	600UL
7118	71	96	0.81	123	INR	3	F09	+8.55	TECTEH			21H00004	600UL
7119			0.55	71	INR	6	F10	+0.00	TECTEH			21H00004	600UL
7120					INF		F10	+5.12	TECTEH	HR		21H00004	600UL
7121	73	96							TECTEH			21H00003	600UL
7122	75	96							TECTEH			21H00004	600UL
7123	77	96							TECTEH			21H00003	600UL
7124	79	96							TECTEH			21H00004	600UL
7125	81	96							TECTEH			21H00003	600UL
7126	83	96							TECTEH			21H00053	600UL
7127	85	96							TECTEH			21H00052	600UL
7128	87	96							TECTEH			21H00053	600UL
7129	89	96							TECTEH			21H00052	600UL
7130	91	96							TECTEH			21H00053	600UL
7131	93	96	0.52	57	INR	6	04H	+39.41	TECTEH			21H00052	600UL
7132	95	96	0.58	93	INR	6	01C	+8.94	TECTEH			21H00053	600UL
7133	97	96	0.35	62	INR	6	07H	+5.85	TECTEH			21H00052	600UL
7134	99	96	0.46	85	INR	6	02H	+33.70	TECTEH			21H00053	600UL
7135			0.81	71	INR	6	03H	+28.74	TECTEH			21H00053	600UL
7136	101	96							TECTEH			21H00052	600UL
7137	103	96	1.03	76	INR	6	03H	+29.04	TECTEH			21H00053	600UL
7138			0.45	80	INR	6	TSC	+19.56	TECTEH			21H00053	600UL
7139	105	96							TECTEH			21H00052	600UL
7140	107	96	0.54	74	INR	6	07H	+10.60	TECTEH			21H00053	600UL
7141	109	96	0.76	84	INR	6	01H	+29.06	TECTEH			21H00052	600UL
7142	111	96							TECTEH			21H00053	600UL
7143	113	96							TECTEH			21H00052	600UL
7144	115	96							TECTEH			21H00053	600UL
7145	117	96							TECTEH			21H00052	600UL
7146	119	96							TECTEH			21H00053	600UL
7147	121	96	0.43	88	INR	6	03C	+11.61	TECTEH			21H00052	600UL
7148	123	96	0.31	80	INR	6	01H	+29.74	TECTEH			21H00053	600UL
7149	125	96	0.44	84	NQH	3	F03	+10.83	TECTEH			21H00052	600UL
7150	127	96	0.49	81	INR	6	05H	+34.72	TECTEH			21H00053	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7151	129	96							TECTEH			21H00052	600UL
7152	131	96	0.57	49	INR	6	F06	+10.31	TECTEH			21H00052	600UL
7153	133	96							TECTEH			21H00047	600UL
7154	135	96							TECTEH			21H00048	600UL
7155	137	96							TECTEH			21H00047	600UL
7156	139	96							TECTEH			21H00048	600UL
7157	30	97							TECTEH			21H00004	600UL
7158	32	97							TECTEH			21H00003	600UL
7159	34	97							TECTEH			21H00004	600UL
7160	36	97							TECTEH			21H00003	600UL
7161	38	97							TECTEH			21H00004	600UL
7162	40	97							TECTEH			21H00003	600UL
7163	42	97	0.36	124	INR	3	02C	+38.09	TECTEH			21H00004	600UL
7164	44	97							TECTEH			21H00003	600UL
7165	46	97							TECTEH			21H00004	600UL
7166	48	97							TECTEH			21H00003	600UL
7167	50	97							TECTEH			21H00004	600UL
7168	52	97							TECTEH			21H00003	600UL
7169	54	97							TECTEH			21H00004	600UL
7170	56	97							TECTEH			21H00003	600UL
7171	58	97							TECTEH			21H00004	600UL
7172	60	97	0.79	82	INR	6	01C	+9.71	TECTEH			21H00003	600UL
7173			0.53	73	INR	6	01C	+15.75	TECTEH			21H00003	600UL
7174	62	97	0.56	32	INR	3	04H	+36.66	TECTEH			21H00004	600UL
7175			0.49	149	INR	3	06H	+11.24	TECTEH			21H00004	600UL
7176			0.42	129	INR	3	06H	+12.30	TECTEH			21H00004	600UL
7177			0.61	66	NQH	3	F03	+9.72	TECTEH			21H00004	600UL
7178			0.32	107	INR	3	06C	+25.94	TECTEH			21H00004	600UL
7179			0.71	69	INR	6	06C	+31.20	TECTEH			21H00004	600UL
7180			0.29	126	INR	3	05C	+36.63	TECTEH			21H00004	600UL
7181			0.48	144	INR	3	01C	+6.55	TECTEH			21H00004	600UL
7182	64	97	0.99	78	INR	6	05C	+15.04	TECTEH			21H00003	600UL
7183	66	97	0.59	151	INR	3	07H	+12.71	TECTEH			21H00004	600UL
7184			0.36	139	INR	3	01C	+30.09	TECTEH			21H00004	600UL
7185	68	97							TECTEH			21H00003	600UL
7186	70	97							TECTEH			21H00004	600UL
7187	72	97							TECTEH			21H00003	600UL
7188	74	97	0.66	134	INR	3	03H	+28.72	TECTEH			21H00004	600UL
7189			0.73	131	INR	3	05H	+10.34	TECTEH			21H00004	600UL
7190			0.66	130	INR	3	02C	+32.72	TECTEH			21H00004	600UL
7191			0.69	69	INR	6	TSC	+16.83	TECTEH			21H00004	600UL
7192			0.50	128	INR	3	TSC	+17.97	TECTEH			21H00004	600UL
7193			0.61	127	INR	3	TSC	+19.77	TECTEH			21H00004	600UL
7194	76	97							TECTEH			21H00003	600UL
7195	78	97							TECTEH			21H00004	600UL
7196	80	97							TECTEH			21H00003	600UL
7197	82	97							TECTEH			21H00055	600UL
7198	84	97							TECTEH			21H00055	600UL
7199	86	97							TECTEH			21H00054	600UL
7200	88	97	0.46	58	INR	6	02H	+18.36	TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7201	90	97	0.55	82	INR	6	01H	+25.82	TECTEH			21H00054	600UL
7202			1.24	82	INR	6	03H	+26.09	TECTEH			21H00054	600UL
7203			0.66	62	INR	6	F03	+11.94	TECTEH			21H00054	600UL
7204			0.45	91	INR	6	01C	+7.10	TECTEH			21H00054	600UL
7205	92	97	1.04	58	INR	6	F03	+6.00	TECTEH			21H00055	600UL
7206			0.54	82	INR	6	F06	+6.10	TECTEH			21H00055	600UL
7207	94	97							TECTEH			21H00054	600UL
7208	96	97	0.54	75	INR	6	03C	+22.36	TECTEH			21H00055	600UL
7209	98	97	0.50	87	INR	6	05H	+8.66	TECTEH			21H00054	600UL
7210			0.38	67	INR	6	F10	+6.30	TECTEH			21H00054	600UL
7211					INF		F11	+6.40	TECTEH	HR		21H00054	600UL
7212					INF		F11	+8.85	TECTEH	HR		21H00054	600UL
7213	100	97			INF		F03	+13.90	TECTEH	HR		21H00053	600UL
7214			0.94	36	INR	6	F04	-0.74	TECTEH			21H00053	600UL
7215			0.67	63	INR	6	F09	+8.10	TECTEH			21H00053	600UL
7216					INF		F10	+8.83	TECTEH	HR		21H00053	600UL
7217			1.04	73	INR	6	03C	+8.62	TECTEH			21H00053	600UL
7218			0.57	83	INR	6	01C	+19.50	TECTEH			21H00053	600UL
7219	102	97							TECTEH			21H00052	600UL
7220	104	97	0.85	86	INR	6	02C	+35.11	TECTEH			21H00053	600UL
7221	106	97	0.42	70	INR	6	03H	+14.87	TECTEH			21H00052	600UL
7222	108	97							TECTEH			21H00053	600UL
7223	110	97	0.52	109	INR	6	F05	+2.27	TECTEH			21H00052	600UL
7224	112	97							TECTEH			21H00053	600UL
7225	114	97							TECTEH			21H00052	600UL
7226	116	97	1.05	62	INR	6	F07	+14.31	TECTEH			21H00053	600UL
7227					INF		F08	+2.00	TECTEH	HR		21H00053	600UL
7228	118	97							TECTEH			21H00052	600UL
7229	120	97							TECTEH			21H00053	600UL
7230	122	97							TECTEH			21H00052	600UL
7231	124	97							TECTEH			21H00053	600UL
7232	126	97	0.83	79	INR	6	04H	+18.95	TECTEH			21H00052	600UL
7233	128	97	0.98	84	INR	6	01C	+22.45	TECTEH			21H00053	600UL
7234	130	97							TECTEH			21H00052	600UL
7235	132	97	0.90	85	INR	6	06H	+26.92	TECTEH			21H00047	600UL
7236	134	97							TECTEH			21H00048	600UL
7237	136	97							TECTEH			21H00047	600UL
7238	138	97							TECTEH			21H00048	600UL
7239	29	98							TECTEH			21H00004	600UL
7240	31	98							TECTEH			21H00003	600UL
7241	33	98							TECTEH			21H00004	600UL
7242	35	98							TECTEH			21H00003	600UL
7243	37	98							TECTEH			21H00004	600UL
7244	39	98							TECTEH			21H00003	600UL
7245	41	98							TECTEH			21H00004	600UL
7246	43	98							TECTEH			21H00003	600UL
7247	45	98							TECTEH			21H00004	600UL
7248	47	98							TECTEH			21H00003	600UL
7249	49	98	0.27	122	INR	3	TSC	+8.45	TECTEH			21H00004	600UL
7250	51	98	0.58	68	INR	6	F07	+6.93	TECTEH			21H00003	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7251					INF		F08	+0.00	TECTEH	HR		21H00003	600UL
7252					INF		F08	+3.99	TECTEH	HR		21H00003	600UL
7253	53	98							TECTEH			21H00004	600UL
7254	55	98							TECTEH			21H00003	600UL
7255	57	98							TECTEH			21H00004	600UL
7256	59	98							TECTEH			21H00003	600UL
7257	61	98							TECTEH			21H00004	600UL
7258	63	98			INF		F02	+2.33	TECTEH	HR		21H00003	600UL
7259			0.14	184	INR	6	F03	+2.33	TECTEH			21H00003	600UL
7260			0.98	138	INR	6	F10	+2.89	TECTEH			21H00003	600UL
7261	65	98	0.42	135	INR	3	02H	+16.40	TECTEH			21H00004	600UL
7262	67	98							TECTEH			21H00003	600UL
7263	69	98							TECTEH			21H00004	600UL
7264	71	98							TECTEH			21H00003	600UL
7265	73	98							TECTEH			21H00004	600UL
7266	75	98							TECTEH			21H00003	600UL
7267	77	98							TECTEH			21H00004	600UL
7268	79	98	0.34	115	INR	3	01H	+32.71	TECTEH			21H00003	600UL
7269			0.48	50	INR	6	04H	-1.88	TECTEH			21H00003	600UL
7270	81	98							TECTEH			21H00003	600UL
7271	83	98							TECTEH			21H00055	600UL
7272	85	98	0.69	80	INR	6	06C	+17.56	TECTEH			21H00054	600UL
7273			0.56	83	INR	6	05C	+36.54	TECTEH			21H00054	600UL
7274	87	98							TECTEH			21H00055	600UL
7275	89	98	0.36	119	INR	3	02H	+30.18	TECTEH			21H00054	600UL
7276	91	98							TECTEH			21H00055	600UL
7277	93	98							TECTEH			21H00054	600UL
7278	95	98	0.43	67	INR	6	05C	+26.49	TECTEH			21H00055	600UL
7279	97	98	0.61	85	INR	6	03H	+22.54	TECTEH			21H00054	600UL
7280	99	98	0.68	73	INR	6	02H	+6.13	TECTEH			21H00055	600UL
7281			0.50	78	INR	6	06C	+7.01	TECTEH			21H00055	600UL
7282			0.35	65	INR	6	05C	+6.55	TECTEH			21H00055	600UL
7283	101	98	0.34	80	INR	6	05C	+15.24	TECTEH			21H00054	600UL
7284	103	98							TECTEH			21H00055	600UL
7285	105	98	0.36	66	INR	3	F09	+6.73	TECTEH			21H00054	600UL
7286					INF		F10	+8.26	TECTEH	HR		21H00054	600UL
7287	107	98							TECTEH			21H00055	600UL
7288	109	98							TECTEH			21H00054	600UL
7289	111	98	0.35	139	INR	3	06C	+14.27	TECTEH			21H00055	600UL
7290	113	98							TECTEH			21H00054	600UL
7291	115	98							TECTEH			21H00055	600UL
7292	117	98							TECTEH			21H00054	600UL
7293	119	98							TECTEH			21H00055	600UL
7294	121	98							TECTEH			21H00054	600UL
7295	123	98							TECTEH			21H00055	600UL
7296	125	98							TECTEH			21H00054	600UL
7297	127	98							TECTEH			21H00055	600UL
7298	129	98							TECTEH			21H00054	600UL
7299	131	98	0.49	72	INR	6	TSH	+19.90	TECTEH			21H00054	600UL
7300			0.61	57	INR	6	F02	+5.25	TECTEH			21H00054	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7301			0.39	104	INR	6	F10	+4.01	TECTEH			21H00054	600UL
7302			1.42	51	INR	6	F11	+0.00	TECTEH			21H00054	600UL
7303			0.54	79	INR	6	F12	+11.35	TECTEH			21H00054	600UL
7304					INF		07C	+10.66	TECTEH	HR		21H00054	600UL
7305			0.59	75	INR	6	05C	+37.68	TECTEH			21H00054	600UL
7306	133	98							TECTEH			21H00047	600UL
7307	135	98							TECTEH			21H00048	600UL
7308	137	98							TECTEH			21H00047	600UL
7309	139	98							TECTEH			21H00048	600UL
7310	28	99							TECTEH			21H00004	600UL
7311	30	99							TECTEH			21H00004	600UL
7312	32	99	4.31	185	INR	3	F01	+6.32	TECTEH			21H00003	600UL
7313					INF		F04	+5.74	TECTEH	HR		21H00003	600UL
7314			2.45	187	INR	1	04C	+33.64	TECTEH			21H00003	600UL
7315	34	99							TECTEH			21H00004	600UL
7316	36	99							TECTEH			21H00003	600UL
7317	38	99							TECTEH			21H00004	600UL
7318	40	99	0.30	103	NQH	3	F05	+8.83	TECTEH			21H00003	600UL
7319	42	99							TECTEH			21H00004	600UL
7320	44	99							TECTEH			21H00003	600UL
7321	46	99							TECTEH			21H00004	600UL
7322	48	99	0.21	79	INR	6	02H	+32.27	TECTEH			21H00003	600UL
7323	50	99							TECTEH			21H00004	600UL
7324	52	99							TECTEH			21H00003	600UL
7325	54	99							TECTEH			21H00004	600UL
7326	56	99							TECTEH			21H00003	600UL
7327	58	99							TECTEH			21H00004	600UL
7328	60	99	0.39	50	INR	6	F05	+5.77	TECTEH			21H00003	600UL
7329			0.78	72	INR	6	02C	+5.60	TECTEH			21H00003	600UL
7330	62	99			INF		06C	+31.42	TECTEH	HR		21H00004	600UL
7331	64	99	0.44	45	INR	3	F03	+3.95	TECTEH			21H00003	600UL
7332	66	99							TECTEH			21H00004	600UL
7333	68	99							TECTEH			21H00003	600UL
7334	70	99							TECTEH			21H00004	600UL
7335	72	99							TECTEH			21H00003	600UL
7336	74	99							TECTEH			21H00004	600UL
7337	76	99	0.47	79	INR	6	02H	+18.08	TECTEH			21H00003	600UL
7338	78	99							TECTEH			21H00004	600UL
7339	80	99							TECTEH			21H00003	600UL
7340	82	99	0.37	58	INR	6	03C	+30.62	TECTEH			21H00054	600UL
7341	84	99							TECTEH			21H00055	600UL
7342	86	99							TECTEH			21H00054	600UL
7343	88	99							TECTEH			21H00055	600UL
7344	90	99	0.46	75	INR	6	04H	+4.59	TECTEH			21H00054	600UL
7345	92	99	0.24	99	INR	3	06H	+32.52	TECTEH			21H00055	600UL
7346			0.40	143	INR	3	02C	+6.12	TECTEH			21H00055	600UL
7347	94	99							TECTEH			21H00054	600UL
7348	96	99	0.31	132	INR	3	03H	+29.14	TECTEH			21H00055	600UL
7349			0.65	261	INR	6	03C	-0.03	TECTEH			21H00055	600UL
7350			0.16	94	INR	3	01C	+30.55	TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7351			0.36	131	INR	3	01C	+31.11	TECTEH			21H00055	600UL
7352	98	99							TECTEH			21H00054	600UL
7353	100	99	0.44	75	INR	6	03H	+17.72	TECTEH			21H00054	600UL
7354			0.50	77	INR	6	05H	+31.30	TECTEH			21H00054	600UL
7355			0.39	80	INR	6	05C	+35.19	TECTEH			21H00054	600UL
7356	102	99	0.51	85	INR	3	F09	+6.55	TECTEH			21H00055	600UL
7357					INF		F10	+9.92	TECTEH	HR		21H00055	600UL
7358			0.75	75	INR	3	F11	-1.16	TECTEH			21H00055	600UL
7359					INF		F11	+1.07	TECTEH	HR		21H00055	600UL
7360	104	99							TECTEH			21H00054	600UL
7361	106	99	0.73	79	INR	6	F03	+10.12	TECTEH			21H00060	600UL
7362	108	99							TECTEH			21H00061	600UL
7363	110	99							TECTEH			21H00054	600UL
7364	112	99							TECTEH			21H00055	600UL
7365	114	99							TECTEH			21H00054	600UL
7366	116	99	0.38	138	INR	3	01H	+30.67	TECTEH			21H00055	600UL
7367	118	99							TECTEH			21H00054	600UL
7368	120	99							TECTEH			21H00055	600UL
7369	122	99							TECTEH			21H00054	600UL
7370	124	99	1.24	148	INR	3	F06	+13.28	TECTEH			21H00055	600UL
7371					INF		F07	+5.53	TECTEH	HR		21H00055	600UL
7372	126	99	0.46	79	INR	6	04H	+3.04	TECTEH			21H00054	600UL
7373	128	99							TECTEH			21H00055	600UL
7374	130	99	0.36	112	INR	3	02H	+4.55	TECTEH			21H00054	600UL
7375			0.47	65	INR	3	F07	+12.26	TECTEH			21H00054	600UL
7376					INF		F08	+7.19	TECTEH	HR		21H00054	600UL
7377			0.52	92	INR	3	F10	+14.80	TECTEH			21H00054	600UL
7378					INF		F11	+4.31	TECTEH	HR		21H00054	600UL
7379			0.65	70	INR	6	02C	+25.90	TECTEH			21H00054	600UL
7380	132	99	0.77	76	INR	6	02H	+19.26	TECTEH			21H00047	600UL
7381			0.27	74	INR	3	06C	+22.88	TECTEH			21H00047	600UL
7382	134	99							TECTEH			21H00048	600UL
7383	136	99							TECTEH			21H00047	600UL
7384	138	99	0.55	89	INR	6	01H	+5.99	TECTEH			21H00048	600UL
7385	27	100							TECTEH			21H00006	600UL
7386	29	100							TECTEH			21H00005	600UL
7387	31	100	0.71	82	INR	6	TSC	+5.09	TECTEH			21H00006	600UL
7388	33	100							TECTEH			21H00005	600UL
7389	35	100							TECTEH			21H00006	600UL
7390	37	100							TECTEH			21H00005	600UL
7391	39	100	0.52	70	INR	6	06C	+31.99	TECTEH			21H00006	600UL
7392	41	100							TECTEH			21H00005	600UL
7393	43	100							TECTEH			21H00006	600UL
7394	45	100							TECTEH			21H00005	600UL
7395	47	100	0.60	66	INR	6	05H	+5.48	TECTEH			21H00006	600UL
7396			0.62	72	INR	6	04C	+17.88	TECTEH			21H00006	600UL
7397	49	100							TECTEH			21H00005	600UL
7398	51	100							TECTEH			21H00006	600UL
7399	53	100							TECTEH			21H00005	600UL
7400	55	100							TECTEH			21H00006	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7401	57	100	0.73	35	INR	6	F04	-0.03	TECTEH			21H00005	600UL
7402			0.71	75	INR	6	04C	+4.02	TECTEH			21H00005	600UL
7403			0.59	72	INR	6	04C	+34.86	TECTEH			21H00005	600UL
7404	59	100	0.81	81	INR	6	F12	+9.07	TECTEH			21H00006	600UL
7405					INF		07C	+1.87	TECTEH	HR		21H00006	600UL
7406	61	100	0.93	82	INR	6	01H	+26.75	TECTEH			21H00005	600UL
7407			0.51	77	INR	6	06H	+18.53	TECTEH			21H00005	600UL
7408			0.72	94	INR	6	03C	+17.92	TECTEH			21H00005	600UL
7409	63	100							TECTEH			21H00006	600UL
7410	65	100	0.39	74	INR	6	05H	+32.16	TECTEH			21H00005	600UL
7411			0.65	86	INR	6	04C	+29.53	TECTEH			21H00005	600UL
7412			1.52	57	INR	6	01C	-0.51	TECTEH			21H00005	600UL
7413			0.68	86	INR	6	01C	+21.72	TECTEH			21H00005	600UL
7414	67	100	1.03		INR	6	F09	+3.31 TO+17.93	TECTEH			21H00006	600UL
7415	69	100	0.49	65	INR	6	05C	+23.23	TECTEH			21H00005	600UL
7416	71	100	0.68	72	INR	6	01H	+3.71	TECTEH			21H00006	600UL
7417			0.79	70	INR	6	04H	+32.83	TECTEH			21H00006	600UL
7418			0.74	68	INR	6	06H	+5.03	TECTEH			21H00006	600UL
7419			0.46	75	INR	6	06H	+6.61	TECTEH			21H00006	600UL
7420			0.83	67	INR	6	02C	+19.01	TECTEH			21H00006	600UL
7421			0.74	68	INR	6	01C	+8.74	TECTEH			21H00006	600UL
7422	73	100	0.76	86	INR	6	06C	+10.98	TECTEH			21H00005	600UL
7423			0.67	83	INR	6	01C	+2.87	TECTEH			21H00005	600UL
7424	75	100							TECTEH			21H00006	600UL
7425	77	100							TECTEH			21H00005	600UL
7426	79	100							TECTEH			21H00006	600UL
7427	81	100							TECTEH			21H00005	600UL
7428	83	100							TECTEH			21H00055	600UL
7429	85	100							TECTEH			21H00054	600UL
7430	87	100							TECTEH			21H00055	600UL
7431	89	100							TECTEH			21H00054	600UL
7432	91	100	0.40	118	INR	3	TSC	+9.10	TECTEH			21H00055	600UL
7433	93	100							TECTEH			21H00054	600UL
7434	95	100							TECTEH			21H00055	600UL
7435	97	100							TECTEH			21H00054	600UL
7436	99	100							TECTEH			21H00055	600UL
7437	101	100	0.49	83	INR	6	F12	+0.08	TECTEH			21H00054	600UL
7438			0.47	80	INR	6	03C	+15.25	TECTEH			21H00054	600UL
7439	103	100	0.37	122	INR	3	F08	+7.75	TECTEH			21H00055	600UL
7440			0.62	161	INR	3	F08	+10.90	TECTEH			21H00055	600UL
7441					INF		F09	+3.83	TECTEH	HR		21H00055	600UL
7442					INF		F09	+7.00	TECTEH	HR		21H00055	600UL
7443	105	100	0.36	77	INR	6	TSH	+6.28	TECTEH			21H00054	600UL
7444			0.29	73	INR	6	F06	+4.66	TECTEH			21H00054	600UL
7445	107	100							TECTEH			21H00055	600UL
7446	109	100	0.47	89	INR	6	03C	+22.76	TECTEH			21H00054	600UL
7447	111	100	0.40	151	INR	3	F09	+9.85	TECTEH			21H00055	600UL
7448			0.47	134	INR	3	06C	+21.24	TECTEH			21H00055	600UL
7449			0.22	148	INR	3	06C	+27.25	TECTEH			21H00055	600UL
7450			0.21	130	INR	3	04C	+28.24	TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7451			0.36	131	INR	3	03C	+19.14	TECTEH			21H00055	600UL
7452	113	100							TECTEH			21H00054	600UL
7453	115	100	0.25	92	INR	3	04H	+20.38	TECTEH			21H00055	600UL
7454			0.45	140	INR	3	06C	+8.42	TECTEH			21H00055	600UL
7455			0.29	83	INR	3	02C	+8.42	TECTEH			21H00055	600UL
7456	117	100							TECTEH			21H00054	600UL
7457	119	100	0.36	131	INR	3	F08	+9.22	TECTEH			21H00055	600UL
7458					INF		F09	+6.41	TECTEH	HR		21H00055	600UL
7459	121	100							TECTEH			21H00054	600UL
7460	123	100							TECTEH			21H00055	600UL
7461	125	100	0.44	95	INR	6	06C	+8.05	TECTEH			21H00054	600UL
7462			0.55	85	INR	6	03C	+17.93	TECTEH			21H00054	600UL
7463			0.44	79	INR	6	TSC	+8.31	TECTEH			21H00054	600UL
7464	127	100							TECTEH			21H00055	600UL
7465	129	100							TECTEH			21H00054	600UL
7466	131	100							TECTEH			21H00054	600UL
7467	133	100							TECTEH			21H00047	600UL
7468	135	100	0.68	72	INR	6	02H	+36.92	TECTEH			21H00048	600UL
7469	137	100	0.38	69	INR	6	07H	+13.28	TECTEH			21H00048	600UL
7470	24	101							TECTEH			21H00080	600UL
7471	26	101							TECTEH			21H00006	600UL
7472	28	101							TECTEH			21H00005	600UL
7473	30	101							TECTEH			21H00006	600UL
7474	32	101							TECTEH			21H00005	600UL
7475	34	101	0.81	173	INR	6	F01	+6.36	TECTEH			21H00006	600UL
7476					INF		F04	+4.20	TECTEH	HR		21H00006	600UL
7477			0.58	69	INR	6	04C	+30.61	TECTEH			21H00006	600UL
7478	36	101							TECTEH			21H00005	600UL
7479	38	101							TECTEH			21H00006	600UL
7480	40	101							TECTEH			21H00005	600UL
7481	42	101							TECTEH			21H00006	600UL
7482	44	101	0.52	71	INR	6	05H	+11.06	TECTEH			21H00005	600UL
7483	46	101							TECTEH			21H00006	600UL
7484	48	101	0.45	84	INR	6	03C	+33.35	TECTEH			21H00005	600UL
7485	50	101							TECTEH			21H00006	600UL
7486	52	101							TECTEH			21H00005	600UL
7487	54	101							TECTEH			21H00006	600UL
7488	56	101							TECTEH			21H00005	600UL
7489	58	101	0.43	80	INR	6	03C	+27.32	TECTEH			21H00006	600UL
7490	60	101							TECTEH			21H00005	600UL
7491	62	101	0.85	82	INR	6	F08	+5.01	TECTEH			21H00006	600UL
7492					INF		F09	+8.96	TECTEH	HR		21H00006	600UL
7493	64	101							TECTEH			21H00005	600UL
7494	66	101	0.52	73	INR	6	04H	+27.99	TECTEH			21H00006	600UL
7495			0.29	85	INR	3	F04	+6.69	TECTEH			21H00006	600UL
7496			0.45	76	INR	6	04C	+13.94	TECTEH			21H00006	600UL
7497			0.73	85	INR	6	01C	+11.85	TECTEH			21H00006	600UL
7498	68	101							TECTEH			21H00005	600UL
7499	70	101	0.56	63	INR	6	05H	+12.81	TECTEH			21H00006	600UL
7500	72	101							TECTEH			21H00005	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7501	74	101	0.52	73	INR	6	05H	+18.10	TECTEH			21H00006	600UL
7502	76	101							TECTEH			21H00005	600UL
7503	78	101	0.98	74	INR	6	02H	+9.62	TECTEH			21H00006	600UL
7504					INF		03C	+23.17	TECTEH	HR		21H00006	600UL
7505			0.83	76	INR	6	03C	+30.99	TECTEH			21H00006	600UL
7506	80	101							TECTEH			21H00005	600UL
7507	82	101							TECTEH			21H00054	600UL
7508	84	101	0.48	47	INR	6	F03	+0.00	TECTEH			21H00055	600UL
7509					INF		05C	+26.57	TECTEH	HR		21H00055	600UL
7510			0.41	142	INR	3	05C	+30.87	TECTEH			21H00055	600UL
7511	86	101	0.51	73	INR	6	TSC	+13.74	TECTEH			21H00054	600UL
7512	88	101							TECTEH			21H00055	600UL
7513	90	101	0.57	66	INR	6	07H	+5.62	TECTEH			21H00054	600UL
7514			0.44	91	NQH	3	F03	+10.51	TECTEH			21H00054	600UL
7515			0.49	106	INR	6	F05	+2.00	TECTEH			21H00054	600UL
7516			0.72	117	INR	6	F09	-0.65	TECTEH			21H00054	600UL
7517			0.36	80	INR	6	03C	+29.14	TECTEH			21H00054	600UL
7518	92	101							TECTEH			21H00055	600UL
7519	94	101	0.38	95	INR	6	F04	+9.22	TECTEH			21H00054	600UL
7520	96	101	0.41	119	INR	3	02C	+12.49	TECTEH			21H00055	600UL
7521	98	101	0.33	66	INR	6	F09	+12.19	TECTEH			21H00054	600UL
7522					INF		F10	+2.22	TECTEH	HR		21H00054	600UL
7523	100	101							TECTEH			21H00055	600UL
7524	102	101							TECTEH			21H00054	600UL
7525	104	101	0.58	128	INR	3	04H	+35.35	TECTEH			21H00055	600UL
7526			0.37	131	INR	3	05H	+15.17	TECTEH			21H00055	600UL
7527			0.78	133	INR	3	06C	+18.02	TECTEH			21H00055	600UL
7528					INF		06C	+20.30	TECTEH	HR		21H00055	600UL
7529	106	101	1.03	72	INR	6	F06	+3.20	TECTEH			21H00054	600UL
7530			0.43	75	INR	6	01C	+8.94	TECTEH			21H00054	600UL
7531	108	101	0.37	126	INR	3	TSH	+12.11	TECTEH			21H00055	600UL
7532			0.38	137	INR	3	02H	+2.21	TECTEH			21H00055	600UL
7533	110	101	0.41	73	INR	6	01C	+28.37	TECTEH			21H00054	600UL
7534	112	101							TECTEH			21H00055	600UL
7535	114	101	0.48	78	INR	6	05H	+7.53	TECTEH			21H00054	600UL
7536			0.37	115	INR	6	F05	+13.74	TECTEH			21H00054	600UL
7537	116	101	0.98	83	INR	3	02C	+1.93	TECTEH			21H00055	600UL
7538	118	101							TECTEH			21H00054	600UL
7539	120	101	0.32	144	INR	3	02C	+3.96	TECTEH			21H00055	600UL
7540	122	101	0.27	75	INR	6	07H	+12.34	TECTEH			21H00054	600UL
7541			0.46	35	INR	6	F01	+9.45	TECTEH			21H00054	600UL
7542			0.31	88	INR	6	F09	+14.49	TECTEH			21H00054	600UL
7543					INF		F10	+2.59	TECTEH	HR		21H00054	600UL
7544			0.38	95	INR	6	F11	+7.62	TECTEH			21H00054	600UL
7545					INF		F12	+6.36	TECTEH	HR		21H00054	600UL
7546			0.32	68	INR	6	04C	+4.73	TECTEH			21H00054	600UL
7547			0.43	76	INR	6	TSC	+3.56	TECTEH			21H00054	600UL
7548	124	101	0.63	118	INR	3	F12	+2.71	TECTEH			21H00055	600UL
7549					INF		07C	+16.38	TECTEH	HR		21H00055	600UL
7550			0.42	127	INR	3	06C	+3.02	TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7551	126	101							TECTEH			21H00054	600UL
7552	128	101							TECTEH			21H00055	600UL
7553	130	101	0.63	73	INR	6	06C	+8.00	TECTEH			21H00054	600UL
7554			0.22	66	INR	6	06C	+8.83	TECTEH			21H00054	600UL
7555			0.59	80	INR	6	05C	+34.04	TECTEH			21H00054	600UL
7556			0.69	76	INR	6	05C	+35.51	TECTEH			21H00054	600UL
7557	132	101	0.34	115	INR	3	F01	+15.95	TECTEH			21H00047	600UL
7558			0.44	58	INR	6	06C	+26.45	TECTEH			21H00047	600UL
7559			0.67	95	INR	6	04C	+12.59	TECTEH			21H00047	600UL
7560	134	101							TECTEH			21H00048	600UL
7561	136	101							TECTEH			21H00047	600UL
7562	138	101	2.48	13	INR	1	F12	+7.60	TECTEH			21H00048	600UL
7563	23	102							TECTEH			21H00080	600UL
7564	25	102							TECTEH			21H00045	600UL
7565	27	102	0.60	56	INR	6	06H	+5.10	TECTEH			21H00006	600UL
7566	29	102							TECTEH			21H00005	600UL
7567	31	102							TECTEH			21H00006	600UL
7568	33	102							TECTEH			21H00005	600UL
7569	35	102							TECTEH			21H00006	600UL
7570	37	102							TECTEH			21H00005	600UL
7571	39	102	0.66	72	INR	6	01C	+23.05	TECTEH			21H00006	600UL
7572	41	102							TECTEH			21H00005	600UL
7573	43	102							TECTEH			21H00006	600UL
7574	45	102							TECTEH			21H00005	600UL
7575	47	102							TECTEH			21H00006	600UL
7576	49	102							TECTEH			21H00005	600UL
7577	51	102							TECTEH			21H00006	600UL
7578	53	102							TECTEH			21H00005	600UL
7579	55	102							TECTEH			21H00006	600UL
7580	57	102							TECTEH			21H00005	600UL
7581	59	102							TECTEH			21H00006	600UL
7582	61	102							TECTEH			21H00005	600UL
7583	63	102			INF		07C	-2.04	TECTEH	HR		21H00006	600UL
7584					INF		06C	-2.00	TECTEH	HR		21H00006	600UL
7585			0.39	115	INR	6	06C	+39.47	TECTEH			21H00006	600UL
7586	65	102	0.77	72	INR	6	02C	+9.81	TECTEH			21H00005	600UL
7587	67	102							TECTEH			21H00006	600UL
7588	69	102	0.82	89	INR	6	02C	+35.16	TECTEH			21H00005	600UL
7589	71	102							TECTEH			21H00006	600UL
7590	73	102	0.59	82	INR	6	03H	+21.79	TECTEH			21H00005	600UL
7591	75	102							TECTEH			21H00006	600UL
7592	77	102							TECTEH			21H00005	600UL
7593	79	102							TECTEH			21H00006	600UL
7594	81	102							TECTEH			21H00005	600UL
7595	83	102							TECTEH			21H00055	600UL
7596	85	102	0.43	58	INR	6	F03	+5.82	TECTEH			21H00054	600UL
7597	87	102							TECTEH			21H00055	600UL
7598	89	102							TECTEH			21H00054	600UL
7599	91	102	0.46	157	INR	3	02C	+5.42	TECTEH			21H00055	600UL
7600	93	102							TECTEH			21H00054	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7601	95	102							TECTEH			21H00055	600UL
7602	97	102	0.44	79	INR	6	01C	+19.72	TECTEH			21H00054	600UL
7603	99	102							TECTEH			21H00055	600UL
7604	101	102	1.12	44	INR	6	F05	-0.10	TECTEH			21H00054	600UL
7605			0.48	69	INR	6	05C	+23.93	TECTEH			21H00054	600UL
7606	103	102							TECTEH			21H00055	600UL
7607	105	102	0.57	58	INR	6	F01	+6.37	TECTEH			21H00054	600UL
7608	107	102							TECTEH			21H00055	600UL
7609	109	102	0.47	80	INR	6	04C	+36.91	TECTEH			21H00054	600UL
7610	111	102							TECTEH			21H00055	600UL
7611	113	102							TECTEH			21H00054	600UL
7612	115	102	0.60	75	INR	3	F03	+13.89	TECTEH			21H00055	600UL
7613			0.23	112	INR	3	02C	+14.83	TECTEH			21H00055	600UL
7614	117	102							TECTEH			21H00054	600UL
7615	119	102							TECTEH			21H00055	600UL
7616	121	102	1.28	38	INR	6	F09	+0.00	TECTEH			21H00054	600UL
7617	123	102	0.44	127	INR	3	01H	+7.65	TECTEH			21H00055	600UL
7618			0.28	118	INR	3	F10	+6.04	TECTEH			21H00055	600UL
7619			0.66	119	INR	3	F10	+12.50	TECTEH			21H00055	600UL
7620					INF		F11	+3.70	TECTEH	HR		21H00055	600UL
7621					INF		F11	+9.96	TECTEH	HR		21H00055	600UL
7622	125	102	0.53	78	INR	6	04H	+24.44	TECTEH			21H00054	600UL
7623			0.39	78	INR	6	02C	+37.93	TECTEH			21H00054	600UL
7624			1.36	77	INR	6	01C	+13.03	TECTEH			21H00054	600UL
7625	127	102							TECTEH			21H00055	600UL
7626	129	102							TECTEH			21H00054	600UL
7627	131	102	0.38	96	INR	6	F05	+13.54	TECTEH			21H00054	600UL
7628	133	102							TECTEH			21H00047	600UL
7629	135	102							TECTEH			21H00048	600UL
7630	137	102	0.65	66	INR	6	03H	+4.03	TECTEH			21H00048	600UL
7631			0.43	70	INR	6	03C	+18.31	TECTEH			21H00048	600UL
7632	20	103	0.59	69	INR	6	01H	+16.96	TECTEH			21H00081	600UL
7633	22	103							TECTEH			21H00080	600UL
7634	24	103	0.33	67	INR	6	05H	+27.92	TECTEH			21H00080	600UL
7635			0.43	66	INR	6	05H	+37.63	TECTEH			21H00080	600UL
7636			0.63	79	INR	6	TSC	+10.27	TECTEH			21H00080	600UL
7637	26	103							TECTEH			21H00006	600UL
7638	28	103	0.48	57	INR	6	06H	+11.93	TECTEH			21H00005	600UL
7639	30	103							TECTEH			21H00006	600UL
7640	32	103							TECTEH			21H00005	600UL
7641	34	103	0.25		INR	6	02H	+31.36 TO+39.14	TECTEH			21H00006	600UL
7642	36	103							TECTEH			21H00005	600UL
7643	38	103							TECTEH			21H00006	600UL
7644	40	103							TECTEH			21H00005	600UL
7645	42	103	0.53	78	INR	6	TSH	+2.29	TECTEH			21H00006	600UL
7646	44	103							TECTEH			21H00005	600UL
7647	46	103							TECTEH			21H00006	600UL
7648	48	103							TECTEH			21H00005	600UL
7649	50	103							TECTEH			21H00006	600UL
7650	52	103							TECTEH			21H00005	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7651	54	103								TECTEH			21H00006	600UL
7652	56	103								TECTEH			21H00005	600UL
7653	58	103	0.67	73	INR	6	06C	+15.76		TECTEH			21H00006	600UL
7654			0.67	77	INR	6	03C	+22.34		TECTEH			21H00006	600UL
7655	60	103								TECTEH			21H00005	600UL
7656	62	103								TECTEH			21H00006	600UL
7657	64	103	1.70		INR	6	02H	+7.98	TO+15.23	TECTEH			21H00005	600UL
7658			0.49	63	INR	6	06C	+27.07		TECTEH			21H00005	600UL
7659			0.55	77	INR	6	04C	+24.48		TECTEH			21H00005	600UL
7660	66	103								TECTEH			21H00006	600UL
7661	68	103	0.27	123	INR	3	03H	+34.92		TECTEH			21H00005	600UL
7662			0.37	76	INR	6	04H	+17.98		TECTEH			21H00005	600UL
7663	70	103	0.91	62	INR	6	06C	+21.85		TECTEH			21H00006	600UL
7664	72	103	0.51	79	INR	6	TSH	+4.32		TECTEH			21H00005	600UL
7665			0.61	89	INR	6	01C	+28.86		TECTEH			21H00005	600UL
7666	74	103	0.64	70	INR	6	03C	+2.85		TECTEH			21H00006	600UL
7667			0.72	77	INR	6	01C	+5.94		TECTEH			21H00006	600UL
7668	76	103	0.46	77	INR	6	02H	+26.71		TECTEH			21H00005	600UL
7669	78	103								TECTEH			21H00006	600UL
7670	80	103								TECTEH			21H00005	600UL
7671	82	103	0.58	137	INR	6	F01	+0.00		TECTEH			21H00054	600UL
7672	84	103								TECTEH			21H00055	600UL
7673	86	103								TECTEH			21H00054	600UL
7674	88	103								TECTEH			21H00055	600UL
7675	90	103	0.52	94	INR	6	F12	+0.11		TECTEH			21H00054	600UL
7676			0.43	91	INR	6	01C	-0.12		TECTEH			21H00054	600UL
7677	92	103	0.39	129	INR	3	06C	+36.26		TECTEH			21H00055	600UL
7678			0.35	151	INR	3	03C	+24.36		TECTEH			21H00055	600UL
7679			0.51	132	INR	3	TSC	+5.31		TECTEH			21H00055	600UL
7680	94	103								TECTEH			21H00054	600UL
7681	96	103	0.39	128	INR	3	04H	+3.55		TECTEH			21H00055	600UL
7682			0.58	326	INR	6	F09	+0.00		TECTEH			21H00055	600UL
7683			0.43	33	INR	3	F11	+3.85		TECTEH			21H00055	600UL
7684					INF		F12	+4.87		TECTEH	HR		21H00055	600UL
7685	98	103								TECTEH			21H00054	600UL
7686	100	103	0.26	112	INR	3	04H	+35.37		TECTEH			21H00055	600UL
7687	102	103								TECTEH			21H00054	600UL
7688	104	103	0.58	136	INR	3	02H	+15.86		TECTEH			21H00055	600UL
7689	106	103	0.37	80	INR	6	F05	+7.96		TECTEH			21H00054	600UL
7690	108	103								TECTEH			21H00055	600UL
7691	110	103								TECTEH			21H00054	600UL
7692	112	103								TECTEH			21H00055	600UL
7693	114	103								TECTEH			21H00054	600UL
7694	116	103	0.21	106	INR	3	TSH	+10.08		TECTEH			21H00055	600UL
7695	118	103								TECTEH			21H00054	600UL
7696	120	103	0.39	130	INR	3	04H	+4.75		TECTEH			21H00055	600UL
7697	122	103								TECTEH			21H00054	600UL
7698	124	103	0.28	99	INR	3	04H	+7.19		TECTEH			21H00055	600UL
7699	126	103								TECTEH			21H00054	600UL
7700	128	103								TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7701	130	103							TECTEH			21H00054	600UL
7702	132	103	0.52	73	INR	6	F04	+3.41	TECTEH			21H00047	600UL
7703	134	103							TECTEH			21H00047	600UL
7704	136	103	0.39	67	INR	6	04H	+18.35	TECTEH			21H00048	600UL
7705			0.44	77	INR	6	F03	+3.59	TECTEH			21H00048	600UL
7706	17	104							TECTEH			21H00081	600UL
7707	19	104							TECTEH			21H00080	600UL
7708	21	104	6.09	184	INR	1	F01	+6.44	TECTEH			21H00081	600UL
7709					INF		F05	+2.82	TECTEH	HR		21H00081	600UL
7710	23	104							TECTEH			21H00080	600UL
7711	25	104							TECTEH			21H00006	600UL
7712	27	104							TECTEH			21H00005	600UL
7713	29	104							TECTEH			21H00006	600UL
7714	31	104							TECTEH			21H00005	600UL
7715	33	104							TECTEH			21H00006	600UL
7716	35	104							TECTEH			21H00005	600UL
7717	37	104							TECTEH			21H00006	600UL
7718	39	104							TECTEH			21H00005	600UL
7719	41	104	0.87	73	INR	6	01C	+4.22	TECTEH			21H00006	600UL
7720	43	104							TECTEH			21H00005	600UL
7721	45	104							TECTEH			21H00006	600UL
7722	47	104	0.51	63	INR	6	05H	+29.27	TECTEH			21H00005	600UL
7723	49	104	0.90		INR	6	01H	+18.44 TO+30.92	TECTEH			21H00006	600UL
7724	51	104							TECTEH			21H00005	600UL
7725	53	104							TECTEH			21H00006	600UL
7726	55	104							TECTEH			21H00005	600UL
7727	57	104							TECTEH			21H00006	600UL
7728	59	104							TECTEH			21H00005	600UL
7729	61	104	0.52	77	INR	6	05C	+5.51	TECTEH			21H00006	600UL
7730			1.16	76	INR	6	01C	+15.76	TECTEH			21H00006	600UL
7731	63	104	0.49	57	INR	6	06H	+19.07	TECTEH			21H00005	600UL
7732			0.71	84	INR	6	03C	+7.74	TECTEH			21H00005	600UL
7733	65	104	0.89	66	INR	6	05H	+3.75	TECTEH			21H00006	600UL
7734			0.69	65	INR	6	01C	+20.33	TECTEH			21H00006	600UL
7735	67	104	0.48	75	INR	6	01C	+21.69	TECTEH			21H00005	600UL
7736	69	104							TECTEH			21H00006	600UL
7737	71	104			INF		F02	+2.49	TECTEH	HR		21H00005	600UL
7738			0.22	149	INR	3	F03	+10.42	TECTEH			21H00005	600UL
7739	73	104			INF		F09	+2.71	TECTEH	HR		21H00006	600UL
7740					INF		F10	+9.00	TECTEH	HR		21H00006	600UL
7741			0.56	65	INR	6	02C	+20.29	TECTEH			21H00006	600UL
7742	75	104							TECTEH			21H00005	600UL
7743	77	104							TECTEH			21H00006	600UL
7744	79	104							TECTEH			21H00005	600UL
7745	81	104							TECTEH			21H00005	600UL
7746	83	104							TECTEH			21H00055	600UL
7747	85	104							TECTEH			21H00054	600UL
7748	87	104							TECTEH			21H00055	600UL
7749	89	104							TECTEH			21H00054	600UL
7750	91	104	0.33	132	INR	3	04H	+25.24	TECTEH			21H00055	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7751			0.30	129	INR	3	01C	+31.33		TECTEH			21H00055	600UL
7752	93	104	0.65	93	INR	6	F07	+5.06		TECTEH			21H00054	600UL
7753					INF		F08	+9.44		TECTEH	HR		21H00054	600UL
7754	95	104			INF		F12	+14.57		TECTEH	HR		21H00055	600UL
7755			4.40	182	DNT	P1	07C	+1.45		TECTEH			21H00055	600UL
7756	97	104	0.43	73	INR	6	F12	+6.78		TECTEH			21H00054	600UL
7757					INF		07C	+9.12		TECTEH	HR		21H00054	600UL
7758	99	104								TECTEH			21H00055	600UL
7759	101	104								TECTEH			21H00054	600UL
7760	103	104								TECTEH			21H00055	600UL
7761	105	104	0.76	80	INR	6	TSH	+10.56		TECTEH			21H00054	600UL
7762	107	104	0.58	127	INR	3	06C	+5.83		TECTEH			21H00055	600UL
7763	109	104								TECTEH			21H00054	600UL
7764	111	104								TECTEH			21H00055	600UL
7765	113	104	0.42	93	INR	6	F11	+6.20		TECTEH			21H00054	600UL
7766					INF		F12	+4.95		TECTEH	HR		21H00054	600UL
7767			0.49	75	INR	6	06C	+19.12		TECTEH			21H00054	600UL
7768			0.67	80	INR	6	04C	+30.59		TECTEH			21H00054	600UL
7769					INF		04C	+35.28		TECTEH	HR		21H00054	600UL
7770			0.46	77	INR	6	03C	+6.25		TECTEH			21H00054	600UL
7771	115	104								TECTEH			21H00055	600UL
7772	117	104								TECTEH			21H00054	600UL
7773	119	104								TECTEH			21H00055	600UL
7774	121	104								TECTEH			21H00054	600UL
7775	123	104	0.32	130	INR	3	04H	+15.12		TECTEH			21H00055	600UL
7776			0.48	134	INR	3	05C	+13.08		TECTEH			21H00055	600UL
7777	125	104								TECTEH			21H00054	600UL
7778	127	104								TECTEH			21H00055	600UL
7779	129	104	1.06		INR	6	TSH	+0.51	TO+21.53	TECTEH			21H00054	600UL
7780	131	104	0.44	77	INR	6	02H	+9.00		TECTEH			21H00054	600UL
7781			0.43	75	INR	6	05H	+34.00		TECTEH			21H00054	600UL
7782	133	104								TECTEH			21H00047	600UL
7783	135	104								TECTEH			21H00048	600UL
7784	137	104								TECTEH			21H00048	600UL
7785	14	105								TECTEH			21H00082	600UL
7786	16	105								TECTEH			21H00081	600UL
7787	18	105								TECTEH			21H00080	600UL
7788	20	105								TECTEH			21H00081	600UL
7789	22	105								TECTEH			21H00080	600UL
7790	24	105								TECTEH			21H00080	600UL
7791	26	105								TECTEH			21H00006	600UL
7792	28	105								TECTEH			21H00005	600UL
7793	30	105								TECTEH			21H00006	600UL
7794	32	105								TECTEH			21H00005	600UL
7795	34	105								TECTEH			21H00006	600UL
7796	36	105								TECTEH			21H00005	600UL
7797	38	105								TECTEH			21H00006	600UL
7798	40	105								TECTEH			21H00005	600UL
7799	42	105								TECTEH			21H00006	600UL
7800	44	105	1.48	48	INR	6	01C	-0.05		TECTEH			21H00005	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7801	46	105							TECTEH			21H00006	600UL
7802	48	105	0.50	80	INR	6	01H	+30.87	TECTEH			21H00005	600UL
7803			0.74	79	INR	6	02H	+38.45	TECTEH			21H00005	600UL
7804	50	105							TECTEH			21H00006	600UL
7805	52	105							TECTEH			21H00005	600UL
7806	54	105							TECTEH			21H00006	600UL
7807	56	105							TECTEH			21H00005	600UL
7808	58	105							TECTEH			21H00006	600UL
7809	60	105							TECTEH			21H00005	600UL
7810	62	105							TECTEH			21H00006	600UL
7811	64	105							TECTEH			21H00005	600UL
7812	66	105							TECTEH			21H00006	600UL
7813	68	105							TECTEH			21H00005	600UL
7814	70	105							TECTEH			21H00006	600UL
7815	72	105							TECTEH			21H00005	600UL
7816	74	105							TECTEH			21H00006	600UL
7817	76	105							TECTEH			21H00005	600UL
7818	78	105							TECTEH			21H00006	600UL
7819	80	105	0.42	101	INR	3	F08	+0.00	TECTEH			21H00005	600UL
7820	82	105	0.29	79	INR	6	TSH	+9.10	TECTEH			21H00056	600UL
7821	84	105	0.68	79	INR	6	02H	+18.79	TECTEH			21H00057	600UL
7822	86	105							TECTEH			21H00056	600UL
7823	88	105							TECTEH			21H00057	600UL
7824	90	105	0.35	78	INR	6	TSH	+17.73	TECTEH			21H00056	600UL
7825	92	105			INF		F03	+4.00	TECTEH	HR		21H00057	600UL
7826			0.58	21	INR	6	F03	+5.25	TECTEH			21H00057	600UL
7827					INF		04C	+28.68	TECTEH	HR		21H00057	600UL
7828			0.54	77	INR	6	04C	+31.05	TECTEH			21H00057	600UL
7829	94	105							TECTEH			21H00056	600UL
7830	96	105	0.44	75	INR	6	01H	+6.67	TECTEH			21H00057	600UL
7831			0.34	92	INR	3	05H	+22.04	TECTEH			21H00057	600UL
7832			1.35	48	INR	6	F07	+14.42	TECTEH			21H00057	600UL
7833					INF		F08	+2.43	TECTEH	HR		21H00057	600UL
7834			1.66	77	INR	6	03C	+10.24	TECTEH			21H00057	600UL
7835					INF		03C	+11.55	TECTEH	HR		21H00057	600UL
7836	98	105							TECTEH			21H00056	600UL
7837	100	105							TECTEH			21H00057	600UL
7838	102	105	0.47	68	INR	6	02H	+9.06	TECTEH			21H00056	600UL
7839			0.44	70	INR	6	03H	+38.37	TECTEH			21H00056	600UL
7840			0.25	103	INR	6	F04	+0.00	TECTEH			21H00056	600UL
7841			0.46	76	INR	6	05C	+4.41	TECTEH			21H00056	600UL
7842			0.36	79	INR	6	05C	+20.38	TECTEH			21H00056	600UL
7843	104	105	0.55	69	INR	6	F04	+5.66	TECTEH			21H00057	600UL
7844	106	105	1.07	80	INR	6	05H	+26.52	TECTEH			21H00056	600UL
7845			0.51	81	INR	6	05H	+28.55	TECTEH			21H00056	600UL
7846	108	105							TECTEH			21H00056	600UL
7847	110	105							TECTEH			21H00056	600UL
7848	112	105	0.34	71	INR	6	04C	+22.81	TECTEH			21H00056	600UL
7849	114	105	0.40	89	INR	6	F01	+3.44	TECTEH			21H00056	600UL
7850	116	105							TECTEH			21H00056	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7851	118	105							TECTEH			21H00056	600UL
7852	120	105							TECTEH			21H00056	600UL
7853	122	105	0.65	63	INR	6	F07	+10.99	TECTEH			21H00056	600UL
7854					INF		F08	+6.78	TECTEH	HR		21H00056	600UL
7855	124	105	0.35	128	INR	3	TSC	+18.53	TECTEH			21H00055	600UL
7856	126	105	0.42	77	INR	6	02H	+9.98	TECTEH			21H00054	600UL
7857			1.05	79	INR	6	02C	+7.16	TECTEH			21H00054	600UL
7858	128	105	0.54	114	INR	3	F05	+12.35	TECTEH			21H00055	600UL
7859			0.50	122	INR	3	F05	+15.59	TECTEH			21H00055	600UL
7860			0.29	136	INR	3	02C	+14.46	TECTEH			21H00055	600UL
7861			0.26	125	INR	3	02C	+22.04	TECTEH			21H00055	600UL
7862	130	105							TECTEH			21H00054	600UL
7863	132	105							TECTEH			21H00047	600UL
7864	134	105							TECTEH			21H00047	600UL
7865	136	105	0.46	45	INR	6	F01	+3.87	TECTEH			21H00048	600UL
7866	11	106							TECTEH			21H00082	600UL
7867	13	106							TECTEH			21H00083	600UL
7868	15	106							TECTEH			21H00082	600UL
7869	17	106							TECTEH			21H00081	600UL
7870	19	106							TECTEH			21H00080	600UL
7871	21	106							TECTEH			21H00081	600UL
7872	23	106	0.34	78	INR	6	04H	+20.69	TECTEH			21H00080	600UL
7873	25	106							TECTEH			21H00006	600UL
7874	27	106							TECTEH			21H00005	600UL
7875	29	106							TECTEH			21H00006	600UL
7876	31	106							TECTEH			21H00005	600UL
7877	33	106							TECTEH			21H00006	600UL
7878	35	106							TECTEH			21H00005	600UL
7879	37	106							TECTEH			21H00006	600UL
7880	39	106							TECTEH			21H00005	600UL
7881	41	106							TECTEH			21H00006	600UL
7882	43	106							TECTEH			21H00005	600UL
7883	45	106							TECTEH			21H00006	600UL
7884	47	106	0.41	72	INR	6	05H	+35.46	TECTEH			21H00005	600UL
7885	49	106	0.52	73	INR	6	06H	+4.54	TECTEH			21H00006	600UL
7886			0.39	59	INR	6	06H	+29.79	TECTEH			21H00006	600UL
7887			0.74	41	INR	6	05C	+25.28	TECTEH			21H00006	600UL
7888	51	106							TECTEH			21H00005	600UL
7889	53	106							TECTEH			21H00006	600UL
7890	55	106							TECTEH			21H00005	600UL
7891	57	106							TECTEH			21H00006	600UL
7892	59	106							TECTEH			21H00005	600UL
7893	61	106							TECTEH			21H00006	600UL
7894	63	106							TECTEH			21H00005	600UL
7895	65	106	0.72	84	INR	6	06H	+8.63	TECTEH			21H00006	600UL
7896					INF		F08	+10.84	TECTEH	HR		21H00006	600UL
7897	67	106	0.53	95	INR	6	01H	+1.96	TECTEH			21H00005	600UL
7898					INF		F04	+0.00	TECTEH	HR		21H00005	600UL
7899			1.70	73	INR	6	F04	+8.66	TECTEH			21H00005	600UL
7900	69	106	1.13		INR	6	05C	+16.18 TO+30.74	TECTEH			21H00006	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7901	71	106	0.43	76	INR	6	02H	+33.74	TECTEH			21H00005	600UL
7902	73	106							TECTEH			21H00006	600UL
7903	75	106							TECTEH			21H00005	600UL
7904	77	106	0.51	75	INR	6	05H	+21.43	TECTEH			21H00006	600UL
7905			0.27	104	INR	6	F04	+11.04	TECTEH			21H00006	600UL
7906	79	106	0.73	50	INR	6	05C	+2.32	TECTEH			21H00005	600UL
7907	81	106							TECTEH			21H00005	600UL
7908	83	106	0.49	77	INR	6	01C	+2.22	TECTEH			21H00057	600UL
7909	85	106							TECTEH			21H00056	600UL
7910	87	106							TECTEH			21H00057	600UL
7911	89	106							TECTEH			21H00056	600UL
7912	91	106							TECTEH			21H00057	600UL
7913	93	106	0.59	63	INR	6	06C	+20.37	TECTEH			21H00056	600UL
7914			0.62	72	INR	6	03C	+16.76	TECTEH			21H00056	600UL
7915			0.41	69	INR	6	02C	+12.33	TECTEH			21H00056	600UL
7916	95	106							TECTEH			21H00057	600UL
7917	97	106							TECTEH			21H00056	600UL
7918	99	106	0.50	62	INR	6	TSH	+12.94	TECTEH			21H00057	600UL
7919	101	106							TECTEH			21H00056	600UL
7920	103	106							TECTEH			21H00057	600UL
7921	105	106	0.68	94	INR	6	F03	+9.55	TECTEH			21H00056	600UL
7922	107	106							TECTEH			21H00057	600UL
7923	109	106							TECTEH			21H00056	600UL
7924	111	106							TECTEH			21H00057	600UL
7925	113	106	0.38	75	INR	6	TSH	+10.30	TECTEH			21H00056	600UL
7926	115	106							TECTEH			21H00057	600UL
7927	117	106							TECTEH			21H00056	600UL
7928	119	106							TECTEH			21H00057	600UL
7929	121	106	0.29	66	INR	6	07H	+8.01	TECTEH			21H00056	600UL
7930	123	106	0.32	70	INR	6	TSH	+19.58	TECTEH			21H00057	600UL
7931			0.37	74	INR	6	04C	+30.55	TECTEH			21H00057	600UL
7932			0.48	75	INR	6	03C	+13.04	TECTEH			21H00057	600UL
7933	125	106	0.35	68	INR	6	07H	+18.88	TECTEH			21H00056	600UL
7934			0.54	63	INR	6	F07	+8.38	TECTEH			21H00056	600UL
7935					INF		F08	+11.92	TECTEH	HR		21H00056	600UL
7936			0.31	108	INR	6	F09	+2.21	TECTEH			21H00056	600UL
7937					INF		F10	+15.71	TECTEH	HR		21H00056	600UL
7938	127	106							TECTEH			21H00057	600UL
7939	129	106							TECTEH			21H00056	600UL
7940	131	106	0.52	76	INR	6	02C	+17.42	TECTEH			21H00056	600UL
7941			0.30	73	INR	6	02C	+18.92	TECTEH			21H00056	600UL
7942			0.49	82	INR	6	TSC	+17.01	TECTEH			21H00056	600UL
7943	133	106							TECTEH			21H00047	600UL
7944	135	106			INF		F03	+6.49	TECTEH	HR		21H00048	600UL
7945			0.58	54	INR	6	F03	+7.68	TECTEH			21H00048	600UL
7946			0.43	77	INR	6	F10	+6.22	TECTEH			21H00048	600UL
7947	4	107							TECTEH			21H00084	600UL
7948	6	107							TECTEH			21H00083	600UL
7949	8	107							TECTEH			21H00083	600UL
7950	10	107							TECTEH			21H00083	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
7951	12	107							TECTEH			21H00083	600UL
7952	14	107							TECTEH			21H00082	600UL
7953	16	107							TECTEH			21H00081	600UL
7954	18	107							TECTEH			21H00080	600UL
7955	20	107							TECTEH			21H00081	600UL
7956	22	107	0.71	79	INR	6	01H	+21.93	TECTEH			21H00080	600UL
7957			5.42	179	INR	P1	F05	+1.12	TECTEH			21H00080	600UL
7958	24	107							TECTEH			21H00080	600UL
7959	26	107							TECTEH			21H00006	600UL
7960	28	107							TECTEH			21H00005	600UL
7961	30	107							TECTEH			21H00006	600UL
7962	32	107							TECTEH			21H00005	600UL
7963	34	107							TECTEH			21H00006	600UL
7964	36	107							TECTEH			21H00005	600UL
7965	38	107	0.34	65	INR	6	F12	+1.92	TECTEH			21H00006	600UL
7966					INF		07C	+9.30	TECTEH	HR		21H00006	600UL
7967	40	107							TECTEH			21H00005	600UL
7968	42	107							TECTEH			21H00006	600UL
7969	44	107							TECTEH			21H00005	600UL
7970	46	107							TECTEH			21H00006	600UL
7971	48	107	0.38	66	INR	6	TSH	+2.61	TECTEH			21H00005	600UL
7972			0.45	77	INR	6	02H	+33.42	TECTEH			21H00005	600UL
7973	50	107							TECTEH			21H00006	600UL
7974	52	107							TECTEH			21H00005	600UL
7975	54	107							TECTEH			21H00006	600UL
7976	56	107							TECTEH			21H00005	600UL
7977	58	107	0.37	62	INR	6	06H	+8.19	TECTEH			21H00006	600UL
7978			0.57	66	INR	6	02C	+9.83	TECTEH			21H00006	600UL
7979	60	107	0.91	67	INR	6	02C	+5.44	TECTEH			21H00005	600UL
7980	62	107							TECTEH			21H00006	600UL
7981	64	107	0.45	95	INR	6	03H	+11.98	TECTEH			21H00005	600UL
7982	66	107			INF		F09	+0.00	TECTEH	HR		21H00006	600UL
7983	68	107	0.55	91	INR	6	F10	+3.44	TECTEH			21H00005	600UL
7984					INF		F12	+3.99	TECTEH	HR		21H00005	600UL
7985	70	107	0.39	82	INR	6	TSH	+5.90	TECTEH			21H00006	600UL
7986			0.37	87	INR	6	05H	+20.33	TECTEH			21H00006	600UL
7987			0.64	68	INR	6	05H	+36.93	TECTEH			21H00006	600UL
7988			0.42	61	INR	6	06H	+22.28	TECTEH			21H00006	600UL
7989			0.52	81	INR	6	F12	+3.58	TECTEH			21H00006	600UL
7990					INF		07C	+11.02	TECTEH	HR		21H00006	600UL
7991	72	107	0.35	81	INR	6	01H	+26.49	TECTEH			21H00005	600UL
7992	74	107	0.68	71	INR	6	F04	+5.70	TECTEH			21H00006	600UL
7993	76	107	0.39	81	INR	6	04H	+2.59	TECTEH			21H00005	600UL
7994	78	107	0.54	86	INR	6	F04	+9.53	TECTEH			21H00006	600UL
7995			0.59	77	INR	6	F12	+9.05	TECTEH			21H00006	600UL
7996					INF		07C	+4.26	TECTEH	HR		21H00006	600UL
7997	80	107							TECTEH			21H00005	600UL
7998	82	107							TECTEH			21H00056	600UL
7999	84	107	0.54	76	INR	6	01H	+18.03	TECTEH			21H00057	600UL
8000	86	107							TECTEH			21H00056	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8001	88	107							TECTEH			21H00057	600UL
8002	90	107							TECTEH			21H00056	600UL
8003	92	107							TECTEH			21H00057	600UL
8004	94	107	1.08	120	INR	3	06C	+22.68	TECTEH			21H00056	600UL
8005			0.88	123	INR	3	05C	+22.32	TECTEH			21H00056	600UL
8006	96	107							TECTEH			21H00057	600UL
8007	98	107	0.38	123	INR	3	F05	+2.85	TECTEH			21H00056	600UL
8008			0.41	91	INR	3	F05	+9.40	TECTEH			21H00056	600UL
8009	100	107							TECTEH			21H00057	600UL
8010	102	107	0.50	73	INR	6	04H	+12.96	TECTEH			21H00056	600UL
8011	104	107							TECTEH			21H00057	600UL
8012	106	107	0.36	67	INR	6	06C	+5.12	TECTEH			21H00056	600UL
8013	108	107	1.35	74	INR	6	06C	+12.87	TECTEH			21H00057	600UL
8014	110	107	0.54	76	INR	6	04H	+3.34	TECTEH			21H00056	600UL
8015			0.54	83	INR	6	06C	+20.63	TECTEH			21H00056	600UL
8016	112	107	0.40	124	INR	3	06C	+18.95	TECTEH			21H00057	600UL
8017			0.53	67	INR	6	02C	+27.24	TECTEH			21H00057	600UL
8018	114	107							TECTEH			21H00056	600UL
8019	116	107							TECTEH			21H00057	600UL
8020	118	107							TECTEH			21H00056	600UL
8021	120	107							TECTEH			21H00057	600UL
8022	122	107							TECTEH			21H00056	600UL
8023	124	107							TECTEH			21H00057	600UL
8024	126	107	0.61	79	INR	6	02H	+4.04	TECTEH			21H00056	600UL
8025			0.38	76	INR	6	03H	+8.34	TECTEH			21H00056	600UL
8026			0.67	77	INR	6	04H	+15.13	TECTEH			21H00056	600UL
8027			0.62	73	INR	6	F08	+10.63	TECTEH			21H00056	600UL
8028					INF		F09	+5.44	TECTEH	HR		21H00056	600UL
8029	128	107	0.58	56	INR	6	F10	+6.91	TECTEH			21H00057	600UL
8030					INF		F11	+10.69	TECTEH	HR		21H00057	600UL
8031			0.43	99	INR	6	05C	+19.04	TECTEH			21H00057	600UL
8032	130	107	0.57	62	INR	6	F11	+10.26	TECTEH			21H00056	600UL
8033					INF		F12	+7.93	TECTEH	HR		21H00056	600UL
8034			0.59	80	INR	6	01C	+6.42	TECTEH			21H00056	600UL
8035	132	107	0.42	84	INR	6	04H	+23.39	TECTEH			21H00052	600UL
8036			0.39	94	INR	6	04H	+36.01	TECTEH			21H00052	600UL
8037			0.50	80	INR	6	05H	+21.34	TECTEH			21H00052	600UL
8038			0.80	37	INR	6	F03	+0.23	TECTEH			21H00052	600UL
8039			0.67	66	INR	6	F04	+17.16	TECTEH			21H00052	600UL
8040			0.50	76	INR	6	F05	+15.49	TECTEH			21H00052	600UL
8041			0.52	82	INR	6	06C	+24.47	TECTEH			21H00052	600UL
8042			0.41	91	INR	6	05C	+13.09	TECTEH			21H00052	600UL
8043	134	107	0.46	94	INR	6	F01	+14.91	TECTEH			21H00053	600UL
8044			1.07	28	INR	6	F02	+17.08	TECTEH			21H00053	600UL
8045	5	108							TECTEH			21H00085	600UL
8046	7	108							TECTEH			21H00083	600UL
8047	9	108							TECTEH			21H00083	600UL
8048	11	108							TECTEH			21H00082	600UL
8049	13	108							TECTEH			21H00083	600UL
8050	15	108							TECTEH			21H00082	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8051	17	108							TECTEH			21H00081	600UL
8052	19	108							TECTEH			21H00080	600UL
8053	21	108							TECTEH			21H00081	600UL
8054	23	108							TECTEH			21H00080	600UL
8055	25	108							TECTEH			21H00006	600UL
8056	27	108							TECTEH			21H00005	600UL
8057	29	108							TECTEH			21H00006	600UL
8058	31	108							TECTEH			21H00005	600UL
8059	33	108							TECTEH			21H00006	600UL
8060	35	108							TECTEH			21H00005	600UL
8061	37	108							TECTEH			21H00006	600UL
8062	39	108							TECTEH			21H00005	600UL
8063	41	108	0.55	52	INR	6	05H	+16.11	TECTEH			21H00006	600UL
8064	43	108							TECTEH			21H00005	600UL
8065	45	108	0.59	50	INR	6	F09	+0.00	TECTEH			21H00006	600UL
8066			0.60	64	INR	6	01C	+23.90	TECTEH			21H00006	600UL
8067	47	108							TECTEH			21H00005	600UL
8068	49	108							TECTEH			21H00006	600UL
8069	51	108							TECTEH			21H00005	600UL
8070	53	108							TECTEH			21H00006	600UL
8071	55	108			INF		F12	+0.00	TECTEH	HR		21H00005	600UL
8072	57	108							TECTEH			21H00006	600UL
8073	59	108							TECTEH			21H00005	600UL
8074	61	108	0.62	100	INR	6	F09	+6.43	TECTEH			21H00006	600UL
8075					INF		F10	+8.22	TECTEH	HR		21H00006	600UL
8076	63	108							TECTEH			21H00005	600UL
8077	65	108	0.90	71	INR	6	06C	+0.00	TECTEH			21H00006	600UL
8078	67	108							TECTEH			21H00005	600UL
8079	69	108	0.38	67	INR	6	01H	+31.31	TECTEH			21H00006	600UL
8080	71	108							TECTEH			21H00005	600UL
8081	73	108							TECTEH			21H00006	600UL
8082	75	108	0.48	87	INR	6	01H	+28.41	TECTEH			21H00005	600UL
8083	77	108							TECTEH			21H00006	600UL
8084	79	108							TECTEH			21H00005	600UL
8085	81	108							TECTEH			21H00005	600UL
8086	83	108							TECTEH			21H00057	600UL
8087	85	108							TECTEH			21H00056	600UL
8088	87	108							TECTEH			21H00057	600UL
8089	89	108							TECTEH			21H00056	600UL
8090	91	108							TECTEH			21H00057	600UL
8091	93	108	0.20	129	INR	3	03H	+17.15	TECTEH			21H00056	600UL
8092	95	108							TECTEH			21H00057	600UL
8093	97	108	0.31	82	INR	3	F10	+8.25	TECTEH			21H00056	600UL
8094					INF		F11	+4.22	TECTEH	HR		21H00056	600UL
8095	99	108							TECTEH			21H00057	600UL
8096	101	108	0.39	126	INR	3	F12	+6.93	TECTEH			21H00056	600UL
8097					INF		07C	+10.38	TECTEH	HR		21H00056	600UL
8098	103	108							TECTEH			21H00057	600UL
8099	105	108							TECTEH			21H00056	600UL
8100	107	108	0.60	81	INR	6	F02	+10.15	TECTEH			21H00057	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8101	109	108	0.61	81	INR	6	TSH	+18.69	TECTEH			21H00056	600UL
8102			1.55	76	INR	6	04H	+14.01	TECTEH			21H00056	600UL
8103			0.61	77	INR	6	05H	+12.85	TECTEH			21H00056	600UL
8104			0.60	64	INR	6	07H	+13.98	TECTEH			21H00056	600UL
8105			0.57	77	INR	6	05C	+30.40	TECTEH			21H00056	600UL
8106	111	108	0.42	74	INR	6	06H	+28.98	TECTEH			21H00057	600UL
8107			0.29	133	INR	3	F08	+8.20	TECTEH			21H00057	600UL
8108					INF		F09	+8.01	TECTEH	HR		21H00057	600UL
8109	113	108	0.34	75	INR	6	06C	+38.56	TECTEH			21H00056	600UL
8110	115	108							TECTEH			21H00057	600UL
8111	117	108							TECTEH			21H00056	600UL
8112	119	108			INF		F10	+0.00	TECTEH	HR		21H00057	600UL
8113			0.37	81	INR	6	F10	+3.40	TECTEH			21H00057	600UL
8114	121	108							TECTEH			21H00056	600UL
8115	123	108							TECTEH			21H00057	600UL
8116	125	108	0.33	74	INR	6	04H	+12.49	TECTEH			21H00056	600UL
8117	127	108							TECTEH			21H00057	600UL
8118	129	108	0.19	139	INR	3	TSH	+12.76	TECTEH			21H00056	600UL
8119			0.29	128	INR	3	06C	+21.40	TECTEH			21H00056	600UL
8120			0.27	119	INR	3	TSC	+13.46	TECTEH			21H00056	600UL
8121	131	108	0.25	92	INR	6	05C	+14.05	TECTEH			21H00056	600UL
8122	133	108							TECTEH			21H00052	600UL
8123	135	108							TECTEH			21H00053	600UL
8124	4	109							TECTEH			21H00084	600UL
8125	6	109							TECTEH			21H00084	600UL
8126	8	109							TECTEH			21H00083	600UL
8127	10	109							TECTEH			21H00082	600UL
8128	12	109							TECTEH			21H00083	600UL
8129	14	109							TECTEH			21H00082	600UL
8130	16	109							TECTEH			21H00081	600UL
8131	18	109							TECTEH			21H00080	600UL
8132	20	109							TECTEH			21H00081	600UL
8133	22	109	5.26	178	INR	P1	F05	+2.52	TECTEH			21H00080	600UL
8134			0.45	78	INR	6	02C	+32.68	TECTEH			21H00080	600UL
8135	24	109							TECTEH			21H00080	600UL
8136	26	109							TECTEH			21H00006	600UL
8137	28	109							TECTEH			21H00005	600UL
8138	30	109							TECTEH			21H00006	600UL
8139	32	109							TECTEH			21H00005	600UL
8140	34	109							TECTEH			21H00006	600UL
8141	36	109							TECTEH			21H00005	600UL
8142	38	109							TECTEH			21H00006	600UL
8143	40	109							TECTEH			21H00005	600UL
8144	42	109							TECTEH			21H00006	600UL
8145	44	109							TECTEH			21H00005	600UL
8146	46	109							TECTEH			21H00006	600UL
8147	48	109							TECTEH			21H00005	600UL
8148	50	109							TECTEH			21H00006	600UL
8149	52	109							TECTEH			21H00005	600UL
8150	54	109							TECTEH			21H00006	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8151	56	109								TECTEH			21H00005	600UL
8152	58	109	0.46	63	INR	6	TSC	+3.26		TECTEH			21H00006	600UL
8153	60	109								TECTEH			21H00005	600UL
8154	62	109								TECTEH			21H00006	600UL
8155	64	109	0.41	68	INR	6	03H	+16.07		TECTEH			21H00005	600UL
8156			1.29	65	INR	6	07C	+0.08		TECTEH			21H00005	600UL
8157			0.90	76	INR	6	05C	+11.54		TECTEH			21H00005	600UL
8158			0.66	65	INR	6	05C	+35.01		TECTEH			21H00005	600UL
8159	66	109			INF		F12	+4.17		TECTEH	HR		21H00006	600UL
8160					INF		F12	+5.06		TECTEH	HR		21H00006	600UL
8161	68	109								TECTEH			21H00005	600UL
8162	70	109								TECTEH			21H00006	600UL
8163	72	109			INF		F09	-0.35		TECTEH	HR		21H00005	600UL
8164			1.59	70	INR	6	F10	+0.63		TECTEH			21H00005	600UL
8165	74	109								TECTEH			21H00006	600UL
8166	76	109								TECTEH			21H00005	600UL
8167	78	109								TECTEH			21H00006	600UL
8168	80	109								TECTEH			21H00005	600UL
8169	82	109								TECTEH			21H00056	600UL
8170	84	109								TECTEH			21H00057	600UL
8171	86	109								TECTEH			21H00056	600UL
8172	88	109								TECTEH			21H00057	600UL
8173	90	109	0.52	124	INR	3	03H	+37.67		TECTEH			21H00056	600UL
8174			0.38	128	INR	3	04H	+31.50		TECTEH			21H00056	600UL
8175			0.32	129	INR	3	06H	+36.72		TECTEH			21H00056	600UL
8176					INF		05C	+11.54		TECTEH	HR		21H00056	600UL
8177			0.38	125	INR	3	05C	+14.85		TECTEH			21H00056	600UL
8178	92	109								TECTEH			21H00057	600UL
8179	94	109								TECTEH			21H00056	600UL
8180	96	109	0.87	79	INR	6	04H	+3.72		TECTEH			21H00057	600UL
8181	98	109								TECTEH			21H00056	600UL
8182	100	109	0.56	77	INR	6	03H	+11.70		TECTEH			21H00057	600UL
8183	102	109								TECTEH			21H00056	600UL
8184	104	109	0.78	77	INR	6	02C	+14.99		TECTEH			21H00057	600UL
8185	106	109	0.36	71	INR	3	F02	+5.74		TECTEH			21H00056	600UL
8186			0.44	111	INR	3	F03	+1.25		TECTEH			21H00056	600UL
8187			1.29	205	INR	6	F10	+0.00		TECTEH			21H00056	600UL
8188	108	109	0.54	61	INR	6	TSC	+19.51		TECTEH			21H00057	600UL
8189	110	109								TECTEH			21H00056	600UL
8190	112	109								TECTEH			21H00057	600UL
8191	114	109	0.28	115	INR	3	04C	+15.60		TECTEH			21H00056	600UL
8192	116	109								TECTEH			21H00057	600UL
8193	118	109								TECTEH			21H00056	600UL
8194	120	109								TECTEH			21H00057	600UL
8195	122	109								TECTEH			21H00056	600UL
8196	124	109	0.41		INR	6	F07	+0.89	TO+8.84	TECTEH			21H00057	600UL
8197					INF		F08	+10.15	TO+15.82	TECTEH	HR		21H00057	600UL
8198	126	109								TECTEH			21H00056	600UL
8199	128	109	0.60	76	INR	6	06H	+2.80		TECTEH			21H00057	600UL
8200			1.21	75	INR	6	F06	+8.61		TECTEH			21H00057	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8201			0.73	52	INR	6	F07	+0.08	TECTEH			21H00057	600UL
8202			0.39	113	INR	3	05C	+29.55	TECTEH			21H00057	600UL
8203	130	109			INF		F03	+11.21	TECTEH	HR		21H00056	600UL
8204			0.68	73	INR	6	F03	+12.65	TECTEH			21H00056	600UL
8205			0.32	65	INR	6	05C	+29.18	TECTEH			21H00056	600UL
8206	132	109	0.35	67	INR	6	05H	+28.25	TECTEH			21H00052	600UL
8207			1.44	22	INR	6	F04	+17.72	TECTEH			21H00052	600UL
8208			0.51	83	INR	6	06C	+30.00	TECTEH			21H00052	600UL
8209	134	109	0.18	65	INR	3	06H	+4.07	TECTEH			21H00053	600UL
8210			0.46	102	INR	6	01C	+13.59	TECTEH			21H00053	600UL
8211	5	110							TECTEH			21H00085	600UL
8212	7	110							TECTEH			21H00084	600UL
8213	9	110							TECTEH			21H00083	600UL
8214	11	110							TECTEH			21H00082	600UL
8215	13	110							TECTEH			21H00083	600UL
8216	15	110							TECTEH			21H00082	600UL
8217	17	110							TECTEH			21H00081	600UL
8218	19	110	0.51	77	INR	6	04C	+37.34	TECTEH			21H00080	600UL
8219	21	110	6.97	183	INR	1	F01	+6.29	TECTEH			21H00081	600UL
8220					INF		F05	+2.00	TECTEH	HR		21H00081	600UL
8221	23	110							TECTEH			21H00080	600UL
8222	25	110	0.48	72	INR	6	03H	+26.86	TECTEH			21H00008	600UL
8223	27	110							TECTEH			21H00007	600UL
8224	29	110							TECTEH			21H00008	600UL
8225	31	110							TECTEH			21H00007	600UL
8226	33	110							TECTEH			21H00008	600UL
8227	35	110							TECTEH			21H00007	600UL
8228	37	110							TECTEH			21H00008	600UL
8229	39	110							TECTEH			21H00007	600UL
8230	41	110							TECTEH			21H00008	600UL
8231	43	110							TECTEH			21H00007	600UL
8232	45	110	0.52	91	INR	6	03C	+25.30	TECTEH			21H00008	600UL
8233	47	110							TECTEH			21H00007	600UL
8234	49	110							TECTEH			21H00008	600UL
8235	51	110							TECTEH			21H00007	600UL
8236	53	110							TECTEH			21H00008	600UL
8237	55	110	0.47	69	INR	6	01H	+25.95	TECTEH			21H00007	600UL
8238	57	110	0.51	96	INR	6	06C	+25.82	TECTEH			21H00008	600UL
8239			0.61	84	INR	6	02C	+28.93	TECTEH			21H00008	600UL
8240	59	110							TECTEH			21H00007	600UL
8241	61	110							TECTEH			21H00008	600UL
8242	63	110							TECTEH			21H00007	600UL
8243	65	110							TECTEH			21H00008	600UL
8244	67	110							TECTEH			21H00007	600UL
8245	69	110							TECTEH			21H00008	600UL
8246	71	110	0.54	82	INR	6	02C	+6.91	TECTEH			21H00007	600UL
8247	73	110							TECTEH			21H00008	600UL
8248	75	110	0.56	88	INR	6	TSC	+11.92	TECTEH			21H00007	600UL
8249	77	110							TECTEH			21H00008	600UL
8250	79	110							TECTEH			21H00007	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8251	81	110								TECTEH			21H00007	600UL
8252	83	110								TECTEH			21H00057	600UL
8253	85	110								TECTEH			21H00056	600UL
8254	87	110								TECTEH			21H00057	600UL
8255	89	110								TECTEH			21H00056	600UL
8256	91	110	0.46	93	INR	6	F04	+8.74		TECTEH			21H00057	600UL
8257	93	110	0.41	147	INR	3	TSH	+4.52		TECTEH			21H00056	600UL
8258	95	110								TECTEH			21H00057	600UL
8259	97	110								TECTEH			21H00056	600UL
8260	99	110								TECTEH			21H00057	600UL
8261	101	110								TECTEH			21H00056	600UL
8262	103	110								TECTEH			21H00057	600UL
8263	105	110	0.74	142	INR	3	F06	+1.77		TECTEH			21H00056	600UL
8264	107	110								TECTEH			21H00057	600UL
8265	109	110								TECTEH			21H00056	600UL
8266	111	110								TECTEH			21H00057	600UL
8267	113	110								TECTEH			21H00056	600UL
8268	115	110								TECTEH			21H00057	600UL
8269	117	110								TECTEH			21H00056	600UL
8270	119	110								TECTEH			21H00057	600UL
8271	121	110	1.35		INR	6	F05	+6.64	TO+16.54	TECTEH			21H00056	600UL
8272	123	110								TECTEH			21H00057	600UL
8273	125	110	0.41	81	INR	6	02C	+7.54		TECTEH			21H00056	600UL
8274	127	110								TECTEH			21H00057	600UL
8275	129	110	0.23	126	INR	3	05C	+2.95		TECTEH			21H00056	600UL
8276	131	110								TECTEH			21H00056	600UL
8277	133	110								TECTEH			21H00052	600UL
8278	4	111								TECTEH			21H00084	600UL
8279	6	111								TECTEH			21H00084	600UL
8280	8	111								TECTEH			21H00083	600UL
8281	10	111								TECTEH			21H00082	600UL
8282	12	111								TECTEH			21H00083	600UL
8283	14	111	0.41	65	INR	6	03C	+37.03		TECTEH			21H00082	600UL
8284	16	111								TECTEH			21H00081	600UL
8285	18	111								TECTEH			21H00080	600UL
8286	20	111								TECTEH			21H00081	600UL
8287	22	111	5.76	178	INR	P1	F05	+2.72		TECTEH			21H00080	600UL
8288	24	111								TECTEH			21H00080	600UL
8289	26	111								TECTEH			21H00007	600UL
8290	28	111								TECTEH			21H00008	600UL
8291	30	111								TECTEH			21H00007	600UL
8292	32	111								TECTEH			21H00008	600UL
8293	34	111								TECTEH			21H00007	600UL
8294	36	111								TECTEH			21H00008	600UL
8295	38	111								TECTEH			21H00007	600UL
8296	40	111								TECTEH			21H00008	600UL
8297	42	111								TECTEH			21H00007	600UL
8298	44	111			INF		06H	+37.17		TECTEH	HR		21H00008	600UL
8299			0.43	111	INR	3	07H	+2.06		TECTEH			21H00008	600UL
8300			0.43	102	NQH	3	07H	+7.41		TECTEH			21H00008	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8301	46	111							TECTEH			21H00007	600UL
8302	48	111							TECTEH			21H00008	600UL
8303	50	111	0.43	87	INR	6	F05	-0.03	TECTEH			21H00007	600UL
8304	52	111							TECTEH			21H00008	600UL
8305	54	111							TECTEH			21H00007	600UL
8306	56	111							TECTEH			21H00007	600UL
8307	58	111							TECTEH			21H00007	600UL
8308	60	111	0.44	75	INR	6	04H	+12.69	TECTEH			21H00007	600UL
8309			0.43	74	INR	6	04H	+18.38	TECTEH			21H00007	600UL
8310			0.51	75	INR	6	04C	+18.47	TECTEH			21H00007	600UL
8311	62	111	0.27	110	INR	3	01C	+7.94	TECTEH			21H00008	600UL
8312	64	111							TECTEH			21H00008	600UL
8313	66	111	0.64	75	INR	6	07H	+9.73	TECTEH			21H00008	600UL
8314	68	111	0.48	76	INR	6	01H	+31.96	TECTEH			21H00007	600UL
8315			0.43	59	INR	6	06H	+29.78	TECTEH			21H00007	600UL
8316			0.42	89	INR	6	F07	+8.53	TECTEH			21H00007	600UL
8317					INF		F08	+5.55	TECTEH	HR		21H00007	600UL
8318			0.42	75	INR	6	F12	+5.33	TECTEH			21H00007	600UL
8319					INF		07C	+9.29	TECTEH	HR		21H00007	600UL
8320			0.63	71	INR	6	TSC	+16.23	TECTEH			21H00007	600UL
8321	70	111	0.44	83	INR	6	TSH	+3.72	TECTEH			21H00008	600UL
8322			0.39	127	INR	3	01H	+11.39	TECTEH			21H00008	600UL
8323			0.54	86	INR	6	02H	+33.85	TECTEH			21H00008	600UL
8324			0.51	96	INR	6	F05	+3.95	TECTEH			21H00008	600UL
8325			0.62	36	INR	6	F09	-0.13	TECTEH			21H00008	600UL
8326			0.49	96	INR	6	04C	+7.78	TECTEH			21H00008	600UL
8327	72	111							TECTEH			21H00007	600UL
8328	74	111			INF		F10	+0.44	TECTEH	HR		21H00008	600UL
8329			0.56	86	INR	6	03C	+11.05	TECTEH			21H00008	600UL
8330			0.63	89	INR	6	01C	+29.22	TECTEH			21H00008	600UL
8331	76	111	0.38	42	INR	6	07H	+10.54	TECTEH			21H00007	600UL
8332	78	111	0.69	89	INR	6	03C	+37.13	TECTEH			21H00008	600UL
8333	80	111							TECTEH			21H00007	600UL
8334	82	111			INF		F11	+0.00	TECTEH	HR		21H00056	600UL
8335	84	111	0.58	96	INR	6	02C	+34.14	TECTEH			21H00057	600UL
8336	86	111							TECTEH			21H00056	600UL
8337	88	111							TECTEH			21H00057	600UL
8338	90	111	0.35	139	INR	3	F02	+10.76	TECTEH			21H00056	600UL
8339	92	111	0.59	70	INR	6	F12	+7.07	TECTEH			21H00057	600UL
8340			0.33	73	INR	6	F12	+9.47	TECTEH			21H00057	600UL
8341			0.98	59	NQH	6	07C	-0.18	TECTEH			21H00057	600UL
8342			0.27	128	NQH	P1	07C	+0.13	TECTEH			21H00057	600UL
8343					INF		07C	+9.08	TECTEH	HR		21H00057	600UL
8344					INF		07C	+10.16	TECTEH	HR		21H00057	600UL
8345			0.41	69	INR	6	06C	+7.25	TECTEH			21H00057	600UL
8346			0.60	72	INR	6	05C	+22.79	TECTEH			21H00057	600UL
8347			0.55	111	INR	6	03C	+20.72	TECTEH			21H00057	600UL
8348	94	111							TECTEH			21H00056	600UL
8349	96	111							TECTEH			21H00057	600UL
8350	98	111							TECTEH			21H00056	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8351	100	111	0.35	82	INR	6	06H	+32.50	TECTEH			21H00057	600UL
8352			0.35	76	INR	6	02C	+22.45	TECTEH			21H00057	600UL
8353	102	111	0.29	84	INR	3	F06	+5.20	TECTEH			21H00056	600UL
8354	104	111							TECTEH			21H00057	600UL
8355	106	111	0.41	22	INR	6	05H	+39.43	TECTEH			21H00056	600UL
8356			1.15	130	INR	3	02C	+2.63	TECTEH			21H00056	600UL
8357	108	111							TECTEH			21H00057	600UL
8358	110	111							TECTEH			21H00056	600UL
8359	112	111	0.83	76	INR	6	03H	+32.68	TECTEH			21H00057	600UL
8360	114	111							TECTEH			21H00056	600UL
8361	116	111	0.72	71	INR	6	01H	+9.28	TECTEH			21H00057	600UL
8362	118	111							TECTEH			21H00056	600UL
8363	120	111							TECTEH			21H00057	600UL
8364	122	111	1.07	79	INR	6	04C	+4.96	TECTEH			21H00056	600UL
8365	124	111	2.90	44	NQH	6	04H	+0.81	TECTEH			21H00057	600UL
8366	126	111	0.32	140	INR	3	02H	+36.97	TECTEH			21H00056	600UL
8367			0.30	118	INR	3	06C	+6.45	TECTEH			21H00056	600UL
8368	128	111	0.71	92	INR	6	F05	+15.42	TECTEH			21H00057	600UL
8369	130	111							TECTEH			21H00056	600UL
8370	132	111							TECTEH			21H00052	600UL
8371	3	112							TECTEH			21H00085	600UL
8372	5	112							TECTEH			21H00084	600UL
8373	7	112							TECTEH			21H00084	600UL
8374	9	112							TECTEH			21H00083	600UL
8375	11	112							TECTEH			21H00082	600UL
8376	13	112							TECTEH			21H00083	600UL
8377	15	112							TECTEH			21H00082	600UL
8378	17	112							TECTEH			21H00081	600UL
8379	19	112							TECTEH			21H00080	600UL
8380	21	112	6.28	183	INR	1	F01	+6.93	TECTEH			21H00081	600UL
8381					INF		F05	+3.31	TECTEH	HR		21H00081	600UL
8382	23	112							TECTEH			21H00080	600UL
8383	25	112	0.38	61	INR	3	02H	+28.99	TECTEH			21H00008	600UL
8384	27	112							TECTEH			21H00007	600UL
8385	29	112							TECTEH			21H00008	600UL
8386	31	112							TECTEH			21H00007	600UL
8387	33	112							TECTEH			21H00008	600UL
8388	35	112							TECTEH			21H00007	600UL
8389	37	112	0.57	96	INR	6	02C	+25.16	TECTEH			21H00008	600UL
8390	39	112							TECTEH			21H00007	600UL
8391	41	112	0.66	82	INR	6	06C	+18.11	TECTEH			21H00008	600UL
8392	43	112							TECTEH			21H00007	600UL
8393	45	112							TECTEH			21H00008	600UL
8394	47	112							TECTEH			21H00007	600UL
8395	49	112							TECTEH			21H00008	600UL
8396	51	112	0.37	78	INR	6	04H	+8.46	TECTEH			21H00007	600UL
8397	53	112							TECTEH			21H00008	600UL
8398	55	112							TECTEH			21H00007	600UL
8399	57	112							TECTEH			21H00008	600UL
8400	59	112							TECTEH			21H00007	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8401	61	112							TECTEH			21H00008	600UL
8402	63	112							TECTEH			21H00007	600UL
8403	65	112							TECTEH			21H00008	600UL
8404	67	112			INF		04H	+21.59	TECTEH	HR		21H00007	600UL
8405			0.63	69	INR	6	04H	+23.52	TECTEH			21H00007	600UL
8406	69	112							TECTEH			21H00008	600UL
8407	71	112							TECTEH			21H00007	600UL
8408	73	112							TECTEH			21H00008	600UL
8409	75	112							TECTEH			21H00007	600UL
8410	77	112	0.57	93	NQH	3	F05	+11.11	TECTEH			21H00008	600UL
8411			0.89	87	INR	6	01C	+3.01	TECTEH			21H00008	600UL
8412	79	112							TECTEH			21H00007	600UL
8413	81	112							TECTEH			21H00007	600UL
8414	83	112	0.51	81	INR	6	TSC	+20.41	TECTEH			21H00057	600UL
8415	85	112							TECTEH			21H00056	600UL
8416	87	112							TECTEH			21H00057	600UL
8417	89	112	0.38	101	INR	3	05C	+38.14	TECTEH			21H00056	600UL
8418	91	112							TECTEH			21H00057	600UL
8419	93	112	0.29	107	INR	3	01H	+10.95	TECTEH			21H00056	600UL
8420			0.18	130	INR	3	02H	+12.91	TECTEH			21H00056	600UL
8421			0.16	96	INR	3	02H	+39.00	TECTEH			21H00056	600UL
8422			0.46	134	INR	3	07H	+10.59	TECTEH			21H00056	600UL
8423			0.30	129	INR	3	F12	+6.38	TECTEH			21H00056	600UL
8424					INF		07C	+9.13	TECTEH	HR		21H00056	600UL
8425	95	112	0.55	84	INR	6	01H	+13.29	TECTEH			21H00057	600UL
8426			0.33	72	INR	6	01H	+32.08	TECTEH			21H00057	600UL
8427			0.45	74	INR	6	02H	+32.96	TECTEH			21H00057	600UL
8428			0.38	74	INR	6	04H	+36.25	TECTEH			21H00057	600UL
8429			1.03	85	INR	3	F06	+13.94	TECTEH			21H00057	600UL
8430					INF		F07	+2.65	TECTEH	HR		21H00057	600UL
8431					INF		05C	+19.87	TECTEH	HR		21H00057	600UL
8432			0.42	77	INR	6	05C	+22.74	TECTEH			21H00057	600UL
8433	97	112	0.41	81	INR	3	F03	+2.80	TECTEH			21H00056	600UL
8434			0.21	64	INR	3	F10	+6.30	TECTEH			21H00056	600UL
8435					INF		F11	+7.43	TECTEH	HR		21H00056	600UL
8436	99	112	0.86	67	INR	6	TSH	+22.05	TECTEH			21H00057	600UL
8437			0.38	76	INR	3	03H	+31.76	TECTEH			21H00057	600UL
8438			0.48	75	INR	6	03C	+16.58	TECTEH			21H00057	600UL
8439	101	112	0.39	71	INR	6	04H	+18.16	TECTEH			21H00056	600UL
8440			0.37	71	INR	6	05H	+36.21	TECTEH			21H00056	600UL
8441	103	112							TECTEH			21H00057	600UL
8442	105	112							TECTEH			21H00056	600UL
8443	107	112	0.43	83	INR	6	02C	+7.31	TECTEH			21H00057	600UL
8444	109	112							TECTEH			21H00056	600UL
8445	111	112							TECTEH			21H00057	600UL
8446	113	112							TECTEH			21H00056	600UL
8447	115	112	0.45	85	INR	6	04H	+17.65	TECTEH			21H00057	600UL
8448			0.57	69	INR	6	07H	+16.00	TECTEH			21H00057	600UL
8449			0.57	58	INR	6	F07	+13.58	TECTEH			21H00057	600UL
8450					INF		F08	+4.96	TECTEH	HR		21H00057	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8451			0.58	123	INR	6	F11	+2.65	TECTEH			21H00057	600UL
8452					INF		F12	+11.29	TECTEH	HR		21H00057	600UL
8453			0.64	83	INR	6	03C	+5.44	TECTEH			21H00057	600UL
8454			0.81	77	INR	6	02C	+8.17	TECTEH			21H00057	600UL
8455	117	112							TECTEH			21H00056	600UL
8456	119	112	0.55	114	NQH	3	F08	+15.71	TECTEH			21H00057	600UL
8457					INF		F09	+3.19	TECTEH	HR		21H00057	600UL
8458	121	112							TECTEH			21H00056	600UL
8459	123	112	0.35	74	INR	6	F12	+16.14	TECTEH			21H00057	600UL
8460					INF		07C	+3.12	TECTEH	HR		21H00057	600UL
8461	125	112	0.36	62	INR	6	06H	+32.20	TECTEH			21H00056	600UL
8462			0.41	70	INR	6	06C	+21.80	TECTEH			21H00056	600UL
8463	127	112							TECTEH			21H00057	600UL
8464	129	112	0.47	65	INR	6	TSH	+17.48	TECTEH			21H00056	600UL
8465			0.43	84	INR	6	04H	+27.72	TECTEH			21H00056	600UL
8466			0.44	84	INR	6	F04	+11.92	TECTEH			21H00056	600UL
8467			0.41	80	INR	6	05C	+28.74	TECTEH			21H00056	600UL
8468			0.40	67	INR	6	05C	+32.40	TECTEH			21H00056	600UL
8469			0.42	91	INR	6	04C	+16.40	TECTEH			21H00056	600UL
8470	131	112	0.45	63	INR	6	04H	+11.51	TECTEH			21H00056	600UL
8471			0.52	50	INR	6	F04	+16.91	TECTEH			21H00056	600UL
8472					INF		F04	+18.50	TECTEH	HR		21H00056	600UL
8473			0.44	70	INR	6	05C	+22.48	TECTEH			21H00056	600UL
8474					INF		05C	+24.20	TECTEH	HR		21H00056	600UL
8475	4	113							TECTEH			21H00085	600UL
8476	6	113							TECTEH			21H00084	600UL
8477	8	113	0.36	103	INR	3	02H	+19.61	TECTEH			21H00083	600UL
8478	10	113							TECTEH			21H00082	600UL
8479	12	113							TECTEH			21H00083	600UL
8480	14	113	0.42	74	INR	6	02C	+34.76	TECTEH			21H00082	600UL
8481	16	113							TECTEH			21H00081	600UL
8482	18	113							TECTEH			21H00080	600UL
8483	20	113							TECTEH			21H00081	600UL
8484	22	113							TECTEH			21H00080	600UL
8485	24	113							TECTEH			21H00080	600UL
8486	26	113	0.30	120	INR	3	06H	+6.61	TECTEH			21H00008	600UL
8487			0.46	80	INR	6	06H	+10.99	TECTEH			21H00008	600UL
8488	28	113	0.47	68	INR	6	06C	+19.75	TECTEH			21H00007	600UL
8489	30	113							TECTEH			21H00008	600UL
8490	32	113							TECTEH			21H00007	600UL
8491	34	113							TECTEH			21H00008	600UL
8492	36	113							TECTEH			21H00007	600UL
8493	38	113	0.43	126	NQH	3	05C	+28.18	TECTEH			21H00008	600UL
8494	40	113							TECTEH			21H00007	600UL
8495	42	113							TECTEH			21H00008	600UL
8496	44	113							TECTEH			21H00007	600UL
8497	46	113							TECTEH			21H00008	600UL
8498	48	113							TECTEH			21H00007	600UL
8499	50	113							TECTEH			21H00008	600UL
8500	52	113							TECTEH			21H00007	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8501	54	113							TECTEH			21H00008	600UL
8502	56	113							TECTEH			21H00008	600UL
8503	58	113							TECTEH			21H00008	600UL
8504	60	113							TECTEH			21H00008	600UL
8505	62	113	0.56	86	INR	6	04H	+15.19	TECTEH			21H00008	600UL
8506	64	113							TECTEH			21H00008	600UL
8507	66	113	0.55	85	INR	6	02H	+11.24	TECTEH			21H00008	600UL
8508			0.44	66	INR	6	07H	+10.14	TECTEH			21H00008	600UL
8509			0.52	82	INR	6	06C	+37.21	TECTEH			21H00008	600UL
8510			0.87	87	INR	6	05C	+4.38	TECTEH			21H00008	600UL
8511	68	113	0.96	92	INR	6	02H	+16.20	TECTEH			21H00008	600UL
8512			0.53	105	INR	6	02C	+9.44	TECTEH			21H00008	600UL
8513	70	113							TECTEH			21H00008	600UL
8514	72	113	0.57	90	INR	6	01H	+25.71	TECTEH			21H00008	600UL
8515			0.83	85	INR	6	03H	+8.41	TECTEH			21H00008	600UL
8516			0.32	13	INR	6	F04	+10.74	TECTEH			21H00008	600UL
8517			0.30	114	INR	3	06C	+34.19	TECTEH			21H00008	600UL
8518	74	113	0.61	29	INR	6	F08	+0.20	TECTEH			21H00008	600UL
8519	76	113	0.85	97	INR	6	F07	+2.68	TECTEH			21H00008	600UL
8520			0.76	82	INR	6	F08	+7.49	TECTEH			21H00008	600UL
8521					INF		F08	+11.22	TECTEH	HR		21H00008	600UL
8522					INF		F09	+7.34	TECTEH	HR		21H00008	600UL
8523			0.42	88	INR	6	03C	+39.20	TECTEH			21H00008	600UL
8524	78	113	1.02	126	NQH	3	07H	+6.51	TECTEH			21H00008	600UL
8525	80	113							TECTEH			21H00007	600UL
8526	82	113							TECTEH			21H00056	600UL
8527	84	113							TECTEH			21H00057	600UL
8528	86	113							TECTEH			21H00056	600UL
8529	88	113							TECTEH			21H00057	600UL
8530	90	113							TECTEH			21H00056	600UL
8531	92	113	0.62	65	INR	6	06H	+35.00	TECTEH			21H00057	600UL
8532					INF		F02	+3.77	TECTEH	HR		21H00057	600UL
8533			0.71	98	INR	3	F02	+4.84	TECTEH			21H00057	600UL
8534			0.55	80	INR	6	02C	+32.53	TECTEH			21H00057	600UL
8535	94	113	0.73	46	INR	6	F03	+10.80	TECTEH			21H00056	600UL
8536	96	113	0.53	84	INR	6	03H	+2.20	TECTEH			21H00057	600UL
8537			0.19	123	INR	3	03H	+7.62	TECTEH			21H00057	600UL
8538	98	113							TECTEH			21H00056	600UL
8539	100	113							TECTEH			21H00057	600UL
8540	102	113	0.37	138	INR	3	03H	+29.05	TECTEH			21H00056	600UL
8541	104	113							TECTEH			21H00057	600UL
8542	106	113	0.43	133	INR	3	04H	+17.95	TECTEH			21H00056	600UL
8543			0.94	148	INR	3	F06	+6.64	TECTEH			21H00056	600UL
8544			0.33	134	INR	3	06C	+11.29	TECTEH			21H00056	600UL
8545					INF		06C	+12.84	TECTEH	HR		21H00056	600UL
8546	108	113	0.64	75	INR	6	02H	+20.33	TECTEH			21H00057	600UL
8547			0.43	76	INR	6	04H	+2.98	TECTEH			21H00057	600UL
8548			0.40	64	INR	6	06H	+18.73	TECTEH			21H00057	600UL
8549			0.38	80	INR	3	F02	+9.52	TECTEH			21H00057	600UL
8550			0.86	89	INR	6	F10	+12.95	TECTEH			21H00057	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8551					INF		F11	+4.31	TECTEH	HR		21H00057	600UL
8552			0.47	68	INR	6	05C	+21.28	TECTEH			21H00057	600UL
8553	110	113			INF		07H	+6.51	TECTEH	HR		21H00056	600UL
8554	112	113							TECTEH			21H00057	600UL
8555	114	113							TECTEH			21H00056	600UL
8556	116	113							TECTEH			21H00057	600UL
8557	118	113							TECTEH			21H00056	600UL
8558	120	113	0.50	84	INR	6	07H	+12.76	TECTEH			21H00057	600UL
8559	122	113							TECTEH			21H00056	600UL
8560	124	113							TECTEH			21H00057	600UL
8561	126	113							TECTEH			21H00056	600UL
8562	128	113							TECTEH			21H00057	600UL
8563	130	113	0.51	78	INR	6	05H	+9.04	TECTEH			21H00056	600UL
8564	132	113							TECTEH			21H00052	600UL
8565	3	114	0.49	65	INR	6	04C	+10.82	TECTEH			21H00084	600UL
8566	5	114	0.54	70	INR	6	TSH	+9.40	TECTEH			21H00085	600UL
8567	7	114	0.57	112	INR	6	02H	+19.08	TECTEH			21H00084	600UL
8568	9	114							TECTEH			21H00083	600UL
8569	11	114							TECTEH			21H00082	600UL
8570	13	114							TECTEH			21H00083	600UL
8571	15	114							TECTEH			21H00082	600UL
8572	17	114							TECTEH			21H00081	600UL
8573	19	114							TECTEH			21H00080	600UL
8574	21	114	6.59	182	INR	1	F01	+6.89	TECTEH			21H00081	600UL
8575					INF		F05	+3.42	TECTEH	HR		21H00081	600UL
8576			0.62	84	INR	6	TSC	+2.14	TECTEH			21H00081	600UL
8577	23	114							TECTEH			21H00080	600UL
8578	25	114	0.30	113	INR	3	TSC	+9.43	TECTEH			21H00008	600UL
8579	27	114							TECTEH			21H00007	600UL
8580	29	114							TECTEH			21H00008	600UL
8581	31	114							TECTEH			21H00007	600UL
8582	33	114	0.41	88	INR	6	02H	+14.19	TECTEH			21H00008	600UL
8583	35	114							TECTEH			21H00007	600UL
8584	37	114							TECTEH			21H00008	600UL
8585	39	114	0.34	104	INR	3	05H	+14.44	TECTEH			21H00007	600UL
8586	41	114							TECTEH			21H00008	600UL
8587	43	114							TECTEH			21H00007	600UL
8588	45	114							TECTEH			21H00008	600UL
8589	47	114							TECTEH			21H00007	600UL
8590	49	114							TECTEH			21H00008	600UL
8591	51	114							TECTEH			21H00007	600UL
8592	53	114							TECTEH			21H00008	600UL
8593	55	114							TECTEH			21H00007	600UL
8594	57	114							TECTEH			21H00008	600UL
8595	59	114							TECTEH			21H00007	600UL
8596	61	114			INF		F05	+7.52	TECTEH	HR		21H00008	600UL
8597			0.47	120	INR	3	F05	+8.52	TECTEH			21H00008	600UL
8598			0.43	68	INR	3	F06	+12.44	TECTEH			21H00008	600UL
8599					INF		F07	+1.71	TECTEH	HR		21H00008	600UL
8600	63	114							TECTEH			21H00007	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8601	65	114							TECTEH			21H00008	600UL
8602	67	114	0.61	76	INR	6	04C	+27.11	TECTEH			21H00007	600UL
8603	69	114	0.40	99	INR	6	01C	+2.40	TECTEH			21H00008	600UL
8604			0.83	106	INR	6	TSC	+22.06	TECTEH			21H00008	600UL
8605	71	114							TECTEH			21H00007	600UL
8606	73	114	0.51	69	INR	6	F03	+7.93	TECTEH			21H00008	600UL
8607			0.55	82	INR	6	02C	+34.18	TECTEH			21H00008	600UL
8608	75	114							TECTEH			21H00007	600UL
8609	77	114	0.65	89	INR	6	01C	+29.90	TECTEH			21H00008	600UL
8610	79	114							TECTEH			21H00007	600UL
8611	81	114							TECTEH			21H00007	600UL
8612	83	114							TECTEH			21H00057	600UL
8613	85	114	0.41	72	INR	6	06H	+28.94	TECTEH			21H00056	600UL
8614	87	114							TECTEH			21H00057	600UL
8615	89	114							TECTEH			21H00056	600UL
8616	91	114	0.49	75	INR	6	TSH	+14.88	TECTEH			21H00057	600UL
8617	93	114							TECTEH			21H00056	600UL
8618	95	114							TECTEH			21H00057	600UL
8619	97	114	0.87	77	INR	6	02C	+19.25	TECTEH			21H00056	600UL
8620			0.20	108	INR	3	TSC	+14.82	TECTEH			21H00056	600UL
8621	99	114							TECTEH			21H00057	600UL
8622	101	114	0.26	110	INR	3	F12	+15.42	TECTEH			21H00056	600UL
8623					INF		07C	+2.51	TECTEH	HR		21H00056	600UL
8624	103	114							TECTEH			21H00057	600UL
8625	105	114	0.70	58	INR	3	F04	+13.55	TECTEH			21H00056	600UL
8626	107	114	0.57	73	INR	6	02H	+34.55	TECTEH			21H00057	600UL
8627			0.51	64	INR	6	F05	+14.91	TECTEH			21H00057	600UL
8628	109	114	0.51	154	INR	3	F05	+9.55	TECTEH			21H00056	600UL
8629			0.53	142	INR	3	F05	+14.77	TECTEH			21H00056	600UL
8630			0.30	129	INR	3	06C	+5.07	TECTEH			21H00056	600UL
8631			0.33	126	INR	3	06C	+13.04	TECTEH			21H00056	600UL
8632	111	114							TECTEH			21H00057	600UL
8633	113	114							TECTEH			21H00056	600UL
8634	115	114							TECTEH			21H00057	600UL
8635	117	114	0.79	76	INR	6	06C	+39.26	TECTEH			21H00056	600UL
8636	119	114	0.51	61	INR	6	02H	+8.04	TECTEH			21H00057	600UL
8637			0.86	83	INR	6	F07	+13.20	TECTEH			21H00057	600UL
8638					INF		F08	+5.45	TECTEH	HR		21H00057	600UL
8639			1.12	81	INR	6	06C	+23.44	TECTEH			21H00057	600UL
8640			0.59	89	INR	6	01C	+27.49	TECTEH			21H00057	600UL
8641			0.65	83	INR	6	01C	+32.24	TECTEH			21H00057	600UL
8642	121	114	0.68	86	INR	3	F06	+5.01	TECTEH			21H00056	600UL
8643			0.52	75	INR	6	03C	+29.99	TECTEH			21H00056	600UL
8644					INF		03C	+34.80	TECTEH	HR		21H00056	600UL
8645	123	114							TECTEH			21H00057	600UL
8646	125	114							TECTEH			21H00056	600UL
8647	127	114							TECTEH			21H00057	600UL
8648	129	114	0.20	122	INR	3	05H	+29.11	TECTEH			21H00056	600UL
8649			0.88	123	INR	3	06C	+10.87	TECTEH			21H00056	600UL
8650	131	114	0.60	127	INR	3	05C	+5.92	TECTEH			21H00056	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8651			0.40	120	INR	3	05C	+8.69	TECTEH			21H00056	600UL
8652			0.38	129	INR	3	05C	+13.20	TECTEH			21H00056	600UL
8653			0.41	128	INR	3	05C	+20.61	TECTEH			21H00056	600UL
8654	2	115							TECTEH			21H00084	600UL
8655	4	115							TECTEH			21H00085	600UL
8656	6	115							TECTEH			21H00084	600UL
8657	8	115							TECTEH			21H00083	600UL
8658	10	115							TECTEH			21H00082	600UL
8659	12	115							TECTEH			21H00083	600UL
8660	14	115							TECTEH			21H00082	600UL
8661	16	115							TECTEH			21H00081	600UL
8662	18	115							TECTEH			21H00080	600UL
8663	20	115							TECTEH			21H00081	600UL
8664	22	115			INF		07H	+15.51	TECTEH	HR		21H00080	600UL
8665			3.28	344	INR	6	F01	+7.19	TECTEH			21H00080	600UL
8666					INF		F05	+1.44	TECTEH	HR		21H00080	600UL
8667	24	115							TECTEH			21H00080	600UL
8668	26	115							TECTEH			21H00008	600UL
8669	28	115							TECTEH			21H00007	600UL
8670	30	115							TECTEH			21H00008	600UL
8671	32	115	0.38	72	INR	6	03C	+34.34	TECTEH			21H00007	600UL
8672	34	115							TECTEH			21H00008	600UL
8673	36	115			NDF	3	TEH	+10.00	TEHTSH			21H00051	610PP
8674			3.92	187	DNG	1	F04	+3.35	TECTEH			21H00007	600UL
8675	38	115							TECTEH			21H00008	600UL
8676	40	115							TECTEH			21H00007	600UL
8677	42	115							TECTEH			21H00008	600UL
8678	44	115							TECTEH			21H00007	600UL
8679	46	115							TECTEH			21H00008	600UL
8680	48	115							TECTEH			21H00007	600UL
8681	50	115							TECTEH			21H00008	600UL
8682	52	115							TECTEH			21H00007	600UL
8683	54	115							TECTEH			21H00008	600UL
8684	56	115							TECTEH			21H00007	600UL
8685	58	115	0.37	86	INR	3	02C	+7.34	TECTEH			21H00008	600UL
8686			0.54	87	INR	6	TSC	+9.25	TECTEH			21H00008	600UL
8687	60	115	0.41	84	INR	6	01H	+2.64	TECTEH			21H00007	600UL
8688			0.63	66	INR	6	01H	+4.62	TECTEH			21H00007	600UL
8689			0.84	59	INR	6	06H	+32.88	TECTEH			21H00007	600UL
8690	62	115	0.99	87	INR	6	01H	+3.01	TECTEH			21H00008	600UL
8691			0.46	73	INR	6	06H	+33.68	TECTEH			21H00008	600UL
8692			0.56	84	INR	6	06C	+4.81	TECTEH			21H00008	600UL
8693			0.58	88	INR	6	04C	+18.58	TECTEH			21H00008	600UL
8694			0.73	84	INR	6	02C	+19.06	TECTEH			21H00008	600UL
8695			0.76	98	INR	6	02C	+25.55	TECTEH			21H00008	600UL
8696	64	115	0.51	61	INR	6	06H	+20.88	TECTEH			21H00007	600UL
8697			1.03	80	INR	6	01C	+21.50	TECTEH			21H00007	600UL
8698	66	115	0.49	77	INR	6	03C	+3.18	TECTEH			21H00008	600UL
8699	68	115	0.38	73	INR	6	05C	+34.81	TECTEH			21H00007	600UL
8700	70	115							TECTEH			21H00008	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8701	72	115	0.42	63	INR	6	06H	+8.99	TECTEH			21H00007	600UL
8702					INF		F10	+3.76	TECTEH	HR		21H00007	600UL
8703			0.50	57	INR	6	F11	+4.52	TECTEH			21H00007	600UL
8704					INF		F12	+7.61	TECTEH	HR		21H00007	600UL
8705			0.50	69	INR	6	TSC	+7.51	TECTEH			21H00007	600UL
8706	74	115	0.50	94	INR	6	TSH	+1.77	TECTEH			21H00008	600UL
8707	76	115							TECTEH			21H00007	600UL
8708	78	115	0.45	92	NQH	3	F07	+4.86	TECTEH			21H00008	600UL
8709					INF		F08	+10.03	TECTEH	HR		21H00008	600UL
8710			0.44	80	INR	6	06C	+7.50	TECTEH			21H00008	600UL
8711	80	115	0.45	83	INR	6	02C	+17.81	TECTEH			21H00007	600UL
8712			0.49	112	NQH	3	TSC	+16.79	TECTEH			21H00007	600UL
8713	82	115							TECTEH			21H00056	600UL
8714	84	115							TECTEH			21H00057	600UL
8715	86	115	0.61	64	INR	3	F05	+12.20	TECTEH			21H00056	600UL
8716			0.73	117	INR	3	F09	+8.33	TECTEH			21H00056	600UL
8717					INF		F10	+6.68	TECTEH	HR		21H00056	600UL
8718	88	115							TECTEH			21H00057	600UL
8719	90	115	0.24	130	INR	3	04C	+14.61	TECTEH			21H00056	600UL
8720	92	115							TECTEH			21H00057	600UL
8721	94	115	7.20	182	DNG	1	01C	+11.19	TECTEH			21H00056	600UL
8722			3.25	184	DNG	1	01C	+11.88	TECTEH			21H00056	600UL
8723	96	115	1.50		INR	6	04C	+10.89 TO+22.39	TECTEH			21H00057	600UL
8724	98	115							TECTEH			21H00056	600UL
8725	100	115	0.41	75	INR	6	02C	+22.47	TECTEH			21H00057	600UL
8726	102	115	0.43	120	INR	3	04C	+19.33	TECTEH			21H00056	600UL
8727	104	115			INF		F03	+1.79	TECTEH	HR		21H00057	600UL
8728			0.69	73	INR	6	F03	+3.23	TECTEH			21H00057	600UL
8729	106	115	0.46	133	INR	3	03C	+3.91	TECTEH			21H00056	600UL
8730	108	115							TECTEH			21H00057	600UL
8731	110	115							TECTEH			21H00056	600UL
8732	112	115	0.62	79	INR	6	05C	+14.54	TECTEH			21H00057	600UL
8733	114	115	0.44	152	INR	3	01H	+31.35	TECTEH			21H00056	600UL
8734			0.61	139	INR	3	01C	+22.59	TECTEH			21H00056	600UL
8735	116	115	0.69	77	INR	6	F03	+15.66	TECTEH			21H00057	600UL
8736	118	115	0.59	129	INR	3	07H	+4.84	TECTEH			21H00056	600UL
8737	120	115							TECTEH			21H00057	600UL
8738	122	115	0.25	112	INR	3	05H	+30.03	TECTEH			21H00056	600UL
8739			0.49	109	INR	3	03C	+12.94	TECTEH			21H00056	600UL
8740	124	115							TECTEH			21H00057	600UL
8741	126	115							TECTEH			21H00056	600UL
8742	128	115	0.63	69	INR	6	02H	+10.79	TECTEH			21H00057	600UL
8743			0.59	81	INR	6	F03	+10.26	TECTEH			21H00057	600UL
8744			0.52	78	INR	6	05C	+14.72	TECTEH			21H00057	600UL
8745	130	115							TECTEH			21H00056	600UL
8746	1	116	6.66	182	DNG	1	03H	+34.78	TECTEH			21H00085	600UL
8747			4.95	182	DNG	1	04H	+32.30	TECTEH			21H00085	600UL
8748	3	116							TECTEH			21H00084	600UL
8749	5	116							TECTEH			21H00085	600UL
8750	7	116							TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8751	9	116							TECTEH			21H00083	600UL
8752	11	116							TECTEH			21H00082	600UL
8753	13	116							TECTEH			21H00083	600UL
8754	15	116							TECTEH			21H00082	600UL
8755	17	116							TECTEH			21H00081	600UL
8756	19	116							TECTEH			21H00080	600UL
8757	21	116	6.46	185	INR	1	F01	+6.94	TECTEH			21H00081	600UL
8758					INF		F05	+3.39	TECTEH	HR		21H00081	600UL
8759	23	116							TECTEH			21H00080	600UL
8760	25	116							TECTEH			21H00077	600UL
8761	27	116							TECTEH			21H00076	600UL
8762	29	116							TECTEH			21H00077	600UL
8763	31	116							TECTEH			21H00076	600UL
8764	33	116	3.66	181	INR	1	F01	+6.36	TECTEH			21H00077	600UL
8765					INF		F04	+4.64	TECTEH	HR		21H00077	600UL
8766					INF		F04	+6.05	TECTEH	HR		21H00077	600UL
8767	35	116	3.53	184	INR	3	F04	+5.25	TECTEH			21H00076	600UL
8768	37	116							TECTEH			21H00077	600UL
8769	39	116	0.39	79	INR	6	06C	+5.09	TECTEH			21H00076	600UL
8770	41	116							TECTEH			21H00077	600UL
8771	43	116							TECTEH			21H00076	600UL
8772	45	116							TECTEH			21H00077	600UL
8773	47	116	0.47	68	INR	6	06C	+25.42	TECTEH			21H00076	600UL
8774			0.40	65	INR	6	05C	+37.77	TECTEH			21H00076	600UL
8775	49	116							TECTEH			21H00076	600UL
8776	51	116							TECTEH			21H00071	600UL
8777	53	116							TECTEH			21H00070	600UL
8778	55	116	0.39	57	INR	6	05H	+28.06	TECTEH			21H00071	600UL
8779	57	116							TECTEH			21H00070	600UL
8780	59	116							TECTEH			21H00071	600UL
8781	61	116							TECTEH			21H00070	600UL
8782	63	116	0.58	70	INR	6	01C	+12.17	TECTEH			21H00071	600UL
8783	65	116	0.50	70	INR	6	05H	+14.27	TECTEH			21H00070	600UL
8784			0.58	49	INR	6	F04	+8.95	TECTEH			21H00070	600UL
8785			0.50	60	INR	6	F06	+10.74	TECTEH			21H00070	600UL
8786					INF		F07	+4.60	TECTEH	HR		21H00070	600UL
8787			0.49	54	INR	6	F08	+6.88	TECTEH			21H00070	600UL
8788					INF		F09	+6.68	TECTEH	HR		21H00070	600UL
8789			0.43	88	INR	6	02C	+3.46	TECTEH			21H00070	600UL
8790	67	116	0.68	54	INR	6	F06	+2.51	TECTEH			21H00071	600UL
8791	69	116							TECTEH			21H00070	600UL
8792	71	116	0.59	64	INR	6	F12	+3.35	TECTEH			21H00071	600UL
8793					INF		07C	+10.00	TECTEH	HR		21H00071	600UL
8794	73	116							TECTEH			21H00070	600UL
8795	75	116							TECTEH			21H00071	600UL
8796	77	116							TECTEH			21H00070	600UL
8797	79	116							TECTEH			21H00071	600UL
8798	81	116							TECTEH			21H00070	600UL
8799	83	116							TECTEH			21H00059	600UL
8800	85	116							TECTEH			21H00058	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8801	87	116	0.34	123	INR	3	05C	+8.63	TECTEH			21H00059	600UL
8802	89	116							TECTEH			21H00058	600UL
8803	91	116	1.40	128	INR	3	06H	+7.51	TECTEH			21H00059	600UL
8804	93	116							TECTEH			21H00058	600UL
8805	95	116							TECTEH			21H00059	600UL
8806	97	116	0.29	90	INR	6	01C	+15.07	TECTEH			21H00058	600UL
8807	99	116							TECTEH			21H00059	600UL
8808	101	116	0.68	76	INR	6	TSH	+11.96	TECTEH			21H00058	600UL
8809	103	116	0.84	47	INR	6	06H	+0.05	TECTEH			21H00059	600UL
8810	105	116			NDF	3	TEH	+10.62	TEHTSH			21H00087	610PP
8811			1.46	96	NQH	3	F08	+4.93	TECTEH			21H00058	600UL
8812					INF		F08	+9.77	TECTEH	HR		21H00058	600UL
8813	107	116							TECTEH			21H00059	600UL
8814	109	116							TECTEH			21H00058	600UL
8815	111	116							TECTEH			21H00059	600UL
8816	113	116							TECTEH			21H00058	600UL
8817	115	116							TECTEH			21H00059	600UL
8818	117	116	0.64	41	INR	6	F11	+0.00	TECTEH			21H00058	600UL
8819	119	116							TECTEH			21H00059	600UL
8820	121	116	0.91	78	INR	6	06C	+15.67	TECTEH			21H00058	600UL
8821			0.49	74	INR	6	06C	+26.31	TECTEH			21H00058	600UL
8822					INF		06C	+28.08	TECTEH	HR		21H00058	600UL
8823	123	116	0.41	123	INR	3	04C	+11.36	TECTEH			21H00059	600UL
8824	125	116							TECTEH			21H00058	600UL
8825	127	116							TECTEH			21H00059	600UL
8826	129	116							TECTEH			21H00058	600UL
8827	2	117							TECTEH			21H00084	600UL
8828	4	117							TECTEH			21H00085	600UL
8829	6	117							TECTEH			21H00084	600UL
8830	8	117							TECTEH			21H00083	600UL
8831	10	117							TECTEH			21H00082	600UL
8832	12	117							TECTEH			21H00083	600UL
8833	14	117							TECTEH			21H00082	600UL
8834	16	117			INF		02C	+25.77	TECTEH	HR		21H00081	600UL
8835			0.70	62	INR	6	02C	+28.39	TECTEH			21H00081	600UL
8836	18	117							TECTEH			21H00080	600UL
8837	20	117							TECTEH			21H00081	600UL
8838	22	117							TECTEH			21H00080	600UL
8839	24	117							TECTEH			21H00080	600UL
8840	26	117							TECTEH			21H00077	600UL
8841	28	117							TECTEH			21H00076	600UL
8842	30	117							TECTEH			21H00077	600UL
8843	32	117							TECTEH			21H00076	600UL
8844	34	117							TECTEH			21H00077	600UL
8845	36	117							TECTEH			21H00076	600UL
8846	38	117							TECTEH			21H00077	600UL
8847	40	117							TECTEH			21H00076	600UL
8848	42	117							TECTEH			21H00077	600UL
8849	44	117							TECTEH			21H00076	600UL
8850	46	117							TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8851	48	117							TECTEH			21H00076	600UL
8852	50	117							TECTEH			21H00071	600UL
8853	52	117							TECTEH			21H00070	600UL
8854					NDF	3	TEH	+1.68	TEHTSH			21H00087	610PP
8855	54	117							TECTEH			21H00071	600UL
8856	56	117							TECTEH			21H00070	600UL
8857	58	117	0.79	74	INR	6	02C	+20.20	TECTEH			21H00071	600UL
8858	60	117							TECTEH			21H00070	600UL
8859	62	117	0.49	59	INR	6	05H	+27.17	TECTEH			21H00071	600UL
8860	64	117	0.63	80	INR	6	03H	+11.80	TECTEH			21H00070	600UL
8861	66	117	0.63	80	INR	6	01C	+7.04	TECTEH			21H00071	600UL
8862					INF		01C	+13.11	TECTEH	HR		21H00071	600UL
8863	68	117	0.61	82	INR	6	F07	+7.17	TECTEH			21H00070	600UL
8864					INF		F08	+5.34	TECTEH	HR		21H00070	600UL
8865	70	117	1.12	34	INR	6	F05	+0.71	TECTEH			21H00071	600UL
8866			0.47	93	INR	6	04C	+39.28	TECTEH			21H00071	600UL
8867	72	117	0.63	80	INR	6	03H	+16.10	TECTEH			21H00070	600UL
8868					INF		F04	+12.99	TECTEH	HR		21H00070	600UL
8869			0.96	129	INR	6	F06	-0.74	TECTEH			21H00070	600UL
8870			0.58	74	INR	6	06C	+15.53	TECTEH			21H00070	600UL
8871			0.49	73	INR	6	03C	+30.43	TECTEH			21H00070	600UL
8872	74	117							TECTEH			21H00071	600UL
8873	76	117	1.39	78	INR	6	F03	+10.77	TECTEH			21H00070	600UL
8874	78	117	0.57	74	INR	6	01H	+21.22	TECTEH			21H00071	600UL
8875			0.52	84	INR	6	02H	+13.17	TECTEH			21H00071	600UL
8876			0.50	77	INR	6	02H	+29.08	TECTEH			21H00071	600UL
8877			0.49	77	INR	6	04H	+25.65	TECTEH			21H00071	600UL
8878			0.47	112	INR	3	06H	+29.22	TECTEH			21H00071	600UL
8879			0.39	78	INR	6	05C	+22.28	TECTEH			21H00071	600UL
8880			0.73	76	INR	6	04C	+28.35	TECTEH			21H00071	600UL
8881	80	117							TECTEH			21H00070	600UL
8882	82	117	0.67	77	INR	6	01C	+30.17	TECTEH			21H00061	600UL
8883	84	117	0.74	81	INR	6	02H	+32.71	TECTEH			21H00060	600UL
8884			0.74	81	INR	6	03H	+36.55	TECTEH			21H00060	600UL
8885			0.74	77	INR	6	05H	+32.37	TECTEH			21H00060	600UL
8886			0.43	60	INR	6	F09	+11.17	TECTEH			21H00060	600UL
8887					INF		F10	+0.85	TECTEH	HR		21H00060	600UL
8888	86	117	0.61	50	INR	6	F04	+0.00	TECTEH			21H00061	600UL
8889			0.46	81	INR	6	06C	+2.49	TECTEH			21H00061	600UL
8890			0.47	64	INR	6	06C	+36.16	TECTEH			21H00061	600UL
8891			0.47	66	INR	6	04C	+27.12	TECTEH			21H00061	600UL
8892	88	117							TECTEH			21H00060	600UL
8893	90	117							TECTEH			21H00061	600UL
8894	92	117	0.39	73	INR	3	F07	+2.96	TECTEH			21H00060	600UL
8895					INF		F08	+11.70	TECTEH	HR		21H00060	600UL
8896	94	117							TECTEH			21H00061	600UL
8897	96	117							TECTEH			21H00060	600UL
8898	98	117							TECTEH			21H00061	600UL
8899	100	117							TECTEH			21H00060	600UL
8900	102	117	0.86	70	INR	6	04H	+37.30	TECTEH			21H00061	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8901			1.03	60	INR	6	F06	+8.80	TECTEH			21H00061	600UL
8902	104	117							TECTEH			21H00060	600UL
8903	106	117							TECTEH			21H00061	600UL
8904	108	117	0.76	52	INR	6	TSH	+22.19	TECTEH			21H00060	600UL
8905	110	117							TECTEH			21H00061	600UL
8906	112	117							TECTEH			21H00060	600UL
8907	114	117							TECTEH			21H00059	600UL
8908	116	117	0.45	85	INR	6	04H	+6.27	TECTEH			21H00060	600UL
8909	118	117							TECTEH			21H00059	600UL
8910	120	117	0.24	80	INR	6	03H	+4.69	TECTEH			21H00058	600UL
8911			0.36	78	INR	6	TSC	+8.60	TECTEH			21H00058	600UL
8912	122	117	0.60	121	INR	3	04H	+26.13	TECTEH			21H00059	600UL
8913			0.70	124	INR	3	05H	+15.50	TECTEH			21H00059	600UL
8914			0.29	103	INR	3	06H	+5.33	TECTEH			21H00059	600UL
8915			0.78	147	INR	3	F03	+14.72	TECTEH			21H00059	600UL
8916			0.49	127	INR	3	01C	+17.69	TECTEH			21H00059	600UL
8917	124	117							TECTEH			21H00058	600UL
8918	126	117							TECTEH			21H00059	600UL
8919	128	117	0.49	95	INR	6	02H	+18.20	TECTEH			21H00058	600UL
8920			0.44	81	INR	6	06C	+16.04	TECTEH			21H00058	600UL
8921			0.49	81	INR	6	06C	+30.78	TECTEH			21H00058	600UL
8922			0.58	87	INR	6	02C	+4.83	TECTEH			21H00058	600UL
8923			0.58	58	INR	6	01C	+0.00	TECTEH			21H00058	600UL
8924			0.56	86	INR	6	01C	+12.70	TECTEH			21H00058	600UL
8925	1	118							TECTEH			21H00085	600UL
8926	3	118							TECTEH			21H00084	600UL
8927	5	118							TECTEH			21H00085	600UL
8928	7	118							TECTEH			21H00084	600UL
8929	9	118							TECTEH			21H00083	600UL
8930	11	118							TECTEH			21H00082	600UL
8931	13	118							TECTEH			21H00083	600UL
8932	15	118							TECTEH			21H00082	600UL
8933	17	118							TECTEH			21H00081	600UL
8934	19	118							TECTEH			21H00080	600UL
8935	21	118	3.74	182	INR	1	F01	+6.69	TECTEH			21H00081	600UL
8936					INF		F05	+2.56	TECTEH	HR		21H00081	600UL
8937	23	118							TECTEH			21H00080	600UL
8938	25	118							TECTEH			21H00077	600UL
8939	27	118							TECTEH			21H00076	600UL
8940	29	118							TECTEH			21H00077	600UL
8941	31	118							TECTEH			21H00076	600UL
8942	33	118							TECTEH			21H00077	600UL
8943	35	118	0.37	63	INR	6	06C	+4.73	TECTEH			21H00076	600UL
8944	37	118							TECTEH			21H00077	600UL
8945	39	118							TECTEH			21H00076	600UL
8946	41	118	0.31	128	INR	3	02H	+11.16	TECTEH			21H00077	600UL
8947			0.45	119	INR	3	02C	+12.89	TECTEH			21H00077	600UL
8948	43	118							TECTEH			21H00076	600UL
8949	45	118							TECTEH			21H00077	600UL
8950	47	118	1.07	75	INR	6	01H	+19.56	TECTEH			21H00076	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
8951			0.61	67	INR	6	02H	+22.74	TECTEH			21H00076	600UL
8952			0.45	74	INR	6	06H	+36.40	TECTEH			21H00076	600UL
8953			4.32	5	INR	1	F12	+10.34	TECTEH			21H00076	600UL
8954	49	118							TECTEH			21H00076	600UL
8955	51	118							TECTEH			21H00071	600UL
8956	53	118							TECTEH			21H00070	600UL
8957	55	118							TECTEH			21H00071	600UL
8958	57	118							TECTEH			21H00070	600UL
8959	59	118	0.51	78	INR	6	02C	+26.62	TECTEH			21H00071	600UL
8960	61	118							TECTEH			21H00070	600UL
8961	63	118							TECTEH			21H00071	600UL
8962	65	118							TECTEH			21H00070	600UL
8963	67	118							TECTEH			21H00071	600UL
8964	69	118							TECTEH			21H00070	600UL
8965	71	118	0.52	81	INR	6	04C	+31.22	TECTEH			21H00071	600UL
8966	73	118	0.70	72	INR	6	03H	+7.94	TECTEH			21H00070	600UL
8967	75	118							TECTEH			21H00071	600UL
8968	77	118							TECTEH			21H00070	600UL
8969	79	118							TECTEH			21H00070	600UL
8970	81	118							TECTEH			21H00061	600UL
8971	83	118							TECTEH			21H00060	600UL
8972	85	118							TECTEH			21H00061	600UL
8973	87	118							TECTEH			21H00060	600UL
8974	89	118							TECTEH			21H00061	600UL
8975	91	118	0.40	91	INR	6	TSH	+12.65	TECTEH			21H00060	600UL
8976			0.53	64	INR	6	03C	+4.75	TECTEH			21H00060	600UL
8977	93	118							TECTEH			21H00061	600UL
8978	95	118							TECTEH			21H00060	600UL
8979	97	118							TECTEH			21H00061	600UL
8980	99	118	0.51	81	INR	6	04H	+30.82	TECTEH			21H00060	600UL
8981	101	118							TECTEH			21H00061	600UL
8982	103	118							TECTEH			21H00060	600UL
8983	105	118	0.93	80	INR	6	03C	+11.60	TECTEH			21H00061	600UL
8984	107	118	0.61	90	INR	6	F06	+14.65	TECTEH			21H00060	600UL
8985					INF		F07	+3.01	TECTEH	HR		21H00060	600UL
8986	109	118	0.42	67	INR	6	F04	+14.66	TECTEH			21H00061	600UL
8987			0.59	60	INR	6	05C	+2.58	TECTEH			21H00061	600UL
8988			0.58	63	INR	6	02C	+7.95	TECTEH			21H00061	600UL
8989			0.50	78	INR	6	02C	+11.36	TECTEH			21H00061	600UL
8990			0.58	65	INR	6	TSC	+11.49	TECTEH			21H00061	600UL
8991	111	118							TECTEH			21H00060	600UL
8992	113	118							TECTEH			21H00061	600UL
8993	115	118	0.60	82	INR	6	TSC	+11.05	TECTEH			21H00060	600UL
8994	117	118							TECTEH			21H00061	600UL
8995	119	118							TECTEH			21H00060	600UL
8996	121	118							TECTEH			21H00061	600UL
8997	123	118	0.77	79	INR	6	02H	+3.25	TECTEH			21H00060	600UL
8998			0.83	78	INR	6	05C	+31.41	TECTEH			21H00060	600UL
8999			0.47	82	INR	6	04C	+35.80	TECTEH			21H00060	600UL
9000	125	118	0.68	65	INR	6	06H	+21.66	TECTEH			21H00061	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9001					INF		06H	+23.04	TECTEH	HR		21H00061	600UL
9002					INF		05C	+18.93	TECTEH	HR		21H00061	600UL
9003			1.91	78	INR	6	05C	+20.46	TECTEH			21H00061	600UL
9004	127	118							TECTEH			21H00060	600UL
9005	2	119	0.68	65	INR	6	03C	+24.80	TECTEH			21H00085	600UL
9006	4	119							TECTEH			21H00084	600UL
9007	6	119							TECTEH			21H00084	600UL
9008	8	119							TECTEH			21H00083	600UL
9009	10	119							TECTEH			21H00082	600UL
9010	12	119							TECTEH			21H00083	600UL
9011	14	119							TECTEH			21H00082	600UL
9012	16	119							TECTEH			21H00081	600UL
9013	18	119							TECTEH			21H00080	600UL
9014	20	119							TECTEH			21H00081	600UL
9015	22	119	6.34	178	INR	P1	F05	+2.47	TECTEH			21H00080	600UL
9016	24	119							TECTEH			21H00080	600UL
9017	26	119							TECTEH			21H00077	600UL
9018	28	119							TECTEH			21H00076	600UL
9019	30	119							TECTEH			21H00077	600UL
9020	32	119							TECTEH			21H00076	600UL
9021	34	119							TECTEH			21H00077	600UL
9022	36	119							TECTEH			21H00076	600UL
9023	38	119							TECTEH			21H00077	600UL
9024	40	119							TECTEH			21H00076	600UL
9025	42	119							TECTEH			21H00077	600UL
9026	44	119							TECTEH			21H00076	600UL
9027	46	119							TECTEH			21H00077	600UL
9028	48	119	0.41	71	INR	6	06H	+22.82	TECTEH			21H00076	600UL
9029			0.42	59	INR	6	06C	+32.36	TECTEH			21H00076	600UL
9030	50	119							TECTEH			21H00071	600UL
9031	52	119	0.32	77	INR	6	04C	+19.85	TECTEH			21H00070	600UL
9032	54	119							TECTEH			21H00071	600UL
9033	56	119							TECTEH			21H00070	600UL
9034	58	119	0.65	84	INR	6	02H	+29.44	TECTEH			21H00071	600UL
9035			0.50	64	INR	6	02C	+29.23	TECTEH			21H00071	600UL
9036	60	119	0.81	59	INR	6	TSH	+21.89	TECTEH			21H00070	600UL
9037	62	119							TECTEH			21H00071	600UL
9038	64	119	0.41	64	INR	6	05C	+18.56	TECTEH			21H00070	600UL
9039	66	119							TECTEH			21H00071	600UL
9040	68	119	0.59	77	INR	6	01C	+12.81	TECTEH			21H00070	600UL
9041	70	119							TECTEH			21H00071	600UL
9042	72	119	0.43	251	INR	6	06H	+27.19	TECTEH			21H00070	600UL
9043			0.33	80	INR	6	02C	+12.18	TECTEH			21H00070	600UL
9044	74	119							TECTEH			21H00071	600UL
9045	76	119	0.94	146	INR	6	F03	+2.40	TECTEH			21H00070	600UL
9046			0.93	144	INR	6	F03	+2.45	TECTEH			21H00070	600UL
9047			0.58	43	INR	6	F04	+4.82	TECTEH			21H00070	600UL
9048			0.58	43	INR	6	F04	+4.85	TECTEH			21H00070	600UL
9049	78	119	0.41	63	INR	6	04H	+22.19	TECTEH			21H00071	600UL
9050	80	119							TECTEH			21H00070	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9051	82	119							TECTEH			21H00060	600UL
9052	84	119			INF		F01	+2.83	TECTEH	HR		21H00061	600UL
9053			2.77	182	INR	P1	F02	-1.94	TECTEH			21H00061	600UL
9054	86	119	0.77	90	NQH	3	TSC	+1.00	TECTEH			21H00060	600UL
9055	88	119							TECTEH			21H00061	600UL
9056	90	119							TECTEH			21H00060	600UL
9057	92	119	0.64	76	INR	6	05H	+26.29	TECTEH			21H00061	600UL
9058			0.52	79	INR	6	05C	+5.21	TECTEH			21H00061	600UL
9059			0.46	58	INR	6	05C	+27.64	TECTEH			21H00061	600UL
9060	94	119							TECTEH			21H00060	600UL
9061	96	119							TECTEH			21H00061	600UL
9062	98	119	0.59	78	INR	6	03C	+17.40	TECTEH			21H00060	600UL
9063	100	119	0.49	77	INR	6	02H	+8.02	TECTEH			21H00061	600UL
9064			0.49	69	INR	6	03H	+6.49	TECTEH			21H00061	600UL
9065	102	119							TECTEH			21H00060	600UL
9066	104	119	0.56	76	INR	6	03C	+16.28	TECTEH			21H00061	600UL
9067	106	119							TECTEH			21H00060	600UL
9068	108	119							TECTEH			21H00061	600UL
9069	110	119							TECTEH			21H00060	600UL
9070	112	119							TECTEH			21H00061	600UL
9071	114	119	0.93	86	NQH	3	F04	+6.74	TECTEH			21H00060	600UL
9072	116	119	0.61	52	INR	6	06H	+39.63	TECTEH			21H00061	600UL
9073	118	119							TECTEH			21H00060	600UL
9074	120	119							TECTEH			21H00061	600UL
9075	122	119	0.46	83	INR	6	07H	+7.47	TECTEH			21H00060	600UL
9076			0.44	74	INR	6	06C	+2.39	TECTEH			21H00060	600UL
9077			0.31	72	INR	3	01C	+16.89	TECTEH			21H00060	600UL
9078	124	119							TECTEH			21H00061	600UL
9079	126	119							TECTEH			21H00060	600UL
9080	1	120							TECTEH			21H00085	600UL
9081	3	120							TECTEH			21H00084	600UL
9082	5	120							TECTEH			21H00085	600UL
9083	7	120							TECTEH			21H00084	600UL
9084	9	120							TECTEH			21H00083	600UL
9085	11	120	0.88	69	INR	6	05H	+21.71	TECTEH			21H00082	600UL
9086	13	120							TECTEH			21H00083	600UL
9087	15	120							TECTEH			21H00082	600UL
9088	17	120							TECTEH			21H00081	600UL
9089	19	120							TECTEH			21H00080	600UL
9090	21	120	6.27	182	INR	1	F01	+7.51	TECTEH			21H00081	600UL
9091					INF		F05	+3.53	TECTEH	HR		21H00081	600UL
9092	23	120							TECTEH			21H00080	600UL
9093	25	120							TECTEH			21H00077	600UL
9094	27	120							TECTEH			21H00076	600UL
9095	29	120							TECTEH			21H00077	600UL
9096	31	120							TECTEH			21H00076	600UL
9097	33	120							TECTEH			21H00077	600UL
9098	35	120							TECTEH			21H00076	600UL
9099	37	120							TECTEH			21H00077	600UL
9100	39	120							TECTEH			21H00076	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9101	41	120							TECTEH			21H00077	600UL
9102	43	120							TECTEH			21H00076	600UL
9103	45	120							TECTEH			21H00077	600UL
9104	47	120							TECTEH			21H00076	600UL
9105	49	120							TECTEH			21H00076	600UL
9106	51	120							TECTEH			21H00071	600UL
9107	53	120							TECTEH			21H00070	600UL
9108	55	120							TECTEH			21H00071	600UL
9109	57	120							TECTEH			21H00070	600UL
9110	59	120	1.01	59	INR	6	04H	+39.80	TECTEH			21H00071	600UL
9111	61	120							TECTEH			21H00070	600UL
9112	63	120			INF		03H	+4.32	TECTEH	PVI		21H00071	600UL
9113					INF		03H	+4.32	TECTEH	PVI	IDOK	21H00072	600UL
9114					INF		06C	+15.61	TECTEH	PVI	IDOK	21H00072	600UL
9115					INF		06C	+15.61	TECTEH	PVI		21H00071	600UL
9116					INF		05C	+31.29	TECTEH	PVI		21H00071	600UL
9117					INF		05C	+31.29	TECTEH	PVI	IDOK	21H00072	600UL
9118	65	120							TECTEH			21H00070	600UL
9119	67	120							TECTEH			21H00071	600UL
9120	69	120							TECTEH			21H00070	600UL
9121	71	120							TECTEH			21H00073	600UL
9122	73	120							TECTEH			21H00072	600UL
9123	75	120	0.70	82	INR	6	TSH	+8.71	TECTEH			21H00073	600UL
9124	77	120							TECTEH			21H00072	600UL
9125	79	120							TECTEH			21H00073	600UL
9126	81	120							TECTEH			21H00072	600UL
9127	83	120							TECTEH			21H00061	600UL
9128	85	120							TECTEH			21H00060	600UL
9129	87	120							TECTEH			21H00061	600UL
9130	89	120							TECTEH			21H00060	600UL
9131	91	120	0.83	84	INR	6	05C	+19.07	TECTEH			21H00061	600UL
9132	93	120							TECTEH			21H00060	600UL
9133	95	120	0.39	73	INR	6	07H	+9.54	TECTEH			21H00061	600UL
9134			1.62	75	INR	6	F07	+7.60	TECTEH			21H00061	600UL
9135					INF		F08	+8.61	TECTEH	HR		21H00061	600UL
9136			0.44	66	INR	6	03C	+37.83	TECTEH			21H00061	600UL
9137	97	120							TECTEH			21H00060	600UL
9138	99	120							TECTEH			21H00061	600UL
9139	101	120	0.29	97	INR	6	01H	+26.11	TECTEH			21H00060	600UL
9140			0.60	61	INR	6	F04	+3.98	TECTEH			21H00060	600UL
9141	103	120	0.51	67	INR	6	06C	+8.98	TECTEH			21H00061	600UL
9142			0.39	65	INR	6	06C	+10.12	TECTEH			21H00061	600UL
9143			0.41	79	INR	6	05C	+28.44	TECTEH			21H00061	600UL
9144	105	120							TECTEH			21H00060	600UL
9145	107	120							TECTEH			21H00061	600UL
9146	109	120			INF		F07	+0.00	TECTEH	HR		21H00060	600UL
9147			0.49	69	INR	6	F07	+3.99	TECTEH			21H00060	600UL
9148	111	120							TECTEH			21H00061	600UL
9149	113	120	0.50	85	INR	6	04H	+38.15	TECTEH			21H00060	600UL
9150			0.54	64	INR	6	05H	+17.42	TECTEH			21H00060	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9151			0.36	106	INR	3	06H	+23.51	TECTEH			21H00060	600UL
9152			0.75	84	INR	6	06C	+24.62	TECTEH			21H00060	600UL
9153			0.59	96	INR	6	02C	+16.98	TECTEH			21H00060	600UL
9154	115	120	0.71	73	INR	6	01C	+10.88	TECTEH			21H00061	600UL
9155					INF		01C	+13.56	TECTEH	HR		21H00061	600UL
9156	117	120	0.61	77	INR	6	01H	+14.42	TECTEH			21H00060	600UL
9157			0.43	103	INR	3	06H	+11.18	TECTEH			21H00060	600UL
9158			0.76	74	INR	6	02C	+19.48	TECTEH			21H00060	600UL
9159			0.61	73	INR	6	02C	+27.98	TECTEH			21H00060	600UL
9160	119	120							TECTEH			21H00061	600UL
9161	121	120	0.41	109	INR	3	05H	+30.17	TECTEH			21H00060	600UL
9162			0.45	83	INR	6	05C	+3.69	TECTEH			21H00060	600UL
9163	123	120							TECTEH			21H00061	600UL
9164	125	120	0.44	97	INR	3	F03	+13.50	TECTEH			21H00060	600UL
9165			0.80	79	INR	6	05C	+4.90	TECTEH			21H00060	600UL
9166	127	120	0.70	41	INR	6	F02	+16.48	TECTEH			21H00060	600UL
9167	2	121							TECTEH			21H00085	600UL
9168	4	121							TECTEH			21H00084	600UL
9169	6	121							TECTEH			21H00084	600UL
9170	8	121							TECTEH			21H00083	600UL
9171	10	121							TECTEH			21H00082	600UL
9172	12	121							TECTEH			21H00083	600UL
9173	14	121							TECTEH			21H00082	600UL
9174	16	121							TECTEH			21H00081	600UL
9175	18	121							TECTEH			21H00080	600UL
9176	20	121							TECTEH			21H00081	600UL
9177	22	121			INF		F01	+5.76	TECTEH	HR		21H00080	600UL
9178			5.90	180	INR	P1	F05	+1.68	TECTEH			21H00080	600UL
9179	24	121							TECTEH			21H00080	600UL
9180	26	121							TECTEH			21H00077	600UL
9181	28	121							TECTEH			21H00076	600UL
9182	30	121							TECTEH			21H00077	600UL
9183	32	121							TECTEH			21H00076	600UL
9184	34	121							TECTEH			21H00077	600UL
9185	36	121							TECTEH			21H00076	600UL
9186	38	121							TECTEH			21H00077	600UL
9187	40	121							TECTEH			21H00076	600UL
9188	42	121							TECTEH			21H00077	600UL
9189	44	121							TECTEH			21H00076	600UL
9190	46	121							TECTEH			21H00077	600UL
9191	48	121							TECTEH			21H00076	600UL
9192	50	121	0.68	77	INR	6	01H	+5.91	TECTEH			21H00073	600UL
9193			0.44	77	INR	6	F05	+9.73	TECTEH			21H00073	600UL
9194			0.76	100	INR	6	F07	+3.66	TECTEH			21H00073	600UL
9195					INF		F08	+9.26	TECTEH	HR		21H00073	600UL
9196	52	121	0.33	73	INR	6	02H	+4.07	TECTEH			21H00072	600UL
9197			0.55	82	INR	6	01C	+25.31	TECTEH			21H00072	600UL
9198	54	121							TECTEH			21H00073	600UL
9199	56	121							TECTEH			21H00072	600UL
9200	58	121	2.63	32	INR	6	F10	+2.46	TECTEH			21H00073	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9201					INF		07C	+4.05	TECTEH	HR		21H00073	600UL
9202	60	121							TECTEH			21H00072	600UL
9203	62	121	1.13	78	INR	6	03H	+13.07	TECTEH			21H00073	600UL
9204	64	121							TECTEH			21H00072	600UL
9205	66	121	0.57	71	INR	6	06H	+33.24	TECTEH			21H00073	600UL
9206			0.96	92	INR	6	F07	+10.83	TECTEH			21H00073	600UL
9207					INF		F08	-1.99	TECTEH	HR		21H00073	600UL
9208					INF		F08	+0.90	TECTEH	HR		21H00073	600UL
9209	68	121	0.40	74	INR	6	F06	+8.02	TECTEH			21H00072	600UL
9210	70	121	0.61	71	INR	6	04H	+6.13	TECTEH			21H00073	600UL
9211	72	121	0.47	157	INR	6	F12	+2.80	TECTEH			21H00072	600UL
9212					INF		07C	+12.07	TECTEH	HR		21H00072	600UL
9213			0.59	80	INR	6	04C	+14.34	TECTEH			21H00072	600UL
9214	74	121							TECTEH			21H00073	600UL
9215	76	121	0.54	79	INR	6	TSC	+20.18	TECTEH			21H00072	600UL
9216	78	121							TECTEH			21H00073	600UL
9217	80	121							TECTEH			21H00072	600UL
9218	82	121							TECTEH			21H00060	600UL
9219	84	121	0.28	126	INR	3	03C	+22.60	TECTEH			21H00061	600UL
9220	86	121	0.47	67	INR	6	02C	+4.42	TECTEH			21H00060	600UL
9221	88	121							TECTEH			21H00061	600UL
9222	90	121	0.45	82	INR	6	02H	+17.34	TECTEH			21H00060	600UL
9223	92	121	0.30	122	INR	3	06H	+3.83	TECTEH			21H00061	600UL
9224	94	121	0.35	83	INR	6	F08	+8.58	TECTEH			21H00060	600UL
9225					INF		F09	+7.40	TECTEH	HR		21H00060	600UL
9226	96	121	0.34	123	INR	3	03H	+27.90	TECTEH			21H00061	600UL
9227			0.34	126	INR	3	04H	+6.74	TECTEH			21H00061	600UL
9228	98	121	0.72	82	INR	6	04H	+8.24	TECTEH			21H00060	600UL
9229			0.55	3	INR	6	F01	+3.68	TECTEH			21H00060	600UL
9230			0.49	79	INR	6	F05	+14.01	TECTEH			21H00060	600UL
9231			0.66	85	INR	6	06C	+8.02	TECTEH			21H00060	600UL
9232	100	121	0.47	133	INR	3	TSH	+2.09	TECTEH			21H00061	600UL
9233	102	121							TECTEH			21H00060	600UL
9234	104	121	0.78	110	INR	3	F08	-1.97	TECTEH			21H00061	600UL
9235					INF		F08	+1.86	TECTEH	HR		21H00061	600UL
9236	106	121							TECTEH			21H00060	600UL
9237	108	121							TECTEH			21H00061	600UL
9238	110	121	1.44	13	INR	6	05H	+39.78	TECTEH			21H00060	600UL
9239	112	121	0.35	127	INR	3	05H	+37.54	TECTEH			21H00061	600UL
9240	114	121							TECTEH			21H00060	600UL
9241	116	121							TECTEH			21H00061	600UL
9242	118	121							TECTEH			21H00060	600UL
9243	120	121	0.35	123	INR	3	05H	+24.75	TECTEH			21H00061	600UL
9244			0.34	129	INR	3	01C	+13.01	TECTEH			21H00061	600UL
9245	122	121	0.46	90	NQH	3	F05	+3.53	TECTEH			21H00060	600UL
9246			0.65	82	INR	6	05C	+33.84	TECTEH			21H00060	600UL
9247			0.45	80	INR	6	03C	+6.21	TECTEH			21H00060	600UL
9248	124	121	0.81	71	INR	6	02H	+23.02	TECTEH			21H00061	600UL
9249			0.66	61	INR	6	F10	+3.15	TECTEH			21H00061	600UL
9250					INF		F11	+14.91	TECTEH	HR		21H00061	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9251	126	121							TECTEH			21H00060	600UL
9252	1	122							TECTEH			21H00085	600UL
9253	3	122							TECTEH			21H00084	600UL
9254	5	122							TECTEH			21H00085	600UL
9255	7	122							TECTEH			21H00084	600UL
9256	9	122							TECTEH			21H00083	600UL
9257	11	122	0.42	59	INR	6	03H	+21.58	TECTEH			21H00082	600UL
9258	13	122							TECTEH			21H00083	600UL
9259	15	122							TECTEH			21H00082	600UL
9260	17	122							TECTEH			21H00081	600UL
9261	19	122							TECTEH			21H00080	600UL
9262	21	122	4.17	183	INR	1	F01	+7.81	TECTEH			21H00081	600UL
9263					INF		F01	+9.93	TECTEH	HR		21H00081	600UL
9264					INF		F05	+3.57	TECTEH	HR		21H00081	600UL
9265	23	122							TECTEH			21H00080	600UL
9266	25	122							TECTEH			21H00077	600UL
9267	27	122							TECTEH			21H00076	600UL
9268	29	122							TECTEH			21H00077	600UL
9269	31	122							TECTEH			21H00076	600UL
9270	33	122							TECTEH			21H00077	600UL
9271	35	122							TECTEH			21H00076	600UL
9272	37	122							TECTEH			21H00077	600UL
9273	39	122							TECTEH			21H00076	600UL
9274	41	122							TECTEH			21H00077	600UL
9275	43	122							TECTEH			21H00076	600UL
9276	45	122							TECTEH			21H00077	600UL
9277	47	122	0.49	57	INR	6	04C	+33.59	TECTEH			21H00076	600UL
9278					INF		01C	+23.93	TECTEH	HR		21H00076	600UL
9279			0.55	64	INR	6	01C	+27.60	TECTEH			21H00076	600UL
9280	49	122							TECTEH			21H00076	600UL
9281	51	122							TECTEH			21H00073	600UL
9282	53	122							TECTEH			21H00072	600UL
9283	55	122							TECTEH			21H00073	600UL
9284	57	122	0.39	66	INR	6	02C	+8.00	TECTEH			21H00072	600UL
9285	59	122							TECTEH			21H00073	600UL
9286	61	122	0.44	80	INR	6	06C	+7.46	TECTEH			21H00072	600UL
9287	63	122							TECTEH			21H00073	600UL
9288	65	122	0.44	63	INR	6	03H	+30.97	TECTEH			21H00072	600UL
9289			0.48	106	INR	6	F06	+11.12	TECTEH			21H00072	600UL
9290					INF		F07	+10.10	TECTEH	HR		21H00072	600UL
9291	67	122	0.94	77	INR	6	01H	+14.02	TECTEH			21H00073	600UL
9292	69	122							TECTEH			21H00072	600UL
9293	71	122							TECTEH			21H00073	600UL
9294	73	122	0.39	74	INR	6	01H	+25.63	TECTEH			21H00072	600UL
9295			0.85	23	INR	6	F05	+12.54	TECTEH			21H00072	600UL
9296			0.28	55	INR	6	F07	+2.03	TECTEH			21H00072	600UL
9297					INF		F08	+12.04	TECTEH	HR		21H00072	600UL
9298	75	122							TECTEH			21H00073	600UL
9299	77	122							TECTEH			21H00072	600UL
9300	79	122							TECTEH			21H00073	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9301	81	122							TECTEH			21H00072	600UL
9302	83	122							TECTEH			21H00061	600UL
9303	85	122							TECTEH			21H00060	600UL
9304	87	122							TECTEH			21H00061	600UL
9305	89	122	0.42	71	INR	6	05H	+24.61	TECTEH			21H00060	600UL
9306	91	122							TECTEH			21H00061	600UL
9307	93	122							TECTEH			21H00060	600UL
9308	95	122							TECTEH			21H00061	600UL
9309	97	122							TECTEH			21H00060	600UL
9310	99	122	0.22	111	INR	3	05H	+16.79	TECTEH			21H00061	600UL
9311	101	122							TECTEH			21H00060	600UL
9312	103	122							TECTEH			21H00061	600UL
9313	105	122							TECTEH			21H00060	600UL
9314	107	122							TECTEH			21H00061	600UL
9315	109	122	0.63	71	INR	6	F06	+15.13	TECTEH			21H00060	600UL
9316					INF		F07	+2.71	TECTEH	HR		21H00060	600UL
9317	111	122							TECTEH			21H00061	600UL
9318	113	122							TECTEH			21H00060	600UL
9319	115	122							TECTEH			21H00061	600UL
9320	117	122							TECTEH			21H00060	600UL
9321	119	122							TECTEH			21H00061	600UL
9322	121	122							TECTEH			21H00060	600UL
9323	123	122	0.44	133	INR	3	F05	+14.76	TECTEH			21H00061	600UL
9324	125	122							TECTEH			21H00060	600UL
9325	2	123	0.49	66	INR	6	01H	+12.87	TECTEH			21H00085	600UL
9326	4	123							TECTEH			21H00084	600UL
9327	6	123							TECTEH			21H00084	600UL
9328	8	123							TECTEH			21H00083	600UL
9329	10	123							TECTEH			21H00082	600UL
9330	12	123							TECTEH			21H00083	600UL
9331	14	123							TECTEH			21H00082	600UL
9332	16	123							TECTEH			21H00081	600UL
9333	18	123							TECTEH			21H00080	600UL
9334	20	123							TECTEH			21H00081	600UL
9335	22	123							TECTEH			21H00080	600UL
9336	24	123							TECTEH			21H00080	600UL
9337	26	123							TECTEH			21H00077	600UL
9338	28	123	0.40	73	INR	6	01H	+5.22	TECTEH			21H00076	600UL
9339	30	123	0.48	221	INR	6	03C	+39.53	TECTEH			21H00077	600UL
9340	32	123							TECTEH			21H00076	600UL
9341	34	123							TECTEH			21H00077	600UL
9342	36	123							TECTEH			21H00076	600UL
9343	38	123							TECTEH			21H00077	600UL
9344	40	123							TECTEH			21H00076	600UL
9345	42	123							TECTEH			21H00077	600UL
9346	44	123							TECTEH			21H00076	600UL
9347	46	123							TECTEH			21H00077	600UL
9348	48	123							TECTEH			21H00076	600UL
9349	50	123							TECTEH			21H00073	600UL
9350	52	123							TECTEH			21H00072	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9351	54	123							TECTEH			21H00073	600UL
9352	56	123							TECTEH			21H00072	600UL
9353	58	123							TECTEH			21H00073	600UL
9354	60	123							TECTEH			21H00072	600UL
9355	62	123	0.49	76	INR	6	03H	+29.23	TECTEH			21H00073	600UL
9356	64	123	0.49	72	INR	6	03H	+8.11	TECTEH			21H00072	600UL
9357	66	123							TECTEH			21H00073	600UL
9358	68	123	0.31	59	INR	6	04H	+38.59	TECTEH			21H00072	600UL
9359			0.32	63	INR	6	05H	+37.79	TECTEH			21H00072	600UL
9360	70	123	0.41	91	INR	6	04H	+18.18	TECTEH			21H00073	600UL
9361	72	123	0.34	76	INR	6	02H	+22.48	TECTEH			21H00072	600UL
9362	74	123	0.39	66	INR	6	06C	+29.69	TECTEH			21H00073	600UL
9363			0.44	88	INR	6	02C	+17.45	TECTEH			21H00073	600UL
9364	76	123							TECTEH			21H00072	600UL
9365	78	123	0.52	81	INR	6	03H	+28.36	TECTEH			21H00073	600UL
9366			0.64	70	INR	6	03H	+36.29	TECTEH			21H00073	600UL
9367			0.46	89	INR	6	04H	+20.81	TECTEH			21H00073	600UL
9368	80	123							TECTEH			21H00072	600UL
9369	82	123							TECTEH			21H00061	600UL
9370	84	123							TECTEH			21H00060	600UL
9371	86	123							TECTEH			21H00061	600UL
9372	88	123	0.34	70	INR	6	04H	+16.55	TECTEH			21H00060	600UL
9373	90	123							TECTEH			21H00061	600UL
9374	92	123							TECTEH			21H00060	600UL
9375	94	123	0.43	70	INR	3	01H	+2.25	TECTEH			21H00061	600UL
9376			0.84	232	INR	6	06H	+0.02	TECTEH			21H00061	600UL
9377			1.42	136	INR	3	02C	+24.78	TECTEH			21H00061	600UL
9378	96	123	0.43	70	INR	6	02H	+18.65	TECTEH			21H00060	600UL
9379	98	123	0.67	180	INR	1	TSC	+2.52	TECTEH			21H00061	600UL
9380	100	123	0.47	80	INR	6	F03	+10.38	TECTEH			21H00060	600UL
9381	102	123	0.73	124	INR	3	TSH	+7.96	TECTEH			21H00061	600UL
9382			0.60	124	INR	3	04H	+3.80	TECTEH			21H00061	600UL
9383	104	123							TECTEH			21H00060	600UL
9384	106	123	0.75	123	INR	3	05H	+22.02	TECTEH			21H00061	600UL
9385	108	123	2.47	46	INR	6	01H	+10.02 TO+22.97	TECTEH			21H00060	600UL
9386			0.73	77	INR	6	02H	+21.91	TECTEH			21H00060	600UL
9387	110	123							TECTEH			21H00061	600UL
9388	112	123	0.45	79	INR	6	06C	+17.45	TECTEH			21H00060	600UL
9389	114	123							TECTEH			21H00061	600UL
9390	116	123	0.65	113	INR	3	05H	+9.49	TECTEH			21H00060	600UL
9391			0.35	69	INR	6	05H	+14.78	TECTEH			21H00060	600UL
9392	118	123	0.26	136	INR	3	05H	+5.87	TECTEH			21H00061	600UL
9393			0.72	98	INR	3	F04	+12.68	TECTEH			21H00061	600UL
9394	120	123	0.36	87	INR	6	05C	+7.62	TECTEH			21H00060	600UL
9395	122	123	1.69	26	INR	6	F07	+0.08	TECTEH			21H00061	600UL
9396	124	123							TECTEH			21H00060	600UL
9397	1	124							TECTEH			21H00085	600UL
9398	3	124							TECTEH			21H00084	600UL
9399	5	124							TECTEH			21H00085	600UL
9400	7	124							TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9401	9	124							TECTEH			21H00083	600UL
9402	11	124							TECTEH			21H00082	600UL
9403	13	124							TECTEH			21H00083	600UL
9404	15	124							TECTEH			21H00082	600UL
9405	17	124							TECTEH			21H00081	600UL
9406	19	124							TECTEH			21H00080	600UL
9407	21	124	5.61	182	INR	1	F01	+7.42	TECTEH			21H00081	600UL
9408					INF		F05	+2.99	TECTEH	HR		21H00081	600UL
9409	23	124							TECTEH			21H00080	600UL
9410	25	124							TECTEH			21H00077	600UL
9411	27	124							TECTEH			21H00076	600UL
9412	29	124							TECTEH			21H00077	600UL
9413	31	124	0.71	72	INR	6	03C	+18.74	TECTEH			21H00076	600UL
9414	33	124							TECTEH			21H00077	600UL
9415	35	124							TECTEH			21H00076	600UL
9416	37	124							TECTEH			21H00077	600UL
9417	39	124	0.44	58	INR	6	04C	+30.70	TECTEH			21H00076	600UL
9418	41	124							TECTEH			21H00077	600UL
9419	43	124							TECTEH			21H00076	600UL
9420	45	124							TECTEH			21H00077	600UL
9421	47	124							TECTEH			21H00076	600UL
9422	49	124							TECTEH			21H00076	600UL
9423	51	124							TECTEH			21H00073	600UL
9424	53	124							TECTEH			21H00072	600UL
9425	55	124							TECTEH			21H00073	600UL
9426	57	124							TECTEH			21H00072	600UL
9427	59	124							TECTEH			21H00073	600UL
9428	61	124	0.76	85	INR	6	F04	-0.31	TECTEH			21H00072	600UL
9429					INF		F04	+0.87	TECTEH	HR		21H00072	600UL
9430			1.18	68	INR	6	F07	+10.44	TECTEH			21H00072	600UL
9431					INF		F08	+1.24	TECTEH	HR		21H00072	600UL
9432			0.40	82	INR	6	04C	+31.64	TECTEH			21H00072	600UL
9433			0.59	79	INR	6	01C	+11.63	TECTEH			21H00072	600UL
9434	63	124	0.38	71	INR	6	F09	+3.33	TECTEH			21H00073	600UL
9435					INF		F10	+7.53	TECTEH	HR		21H00073	600UL
9436	65	124	0.43	77	INR	6	F04	+6.86	TECTEH			21H00072	600UL
9437			0.37	74	INR	6	06C	+27.90	TECTEH			21H00072	600UL
9438	67	124							TECTEH			21H00073	600UL
9439	69	124							TECTEH			21H00072	600UL
9440	71	124	0.46	84	INR	6	F05	+11.47	TECTEH			21H00073	600UL
9441			0.70	76	INR	6	04C	+2.36	TECTEH			21H00073	600UL
9442			0.63	74	INR	6	03C	+36.38	TECTEH			21H00073	600UL
9443					INF		03C	+40.61	TECTEH	HR		21H00073	600UL
9444	73	124	0.21	93	INR	6	02H	+34.38	TECTEH			21H00072	600UL
9445	75	124							TECTEH			21H00073	600UL
9446	77	124	0.47	72	INR	6	02C	+13.18	TECTEH			21H00072	600UL
9447	79	124							TECTEH			21H00073	600UL
9448	81	124	0.32	81	INR	6	05C	+25.65	TECTEH			21H00072	600UL
9449	83	124							TECTEH			21H00061	600UL
9450	85	124							TECTEH			21H00060	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9451	87	124							TECTEH			21H00061	600UL
9452	89	124							TECTEH			21H00060	600UL
9453	91	124	0.26	110	INR	3	04H	+9.41	TECTEH			21H00061	600UL
9454			0.31	121	INR	3	01C	+30.30	TECTEH			21H00061	600UL
9455	93	124							TECTEH			21H00060	600UL
9456	95	124							TECTEH			21H00061	600UL
9457	97	124							TECTEH			21H00060	600UL
9458	99	124	0.64	126	INR	3	06H	+24.15	TECTEH			21H00061	600UL
9459	101	124							TECTEH			21H00060	600UL
9460	103	124	0.53	133	INR	3	06C	+20.46	TECTEH			21H00061	600UL
9461	105	124							TECTEH			21H00060	600UL
9462	107	124							TECTEH			21H00061	600UL
9463	109	124	0.57	83	INR	6	03C	+19.80	TECTEH			21H00060	600UL
9464	111	124	0.42	111	INR	3	F11	+2.48	TECTEH			21H00061	600UL
9465					INF		F12	+9.20	TECTEH	HR		21H00061	600UL
9466			0.29	133	INR	3	06C	+25.21	TECTEH			21H00061	600UL
9467	113	124							TECTEH			21H00060	600UL
9468	115	124	0.58	74	INR	6	03C	+12.56	TECTEH			21H00061	600UL
9469	117	124	0.45	76	INR	6	TSC	+8.05	TECTEH			21H00060	600UL
9470	119	124	1.30	76	INR	6	04H	+12.11	TECTEH			21H00061	600UL
9471			1.00	77	INR	6	04H	+13.04	TECTEH			21H00061	600UL
9472			0.51	76	INR	6	06H	+19.55	TECTEH			21H00061	600UL
9473			0.39	86	INR	6	F04	+6.64	TECTEH			21H00061	600UL
9474			1.74	78	INR	6	F04	+7.17	TECTEH			21H00061	600UL
9475			0.48	68	INR	6	F04	+9.62	TECTEH			21H00061	600UL
9476			0.92	74	INR	6	F04	+15.18	TECTEH			21H00061	600UL
9477			1.06	42	INR	6	F10	+14.86	TECTEH			21H00061	600UL
9478					INF		F11	+2.66	TECTEH	HR		21H00061	600UL
9479			0.54	75	INR	6	05C	+22.45	TECTEH			21H00061	600UL
9480			0.91	78	INR	6	02C	+9.02	TECTEH			21H00061	600UL
9481			1.01	77	INR	6	02C	+15.58	TECTEH			21H00061	600UL
9482			0.39	86	INR	6	TSC	+16.37	TECTEH			21H00061	600UL
9483	121	124							TECTEH			21H00060	600UL
9484	123	124	0.39	100	INR	3	07H	+12.01	TECTEH			21H00060	600UL
9485			0.43	110	INR	6	F01	+4.50	TECTEH			21H00060	600UL
9486					INF		F04	+12.46	TECTEH	HR		21H00060	600UL
9487			0.46	104	INR	6	F04	+13.70	TECTEH			21H00060	600UL
9488	2	125							TECTEH			21H00085	600UL
9489	4	125							TECTEH			21H00084	600UL
9490	6	125							TECTEH			21H00084	600UL
9491	8	125	0.41	118	INR	3	06C	+28.03	TECTEH			21H00083	600UL
9492	10	125							TECTEH			21H00082	600UL
9493	12	125							TECTEH			21H00083	600UL
9494	14	125							TECTEH			21H00082	600UL
9495	16	125							TECTEH			21H00081	600UL
9496	18	125							TECTEH			21H00080	600UL
9497	20	125							TECTEH			21H00081	600UL
9498	22	125			INF		F01	+3.86	TECTEH	HR		21H00080	600UL
9499			4.03	180	INR	P1	F05	+0.00	TECTEH			21H00080	600UL
9500					INF		F05	+4.05	TECTEH	HR		21H00080	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9501	24	125	2.40	187	INR	1	02H	+35.70	TECTEH			21H00080	600UL
9502			0.74	61	INR	6	03H	+0.05	TECTEH			21H00080	600UL
9503			0.26	64	INR	6	05H	+27.61	TECTEH			21H00080	600UL
9504	26	125							TECTEH			21H00077	600UL
9505	28	125							TECTEH			21H00076	600UL
9506	30	125							TECTEH			21H00077	600UL
9507	32	125							TECTEH			21H00076	600UL
9508	34	125							TECTEH			21H00077	600UL
9509	36	125							TECTEH			21H00076	600UL
9510	38	125							TECTEH			21H00077	600UL
9511	40	125							TECTEH			21H00076	600UL
9512	42	125							TECTEH			21H00077	600UL
9513	44	125							TECTEH			21H00076	600UL
9514	46	125							TECTEH			21H00077	600UL
9515	48	125							TECTEH			21H00076	600UL
9516	50	125							TECTEH			21H00073	600UL
9517	52	125							TECTEH			21H00072	600UL
9518	54	125							TECTEH			21H00073	600UL
9519	56	125							TECTEH			21H00072	600UL
9520	58	125	0.61	69	INR	6	05H	+11.80	TECTEH			21H00073	600UL
9521			0.43	82	INR	6	04C	+14.33	TECTEH			21H00073	600UL
9522			0.38	101	INR	6	01C	+11.13	TECTEH			21H00073	600UL
9523	60	125							TECTEH			21H00072	600UL
9524	62	125							TECTEH			21H00073	600UL
9525	64	125							TECTEH			21H00072	600UL
9526	66	125	0.87	67	INR	6	F12	+11.16	TECTEH			21H00073	600UL
9527					INF		07C	+2.37	TECTEH	HR		21H00073	600UL
9528	68	125							TECTEH			21H00072	600UL
9529	70	125							TECTEH			21H00073	600UL
9530	72	125	0.78	58	INR	6	05H	+27.08	TECTEH			21H00072	600UL
9531			0.40	46	INR	6	F10	+9.01	TECTEH			21H00072	600UL
9532					INF		F11	+11.39	TECTEH	HR		21H00072	600UL
9533	74	125	0.57	78	INR	6	06H	+8.21	TECTEH			21H00073	600UL
9534			0.24	77	INR	6	F04	+3.13	TECTEH			21H00073	600UL
9535			0.49	64	INR	6	05C	+17.90	TECTEH			21H00073	600UL
9536	76	125							TECTEH			21H00072	600UL
9537	78	125							TECTEH			21H00073	600UL
9538	80	125							TECTEH			21H00072	600UL
9539	82	125							TECTEH			21H00060	600UL
9540	84	125			INF		F04	+12.30	TECTEH	HR		21H00061	600UL
9541					INF		F04	+12.30	TECTEH	HR		21H00061	600UL
9542			0.40	83	INR	6	F12	+10.31	TECTEH			21H00061	600UL
9543					INF		F12	+14.82	TECTEH	HR		21H00061	600UL
9544					INF		07C	+4.55	TECTEH	HR		21H00061	600UL
9545			1.34	187	INR	1	06C	+2.46	TECTEH			21H00061	600UL
9546	86	125							TECTEH			21H00060	600UL
9547	88	125							TECTEH			21H00061	600UL
9548	90	125							TECTEH			21H00060	600UL
9549	92	125	0.85	73	INR	6	06C	+36.48	TECTEH			21H00061	600UL
9550			0.42	79	INR	6	04C	+19.60	TECTEH			21H00061	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9551			0.81	71	INR	6	02C	+30.61	TECTEH			21H00061	600UL
9552	94	125							TECTEH			21H00060	600UL
9553	96	125	0.51	60	INR	6	05H	+20.41	TECTEH			21H00061	600UL
9554	98	125							TECTEH			21H00060	600UL
9555	100	125							TECTEH			21H00061	600UL
9556	102	125							TECTEH			21H00060	600UL
9557	104	125							TECTEH			21H00061	600UL
9558	106	125	0.39	82	INR	6	F09	+5.27	TECTEH			21H00060	600UL
9559					INF		F09	+8.24	TECTEH	HR		21H00060	600UL
9560			0.83	90	INR	6	F09	+9.87	TECTEH			21H00060	600UL
9561					INF		F10	+7.46	TECTEH	HR		21H00060	600UL
9562					INF		F10	+11.63	TECTEH	HR		21H00060	600UL
9563			1.14	120	INR	3	03C	+35.67	TECTEH			21H00060	600UL
9564	108	125							TECTEH			21H00061	600UL
9565	110	125	0.33	65	INR	6	TSC	+10.13	TECTEH			21H00060	600UL
9566	112	125	0.37	56	INR	6	F09	+11.38	TECTEH			21H00061	600UL
9567					INF		F10	+6.08	TECTEH	HR		21H00061	600UL
9568	114	125							TECTEH			21H00060	600UL
9569	116	125							TECTEH			21H00061	600UL
9570	118	125							TECTEH			21H00060	600UL
9571	120	125	0.72	84	INR	6	06H	+29.90	TECTEH			21H00061	600UL
9572					INF		06H	+31.21	TECTEH	HR		21H00061	600UL
9573			0.44	82	INR	6	F05	+2.46	TECTEH			21H00061	600UL
9574	122	125	0.39	70	INR	6	02H	+17.81	TECTEH			21H00060	600UL
9575			0.49	83	INR	6	07H	+10.09	TECTEH			21H00060	600UL
9576	1	126							TECTEH			21H00085	600UL
9577	3	126							TECTEH			21H00084	600UL
9578	5	126							TECTEH			21H00085	600UL
9579	7	126							TECTEH			21H00084	600UL
9580	9	126	0.50	118	INR	3	TSH	+14.69	TECTEH			21H00083	600UL
9581	11	126							TECTEH			21H00082	600UL
9582	13	126							TECTEH			21H00083	600UL
9583	15	126							TECTEH			21H00082	600UL
9584	17	126							TECTEH			21H00081	600UL
9585	19	126							TECTEH			21H00080	600UL
9586	21	126							TECTEH			21H00081	600UL
9587	23	126							TECTEH			21H00080	600UL
9588	25	126							TECTEH			21H00077	600UL
9589	27	126							TECTEH			21H00076	600UL
9590	29	126							TECTEH			21H00076	600UL
9591	33	126							TECTEH			21H00077	600UL
9592	35	126							TECTEH			21H00076	600UL
9593	37	126							TECTEH			21H00077	600UL
9594	39	126							TECTEH			21H00076	600UL
9595	41	126	0.34	111	INR	3	01H	+13.84	TECTEH			21H00077	600UL
9596			0.28	148	INR	3	05H	+9.08	TECTEH			21H00077	600UL
9597	43	126	0.69	73	INR	6	04H	+11.71	TECTEH			21H00076	600UL
9598			0.64	76	INR	6	05C	+29.38	TECTEH			21H00076	600UL
9599					INF		04C	+30.91	TECTEH	HR		21H00076	600UL
9600			0.98	76	INR	6	04C	+37.01	TECTEH			21H00076	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9601			0.61	80	INR	6	01C	-0.60	TECTEH			21H00076	600UL
9602	45	126							TECTEH			21H00077	600UL
9603	47	126	0.64	70	INR	6	TSC	+5.79	TECTEH			21H00076	600UL
9604	49	126							TECTEH			21H00076	600UL
9605	51	126	0.39	91	INR	6	01C	+30.35	TECTEH			21H00073	600UL
9606					INF		01C	+33.33	TECTEH	HR		21H00073	600UL
9607	53	126							TECTEH			21H00072	600UL
9608	55	126							TECTEH			21H00073	600UL
9609	57	126	0.48	70	INR	6	04C	+29.17	TECTEH			21H00072	600UL
9610					INF		04C	+30.77	TECTEH	HR		21H00072	600UL
9611	59	126			INF		06H	+30.34	TECTEH	HR		21H00072	600UL
9612			0.36	72	INR	6	06H	+31.56	TECTEH			21H00072	600UL
9613			0.48	45	INR	6	F07	+7.52	TECTEH			21H00072	600UL
9614					INF		F08	+6.22	TECTEH	HR		21H00072	600UL
9615			0.40	120	INR	3	06C	+16.02	TECTEH			21H00072	600UL
9616	63	126	0.58	110	INR	6	F08	+7.37	TECTEH			21H00073	600UL
9617					INF		F09	+6.33	TECTEH	HR		21H00073	600UL
9618	65	126							TECTEH			21H00072	600UL
9619	67	126							TECTEH			21H00073	600UL
9620	69	126							TECTEH			21H00072	600UL
9621	71	126							TECTEH			21H00073	600UL
9622	73	126							TECTEH			21H00072	600UL
9623	75	126							TECTEH			21H00073	600UL
9624	77	126							TECTEH			21H00072	600UL
9625	79	126							TECTEH			21H00073	600UL
9626	81	126	1.18	80	INR	6	02C	+37.30	TECTEH			21H00072	600UL
9627	83	126							TECTEH			21H00061	600UL
9628	85	126							TECTEH			21H00060	600UL
9629	87	126							TECTEH			21H00061	600UL
9630	89	126			INF		03H	+19.08	TECTEH	HR		21H00060	600UL
9631			0.35	76	INR	6	03H	+20.40	TECTEH			21H00060	600UL
9632					INF		04H	+30.51	TECTEH	HR		21H00060	600UL
9633			0.38	77	INR	6	04H	+31.83	TECTEH			21H00060	600UL
9634	93	126							TECTEH			21H00061	600UL
9635	95	126	0.36	64	INR	6	F12	+2.21	TECTEH			21H00060	600UL
9636					INF		07C	+17.62	TECTEH	HR		21H00060	600UL
9637	97	126							TECTEH			21H00061	600UL
9638	99	126							TECTEH			21H00060	600UL
9639	101	126							TECTEH			21H00061	600UL
9640	103	126							TECTEH			21H00060	600UL
9641	105	126							TECTEH			21H00061	600UL
9642	107	126							TECTEH			21H00060	600UL
9643	109	126							TECTEH			21H00061	600UL
9644	111	126							TECTEH			21H00060	600UL
9645	113	126	0.40	61	INR	6	02H	+10.27	TECTEH			21H00061	600UL
9646			0.67	65	INR	6	05C	+15.37	TECTEH			21H00061	600UL
9647					INF		01C	+17.45	TECTEH	HR		21H00061	600UL
9648			0.41	70	INR	6	01C	+18.97	TECTEH			21H00061	600UL
9649	115	126							TECTEH			21H00060	600UL
9650	117	126							TECTEH			21H00061	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9651	119	126							TECTEH			21H00060	600UL
9652	121	126							TECTEH			21H00060	600UL
9653	2	127							TECTEH			21H00085	600UL
9654	4	127							TECTEH			21H00084	600UL
9655	6	127							TECTEH			21H00084	600UL
9656	8	127							TECTEH			21H00083	600UL
9657	10	127							TECTEH			21H00082	600UL
9658	12	127							TECTEH			21H00083	600UL
9659	14	127							TECTEH			21H00082	600UL
9660	16	127							TECTEH			21H00081	600UL
9661	18	127	0.43	75	INR	6	04C	+14.92	TECTEH			21H00080	600UL
9662	20	127							TECTEH			21H00081	600UL
9663	22	127							TECTEH			21H00080	600UL
9664	24	127							TECTEH			21H00080	600UL
9665	26	127							TECTEH			21H00077	600UL
9666	28	127							TECTEH			21H00077	600UL
9667	30	127							TECTEH			21H00076	600UL
9668	34	127							TECTEH			21H00077	600UL
9669	36	127	0.42	88	INR	6	TSC	+20.55	TECTEH			21H00076	600UL
9670	38	127							TECTEH			21H00077	600UL
9671	40	127							TECTEH			21H00076	600UL
9672	42	127							TECTEH			21H00077	600UL
9673	44	127							TECTEH			21H00076	600UL
9674	46	127							TECTEH			21H00077	600UL
9675	48	127							TECTEH			21H00076	600UL
9676	50	127							TECTEH			21H00073	600UL
9677	52	127							TECTEH			21H00072	600UL
9678	54	127	0.45	77	INR	6	01H	+7.80	TECTEH			21H00073	600UL
9679			1.00	75	INR	6	06H	+20.91	TECTEH			21H00073	600UL
9680			0.63	77	INR	6	02C	+7.55	TECTEH			21H00073	600UL
9681					INF		02C	+8.71	TECTEH	HR		21H00073	600UL
9682	56	127			INF		02H	+37.65	TECTEH	HR		21H00072	600UL
9683			0.31	76	INR	6	02H	+38.93	TECTEH			21H00072	600UL
9684			0.40	84	INR	6	03H	+8.21	TECTEH			21H00072	600UL
9685	58	127	0.53	81	INR	6	04H	+32.52	TECTEH			21H00073	600UL
9686	60	127	0.45	104	INR	6	F04	+5.55	TECTEH			21H00072	600UL
9687			0.37	67	INR	6	01C	+27.34	TECTEH			21H00072	600UL
9688	64	127	0.41	54	INR	6	F08	+10.21	TECTEH			21H00072	600UL
9689					INF		F09	+3.83	TECTEH	HR		21H00072	600UL
9690			0.54	71	INR	6	04C	+32.55	TECTEH			21H00072	600UL
9691	66	127	1.10	79	INR	6	04C	+14.77	TECTEH			21H00073	600UL
9692					INF		04C	+16.07	TECTEH	HR		21H00073	600UL
9693					INF		04C	+18.60	TECTEH	HR		21H00073	600UL
9694			0.85	70	INR	6	03C	+32.44	TECTEH			21H00073	600UL
9695					INF		03C	+33.54	TECTEH	HR		21H00073	600UL
9696	68	127	0.43	137	INR	3	05H	+21.34	TECTEH			21H00072	600UL
9697			0.99	55	INR	6	F01	+0.23	TECTEH			21H00072	600UL
9698					INF		06C	+32.11	TECTEH	HR		21H00072	600UL
9699			0.49	86	INR	6	06C	+33.67	TECTEH			21H00072	600UL
9700			0.30	139	INR	3	01C	+14.71	TECTEH			21H00072	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9701			0.34	140	INR	3	01C	+28.99		TECTEH			21H00072	600UL
9702	70	127								TECTEH			21H00073	600UL
9703	72	127	0.66	77	INR	6	02C	+19.14		TECTEH			21H00072	600UL
9704	74	127								TECTEH			21H00073	600UL
9705	76	127								TECTEH			21H00072	600UL
9706	78	127			INF		06H	+25.10		TECTEH	HR		21H00073	600UL
9707			0.49	75	INR	6	06H	+26.63		TECTEH			21H00073	600UL
9708					INF		F03	+9.02		TECTEH	HR		21H00073	600UL
9709	80	127								TECTEH			21H00072	600UL
9710	82	127								TECTEH			21H00062	600UL
9711	84	127	0.59	61	INR	6	06C	+19.13		TECTEH			21H00063	600UL
9712			0.71	75	INR	6	04C	+7.83		TECTEH			21H00063	600UL
9713			0.47	96	INR	6	TSC	+3.23		TECTEH			21H00063	600UL
9714	86	127			INF		02C	+2.26		TECTEH	HR		21H00062	600UL
9715			0.53	84	INR	6	02C	+3.70		TECTEH			21H00062	600UL
9716	88	127								TECTEH			21H00063	600UL
9717	90	127								TECTEH			21H00062	600UL
9718	94	127								TECTEH			21H00061	600UL
9719	96	127								TECTEH			21H00060	600UL
9720	98	127								TECTEH			21H00061	600UL
9721	100	127								TECTEH			21H00060	600UL
9722	102	127	0.79	62	INR	6	06H	+33.65		TECTEH			21H00061	600UL
9723			1.10	71	INR	6	04C	+27.74		TECTEH			21H00061	600UL
9724	104	127								TECTEH			21H00060	600UL
9725	106	127								TECTEH			21H00061	600UL
9726	108	127								TECTEH			21H00060	600UL
9727	110	127								TECTEH			21H00061	600UL
9728	112	127	0.47	78	INR	6	TSH	+14.78		TECTEH			21H00060	600UL
9729			0.35	78	INR	6	TSH	+20.74		TECTEH			21H00060	600UL
9730			0.54	86	INR	6	01H	+16.42		TECTEH			21H00060	600UL
9731			0.51	67	INR	6	04H	+30.82		TECTEH			21H00060	600UL
9732			0.45	75	INR	6	06H	+5.44		TECTEH			21H00060	600UL
9733					INF		07H	+61.72		TECTEH	HR		21H00060	600UL
9734					INF		F03	+11.43		TECTEH	HR		21H00060	600UL
9735			0.46	77	INR	6	F09	+4.48		TECTEH			21H00060	600UL
9736					INF		F10	+12.83		TECTEH	HR		21H00060	600UL
9737					INF		05C	+21.98		TECTEH	HR		21H00060	600UL
9738			0.81	70	INR	6	05C	+23.33		TECTEH			21H00060	600UL
9739			0.99	38	INR	6	02C	+3.39		TECTEH			21H00060	600UL
9740			0.41	75	INR	6	02C	+4.98		TECTEH			21H00060	600UL
9741	114	127			INF		05H	+19.98		TECTEH	HR		21H00061	600UL
9742			0.43	65	INR	6	05H	+21.83		TECTEH			21H00061	600UL
9743					INF		F02	+12.84		TECTEH	HR		21H00061	600UL
9744			0.51	61	INR	6	F03	+3.07		TECTEH			21H00061	600UL
9745	116	127								TECTEH			21H00060	600UL
9746	118	127			INF		06H	+22.19		TECTEH	HR		21H00061	600UL
9747			0.51	50	INR	6	06H	+23.94		TECTEH			21H00061	600UL
9748	120	127	0.93		INR	6	F09	+0.95	TO+10.66	TECTEH			21H00060	600UL
9749	1	128								TECTEH			21H00085	600UL
9750	3	128								TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9751	5	128							TECTEH			21H00085	600UL
9752	7	128							TECTEH			21H00084	600UL
9753	9	128	0.33	111	INR	3	02H	+34.02	TECTEH			21H00083	600UL
9754	11	128							TECTEH			21H00082	600UL
9755	13	128							TECTEH			21H00083	600UL
9756	15	128							TECTEH			21H00082	600UL
9757	17	128							TECTEH			21H00081	600UL
9758	19	128							TECTEH			21H00080	600UL
9759	21	128							TECTEH			21H00081	600UL
9760	23	128							TECTEH			21H00080	600UL
9761	25	128							TECTEH			21H00077	600UL
9762	27	128							TECTEH			21H00076	600UL
9763	29	128							TECTEH			21H00077	600UL
9764	31	128							TECTEH			21H00076	600UL
9765	33	128	0.24	122	INR	3	02H	+27.77	TECTEH			21H00077	600UL
9766			0.45	114	INR	3	05H	+27.75	TECTEH			21H00077	600UL
9767	35	128							TECTEH			21H00076	600UL
9768	37	128	0.59	99	INR	3	F06	+3.16	TECTEH			21H00077	600UL
9769	39	128							TECTEH			21H00076	600UL
9770	41	128							TECTEH			21H00077	600UL
9771	43	128							TECTEH			21H00076	600UL
9772	45	128	0.78	132	INR	3	TSC	+7.75	TECTEH			21H00077	600UL
9773	47	128	0.69	72	INR	6	04H	+5.40	TECTEH			21H00076	600UL
9774			0.84	52	INR	6	F04	+5.44	TECTEH			21H00076	600UL
9775			0.40	78	INR	6	06C	+5.92	TECTEH			21H00076	600UL
9776	49	128							TECTEH			21H00076	600UL
9777	51	128							TECTEH			21H00073	600UL
9778	53	128							TECTEH			21H00072	600UL
9779	55	128							TECTEH			21H00073	600UL
9780	57	128	0.39	87	INR	6	06C	+13.36	TECTEH			21H00072	600UL
9781			0.66	79	INR	6	02C	+3.25	TECTEH			21H00072	600UL
9782	59	128							TECTEH			21H00073	600UL
9783	61	128							TECTEH			21H00072	600UL
9784	63	128							TECTEH			21H00073	600UL
9785	65	128							TECTEH			21H00072	600UL
9786	67	128							TECTEH			21H00073	600UL
9787	69	128							TECTEH			21H00072	600UL
9788	71	128							TECTEH			21H00073	600UL
9789	73	128							TECTEH			21H00072	600UL
9790	75	128							TECTEH			21H00073	600UL
9791	77	128							TECTEH			21H00072	600UL
9792	79	128							TECTEH			21H00072	600UL
9793	81	128	0.67	74	INR	6	TSH	+14.09	TECTEH			21H00063	600UL
9794			0.56	75	INR	6	01H	+31.66	TECTEH			21H00063	600UL
9795			0.89	47	INR	6	F07	+10.25	TECTEH			21H00063	600UL
9796					INF		F08	+3.30	TECTEH	HR		21H00063	600UL
9797			0.92	70	INR	6	F12	+7.84	TECTEH			21H00063	600UL
9798					INF		F12	+9.14	TECTEH	HR		21H00063	600UL
9799					INF		07C	+7.19	TECTEH	HR		21H00063	600UL
9800			0.43	64	INR	6	05C	+6.45	TECTEH			21H00063	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9801			0.40	77	INR	6	05C	+37.57	TECTEH			21H00063	600UL
9802	83	128	0.78	83	INR	6	TSC	+8.76	TECTEH			21H00062	600UL
9803	85	128							TECTEH			21H00063	600UL
9804	87	128	0.46	73	INR	6	05H	+6.82	TECTEH			21H00062	600UL
9805			0.48	65	INR	6	01C	+15.83	TECTEH			21H00062	600UL
9806	89	128	0.43	77	INR	6	05H	+28.07	TECTEH			21H00063	600UL
9807	91	128							TECTEH			21H00062	600UL
9808	93	128	0.67	67	INR	6	05H	+37.17	TECTEH			21H00063	600UL
9809			0.41	66	INR	6	F08	+2.81	TECTEH			21H00063	600UL
9810					INF		F09	+12.29	TECTEH	HR		21H00063	600UL
9811	95	128							TECTEH			21H00062	600UL
9812	97	128	0.59	84	INR	6	02C	+5.07	TECTEH			21H00063	600UL
9813			0.41	152	INR	3	02C	+6.24	TECTEH			21H00063	600UL
9814			0.46	84	INR	6	02C	+31.35	TECTEH			21H00063	600UL
9815					INF		02C	+33.90	TECTEH	HR		21H00063	600UL
9816	99	128							TECTEH			21H00062	600UL
9817	101	128	0.83	75	INR	6	02C	+3.02	TECTEH			21H00063	600UL
9818			0.53	61	INR	6	01C	+26.99	TECTEH			21H00063	600UL
9819	103	128	0.44	76	INR	6	06C	+35.84	TECTEH			21H00062	600UL
9820	105	128							TECTEH			21H00063	600UL
9821	107	128	0.42	79	INR	6	04C	+6.28	TECTEH			21H00062	600UL
9822	109	128	0.61	67	INR	6	03H	+35.01	TECTEH			21H00063	600UL
9823			0.74	47	INR	6	F09	+10.57	TECTEH			21H00063	600UL
9824					INF		F10	+6.93	TECTEH	HR		21H00063	600UL
9825	111	128							TECTEH			21H00062	600UL
9826	113	128	0.45	62	INR	6	03H	+16.86	TECTEH			21H00063	600UL
9827			0.47	56	INR	6	06H	+9.67	TECTEH			21H00063	600UL
9828					INF		04C	+30.16	TECTEH	HR		21H00063	600UL
9829	115	128							TECTEH			21H00062	600UL
9830	117	128			INF		01H	+26.93	TECTEH	HR		21H00063	600UL
9831			0.79	65	INR	6	F04	+5.88	TECTEH			21H00063	600UL
9832			0.50	85	INR	6	F07	+14.22	TECTEH			21H00063	600UL
9833					INF		F08	+4.65	TECTEH	HR		21H00063	600UL
9834	119	128							TECTEH			21H00062	600UL
9835	2	129							TECTEH			21H00085	600UL
9836	4	129							TECTEH			21H00084	600UL
9837	6	129							TECTEH			21H00084	600UL
9838	8	129							TECTEH			21H00083	600UL
9839	10	129							TECTEH			21H00082	600UL
9840	12	129							TECTEH			21H00083	600UL
9841	14	129							TECTEH			21H00082	600UL
9842	16	129							TECTEH			21H00081	600UL
9843	18	129							TECTEH			21H00080	600UL
9844					NDF	3	TSH	-0.10	TEHTSH			21H00087	610PP
9845	20	129							TECTEH			21H00081	600UL
9846	22	129							TECTEH			21H00080	600UL
9847	24	129							TECTEH			21H00080	600UL
9848	26	129							TECTEH			21H00077	600UL
9849	28	129	0.41	74	INR	6	TSH	+6.62	TECTEH			21H00076	600UL
9850	30	129							TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9851	32	129							TECTEH			21H00076	600UL
9852	34	129	0.36	126	INR	3	01C	+7.93	TECTEH			21H00077	600UL
9853	36	129	0.50	68	INR	6	F12	+2.85	TECTEH			21H00076	600UL
9854					INF		F12	+7.89	TECTEH	HR		21H00076	600UL
9855					INF		07C	+7.66	TECTEH	HR		21H00076	600UL
9856			0.52	76	INR	6	05C	+12.63	TECTEH			21H00076	600UL
9857	38	129	0.37	104	INR	3	04H	+33.83	TECTEH			21H00077	600UL
9858			0.65	43	INR	3	F08	+8.09	TECTEH			21H00077	600UL
9859					INF		F12	+7.04	TECTEH	HR		21H00077	600UL
9860	40	129							TECTEH			21H00076	600UL
9861	42	129							TECTEH			21H00077	600UL
9862	44	129							TECTEH			21H00076	600UL
9863	46	129							TECTEH			21H00077	600UL
9864	48	129							TECTEH			21H00076	600UL
9865	50	129	0.50	77	INR	6	04H	+14.65	TECTEH			21H00073	600UL
9866			0.40	80	INR	6	TSC	+17.11	TECTEH			21H00073	600UL
9867	52	129	0.48	50	INR	6	05H	+29.86	TECTEH			21H00072	600UL
9868	54	129							TECTEH			21H00073	600UL
9869	56	129							TECTEH			21H00072	600UL
9870	58	129							TECTEH			21H00073	600UL
9871	60	129							TECTEH			21H00072	600UL
9872	62	129	0.74	78	INR	6	05H	+10.55	TECTEH			21H00073	600UL
9873	64	129							TECTEH			21H00072	600UL
9874	66	129							TECTEH			21H00073	600UL
9875	68	129	2.01	19	INR	6	01H	+33.22	TECTEH			21H00072	600UL
9876			0.51	71	INR	6	03H	+30.77	TECTEH			21H00072	600UL
9877			0.50	40	INR	6	05H	+30.55	TECTEH			21H00072	600UL
9878			0.43	89	INR	6	03C	+17.07	TECTEH			21H00072	600UL
9879	70	129	0.57	67	INR	6	04C	+25.68	TECTEH			21H00073	600UL
9880	72	129							TECTEH			21H00072	600UL
9881	74	129							TECTEH			21H00073	600UL
9882	76	129							TECTEH			21H00072	600UL
9883	78	129							TECTEH			21H00073	600UL
9884	80	129							TECTEH			21H00072	600UL
9885	82	129	0.44	78	INR	6	02C	+3.72	TECTEH			21H00062	600UL
9886	84	129	0.31	137	INR	3	06C	+5.71	TECTEH			21H00063	600UL
9887	86	129	0.53	77	INR	6	06C	+11.84	TECTEH			21H00062	600UL
9888	88	129	0.36	130	INR	3	05C	+37.42	TECTEH			21H00063	600UL
9889	90	129							TECTEH			21H00062	600UL
9890	92	129							TECTEH			21H00063	600UL
9891	94	129	0.43	83	INR	6	04C	+36.04	TECTEH			21H00062	600UL
9892	96	129							TECTEH			21H00063	600UL
9893	98	129							TECTEH			21H00062	600UL
9894	100	129							TECTEH			21H00063	600UL
9895	102	129							TECTEH			21H00062	600UL
9896	104	129							TECTEH			21H00063	600UL
9897	106	129							TECTEH			21H00062	600UL
9898	108	129	0.70	77	INR	6	05C	+39.78	TECTEH			21H00063	600UL
9899	110	129	0.78	56	INR	6	F06	+15.35	TECTEH			21H00062	600UL
9900					INF		F07	+2.28	TECTEH	HR		21H00062	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9901			0.80	77	INR	6	TSC	+7.37	TECTEH			21H00062	600UL
9902	112	129							TECTEH			21H00063	600UL
9903	114	129	0.38	66	INR	6	04H	+22.85	TECTEH			21H00062	600UL
9904	116	129							TECTEH			21H00063	600UL
9905	118	129	0.42	58	INR	6	04C	+33.80	TECTEH			21H00062	600UL
9906	1	130							TECTEH			21H00085	600UL
9907	3	130							TECTEH			21H00084	600UL
9908	5	130							TECTEH			21H00085	600UL
9909	7	130							TECTEH			21H00084	600UL
9910	9	130							TECTEH			21H00083	600UL
9911	11	130							TECTEH			21H00082	600UL
9912	13	130							TECTEH			21H00083	600UL
9913	15	130							TECTEH			21H00082	600UL
9914	17	130							TECTEH			21H00081	600UL
9915	19	130	0.59	77	INR	6	05H	+5.09	TECTEH			21H00080	600UL
9916	21	130							TECTEH			21H00081	600UL
9917	23	130							TECTEH			21H00080	600UL
9918	25	130							TECTEH			21H00077	600UL
9919	27	130							TECTEH			21H00076	600UL
9920	29	130							TECTEH			21H00077	600UL
9921	31	130							TECTEH			21H00076	600UL
9922	33	130							TECTEH			21H00077	600UL
9923	35	130							TECTEH			21H00076	600UL
9924	37	130	0.31	128	INR	3	06H	+19.44	TECTEH			21H00077	600UL
9925			0.39	124	INR	3	05C	+5.36	TECTEH			21H00077	600UL
9926			0.48	131	INR	3	TSC	+10.52	TECTEH			21H00077	600UL
9927	39	130	0.50	74	INR	6	06H	+20.43	TECTEH			21H00076	600UL
9928	41	130	0.33	68	INR	6	06H	+10.91	TECTEH			21H00077	600UL
9929					INF		07H	+45.35	TECTEH	HR		21H00077	600UL
9930			0.33	105	INR	6	F06	+2.19	TECTEH			21H00077	600UL
9931			0.44	80	INR	6	04C	+8.91	TECTEH			21H00077	600UL
9932			0.41	83	INR	6	01C	+22.01	TECTEH			21H00077	600UL
9933					INF		01C	+25.62	TECTEH	HR		21H00077	600UL
9934	43	130							TECTEH			21H00076	600UL
9935	45	130							TECTEH			21H00077	600UL
9936	47	130	0.60	74	INR	6	05H	+15.40	TECTEH			21H00076	600UL
9937			0.95	58	INR	6	F12	+9.81	TECTEH			21H00076	600UL
9938					INF		07C	+2.43	TECTEH	HR		21H00076	600UL
9939	49	130							TECTEH			21H00076	600UL
9940	51	130	0.40	71	INR	6	05H	+24.09	TECTEH			21H00073	600UL
9941			0.42	72	INR	6	04C	+33.66	TECTEH			21H00073	600UL
9942	53	130							TECTEH			21H00072	600UL
9943	55	130	0.54	79	INR	6	02C	+37.82	TECTEH			21H00073	600UL
9944	57	130	0.47	65	INR	6	F08	+19.24	TECTEH			21H00072	600UL
9945					INF		F09	+5.97	TECTEH	HR		21H00072	600UL
9946	59	130	1.11	54	INR	6	F04	+10.77	TECTEH			21H00073	600UL
9947	61	130	1.28	49	INR	6	TSH	+21.72	TECTEH			21H00072	600UL
9948					INF		03H	+22.20	TECTEH	HR		21H00072	600UL
9949			1.83	74	INR	6	03H	+23.63	TECTEH			21H00072	600UL
9950			0.34	99	INR	6	04H	+22.31	TECTEH			21H00072	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
9951					INF		F04	-18.66	TECTEH	HR		21H00072	600UL
9952			0.39	68	INR	6	02C	+12.09	TECTEH			21H00072	600UL
9953					INF		01C	+9.99	TECTEH	HR		21H00072	600UL
9954			0.63	77	INR	6	01C	+11.37	TECTEH			21H00072	600UL
9955	63	130							TECTEH			21H00073	600UL
9956	65	130							TECTEH			21H00072	600UL
9957	67	130	0.62	82	INR	6	TSH	+11.69	TECTEH			21H00073	600UL
9958			0.66	80	INR	6	02C	+21.85	TECTEH			21H00073	600UL
9959	69	130	0.53	65	INR	6	01C	+20.38	TECTEH			21H00072	600UL
9960	71	130							TECTEH			21H00073	600UL
9961	73	130	0.77	66	INR	6	01C	+6.05	TECTEH			21H00072	600UL
9962	75	130							TECTEH			21H00073	600UL
9963	77	130							TECTEH			21H00072	600UL
9964	79	130							TECTEH			21H00073	600UL
9965	81	130							TECTEH			21H00072	600UL
9966	83	130	0.37	136	INR	3	03H	+19.83	TECTEH			21H00063	600UL
9967			0.56	116	INR	3	07H	+11.18	TECTEH			21H00063	600UL
9968			1.53	199	INR	6	F03	-0.64	TECTEH			21H00063	600UL
9969	85	130							TECTEH			21H00062	600UL
9970	87	130	0.27	133	INR	3	01H	+19.42	TECTEH			21H00063	600UL
9971			0.48	130	INR	3	01H	+21.13	TECTEH			21H00063	600UL
9972			0.35	136	INR	3	01H	+24.34	TECTEH			21H00063	600UL
9973			0.58	135	INR	3	01H	+26.16	TECTEH			21H00063	600UL
9974			0.42	128	INR	3	02C	+9.41	TECTEH			21H00063	600UL
9975	89	130							TECTEH			21H00062	600UL
9976	91	130	0.64	126	INR	3	06H	+10.27	TECTEH			21H00063	600UL
9977					INF		06C	+21.59	TECTEH	HR		21H00063	600UL
9978			0.36	117	INR	3	06C	+25.62	TECTEH			21H00063	600UL
9979	93	130							TECTEH			21H00062	600UL
9980	95	130	0.46	114	INR	3	01H	+7.22	TECTEH			21H00063	600UL
9981	97	130							TECTEH			21H00062	600UL
9982	99	130							TECTEH			21H00063	600UL
9983	101	130							TECTEH			21H00062	600UL
9984	103	130							TECTEH			21H00063	600UL
9985	105	130							TECTEH			21H00062	600UL
9986	107	130							TECTEH			21H00063	600UL
9987	109	130	0.53	79	INR	6	05C	+22.46	TECTEH			21H00062	600UL
9988			0.60	63	INR	6	01C	+16.68	TECTEH			21H00062	600UL
9989	111	130							TECTEH			21H00063	600UL
9990	113	130							TECTEH			21H00062	600UL
9991	115	130	0.34	107	INR	3	F02	+9.49	TECTEH			21H00063	600UL
9992			0.36	142	INR	3	F05	+5.65	TECTEH			21H00063	600UL
9993			0.42	147	INR	3	F08	+13.45	TECTEH			21H00063	600UL
9994					INF		F09	+4.20	TECTEH	HR		21H00063	600UL
9995			0.35	132	INR	3	06C	+25.54	TECTEH			21H00063	600UL
9996			0.36	133	INR	3	03C	+24.04	TECTEH			21H00063	600UL
9997			0.27	131	INR	3	03C	+37.09	TECTEH			21H00063	600UL
9998	117	130							TECTEH			21H00062	600UL
9999	2	131							TECTEH			21H00085	600UL
10000	4	131							TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10001	6	131	1.68	40	INR	6	05C	-1.70	TO+9.67	TECTEH			21H00084	600UL
10002			2.06	192	INR	6	05C	+6.20	TO+37.16	TECTEH			21H00084	600UL
10003			2.43		ADS	6	04C	+31.85	TO+39.90	TECTEH			21H00084	600UL
10004	8	131								TECTEH			21H00083	600UL
10005	10	131	0.38	80	INR	6	05H	+24.00		TECTEH			21H00082	600UL
10006	12	131								TECTEH			21H00083	600UL
10007	14	131	0.95	73	INR	6	03H	+9.27		TECTEH			21H00082	600UL
10008	16	131	0.44	82	INR	6	TSH	+1.77		TECTEH			21H00081	600UL
10009	18	131								TECTEH			21H00080	600UL
10010	20	131								TECTEH			21H00081	600UL
10011	22	131								TECTEH			21H00080	600UL
10012	24	131								TECTEH			21H00080	600UL
10013	26	131								TECTEH			21H00077	600UL
10014	28	131								TECTEH			21H00076	600UL
10015	30	131								TECTEH			21H00077	600UL
10016	32	131								TECTEH			21H00076	600UL
10017	34	131								TECTEH			21H00077	600UL
10018	36	131								TECTEH			21H00076	600UL
10019	38	131								TECTEH			21H00077	600UL
10020	40	131	0.42	61	INR	6	04H	+35.20		TECTEH			21H00076	600UL
10021			0.46	64	INR	6	05H	+31.58		TECTEH			21H00076	600UL
10022			0.32	80	INR	6	05C	+8.75		TECTEH			21H00076	600UL
10023	42	131								TECTEH			21H00077	600UL
10024	44	131								TECTEH			21H00076	600UL
10025	46	131	1.08	72	INR	3	F01	+4.05		TECTEH			21H00077	600UL
10026			0.60	77	INR	6	TSC	+20.64		TECTEH			21H00077	600UL
10027	48	131								TECTEH			21H00076	600UL
10028	50	131								TECTEH			21H00073	600UL
10029	52	131	0.51	140	INR	3	TSH	+15.85		TECTEH			21H00072	600UL
10030			0.35	146	INR	3	01H	+28.30		TECTEH			21H00072	600UL
10031			0.37	106	NQH	3	06H	+4.18		TECTEH			21H00072	600UL
10032			0.75	151	INR	3	F05	+0.00		TECTEH			21H00072	600UL
10033	54	131	0.46	66	INR	6	06H	+13.88		TECTEH			21H00073	600UL
10034	56	131	0.64	235	INR	6	F12	+3.23		TECTEH			21H00072	600UL
10035					INF		07C	+9.11		TECTEH	HR		21H00072	600UL
10036			0.23	104	NQH	3	TSC	+5.09		TECTEH			21H00072	600UL
10037	58	131								TECTEH			21H00073	600UL
10038	60	131								TECTEH			21H00072	600UL
10039	62	131								TECTEH			21H00073	600UL
10040	64	131								TECTEH			21H00072	600UL
10041	66	131								TECTEH			21H00073	600UL
10042	68	131								TECTEH			21H00072	600UL
10043	70	131	0.53	80	INR	6	03C	+38.16		TECTEH			21H00073	600UL
10044					INF		03C	+42.74		TECTEH	HR		21H00073	600UL
10045	72	131								TECTEH			21H00072	600UL
10046	74	131								TECTEH			21H00073	600UL
10047	76	131								TECTEH			21H00072	600UL
10048	78	131	0.57	80	INR	6	02H	+10.86		TECTEH			21H00073	600UL
10049			0.67	70	INR	6	02H	+26.16		TECTEH			21H00073	600UL
10050			1.67	34	INR	6	F08	+12.16		TECTEH			21H00073	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION		EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10051					INF		F09	+2.24		TECTEH	HR		21H00073	600UL
10052			0.75	78	INR	6	05C	+10.90		TECTEH			21H00073	600UL
10053	80	131								TECTEH			21H00072	600UL
10054	82	131								TECTEH			21H00063	600UL
10055	84	131								TECTEH			21H00062	600UL
10056	86	131								TECTEH			21H00063	600UL
10057	88	131								TECTEH			21H00062	600UL
10058	90	131	0.56	126	INR	3	02C	+7.36		TECTEH			21H00063	600UL
10059	92	131								TECTEH			21H00062	600UL
10060	94	131	2.55	31	INR	6	04C	+1.99	TO+14.06	TECTEH			21H00063	600UL
10061	96	131								TECTEH			21H00062	600UL
10062	98	131								TECTEH			21H00063	600UL
10063	100	131								TECTEH			21H00062	600UL
10064	102	131								TECTEH			21H00063	600UL
10065	104	131								TECTEH			21H00062	600UL
10066	106	131	0.38	145	INR	3	TSC	+7.64		TECTEH			21H00063	600UL
10067	108	131								TECTEH			21H00062	600UL
10068	110	131								TECTEH			21H00063	600UL
10069	112	131	0.36	88	INR	6	01H	+9.92		TECTEH			21H00062	600UL
10070			0.39	76	INR	6	01H	+12.15		TECTEH			21H00062	600UL
10071			0.35	73	INR	6	03H	+35.30		TECTEH			21H00062	600UL
10072			1.16	46	INR	6	F05	+15.75		TECTEH			21H00062	600UL
10073			0.54	53	INR	6	F06	+10.82		TECTEH			21H00062	600UL
10074			0.68	80	INR	6	03C	+30.55		TECTEH			21H00062	600UL
10075			0.39	95	INR	6	02C	+7.22		TECTEH			21H00062	600UL
10076			0.77	76	INR	6	01C	+8.20		TECTEH			21H00062	600UL
10077	114	131								TECTEH			21H00063	600UL
10078	116	131								TECTEH			21H00062	600UL
10079	1	132								TECTEH			21H00085	600UL
10080	3	132								TECTEH			21H00084	600UL
10081	5	132								TECTEH			21H00085	600UL
10082	7	132								TECTEH			21H00084	600UL
10083	9	132								TECTEH			21H00083	600UL
10084	11	132								TECTEH			21H00082	600UL
10085	13	132								TECTEH			21H00083	600UL
10086	15	132								TECTEH			21H00082	600UL
10087	17	132								TECTEH			21H00081	600UL
10088	19	132								TECTEH			21H00080	600UL
10089	21	132	0.73	44	INR	6	01C	+0.78	TO+10.24	TECTEH			21H00081	600UL
10090	23	132	0.50	71	INR	6	TSH	+21.11		TECTEH			21H00080	600UL
10091	25	132								TECTEH			21H00077	600UL
10092	27	132			INF		F01	+7.13		TECTEH	HR		21H00076	600UL
10093			4.19	184	INR	P1	F05	+1.33		TECTEH			21H00076	600UL
10094	29	132	4.24	181	INR	1	F01	+5.98		TECTEH			21H00077	600UL
10095	31	132	3.87	183	INR	1	F01	+6.52		TECTEH			21H00076	600UL
10096	33	132								TECTEH			21H00077	600UL
10097	35	132	0.49	68	INR	6	04H	+4.93		TECTEH			21H00076	600UL
10098			4.37	183	INR	1	F04	+4.11		TECTEH			21H00076	600UL
10099	37	132	0.61	81	INR	6	03H	+28.92		TECTEH			21H00077	600UL
10100			0.39	78	INR	6	05H	+32.35		TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10101			0.78	79	INR	6	06H	+6.54	TECTEH			21H00077	600UL
10102					INF		F04	+0.99	TECTEH	HR		21H00077	600UL
10103			3.99	182	INR	1	F04	+3.57	TECTEH			21H00077	600UL
10104			0.49	79	INR	6	01C	+9.64	TECTEH			21H00077	600UL
10105	39	132							TECTEH			21H00076	600UL
10106	41	132	0.81	79	INR	6	04H	+22.97	TECTEH			21H00077	600UL
10107			0.52	53	INR	6	02C	+4.90	TECTEH			21H00077	600UL
10108	43	132	0.30	77	INR	6	TSH	+11.53	TECTEH			21H00076	600UL
10109					INF		TSH	+13.65	TECTEH	HR		21H00076	600UL
10110	45	132							TECTEH			21H00077	600UL
10111	47	132							TECTEH			21H00076	600UL
10112	49	132							TECTEH			21H00076	600UL
10113	51	132							TECTEH			21H00073	600UL
10114	53	132							TECTEH			21H00072	600UL
10115	55	132							TECTEH			21H00073	600UL
10116	57	132							TECTEH			21H00072	600UL
10117	59	132							TECTEH			21H00073	600UL
10118	61	132							TECTEH			21H00072	600UL
10119	63	132	0.43	82	INR	6	02H	+25.30	TECTEH			21H00073	600UL
10120			0.47	72	INR	6	03H	+14.66	TECTEH			21H00073	600UL
10121			0.95	72	INR	6	05C	+6.52	TECTEH			21H00073	600UL
10122	65	132	2.19	140	INR	3	F08	+4.57	TECTEH			21H00072	600UL
10123					INF		F09	+8.56	TECTEH	HR		21H00072	600UL
10124	67	132	0.74	83	INR	6	02C	+16.80	TECTEH			21H00073	600UL
10125			0.54	64	INR	6	01C	+22.57	TECTEH			21H00073	600UL
10126			0.73	78	INR	6	TSC	+18.02	TECTEH			21H00073	600UL
10127	69	132							TECTEH			21H00072	600UL
10128	71	132	0.42	58	INR	6	07H	+8.21	TECTEH			21H00073	600UL
10129	73	132							TECTEH			21H00072	600UL
10130	75	132							TECTEH			21H00073	600UL
10131	77	132							TECTEH			21H00072	600UL
10132	79	132							TECTEH			21H00073	600UL
10133	81	132							TECTEH			21H00072	600UL
10134	83	132							TECTEH			21H00063	600UL
10135	85	132	0.50	75	INR	6	01H	+23.56	TECTEH			21H00062	600UL
10136			0.54	76	INR	6	06C	+11.19	TECTEH			21H00062	600UL
10137			0.77	76	INR	6	06C	+28.46	TECTEH			21H00062	600UL
10138			0.46	61	INR	6	05C	+22.67	TECTEH			21H00062	600UL
10139	87	132							TECTEH			21H00063	600UL
10140	89	132							TECTEH			21H00062	600UL
10141	91	132	0.81	79	INR	3	F06	+11.75	TECTEH			21H00063	600UL
10142			0.47	120	INR	3	02C	+8.19	TECTEH			21H00063	600UL
10143	93	132	0.92	77	INR	6	01C	+23.86	TECTEH			21H00062	600UL
10144	95	132							TECTEH			21H00063	600UL
10145	97	132							TECTEH			21H00062	600UL
10146	99	132			INF		TSH	+0.00	TECTEH	HR		21H00063	600UL
10147	101	132	0.39	67	INR	6	05H	+26.23	TECTEH			21H00062	600UL
10148	103	132							TECTEH			21H00063	600UL
10149	105	132							TECTEH			21H00062	600UL
10150	107	132							TECTEH			21H00063	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10151	109	132	0.37	66	NQH	3	F04	+7.20	TECTEH			21H00062	600UL
10152			0.65	82	INR	6	06C	+37.70	TECTEH			21H00062	600UL
10153	111	132	0.66	88	INR	6	01C	+20.25	TECTEH			21H00063	600UL
10154	113	132	0.24	78	INR	6	F09	+5.86	TECTEH			21H00062	600UL
10155			0.41	77	INR	6	06C	+20.78	TECTEH			21H00062	600UL
10156	115	132							TECTEH			21H00062	600UL
10157	2	133							TECTEH			21H00085	600UL
10158	4	133							TECTEH			21H00084	600UL
10159	6	133	0.34	72	INR	6	01C	+26.77	TECTEH			21H00084	600UL
10160	8	133							TECTEH			21H00083	600UL
10161	10	133	0.81	74	INR	6	02H	+31.28	TECTEH			21H00082	600UL
10162	12	133	0.48	146	INR	3	02C	+15.93	TECTEH			21H00083	600UL
10163	14	133							TECTEH			21H00082	600UL
10164	16	133							TECTEH			21H00081	600UL
10165	18	133							TECTEH			21H00080	600UL
10166	20	133							TECTEH			21H00081	600UL
10167	22	133							TECTEH			21H00080	600UL
10168	24	133							TECTEH			21H00080	600UL
10169	26	133	0.71	81	INR	6	03H	+8.47	TECTEH			21H00077	600UL
10170	28	133	0.68	67	INR	6	TSH	+1.89	TECTEH			21H00076	600UL
10171	30	133							TECTEH			21H00077	600UL
10172	32	133							TECTEH			21H00076	600UL
10173	34	133							TECTEH			21H00077	600UL
10174	36	133	0.57	76	INR	6	05H	+9.00	TECTEH			21H00076	600UL
10175			0.32	77	INR	6	03C	+31.29	TECTEH			21H00076	600UL
10176	38	133							TECTEH			21H00077	600UL
10177	40	133			INF		F04	+6.00	TECTEH	HR		21H00076	600UL
10178					INF		F04	+8.96	TECTEH	HR		21H00076	600UL
10179			0.63	70	INR	6	TSC	+20.46	TECTEH			21H00076	600UL
10180	42	133							TECTEH			21H00077	600UL
10181	44	133							TECTEH			21H00076	600UL
10182	46	133							TECTEH			21H00077	600UL
10183	48	133	0.39	72	INR	6	02H	+11.34	TECTEH			21H00076	600UL
10184	50	133	0.92	48	NQH	3	F01	+4.15	TECTEH			21H00073	600UL
10185					INF		F03	+4.39	TECTEH	HR		21H00073	600UL
10186	52	133	0.34	143	INR	3	02H	+16.07	TECTEH			21H00072	600UL
10187	54	133	0.45	85	INR	6	02H	+16.28	TECTEH			21H00073	600UL
10188	56	133	0.28	127	INR	3	TSC	+8.73	TECTEH			21H00072	600UL
10189	58	133	0.80	67	INR	6	06H	+3.78	TECTEH			21H00073	600UL
10190	60	133	0.54	141	INR	3	F07	+4.81	TECTEH			21H00072	600UL
10191					INF		F08	+6.03	TECTEH	HR		21H00072	600UL
10192			0.36	97	INR	3	F12	+5.53	TECTEH			21H00072	600UL
10193					INF		07C	+5.81	TECTEH	HR		21H00072	600UL
10194	62	133							TECTEH			21H00073	600UL
10195	64	133							TECTEH			21H00072	600UL
10196	66	133	0.58	70	INR	6	01C	+10.09	TECTEH			21H00073	600UL
10197	68	133							TECTEH			21H00072	600UL
10198	70	133							TECTEH			21H00073	600UL
10199	72	133							TECTEH			21H00072	600UL
10200	74	133							TECTEH			21H00073	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10201	76	133							TECTEH			21H00072	600UL
10202	78	133							TECTEH			21H00073	600UL
10203	80	133							TECTEH			21H00072	600UL
10204	82	133	0.53	66	INR	6	02C	+3.28	TECTEH			21H00063	600UL
10205	84	133							TECTEH			21H00062	600UL
10206	86	133	0.68	76	INR	6	02C	+33.41	TECTEH			21H00063	600UL
10207	88	133							TECTEH			21H00062	600UL
10208	90	133	0.39	77	INR	6	06H	+35.80	TECTEH			21H00063	600UL
10209			0.48	69	INR	6	02C	+18.82	TECTEH			21H00063	600UL
10210	92	133	0.40	57	INR	6	F08	+6.33	TECTEH			21H00062	600UL
10211			0.51	88	INR	6	F09	+11.42	TECTEH			21H00062	600UL
10212					INF		F10	+5.03	TECTEH	HR		21H00062	600UL
10213					INF		F10	+26.41	TECTEH	HR		21H00062	600UL
10214			0.49	70	INR	6	04C	+31.00	TECTEH			21H00062	600UL
10215			0.54	97	INR	6	TSC	+17.81	TECTEH			21H00062	600UL
10216	94	133	0.93	74	INR	6	04H	+27.29	TECTEH			21H00063	600UL
10217			0.75	71	INR	6	04H	+29.73	TECTEH			21H00063	600UL
10218			0.43	70	INR	6	F05	+5.76	TECTEH			21H00063	600UL
10219			0.81	27	INR	6	F09	+0.65	TECTEH			21H00063	600UL
10220			0.83	97	INR	6	F09	+9.73	TECTEH			21H00063	600UL
10221					INF		F10	+3.72	TECTEH	HR		21H00063	600UL
10222	96	133	0.42	73	INR	6	02H	+15.38	TECTEH			21H00062	600UL
10223			0.51	93	INR	6	02C	+14.31	TECTEH			21H00062	600UL
10224			0.54	68	INR	6	TSC	+10.20	TECTEH			21H00062	600UL
10225					INF		TSC	+11.40	TECTEH	HR		21H00062	600UL
10226	98	133							TECTEH			21H00063	600UL
10227	100	133							TECTEH			21H00062	600UL
10228	102	133	0.36	66	INR	6	06H	+12.58	TECTEH			21H00063	600UL
10229			0.52	80	INR	6	F12	+12.34	TECTEH			21H00063	600UL
10230					INF		07C	+2.33	TECTEH	HR		21H00063	600UL
10231	104	133							TECTEH			21H00062	600UL
10232	106	133							TECTEH			21H00063	600UL
10233	108	133							TECTEH			21H00062	600UL
10234	110	133	0.80	68	INR	6	04C	+5.65	TECTEH			21H00063	600UL
10235	112	133							TECTEH			21H00062	600UL
10236	1	134							TECTEH			21H00085	600UL
10237	3	134							TECTEH			21H00084	600UL
10238	5	134							TECTEH			21H00085	600UL
10239	7	134							TECTEH			21H00084	600UL
10240	9	134							TECTEH			21H00083	600UL
10241	11	134							TECTEH			21H00082	600UL
10242	13	134							TECTEH			21H00083	600UL
10243	15	134							TECTEH			21H00082	600UL
10244	17	134							TECTEH			21H00081	600UL
10245	19	134			INF		07H	+5.91	TECTEH	HR		21H00080	600UL
10246					INF		06C	+18.16	TECTEH	HR		21H00080	600UL
10247			0.36	72	INR	6	06C	+20.60	TECTEH			21H00080	600UL
10248	21	134			INF		F01	+2.76	TECTEH	HR		21H00081	600UL
10249			2.89	182	INR	1	F01	+3.64	TECTEH			21H00081	600UL
10250			4.71	183	INR	1	F01	+6.48	TECTEH			21H00081	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10251				INF		F05	+5.00	TECTEH	HR		21H00081	600UL
10252				INF		F05	+5.00	TECTEH	HR		21H00081	600UL
10253	23 134	0.91	76	INR	6	TSH	+19.04	TECTEH			21H00080	600UL
10254		0.55	70	INR	6	01H	+17.98	TECTEH			21H00080	600UL
10255		0.46	67	INR	6	01H	+25.84	TECTEH			21H00080	600UL
10256		0.40	69	INR	6	02H	+4.92	TECTEH			21H00080	600UL
10257	25 134							TECTEH			21H00077	600UL
10258	27 134							TECTEH			21H00076	600UL
10259	29 134							TECTEH			21H00077	600UL
10260	31 134							TECTEH			21H00076	600UL
10261	33 134			INF		F07	+0.84	TECTEH	HR		21H00077	600UL
10262				INF		F07	+0.84	TECTEH	HR		21H00077	600UL
10263		0.69	112	INR	6	F07	+1.93	TECTEH			21H00077	600UL
10264		1.27	67	INR	6	F07	+2.95	TECTEH			21H00077	600UL
10265				INF		F08	+3.77	TECTEH	HR		21H00077	600UL
10266				INF		F08	+9.59	TECTEH	HR		21H00077	600UL
10267	35 134							TECTEH			21H00076	600UL
10268	37 134	0.38	70	INR	6	05H	+10.35	TECTEH			21H00077	600UL
10269		0.70	77	INR	6	02C	+8.50	TECTEH			21H00077	600UL
10270	39 134	0.71	77	INR	6	TSH	+9.52	TECTEH			21H00076	600UL
10271		0.89	74	INR	6	04C	+10.92	TECTEH			21H00076	600UL
10272		0.41	70	INR	6	03C	+8.39	TECTEH			21H00076	600UL
10273	41 134							TECTEH			21H00077	600UL
10274	43 134							TECTEH			21H00076	600UL
10275	45 134							TECTEH			21H00077	600UL
10276	47 134							TECTEH			21H00076	600UL
10277	49 134							TECTEH			21H00076	600UL
10278	51 134							TECTEH			21H00073	600UL
10279	53 134							TECTEH			21H00072	600UL
10280	55 134			INF		F09	+3.19	TECTEH	HR		21H00073	600UL
10281		0.37	68	INR	6	F10	+2.88	TECTEH			21H00073	600UL
10282				INF		F10	+10.28	TECTEH	HR		21H00073	600UL
10283	57 134							TECTEH			21H00072	600UL
10284	59 134							TECTEH			21H00073	600UL
10285	61 134							TECTEH			21H00072	600UL
10286	63 134							TECTEH			21H00073	600UL
10287	65 134	0.25	140	INR	3	01H	+13.89	TECTEH			21H00072	600UL
10288		0.45	155	INR	3	02H	+5.44	TECTEH			21H00072	600UL
10289		0.48	137	INR	3	02H	+22.96	TECTEH			21H00072	600UL
10290		0.43	123	INR	3	03H	+36.31	TECTEH			21H00072	600UL
10291		0.35	139	INR	3	06H	+6.47	TECTEH			21H00072	600UL
10292				INF		06H	+8.08	TECTEH	HR		21H00072	600UL
10293		0.29	134	INR	3	07H	+7.90	TECTEH			21H00072	600UL
10294		0.42	75	INR	3	F05	-0.34	TECTEH			21H00072	600UL
10295		0.53	141	INR	3	F10	-0.15	TECTEH			21H00072	600UL
10296		0.31	138	INR	3	06C	+13.76	TECTEH			21H00072	600UL
10297		0.35	128	INR	3	05C	+23.88	TECTEH			21H00072	600UL
10298		0.44	135	INR	3	05C	+30.88	TECTEH			21H00072	600UL
10299		0.34	133	INR	3	04C	+9.00	TECTEH			21H00072	600UL
10300		0.38	121	INR	3	04C	+31.32	TECTEH			21H00072	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10301		0.15	46	INR	3	02C	+31.43	TECTEH			21H00072	600UL
10302		0.37	122	INR	3	02C	+32.44	TECTEH			21H00072	600UL
10303	67 134	0.71	69	INR	6	05H	+22.50	TECTEH			21H00073	600UL
10304	69 134							TECTEH			21H00072	600UL
10305	71 134							TECTEH			21H00073	600UL
10306	73 134							TECTEH			21H00072	600UL
10307	75 134	0.62	71	INR	6	06H	+38.34	TECTEH			21H00073	600UL
10308		0.89	78	INR	6	02C	+11.89	TECTEH			21H00073	600UL
10309		0.42	80	INR	6	02C	+15.10	TECTEH			21H00073	600UL
10310		0.65	79	INR	6	02C	+17.22	TECTEH			21H00073	600UL
10311		0.58	76	INR	6	01C	+31.94	TECTEH			21H00073	600UL
10312	77 134	0.80	134	INR	3	02H	+12.81	TECTEH			21H00072	600UL
10313		1.19	201	INR	6	F09	+0.00	TECTEH			21H00072	600UL
10314	79 134							TECTEH			21H00073	600UL
10315	81 134	0.56	149	INR	3	F03	+10.76	TECTEH			21H00072	600UL
10316	83 134	0.67	88	INR	6	02C	+23.53	TECTEH			21H00063	600UL
10317	85 134							TECTEH			21H00062	600UL
10318	87 134	0.69	73	INR	6	05C	+17.33	TECTEH			21H00063	600UL
10319	89 134							TECTEH			21H00062	600UL
10320	91 134							TECTEH			21H00063	600UL
10321	93 134	0.27	89	INR	6	05C	+13.39	TECTEH			21H00062	600UL
10322				INF		05C	+14.59	TECTEH	HR		21H00062	600UL
10323		0.38	72	INR	6	04C	+17.82	TECTEH			21H00062	600UL
10324	95 134	0.40	75	INR	6	06H	+8.63	TECTEH			21H00063	600UL
10325		0.69	96	INR	6	F03	+2.46	TECTEH			21H00063	600UL
10326	97 134	0.56	77	INR	6	F12	+9.11	TECTEH			21H00062	600UL
10327				INF		07C	+5.02	TECTEH	HR		21H00062	600UL
10328	99 134	0.60	75	INR	6	01C	+6.77	TECTEH			21H00063	600UL
10329	101 134							TECTEH			21H00062	600UL
10330	103 134							TECTEH			21H00063	600UL
10331	105 134							TECTEH			21H00062	600UL
10332	107 134							TECTEH			21H00063	600UL
10333	109 134	0.37	72	INR	6	01H	+28.48	TECTEH			21H00062	600UL
10334		0.43	89	INR	6	F06	+9.38	TECTEH			21H00062	600UL
10335		0.74	86	INR	6	06C	+8.78	TECTEH			21H00062	600UL
10336	111 134			INF		01H	+7.73	TECTEH	HR		21H00062	600UL
10337				INF		01H	+18.50	TECTEH	HR		21H00062	600UL
10338	2 135							TECTEH			21H00085	600UL
10339	4 135							TECTEH			21H00084	600UL
10340	6 135							TECTEH			21H00085	600UL
10341	8 135							TECTEH			21H00084	600UL
10342	10 135							TECTEH			21H00083	600UL
10343	12 135							TECTEH			21H00083	600UL
10344	14 135							TECTEH			21H00082	600UL
10345	16 135							TECTEH			21H00081	600UL
10346	18 135							TECTEH			21H00080	600UL
10347	20 135							TECTEH			21H00081	600UL
10348	22 135							TECTEH			21H00080	600UL
10349	24 135							TECTEH			21H00080	600UL
10350	26 135							TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10351	28	135							TECTEH			21H00076	600UL
10352	30	135							TECTEH			21H00077	600UL
10353	32	135							TECTEH			21H00076	600UL
10354	34	135							TECTEH			21H00077	600UL
10355	36	135							TECTEH			21H00076	600UL
10356	38	135	0.40	67	INR	6	06C	+18.43	TECTEH			21H00077	600UL
10357			0.60	72	INR	6	01C	+27.54	TECTEH			21H00077	600UL
10358	40	135	0.35	69	INR	6	01H	+13.85	TECTEH			21H00076	600UL
10359			0.40	76	INR	6	03C	+17.35	TECTEH			21H00076	600UL
10360	42	135							TECTEH			21H00077	600UL
10361	44	135							TECTEH			21H00076	600UL
10362	46	135			RBD							21H00077	600UL
10363			0.61	72	INR	6	01H	+19.18	TECTEH			21H00081	600UL
10364			0.51	76	INR	6	03H	+29.80	TECTEH			21H00081	600UL
10365			0.86	61	INR	6	06C	+1.85	TECTEH			21H00081	600UL
10366			0.49	71	INR	6	06C	+18.61	TECTEH			21H00081	600UL
10367			0.50	76	INR	6	03C	+21.52	TECTEH			21H00081	600UL
10368	48	135							TECTEH			21H00076	600UL
10369	50	135	0.51	73	INR	6	06C	+14.51	TECTEH			21H00073	600UL
10370	52	135							TECTEH			21H00072	600UL
10371	54	135							TECTEH			21H00073	600UL
10372	56	135	0.31	110	NQH	3	06H	+2.12	TECTEH			21H00072	600UL
10373	58	135							TECTEH			21H00073	600UL
10374	60	135							TECTEH			21H00072	600UL
10375	62	135	0.88	68	INR	6	06H	+2.57	TECTEH			21H00073	600UL
10376	64	135							TECTEH			21H00072	600UL
10377	66	135	0.50	62	INR	6	F04	+8.62	TECTEH			21H00073	600UL
10378	68	135							TECTEH			21H00072	600UL
10379	70	135							TECTEH			21H00073	600UL
10380	72	135							TECTEH			21H00072	600UL
10381	74	135							TECTEH			21H00073	600UL
10382	76	135							TECTEH			21H00072	600UL
10383	78	135							TECTEH			21H00073	600UL
10384	80	135							TECTEH			21H00072	600UL
10385	82	135			INF		F02	+4.25	TECTEH	HR		21H00062	600UL
10386			0.39	69	INR	6	F02	+5.49	TECTEH			21H00062	600UL
10387	84	135							TECTEH			21H00063	600UL
10388	86	135	0.37	120	INR	3	06H	+4.82	TECTEH			21H00062	600UL
10389			0.52	66	INR	6	07H	+10.05	TECTEH			21H00062	600UL
10390			0.75	69	INR	6	F08	+5.10	TECTEH			21H00062	600UL
10391					INF		F09	+8.43	TECTEH	HR		21H00062	600UL
10392	88	135							TECTEH			21H00063	600UL
10393	90	135							TECTEH			21H00062	600UL
10394	92	135							TECTEH			21H00063	600UL
10395	94	135							TECTEH			21H00062	600UL
10396	96	135							TECTEH			21H00063	600UL
10397	98	135							TECTEH			21H00062	600UL
10398	100	135	0.53	68	INR	6	06H	+24.16	TECTEH			21H00063	600UL
10399			0.37	352	INR	6	F01	+2.67	TECTEH			21H00063	600UL
10400			0.45	53	INR	6	F07	+8.05	TECTEH			21H00063	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10401				INF		F08	+6.53	TECTEH	HR		21H00063	600UL
10402	102 135							TECTEH			21H00062	600UL
10403	104 135							TECTEH			21H00063	600UL
10404	106 135							TECTEH			21H00062	600UL
10405	108 135	0.34	78	INR	6	01H	+13.11	TECTEH			21H00063	600UL
10406		0.60	81	INR	6	02H	+9.70	TECTEH			21H00063	600UL
10407		0.41	73	INR	6	04H	+26.71	TECTEH			21H00063	600UL
10408		0.88	69	INR	6	06H	+14.18	TECTEH			21H00063	600UL
10409		0.65	73	INR	6	01C	+25.15	TECTEH			21H00063	600UL
10410	110 135							TECTEH			21H00062	600UL
10411	1 136							TECTEH			21H00085	600UL
10412	3 136							TECTEH			21H00084	600UL
10413	5 136							TECTEH			21H00085	600UL
10414	7 136							TECTEH			21H00084	600UL
10415	9 136							TECTEH			21H00083	600UL
10416	11 136							TECTEH			21H00082	600UL
10417	13 136							TECTEH			21H00083	600UL
10418	15 136							TECTEH			21H00082	600UL
10419	17 136							TECTEH			21H00081	600UL
10420	19 136							TECTEH			21H00080	600UL
10421	21 136	4.64	185	INR	1	F01	+6.16	TECTEH			21H00081	600UL
10422				INF		F05	+4.73	TECTEH	HR		21H00081	600UL
10423	23 136							TECTEH			21H00080	600UL
10424	25 136							TECTEH			21H00077	600UL
10425	27 136							TECTEH			21H00076	600UL
10426	29 136							TECTEH			21H00077	600UL
10427	31 136							TECTEH			21H00076	600UL
10428	33 136	0.50	76	INR	6	02H	+7.86	TECTEH			21H00077	600UL
10429		0.39	84	INR	6	01C	+8.11	TECTEH			21H00077	600UL
10430	35 136	0.44	60	INR	6	04H	+22.44	TECTEH			21H00076	600UL
10431	37 136	0.70	81	INR	6	06C	+7.43	TECTEH			21H00077	600UL
10432	39 136	0.37	76	INR	6	01C	+22.06	TECTEH			21H00076	600UL
10433	41 136							TECTEH			21H00077	600UL
10434	43 136	0.77	76	INR	6	01H	+4.43	TECTEH			21H00076	600UL
10435	45 136	0.36	72	INR	6	04H	+14.16	TECTEH			21H00077	600UL
10436		0.48	72	INR	6	04H	+26.95	TECTEH			21H00077	600UL
10437	47 136							TECTEH			21H00076	600UL
10438	49 136	0.37	66	INR	6	05H	+21.37	TECTEH			21H00076	600UL
10439	51 136							TECTEH			21H00073	600UL
10440	53 136	0.73	115	INR	3	03H	+30.98	TECTEH			21H00072	600UL
10441	55 136							TECTEH			21H00073	600UL
10442	57 136	0.33	120	INR	3	06C	+30.19	TECTEH			21H00072	600UL
10443	59 136	0.34	54	INR	6	F04	+2.84	TECTEH			21H00073	600UL
10444		0.66	84	INR	6	05C	+27.87	TECTEH			21H00073	600UL
10445	61 136	0.95	165	INR	3	F08	+9.08	TECTEH			21H00072	600UL
10446				INF		F09	+1.59	TECTEH	HR		21H00072	600UL
10447	63 136							TECTEH			21H00073	600UL
10448	65 136	0.44	123	INR	3	06H	+34.78	TECTEH			21H00072	600UL
10449	67 136							TECTEH			21H00073	600UL
10450	69 136	0.52	93	INR	3	F06	+2.48	TECTEH			21H00072	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10451		0.47	103	INR	3	F06	+3.52	TECTEH			21H00072	600UL
10452		0.70	132	INR	3	06C	+12.88	TECTEH			21H00072	600UL
10453	71 136							TECTEH			21H00073	600UL
10454	73 136							TECTEH			21H00072	600UL
10455	75 136							TECTEH			21H00073	600UL
10456	77 136							TECTEH			21H00072	600UL
10457	79 136							TECTEH			21H00073	600UL
10458	81 136	0.30	123	INR	3	04H	+24.25	TECTEH			21H00072	600UL
10459		0.63	159	INR	3	F03	+9.53	TECTEH			21H00072	600UL
10460		0.33	68	INR	3	F06	+6.22	TECTEH			21H00072	600UL
10461		0.40	138	INR	3	04C	+34.77	TECTEH			21H00072	600UL
10462		0.60	141	INR	3	03C	+30.55	TECTEH			21H00072	600UL
10463	83 136	0.60	47	INR	6	03C	+1.64	TECTEH			21H00063	600UL
10464	85 136	0.49	74	INR	6	01H	+17.41	TECTEH			21H00062	600UL
10465		0.80	72	INR	6	01H	+19.28	TECTEH			21H00062	600UL
10466		0.41	73	INR	6	01H	+26.01	TECTEH			21H00062	600UL
10467		0.88	75	INR	6	02H	+25.47	TECTEH			21H00062	600UL
10468		0.55	75	INR	6	03H	+4.52	TECTEH			21H00062	600UL
10469		0.60	71	INR	6	03H	+19.63	TECTEH			21H00062	600UL
10470		0.40	81	INR	6	03H	+30.96	TECTEH			21H00062	600UL
10471		0.49	68	INR	6	04H	+14.48	TECTEH			21H00062	600UL
10472		0.35	55	INR	6	05H	+25.42	TECTEH			21H00062	600UL
10473		0.71	63	INR	6	06H	+24.92	TECTEH			21H00062	600UL
10474		0.48	81	INR	6	01C	+21.20	TECTEH			21H00062	600UL
10475	87 136							TECTEH			21H00063	600UL
10476	89 136							TECTEH			21H00062	600UL
10477	91 136	0.62	65	INR	6	01H	+22.58	TECTEH			21H00063	600UL
10478		0.38	61	INR	6	F12	+0.31	TECTEH			21H00063	600UL
10479		0.80	66	INR	6	04C	+33.18	TECTEH			21H00063	600UL
10480		0.51	81	INR	6	TSC	+6.60	TECTEH			21H00063	600UL
10481	93 136	0.61	72	INR	6	F12	+9.82	TECTEH			21H00062	600UL
10482				INF		F12	+17.73	TECTEH	HR		21H00062	600UL
10483				INF		07C	+4.66	TECTEH	HR		21H00062	600UL
10484	95 136	0.50	52	INR	6	06H	+32.88	TECTEH			21H00063	600UL
10485	97 136							TECTEH			21H00062	600UL
10486	99 136	0.36	74	INR	6	03H	+22.19	TECTEH			21H00063	600UL
10487		0.52	73	INR	6	05H	+19.38	TECTEH			21H00063	600UL
10488		0.32	73	INR	6	01C	+22.91	TECTEH			21H00063	600UL
10489	101 136							TECTEH			21H00062	600UL
10490	103 136							TECTEH			21H00063	600UL
10491	105 136	0.37	68	INR	6	F03	+10.18	TECTEH			21H00062	600UL
10492		0.48	73	INR	6	06C	+25.91	TECTEH			21H00062	600UL
10493	107 136							TECTEH			21H00063	600UL
10494	109 136							TECTEH			21H00062	600UL
10495	2 137							TECTEH			21H00085	600UL
10496	4 137							TECTEH			21H00084	600UL
10497	6 137							TECTEH			21H00084	600UL
10498	8 137							TECTEH			21H00083	600UL
10499	10 137							TECTEH			21H00082	600UL
10500	12 137							TECTEH			21H00083	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10501	14	137							TECTEH			21H00082	600UL
10502	16	137							TECTEH			21H00081	600UL
10503	18	137							TECTEH			21H00080	600UL
10504	20	137							TECTEH			21H00081	600UL
10505	22	137							TECTEH			21H00080	600UL
10506	24	137							TECTEH			21H00080	600UL
10507	26	137							TECTEH			21H00077	600UL
10508	28	137							TECTEH			21H00076	600UL
10509	30	137							TECTEH			21H00077	600UL
10510	32	137							TECTEH			21H00076	600UL
10511	34	137	0.57	79	INR	6	06C	+7.44	TECTEH			21H00077	600UL
10512	36	137							TECTEH			21H00076	600UL
10513	38	137			INF		F04	+9.57	TECTEH	HR		21H00077	600UL
10514			0.50	52	INR	6	F04	+11.03	TECTEH			21H00077	600UL
10515			0.53	107	INR	6	F05	+4.72	TECTEH			21H00077	600UL
10516					INF		03C	+17.87	TECTEH	HR		21H00077	600UL
10517			0.59	66	INR	6	03C	+23.05	TECTEH			21H00077	600UL
10518	40	137							TECTEH			21H00076	600UL
10519	42	137	0.55	61	INR	6	TSC	+16.45	TECTEH			21H00077	600UL
10520	44	137	1.77	59	INR	6	F06	+11.52	TECTEH			21H00076	600UL
10521					INF		F07	+2.47	TECTEH	HR		21H00076	600UL
10522	46	137							TECTEH			21H00077	600UL
10523	48	137							TECTEH			21H00076	600UL
10524	50	137							TECTEH			21H00073	600UL
10525	52	137							TECTEH			21H00072	600UL
10526	54	137							TECTEH			21H00073	600UL
10527	56	137	0.51	132	INR	3	06C	+17.54	TECTEH			21H00072	600UL
10528					INF		05C	+17.30	TECTEH	HR		21H00072	600UL
10529			0.39	133	INR	3	05C	+22.49	TECTEH			21H00072	600UL
10530	58	137	0.84	73	INR	6	06H	+17.17	TECTEH			21H00073	600UL
10531					INF		06H	+18.46	TECTEH	HR		21H00073	600UL
10532	60	137							TECTEH			21H00072	600UL
10533	62	137	0.59	78	INR	6	F03	+2.04	TECTEH			21H00073	600UL
10534			0.55	80	INR	6	03C	+22.24	TECTEH			21H00073	600UL
10535	64	137							TECTEH			21H00072	600UL
10536	66	137	1.26	74	INR	6	04H	+24.71	TECTEH			21H00073	600UL
10537			0.55	86	INR	6	F06	+5.52	TECTEH			21H00073	600UL
10538			0.83	74	INR	6	06C	+16.91	TECTEH			21H00073	600UL
10539	68	137							TECTEH			21H00072	600UL
10540	70	137							TECTEH			21H00073	600UL
10541	72	137							TECTEH			21H00072	600UL
10542	74	137							TECTEH			21H00073	600UL
10543	76	137							TECTEH			21H00072	600UL
10544	78	137							TECTEH			21H00073	600UL
10545	80	137							TECTEH			21H00072	600UL
10546	82	137	0.42	97	INR	6	02C	+9.65	TECTEH			21H00063	600UL
10547	84	137							TECTEH			21H00062	600UL
10548	86	137	0.42	74	INR	6	04H	+21.15	TECTEH			21H00063	600UL
10549			0.45	73	INR	6	04H	+23.01	TECTEH			21H00063	600UL
10550			0.33	85	INR	6	03C	+10.13	TECTEH			21H00063	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10551			0.60	72	INR	6	03C	+32.73	TECTEH			21H00063	600UL
10552			0.52	74	INR	6	02C	+14.60	TECTEH			21H00063	600UL
10553	88	137	0.59	68	INR	6	02C	+3.42	TECTEH			21H00062	600UL
10554	90	137							TECTEH			21H00063	600UL
10555	92	137							TECTEH			21H00062	600UL
10556	94	137							TECTEH			21H00063	600UL
10557	96	137							TECTEH			21H00062	600UL
10558	98	137							TECTEH			21H00063	600UL
10559	100	137							TECTEH			21H00062	600UL
10560	102	137							TECTEH			21H00063	600UL
10561	104	137							TECTEH			21H00062	600UL
10562	106	137	0.41	81	INR	6	06H	+36.09	TECTEH			21H00063	600UL
10563	108	137							TECTEH			21H00062	600UL
10564	1	138							TECTEH			21H00085	600UL
10565	3	138							TECTEH			21H00084	600UL
10566	5	138							TECTEH			21H00085	600UL
10567	7	138							TECTEH			21H00084	600UL
10568	9	138							TECTEH			21H00083	600UL
10569	11	138							TECTEH			21H00082	600UL
10570	13	138							TECTEH			21H00083	600UL
10571	15	138							TECTEH			21H00082	600UL
10572	17	138							TECTEH			21H00081	600UL
10573	19	138							TECTEH			21H00080	600UL
10574	21	138							TECTEH			21H00081	600UL
10575	23	138							TECTEH			21H00080	600UL
10576	25	138							TECTEH			21H00077	600UL
10577	27	138							TECTEH			21H00076	600UL
10578	29	138							TECTEH			21H00077	600UL
10579	31	138							TECTEH			21H00076	600UL
10580	33	138							TECTEH			21H00077	600UL
10581	35	138							TECTEH			21H00076	600UL
10582	37	138							TECTEH			21H00077	600UL
10583	39	138							TECTEH			21H00076	600UL
10584	41	138	0.96	47	INR	6	07H	+9.22	TECTEH			21H00077	600UL
10585	43	138	1.17	72	INR	6	05H	+4.21	TECTEH			21H00076	600UL
10586	45	138							TECTEH			21H00077	600UL
10587	47	138							TECTEH			21H00076	600UL
10588	49	138							TECTEH			21H00076	600UL
10589	51	138							TECTEH			21H00073	600UL
10590	53	138							TECTEH			21H00072	600UL
10591	55	138							TECTEH			21H00073	600UL
10592	57	138							TECTEH			21H00072	600UL
10593	59	138							TECTEH			21H00073	600UL
10594	61	138							TECTEH			21H00072	600UL
10595	63	138							TECTEH			21H00075	600UL
10596	65	138	0.48	65	INR	6	F03	+5.98	TECTEH			21H00074	600UL
10597			0.71	41	INR	6	F05	+0.00	TECTEH			21H00074	600UL
10598	67	138							TECTEH			21H00075	600UL
10599	69	138							TECTEH			21H00074	600UL
10600	71	138							TECTEH			21H00075	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10601	73	138							TECTEH			21H00074	600UL
10602	75	138							TECTEH			21H00075	600UL
10603	77	138							TECTEH			21H00074	600UL
10604	79	138	1.02	75	INR	6	02H	+39.18	TECTEH			21H00075	600UL
10605	81	138	1.02	76	INR	6	02H	+30.16	TECTEH			21H00074	600UL
10606			0.57	72	INR	6	06C	+25.79	TECTEH			21H00074	600UL
10607					INF		06C	+27.28	TECTEH	HR		21H00074	600UL
10608			0.70	69	INR	6	04C	+33.05	TECTEH			21H00074	600UL
10609			0.56	68	INR	6	02C	+16.36	TECTEH			21H00074	600UL
10610			0.67	80	INR	6	02C	+18.28	TECTEH			21H00074	600UL
10611	83	138	0.40	84	INR	6	01H	+16.02	TECTEH			21H00063	600UL
10612	85	138	1.18	61	INR	6	F05	+0.00	TECTEH			21H00062	600UL
10613	87	138	0.67	71	INR	6	04H	+37.85	TECTEH			21H00063	600UL
10614	89	138							TECTEH			21H00062	600UL
10615	91	138							TECTEH			21H00063	600UL
10616									TSHTSH			21H00088	610PP
10617	93	138							TECTEH			21H00062	600UL
10618									TSHTSH			21H00088	610PP
10619	95	138							TECTEH			21H00063	600UL
10620	97	138							TECTEH			21H00062	600UL
10621	99	138							TECTEH			21H00063	600UL
10622	101	138	0.58	39	INR	6	F02	+0.31	TECTEH			21H00062	600UL
10623	103	138							TECTEH			21H00063	600UL
10624	105	138							TECTEH			21H00062	600UL
10625	107	138	0.58	69	INR	6	TSC	+5.57	TECTEH			21H00062	600UL
10626	2	139							TECTEH			21H00085	600UL
10627	4	139							TECTEH			21H00084	600UL
10628	6	139							TECTEH			21H00084	600UL
10629	8	139							TECTEH			21H00083	600UL
10630	10	139	2.34	40	INR	6	02H	+27.07 TO+41.68	TECTEH			21H00082	600UL
10631	12	139							TECTEH			21H00083	600UL
10632	14	139							TECTEH			21H00082	600UL
10633	16	139							TECTEH			21H00081	600UL
10634	18	139							TECTEH			21H00080	600UL
10635	20	139							TECTEH			21H00081	600UL
10636	22	139							TECTEH			21H00080	600UL
10637	24	139							TECTEH			21H00080	600UL
10638	26	139							TECTEH			21H00077	600UL
10639	28	139							TECTEH			21H00076	600UL
10640	30	139							TECTEH			21H00077	600UL
10641	32	139							TECTEH			21H00076	600UL
10642	34	139							TECTEH			21H00077	600UL
10643	36	139			INF		F04	+2.79	TECTEH	HR		21H00076	600UL
10644					INF		F05	+3.00	TECTEH	HR		21H00076	600UL
10645	38	139	0.58	56	INR	6	F07	-0.03	TECTEH			21H00077	600UL
10646			0.64	77	INR	6	02C	+16.92	TECTEH			21H00077	600UL
10647	40	139							TECTEH			21H00076	600UL
10648	42	139							TECTEH			21H00077	600UL
10649	44	139	0.41	65	INR	6	05H	+5.47	TECTEH			21H00076	600UL
10650	46	139	1.65	79	INR	6	03H	+20.42	TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10651	48	139							TECTEH			21H00076	600UL
10652	50	139	0.42	74	INR	6	03C	+35.82	TECTEH			21H00075	600UL
10653					INF		01C	+96.83	TECTEH	HR		21H00075	600UL
10654	52	139							TECTEH			21H00074	600UL
10655	54	139							TECTEH			21H00075	600UL
10656	56	139	0.80	79	INR	6	03H	+6.45	TECTEH			21H00074	600UL
10657	58	139	0.58	80	INR	6	TSH	+16.25	TECTEH			21H00075	600UL
10658			0.47	85	INR	6	01H	+29.57	TECTEH			21H00075	600UL
10659			0.49	81	INR	6	05C	+14.04	TECTEH			21H00075	600UL
10660			0.66	91	INR	6	01C	+29.50	TECTEH			21H00075	600UL
10661	60	139							TECTEH			21H00074	600UL
10662	62	139							TECTEH			21H00075	600UL
10663	64	139	0.62	79	INR	6	04C	+25.41	TECTEH			21H00074	600UL
10664	66	139							TECTEH			21H00075	600UL
10665	68	139							TECTEH			21H00074	600UL
10666	70	139	0.75	80	INR	6	01H	+27.39	TECTEH			21H00075	600UL
10667			0.58	79	INR	6	02H	+36.65	TECTEH			21H00075	600UL
10668			0.37	69	INR	6	07H	+18.04	TECTEH			21H00075	600UL
10669	72	139							TECTEH			21H00074	600UL
10670	74	139							TECTEH			21H00075	600UL
10671	76	139							TECTEH			21H00074	600UL
10672	78	139							TECTEH			21H00075	600UL
10673	80	139	0.49	67	INR	6	F05	+8.45	TECTEH			21H00074	600UL
10674	82	139							TECTEH			21H00063	600UL
10675	84	139							TECTEH			21H00062	600UL
10676	86	139	0.37	169	INR	6	F09	+11.55	TECTEH			21H00063	600UL
10677					INF		F10	+2.93	TECTEH	HR		21H00063	600UL
10678	88	139							TECTEH			21H00062	600UL
10679	90	139							TECTEH			21H00063	600UL
10680									TSHTSH			21H00088	610PP
10681	92	139	1.75	51	PLP	8	TSH	+1.92	TECTEH			21H00062	600UL
10682			0.67	88	PLP	10	TSH	+2.00	TSHTSH			21H00088	610PP
10683			0.71	330	PID	10	TSH	+2.00	TSHTSH			21H00087	610PP
10684	94	139							TECTEH			21H00063	600UL
10685									TSHTSH			21H00088	610PP
10686	96	139							TECTEH			21H00062	600UL
10687	98	139							TECTEH			21H00063	600UL
10688	100	139							TECTEH			21H00062	600UL
10689	102	139	0.50	93	INR	6	F09	+2.35	TECTEH			21H00063	600UL
10690			0.43	89	INR	6	F09	+10.48	TECTEH			21H00063	600UL
10691					INF		F10	+12.94	TECTEH	HR		21H00063	600UL
10692	104	139	0.51	76	INR	6	03H	+37.68	TECTEH			21H00062	600UL
10693			1.00	70	INR	6	05C	+0.00	TECTEH			21H00062	600UL
10694	1	140							TECTEH			21H00085	600UL
10695	3	140							TECTEH			21H00084	600UL
10696	5	140							TECTEH			21H00085	600UL
10697	7	140							TECTEH			21H00084	600UL
10698	9	140							TECTEH			21H00083	600UL
10699	11	140							TECTEH			21H00082	600UL
10700	13	140							TECTEH			21H00083	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10701	15	140							TECTEH			21H00082	600UL
10702	17	140							TECTEH			21H00081	600UL
10703	19	140							TECTEH			21H00080	600UL
10704	21	140							TECTEH			21H00081	600UL
10705	23	140							TECTEH			21H00080	600UL
10706	25	140							TECTEH			21H00077	600UL
10707	27	140							TECTEH			21H00076	600UL
10708	29	140							TECTEH			21H00077	600UL
10709	31	140							TECTEH			21H00076	600UL
10710	33	140	0.43	57	INR	6	04H	+35.87	TECTEH			21H00077	600UL
10711					INF		04H	+37.08	TECTEH	HR		21H00077	600UL
10712	35	140							TECTEH			21H00076	600UL
10713	37	140							TECTEH			21H00077	600UL
10714	39	140							TECTEH			21H00076	600UL
10715	41	140							TECTEH			21H00077	600UL
10716	43	140							TECTEH			21H00076	600UL
10717	45	140							TECTEH			21H00077	600UL
10718	47	140							TECTEH			21H00076	600UL
10719					NDF	3	TSH	-0.13	TEHTSH			21H00087	610PP
10720	49	140			NDF	3	TSH	-0.19	TEHTSH			21H00087	610PP
10721			0.46	84	INR	6	04H	+32.65	TECTEH			21H00076	600UL
10722	51	140							TECTEH			21H00075	600UL
10723	53	140	0.72	48	INR	6	F05	+0.00	TECTEH			21H00074	600UL
10724					INF		F06	+0.00	TECTEH	HR		21H00074	600UL
10725			0.37	89	INR	6	05C	+39.36	TECTEH			21H00074	600UL
10726			0.97	74	INR	6	04C	+8.73	TECTEH			21H00074	600UL
10727	55	140							TECTEH			21H00075	600UL
10728	57	140							TECTEH			21H00074	600UL
10729	59	140							TECTEH			21H00075	600UL
10730	61	140			INF		06H	+22.58	TECTEH	HR		21H00074	600UL
10731			0.61	82	INR	6	06H	+24.26	TECTEH			21H00074	600UL
10732					INF		02C	+19.63	TECTEH	HR		21H00074	600UL
10733			0.58	80	INR	6	02C	+32.90	TECTEH			21H00074	600UL
10734	63	140							TECTEH			21H00075	600UL
10735	65	140							TECTEH			21H00074	600UL
10736					NDF	3	TSH	-0.05	TEHTSH			21H00087	610PP
10737	67	140							TECTEH			21H00075	600UL
10738	69	140							TECTEH			21H00074	600UL
10739					NDF	3	TSH	-0.05	TEHTSH			21H00087	610PP
10740	71	140							TECTEH			21H00075	600UL
10741	73	140							TECTEH			21H00074	600UL
10742					NDF	3	TSH	-0.22	TSHTSH			21H00087	610PP
10743	75	140							TECTEH			21H00075	600UL
10744					NDF	3	TSH	-0.05	TSHTSH			21H00087	610PP
10745	77	140							TECTEH			21H00074	600UL
10746					NDF	3	TSH	-0.27	TSHTSH			21H00087	610PP
10747	79	140							TECTEH			21H00075	600UL
10748	81	140							TECTEH			21H00074	600UL
10749					NDF	3	TSH	-0.11	TSHTSH			21H00087	610PP
10750	83	140			NDF	3	TSH	-0.08	TSHTSH			21H00087	610PP

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10751			0.87	10	INR	6	F09	+0.34	TECTEH			21H00063	600UL
10752	85	140			NDF	3	TSH	-0.08	TSHTSH			21H00087	610PP
10753			0.62	80	INR	6	F12	+10.75	TECTEH			21H00062	600UL
10754					INF		07C	+3.41	TECTEH	HR		21H00062	600UL
10755			1.22	61	INR	6	04C	+1.88	TECTEH			21H00062	600UL
10756	87	140							TECTEH			21H00063	600UL
10757	89	140							TECTEH			21H00062	600UL
10758					NDF	3	TSH	-0.08	TSHTSH			21H00087	610PP
10759					NDF	3	TSH	-0.08	TSHTSH	IDOK		21H00088	610PP
10760	91	140			NDF	3	TSH	-0.03	TSHTSH			21H00087	610PP
10761			1.48	27	PLP	8	TSH	+1.87	TECTEH			21H00063	600UL
10762			0.44	89	PLP	10	TSH	+2.00	TSHTSH			21H00088	610PP
10763			0.46	331	PID	10	TSH	+2.00	TSHTSH			21H00087	610PP
10764	93	140			NDF	3	TSH	-0.14	TSHTSH			21H00087	610PP
10765			1.43	47	PLP	8	TSH	+1.97	TECTEH			21H00062	600UL
10766			0.43	89	PLP	10	TSH	+2.00	TSHTSH			21H00088	610PP
10767			0.44	331	PID	10	TSH	+2.00	TSHTSH			21H00087	610PP
10768			0.46	82	INR	6	04H	+33.41	TECTEH			21H00062	600UL
10769	95	140			NDF	3	TSH	+0.00	TSHTSH			21H00087	610PP
10770					NDF	3	TSH	+0.00	TSHTSH	IDOK		21H00088	610PP
10771			0.39	100	INR	6	F10	+8.62	TECTEH			21H00063	600UL
10772	97	140							TECTEH			21H00062	600UL
10773					NDF	3	TSH	+0.03	TSHTSH			21H00087	610PP
10774	99	140							TECTEH			21H00063	600UL
10775	101	140							TECTEH			21H00062	600UL
10776	103	140	0.54	102	INR	6	F04	+6.61	TECTEH			21H00062	600UL
10777	2	141							TECTEH			21H00085	600UL
10778	4	141							TECTEH			21H00084	600UL
10779					NDF	3	TSH	-0.34	TSHTSH			21H00087	610PP
10780	6	141							TECTEH			21H00084	600UL
10781	8	141	1.05	41	INR	6	03H	+12.62 TO+33.22	TECTEH			21H00083	600UL
10782	10	141							TECTEH			21H00082	600UL
10783					NDF	3	TSH	-0.16	TSHTSH			21H00087	610PP
10784	12	141	0.38	50	INR	6	04H	+22.30	TECTEH			21H00083	600UL
10785	14	141							TECTEH			21H00082	600UL
10786	16	141							TECTEH			21H00081	600UL
10787	18	141							TECTEH			21H00080	600UL
10788	20	141							TECTEH			21H00081	600UL
10789	22	141							TECTEH			21H00080	600UL
10790	24	141							TECTEH			21H00080	600UL
10791	26	141							TECTEH			21H00076	600UL
10792	28	141							TECTEH			21H00077	600UL
10793	30	141							TECTEH			21H00076	600UL
10794	32	141							TECTEH			21H00077	600UL
10795	34	141	3.45	182	INR	1	F01	+5.47	TECTEH			21H00076	600UL
10796	36	141							TECTEH			21H00077	600UL
10797	38	141							TECTEH			21H00076	600UL
10798	40	141			NDF	3	TSH	-0.16	TSHTSH			21H00087	610PP
10799			0.48	71	INR	6	02H	+25.96	TECTEH			21H00077	600UL
10800	42	141							TECTEH			21H00076	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10801	44	141	0.48	76	INR	6	03C	+5.61	TECTEH			21H00077	600UL
10802	46	141							TECTEH			21H00076	600UL
10803									TECTEH	IDOK		21H00077	600UL
10804					NDF	3	TSH	-0.13	TSHTSH			21H00087	610PP
10805	48	141							TECTEH			21H00076	600UL
10806					NDF	3	TSH	-0.13	TSHTSH			21H00087	610PP
10807	50	141			NDF	3	TSH	-0.11	TSHTSH			21H00087	610PP
10808			1.23	70	INR	6	06H	+33.16	TECTEH			21H00075	600UL
10809	52	141							TECTEH			21H00074	600UL
10810	54	141	0.98	78	INR	6	03C	+35.13	TECTEH			21H00075	600UL
10811	56	141							TECTEH			21H00074	600UL
10812	58	141							TECTEH			21H00075	600UL
10813					NDF	3	TSH	-0.19	TSHTSH			21H00087	610PP
10814	60	141			NDF	3	TSH	-0.27	TSHTSH			21H00087	610PP
10815			0.40	47	INR	6	06H	+2.49	TECTEH			21H00074	600UL
10816			0.68	59	NQH	6	F05	+4.72	TECTEH			21H00074	600UL
10817			0.47	72	INR	6	04C	+11.49	TECTEH			21H00074	600UL
10818	62	141							TECTEH			21H00075	600UL
10819	64	141	0.48	73	INR	6	05H	+22.23	TECTEH			21H00074	600UL
10820	66	141							TECTEH			21H00075	600UL
10821					NDF	3	TSH	-0.08	TSHTSH			21H00087	610PP
10822	68	141							TECTEH			21H00074	600UL
10823	70	141							TECTEH			21H00075	600UL
10824	72	141	0.77	73	INR	6	06C	+19.48	TECTEH			21H00074	600UL
10825	74	141							TECTEH			21H00075	600UL
10826	76	141							TECTEH			21H00074	600UL
10827	78	141							TECTEH			21H00075	600UL
10828	80	141	0.52	92	INR	6	04C	+39.42	TECTEH			21H00074	600UL
10829	82	141							TECTEH			21H00062	600UL
10830	84	141	0.79	85	INR	6	03H	+27.61	TECTEH			21H00063	600UL
10831	86	141							TECTEH			21H00062	600UL
10832	88	141	0.47	79	INR	6	02C	+9.91	TECTEH			21H00063	600UL
10833					INF		01C	+9.89	TECTEH	HR		21H00063	600UL
10834	90	141							TECTEH			21H00062	600UL
10835									TSHTSH			21H00088	610PP
10836	92	141							TSHTSH			21H00088	610PP
10837			1.09	76	INR	6	TSH	+1.52	TECTEH			21H00063	600UL
10838	94	141							TSHTSH			21H00088	610PP
10839			0.43	98	INR	6	01H	+23.66	TECTEH			21H00062	600UL
10840					INF		F01	+0.00	TECTEH	HR		21H00062	600UL
10841			0.57	80	INR	6	F05	+13.24	TECTEH			21H00062	600UL
10842					INF		F06	+0.00	TECTEH	HR		21H00062	600UL
10843	96	141	0.31	97	INR	6	F04	+2.48	TECTEH			21H00063	600UL
10844	98	141	0.47	81	INR	6	F03	+12.12	TECTEH			21H00062	600UL
10845	100	141							TECTEH			21H00063	600UL
10846	102	141							TECTEH			21H00062	600UL
10847	1	142							TECTEH			21H00085	600UL
10848	3	142							TECTEH			21H00084	600UL
10849	5	142							TECTEH			21H00085	600UL
10850	7	142							TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10851	9	142							TECTEH			21H00083	600UL
10852	11	142	0.49	84	INR	6	04H	+37.49	TECTEH			21H00082	600UL
10853	13	142							TECTEH			21H00083	600UL
10854	15	142							TECTEH			21H00082	600UL
10855	17	142							TECTEH			21H00081	600UL
10856	19	142							TECTEH			21H00080	600UL
10857	21	142	0.45	84	INR	6	01C	+8.05	TECTEH			21H00081	600UL
10858	23	142							TECTEH			21H00080	600UL
10859	25	142							TECTEH			21H00077	600UL
10860	27	142							TECTEH			21H00076	600UL
10861	29	142							TECTEH			21H00077	600UL
10862	31	142							TECTEH			21H00076	600UL
10863	33	142							TECTEH			21H00077	600UL
10864	35	142	0.60	66	INR	6	01C	+24.50	TECTEH			21H00076	600UL
10865	37	142	0.66	83	INR	6	TSH	+17.58	TECTEH			21H00077	600UL
10866			0.73	74	INR	6	F12	+5.43	TECTEH			21H00077	600UL
10867					INF		07C	+6.26	TECTEH	HR		21H00077	600UL
10868			0.94	73	INR	6	02C	+8.80	TECTEH			21H00077	600UL
10869			0.50	72	INR	6	02C	+38.48	TECTEH			21H00077	600UL
10870	39	142							TECTEH			21H00076	600UL
10871	41	142							TECTEH			21H00077	600UL
10872	43	142	0.47	75	INR	6	TSC	+15.50	TECTEH			21H00076	600UL
10873	45	142							TECTEH			21H00077	600UL
10874	47	142							TECTEH			21H00076	600UL
10875	49	142							TECTEH			21H00076	600UL
10876	51	142							TECTEH			21H00075	600UL
10877	53	142							TECTEH			21H00074	600UL
10878	55	142							TECTEH			21H00075	600UL
10879	57	142	0.52	75	INR	6	02H	+4.79	TECTEH			21H00074	600UL
10880	59	142							TECTEH			21H00075	600UL
10881	61	142							TECTEH			21H00074	600UL
10882	63	142	0.49	68	INR	6	02H	+21.04	TECTEH			21H00075	600UL
10883	65	142							TECTEH			21H00074	600UL
10884	67	142							TECTEH			21H00075	600UL
10885	69	142							TECTEH			21H00074	600UL
10886	71	142							TECTEH			21H00075	600UL
10887	73	142							TECTEH			21H00074	600UL
10888	75	142	1.00	56	INR	6	02C	+2.00	TECTEH			21H00075	600UL
10889	77	142							TECTEH			21H00074	600UL
10890	79	142	0.47	69	INR	6	04H	+19.69	TECTEH			21H00075	600UL
10891	81	142	0.64	76	INR	6	06C	+20.51	TECTEH			21H00074	600UL
10892	83	142							TECTEH			21H00063	600UL
10893	85	142							TECTEH			21H00062	600UL
10894	87	142	0.35	92	INR	6	06C	+29.94	TECTEH			21H00063	600UL
10895			0.67	73	INR	6	04C	+31.58	TECTEH			21H00063	600UL
10896	89	142							TECTEH			21H00062	600UL
10897	91	142	0.69	10	INR	6	F01	+4.06	TECTEH			21H00063	600UL
10898			0.25	76	INR	6	F02	+10.52	TECTEH			21H00063	600UL
10899	93	142							TECTEH			21H00062	600UL
10900	95	142	0.46	77	INR	6	01H	+17.18	TECTEH			21H00063	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10901			0.92	27	INR	6	F08	+13.84	TECTEH			21H00063	600UL
10902					INF		F09	+0.00	TECTEH	HR		21H00063	600UL
10903			0.46	36	INR	6	F10	+7.39	TECTEH			21H00063	600UL
10904					INF		F11	+7.24	TECTEH	HR		21H00063	600UL
10905			0.42	67	INR	6	F12	+10.39	TECTEH			21H00063	600UL
10906					INF		07C	+4.31	TECTEH	HR		21H00063	600UL
10907	97	142	0.39	85	INR	6	TSH	+16.22	TECTEH			21H00062	600UL
10908			0.60	78	INR	6	TSH	+17.48	TECTEH			21H00062	600UL
10909			0.39	83	INR	6	01H	+3.15	TECTEH			21H00062	600UL
10910			0.69	113	INR	6	F10	+0.03	TECTEH			21H00062	600UL
10911			0.60	80	INR	6	06C	+4.95	TECTEH			21H00062	600UL
10912			0.75	62	INR	6	03C	+27.03	TECTEH			21H00062	600UL
10913			0.99	78	INR	6	01C	+31.52	TECTEH			21H00062	600UL
10914	99	142							TECTEH			21H00062	600UL
10915	2	143							TECTEH			21H00085	600UL
10916	4	143							TECTEH			21H00084	600UL
10917	6	143							TECTEH			21H00084	600UL
10918	8	143							TECTEH			21H00083	600UL
10919	10	143							TECTEH			21H00082	600UL
10920	12	143	0.69	79	INR	6	03C	+34.13	TECTEH			21H00083	600UL
10921					INF		03C	+39.29	TECTEH	HR		21H00083	600UL
10922	14	143							TECTEH			21H00082	600UL
10923	16	143	0.49	67	INR	6	03H	+32.15	TECTEH			21H00081	600UL
10924	18	143							TECTEH			21H00080	600UL
10925	20	143							TECTEH			21H00081	600UL
10926	22	143							TECTEH			21H00080	600UL
10927	24	143							TECTEH			21H00080	600UL
10928	26	143	0.39	78	INR	6	06C	+22.11	TECTEH			21H00077	600UL
10929	28	143							TECTEH			21H00076	600UL
10930	30	143							TECTEH			21H00077	600UL
10931	32	143							TECTEH			21H00076	600UL
10932	34	143							TECTEH			21H00077	600UL
10933	36	143							TECTEH			21H00076	600UL
10934	38	143	0.56	75	INR	6	TSH	+7.16	TECTEH			21H00077	600UL
10935	40	143							TECTEH			21H00076	600UL
10936	42	143							TECTEH			21H00077	600UL
10937	44	143							TECTEH			21H00076	600UL
10938	46	143							TECTEH			21H00077	600UL
10939	48	143							TECTEH			21H00076	600UL
10940	50	143	0.82	76	INR	6	03H	+28.15	TECTEH			21H00075	600UL
10941			0.46	48	INR	6	06H	+2.83	TECTEH			21H00075	600UL
10942	52	143							TECTEH			21H00075	600UL
10943	54	143	0.74	74	INR	6	04C	+23.51	TECTEH			21H00074	600UL
10944			0.37	67	INR	6	03C	+4.84	TECTEH			21H00074	600UL
10945	56	143							TECTEH			21H00075	600UL
10946	58	143	0.80	53	INR	6	F09	+5.26	TECTEH			21H00074	600UL
10947					INF		F10	+5.37	TECTEH	HR		21H00074	600UL
10948	60	143							TECTEH			21H00075	600UL
10949	62	143							TECTEH			21H00074	600UL
10950	64	143							TECTEH			21H00075	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
10951	66	143	1.35	51	INR	6	F05	+0.29	TECTEH			21H00074	600UL
10952	68	143							TECTEH			21H00075	600UL
10953	70	143							TECTEH			21H00074	600UL
10954	72	143							TECTEH			21H00075	600UL
10955	74	143							TECTEH			21H00074	600UL
10956	76	143							TECTEH			21H00075	600UL
10957	78	143							TECTEH			21H00074	600UL
10958	80	143							TECTEH			21H00074	600UL
10959	82	143	0.75	73	INR	6	02H	+24.36	TECTEH			21H00062	600UL
10960			0.75	73	INR	6	02H	+24.44	TECTEH			21H00062	600UL
10961	84	143							TECTEH			21H00063	600UL
10962	86	143	0.62	81	INR	6	01C	+3.35	TECTEH			21H00062	600UL
10963	88	143	0.45	81	INR	6	06C	+22.52	TECTEH			21H00063	600UL
10964	90	143	0.52	83	INR	6	04C	+36.65	TECTEH			21H00062	600UL
10965			0.44	65	INR	6	02C	+12.56	TECTEH			21H00062	600UL
10966			0.52	89	INR	6	02C	+28.22	TECTEH			21H00062	600UL
10967	92	143							TECTEH			21H00063	600UL
10968	94	143	0.54	74	INR	6	02H	+31.78	TECTEH			21H00062	600UL
10969			0.43	72	INR	6	06C	+29.08	TECTEH			21H00062	600UL
10970	96	143							TECTEH			21H00063	600UL
10971	98	143	0.69	75	INR	6	F03	+5.40	TECTEH			21H00062	600UL
10972	1	144							TECTEH			21H00085	600UL
10973	3	144							TECTEH			21H00084	600UL
10974	5	144							TECTEH			21H00085	600UL
10975	7	144							TECTEH			21H00084	600UL
10976	9	144							TECTEH			21H00083	600UL
10977	11	144							TECTEH			21H00082	600UL
10978	13	144							TECTEH			21H00083	600UL
10979	15	144							TECTEH			21H00082	600UL
10980	17	144							TECTEH			21H00081	600UL
10981	19	144							TECTEH			21H00080	600UL
10982	21	144							TECTEH			21H00081	600UL
10983	23	144			NDF	3	TSH	-1.59	TSHTSH			21H00087	610PP
10984			0.77	76	INR	6	TSH	+7.77	TECTEH			21H00080	600UL
10985	25	144							TECTEH			21H00077	600UL
10986	27	144							TECTEH			21H00076	600UL
10987	29	144							TECTEH			21H00077	600UL
10988	31	144							TECTEH			21H00076	600UL
10989	33	144							TECTEH			21H00077	600UL
10990	35	144							TECTEH			21H00076	600UL
10991	37	144	0.61	82	INR	6	01C	+13.85	TECTEH			21H00077	600UL
10992	39	144	2.85	183	INR	1	F04	-0.91	TECTEH			21H00076	600UL
10993					INF		F11	+1.13	TECTEH	HR		21H00076	600UL
10994	41	144	1.06	19	INR	6	F08	+0.42	TECTEH			21H00077	600UL
10995	43	144							TECTEH			21H00076	600UL
10996	45	144							TECTEH			21H00077	600UL
10997	47	144							TECTEH			21H00076	600UL
10998	49	144							TECTEH			21H00076	600UL
10999	51	144							TECTEH			21H00075	600UL
11000	53	144							TECTEH			21H00074	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11001	55	144							TECTEH			21H00075	600UL
11002	57	144	0.59	82	INR	6	F07	+0.10	TECTEH			21H00074	600UL
11003			0.34	80	INR	6	03C	+25.23	TECTEH			21H00074	600UL
11004	59	144							TECTEH			21H00075	600UL
11005	61	144							TECTEH			21H00074	600UL
11006	63	144							TECTEH			21H00075	600UL
11007	65	144							TECTEH			21H00074	600UL
11008	67	144							TECTEH			21H00075	600UL
11009	69	144							TECTEH			21H00074	600UL
11010	71	144							TECTEH			21H00075	600UL
11011	73	144							TECTEH			21H00074	600UL
11012	75	144							TECTEH			21H00075	600UL
11013	77	144	0.53	76	INR	6	F05	+11.53	TECTEH			21H00074	600UL
11014			0.53	87	INR	6	04C	+21.88	TECTEH			21H00074	600UL
11015	79	144	0.57	74	INR	6	02H	+31.38	TECTEH			21H00075	600UL
11016	81	144	0.31	121	INR	3	07H	+11.57	TECTEH			21H00074	600UL
11017			0.80	89	NQH	3	F05	+12.27	TECTEH			21H00074	600UL
11018			0.63	70	INR	6	06C	+14.72	TECTEH			21H00074	600UL
11019			0.42	76	INR	6	02C	+14.88	TECTEH			21H00074	600UL
11020	83	144							TECTEH			21H00063	600UL
11021	85	144	0.52	67	INR	6	05H	+29.41	TECTEH			21H00062	600UL
11022			1.08	72	INR	6	F07	+5.50	TECTEH			21H00062	600UL
11023					INF		F08	+10.22	TECTEH	HR		21H00062	600UL
11024	87	144							TECTEH			21H00063	600UL
11025	89	144							TECTEH			21H00062	600UL
11026	91	144	0.41	50	INR	6	F04	+11.00	TECTEH			21H00063	600UL
11027					INF		F07	+2.41	TECTEH	HR		21H00063	600UL
11028			0.37	76	INR	6	F08	+2.45	TECTEH			21H00063	600UL
11029					INF		F09	+10.67	TECTEH	HR		21H00063	600UL
11030	93	144							TECTEH			21H00062	600UL
11031	95	144							TECTEH			21H00063	600UL
11032	97	144	0.59	73	INR	6	01H	+20.48	TECTEH			21H00062	600UL
11033			0.58	77	INR	6	06H	+34.47	TECTEH			21H00062	600UL
11034			0.32	61	INR	6	05C	+37.82	TECTEH			21H00062	600UL
11035	2	145							TECTEH			21H00085	600UL
11036	4	145							TECTEH			21H00084	600UL
11037	6	145							TECTEH			21H00084	600UL
11038	8	145							TECTEH			21H00083	600UL
11039	10	145							TECTEH			21H00082	600UL
11040	12	145							TECTEH			21H00083	600UL
11041	14	145							TECTEH			21H00082	600UL
11042	16	145							TECTEH			21H00081	600UL
11043	18	145							TECTEH			21H00080	600UL
11044	20	145							TECTEH			21H00081	600UL
11045	22	145							TECTEH			21H00080	600UL
11046	24	145							TECTEH			21H00080	600UL
11047	26	145							TECTEH			21H00077	600UL
11048	28	145							TECTEH			21H00076	600UL
11049	30	145							TECTEH			21H00077	600UL
11050	32	145							TECTEH			21H00076	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11051	34	145	0.55	83	INR	6	TSH	+18.74	TECTEH			21H00077	600UL
11052			0.69	83	INR	6	05C	+17.08	TECTEH			21H00077	600UL
11053	36	145							TECTEH			21H00076	600UL
11054	38	145	0.51	78	INR	6	06C	+2.38	TECTEH			21H00077	600UL
11055			0.45	99	INR	6	01C	+26.83	TECTEH			21H00077	600UL
11056	40	145							TECTEH			21H00076	600UL
11057	42	145							TECTEH			21H00077	600UL
11058	44	145							TECTEH			21H00076	600UL
11059	46	145							TECTEH			21H00077	600UL
11060	48	145							TECTEH			21H00076	600UL
11061	50	145							TECTEH			21H00075	600UL
11062	52	145							TECTEH			21H00074	600UL
11063	54	145							TECTEH			21H00075	600UL
11064	56	145	0.51	72	INR	6	06C	+21.38	TECTEH			21H00074	600UL
11065			0.39	82	INR	6	03C	+31.70	TECTEH			21H00074	600UL
11066			0.09	322	INR	6	03C	+35.93	TECTEH			21H00074	600UL
11067			0.55	78	INR	6	02C	+7.77	TECTEH			21H00074	600UL
11068	58	145			INF		F05	+2.28	TECTEH	HR		21H00075	600UL
11069			0.55	64	INR	6	F05	+3.58	TECTEH			21H00075	600UL
11070	60	145							TECTEH			21H00074	600UL
11071	62	145							TECTEH			21H00075	600UL
11072	64	145							TECTEH			21H00074	600UL
11073	66	145	0.74	73	INR	6	06C	+28.30	TECTEH			21H00075	600UL
11074			1.10	75	INR	6	02C	+2.24	TECTEH			21H00075	600UL
11075	68	145							TECTEH			21H00074	600UL
11076	70	145	0.65	71	INR	6	01C	+4.48	TECTEH			21H00075	600UL
11077	72	145							TECTEH			21H00074	600UL
11078	74	145							TECTEH			21H00075	600UL
11079	76	145							TECTEH			21H00074	600UL
11080	78	145							TECTEH			21H00075	600UL
11081	80	145							TECTEH			21H00074	600UL
11082	82	145							TECTEH			21H00062	600UL
11083	84	145	0.66	54	INR	6	04H	+39.47	TECTEH			21H00063	600UL
11084			0.33	65	INR	6	05H	+15.97	TECTEH			21H00063	600UL
11085			0.62	163	INR	6	F06	+1.72	TECTEH			21H00063	600UL
11086					INF		F06	+83.36	TECTEH	HR		21H00063	600UL
11087					INF		F06	+86.52	TECTEH	HR		21H00063	600UL
11088			1.30	69	INR	6	F12	+1.67	TECTEH			21H00063	600UL
11089			0.68	77	INR	6	F12	+4.40	TECTEH			21H00063	600UL
11090					INF		F12	+8.58	TECTEH	HR		21H00063	600UL
11091					INF		F12	+12.07	TECTEH	HR		21H00063	600UL
11092					INF		07C	+7.10	TECTEH	HR		21H00063	600UL
11093					INF		07C	+10.07	TECTEH	HR		21H00063	600UL
11094			0.52	81	INR	6	06C	+21.20	TECTEH			21H00063	600UL
11095			0.69	85	INR	6	06C	+23.48	TECTEH			21H00063	600UL
11096			0.41	77	INR	6	05C	+25.38	TECTEH			21H00063	600UL
11097			0.42	123	INR	3	02C	+16.46	TECTEH			21H00063	600UL
11098			0.24	118	INR	3	02C	+17.83	TECTEH			21H00063	600UL
11099	86	145	0.49	64	INR	6	06H	+4.10	TECTEH			21H00062	600UL
11100			0.38	67	INR	6	07H	+9.75	TECTEH			21H00062	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11101		1.49	62	INR	6	F08	+9.46	TECTEH			21H00062	600UL
11102				INF		F09	+4.42	TECTEH	HR		21H00062	600UL
11103	88 145							TECTEH			21H00063	600UL
11104	90 145							TECTEH			21H00062	600UL
11105	92 145							TECTEH			21H00063	600UL
11106	94 145							TECTEH			21H00062	600UL
11107	1 146							TECTEH			21H00085	600UL
11108	3 146							TECTEH			21H00084	600UL
11109	5 146							TECTEH			21H00085	600UL
11110	7 146							TECTEH			21H00084	600UL
11111	9 146							TECTEH			21H00083	600UL
11112	11 146							TECTEH			21H00082	600UL
11113	13 146							TECTEH			21H00083	600UL
11114	15 146							TECTEH			21H00082	600UL
11115	17 146	1.16	142	INR	6	F01	+0.89	TECTEH			21H00081	600UL
11116	19 146							TECTEH			21H00080	600UL
11117	21 146							TECTEH			21H00081	600UL
11118	23 146							TECTEH			21H00080	600UL
11119	25 146							TECTEH			21H00077	600UL
11120	27 146	0.13	45	INR	6	05H	+27.39	TECTEH			21H00076	600UL
11121	29 146							TECTEH			21H00077	600UL
11122	31 146							TECTEH			21H00076	600UL
11123	33 146	0.34	67	INR	6	06H	+14.94	TECTEH			21H00077	600UL
11124		0.45	57	INR	6	06H	+19.92	TECTEH			21H00077	600UL
11125	35 146							TECTEH			21H00076	600UL
11126				NDF	3	TEH	+6.74	TEHTSH			21H00087	610PP
11127				NDF	3	TEH	+12.74	TEHTSH			21H00087	610PP
11128	37 146	0.38	81	INR	6	01H	+26.05	TECTEH			21H00077	600UL
11129		0.38	87	INR	6	02H	+7.65	TECTEH			21H00077	600UL
11130		0.85	15	INR	6	F07	+0.16	TECTEH			21H00077	600UL
11131		0.85	77	INR	6	05C	+33.60	TECTEH			21H00077	600UL
11132		0.45	88	INR	6	03C	+14.21	TECTEH			21H00077	600UL
11133	39 146			INF		F01	+11.36	TECTEH	HR		21H00076	600UL
11134		0.88	152	INR	3	F01	+15.00	TECTEH			21H00076	600UL
11135		1.23	66	INR	6	F04	+11.66	TECTEH			21H00076	600UL
11136		0.48	69	INR	6	05C	+29.29	TECTEH			21H00076	600UL
11137	41 146							TECTEH			21H00077	600UL
11138	43 146	0.38	88	INR	6	01H	+29.29	TECTEH			21H00076	600UL
11139	45 146	0.53	76	INR	6	TSH	+18.77	TECTEH			21H00077	600UL
11140		1.49	88	INR	6	07H	+10.59	TECTEH			21H00077	600UL
11141		1.50	94	INR	6	F01	-1.04	TECTEH			21H00077	600UL
11142				INF		F02	-1.01	TECTEH	HR		21H00077	600UL
11143	47 146	0.38	76	INR	6	05C	+37.76	TECTEH			21H00076	600UL
11144	49 146							TECTEH			21H00076	600UL
11145	51 146							TECTEH			21H00075	600UL
11146	53 146	0.57	75	INR	6	01H	+26.41	TECTEH			21H00074	600UL
11147		0.71	78	INR	6	02H	+18.77	TECTEH			21H00074	600UL
11148		0.74	72	INR	6	06C	+19.52	TECTEH			21H00074	600UL
11149		0.41	76	INR	6	04C	+12.28	TECTEH			21H00074	600UL
11150		0.65	74	INR	6	04C	+18.61	TECTEH			21H00074	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11151			0.39	78	INR	6	01C	+26.43	TECTEH			21H00074	600UL
11152	55	146							TECTEH			21H00075	600UL
11153	57	146							TECTEH			21H00074	600UL
11154	59	146	1.05	88	INR	6	02H	+11.79	TECTEH			21H00075	600UL
11155					INF		F03	+0.00	TECTEH	HR		21H00075	600UL
11156			0.55	112	INR	6	F03	+5.91	TECTEH			21H00075	600UL
11157	61	146							TECTEH			21H00074	600UL
11158	63	146			INF		F03	+8.43	TECTEH	HR		21H00075	600UL
11159			0.67	55	INR	6	F03	+9.74	TECTEH			21H00075	600UL
11160			0.53	74	INR	6	01C	+13.46	TECTEH			21H00075	600UL
11161			0.59	99	INR	6	TSC	+15.80	TECTEH			21H00075	600UL
11162			0.54	96	INR	6	TSC	+17.95	TECTEH			21H00075	600UL
11163	65	146							TECTEH			21H00074	600UL
11164	67	146							TECTEH			21H00075	600UL
11165	69	146							TECTEH			21H00074	600UL
11166	71	146							TECTEH			21H00075	600UL
11167	73	146							TECTEH			21H00074	600UL
11168	75	146							TECTEH			21H00075	600UL
11169	77	146	0.49	72	INR	6	02H	+11.73	TECTEH			21H00074	600UL
11170	79	146							TECTEH			21H00075	600UL
11171	81	146	0.51	63	INR	6	04H	+26.80	TECTEH			21H00074	600UL
11172			0.43	64	INR	6	04C	+34.66	TECTEH			21H00074	600UL
11173			0.41	81	INR	6	02C	+23.13	TECTEH			21H00074	600UL
11174					INF		02C	+24.85	TECTEH	HR		21H00074	600UL
11175	83	146	0.41	71	INR	6	01H	+8.66	TECTEH			21H00063	600UL
11176	85	146	0.48	89	INR	6	02C	+32.89	TECTEH			21H00062	600UL
11177	87	146	0.38	73	INR	6	02C	+8.63	TECTEH			21H00063	600UL
11178	89	146	0.59	68	INR	6	06C	+18.60	TECTEH			21H00062	600UL
11179			0.47	75	INR	6	05C	+5.87	TECTEH			21H00062	600UL
11180			0.79	73	INR	6	04C	+20.76	TECTEH			21H00062	600UL
11181			0.66	71	INR	6	02C	+3.77	TECTEH			21H00062	600UL
11182	91	146	0.63	57	INR	6	F12	+3.39	TECTEH			21H00063	600UL
11183					INF		F12	+4.49	TECTEH	HR		21H00063	600UL
11184					INF		07C	+12.87	TECTEH	HR		21H00063	600UL
11185	93	146							TECTEH			21H00062	600UL
11186	2	147							TECTEH			21H00085	600UL
11187	4	147							TECTEH			21H00084	600UL
11188	6	147							TECTEH			21H00084	600UL
11189	8	147							TECTEH			21H00083	600UL
11190	10	147							TECTEH			21H00082	600UL
11191	12	147							TECTEH			21H00083	600UL
11192	14	147							TECTEH			21H00082	600UL
11193	16	147							TECTEH			21H00081	600UL
11194	18	147							TECTEH			21H00080	600UL
11195	20	147	6.58	182	INR	1	F01	+6.91	TECTEH			21H00081	600UL
11196					INF		F05	+4.09	TECTEH	HR		21H00081	600UL
11197	22	147	3.84	184	INR	P1	F05	+1.07	TECTEH			21H00080	600UL
11198	24	147							TECTEH			21H00080	600UL
11199	26	147	0.43	78	INR	6	05H	+37.19	TECTEH			21H00077	600UL
11200			0.54	82	INR	6	05H	+38.70	TECTEH			21H00077	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11201	28	147							TECTEH			21H00076	600UL
11202	30	147							TECTEH			21H00077	600UL
11203	32	147	4.08	184	INR	1	F01	+5.48	TECTEH			21H00076	600UL
11204	34	147							TECTEH			21H00077	600UL
11205	36	147							TECTEH			21H00076	600UL
11206	38	147	0.42	92	INR	6	02H	+4.40	TECTEH			21H00077	600UL
11207			0.41	70	INR	6	02H	+11.80	TECTEH			21H00077	600UL
11208					INF		F04	+0.00	TECTEH	HR		21H00077	600UL
11209			3.81	182	INR	1	F04	+2.80	TECTEH			21H00077	600UL
11210	40	147							TECTEH			21H00076	600UL
11211	42	147							TECTEH			21H00077	600UL
11212	44	147	0.44	52	INR	6	03C	+21.28	TECTEH			21H00076	600UL
11213	46	147							TECTEH			21H00077	600UL
11214	48	147							TECTEH			21H00076	600UL
11215	50	147	0.46	73	INR	6	01H	+28.05	TECTEH			21H00075	600UL
11216			0.35	76	INR	6	01H	+30.18	TECTEH			21H00075	600UL
11217	52	147							TECTEH			21H00074	600UL
11218	54	147			INF		F05	+3.55	TECTEH	HR		21H00075	600UL
11219			0.52	52	INR	6	F05	+5.22	TECTEH			21H00075	600UL
11220	56	147	0.46	56	INR	6	02H	+0.20	TECTEH			21H00074	600UL
11221			0.75	53	INR	6	06H	+0.03	TECTEH			21H00074	600UL
11222			0.38	62	INR	6	06H	+20.95	TECTEH			21H00074	600UL
11223			0.49	67	INR	6	06H	+34.24	TECTEH			21H00074	600UL
11224			0.54	78	INR	6	02C	+6.10	TECTEH			21H00074	600UL
11225			0.49	76	INR	6	02C	+18.56	TECTEH			21H00074	600UL
11226	58	147							TECTEH			21H00075	600UL
11227	60	147							TECTEH			21H00074	600UL
11228	62	147							TECTEH			21H00075	600UL
11229	64	147	0.48	65	INR	6	04H	+12.46	TECTEH			21H00074	600UL
11230	66	147							TECTEH			21H00075	600UL
11231	68	147	0.43	75	INR	6	05C	+34.80	TECTEH			21H00074	600UL
11232	70	147	0.53	84	INR	6	03C	+19.65	TECTEH			21H00075	600UL
11233			0.65	81	INR	6	02C	+3.23	TECTEH			21H00075	600UL
11234			0.61	84	INR	6	01C	+23.56	TECTEH			21H00075	600UL
11235	72	147							TECTEH			21H00074	600UL
11236	74	147							TECTEH			21H00075	600UL
11237	76	147							TECTEH			21H00074	600UL
11238	78	147	0.66	88	INR	6	03C	+13.92	TECTEH			21H00075	600UL
11239	80	147			INF		F10	+3.31	TECTEH	HR		21H00074	600UL
11240			0.56	100	NQH	3	F11	+3.92	TECTEH			21H00074	600UL
11241					INF		F12	+12.45	TECTEH	HR		21H00074	600UL
11242			0.45	77	INR	6	06C	+25.29	TECTEH			21H00074	600UL
11243	82	147							TECTEH			21H00062	600UL
11244	84	147	0.43	63	INR	6	02C	+8.82	TECTEH			21H00063	600UL
11245	86	147							TECTEH			21H00062	600UL
11246	88	147	0.70	67	INR	6	02H	+20.98	TECTEH			21H00063	600UL
11247			0.44	57	INR	6	03H	+37.00	TECTEH			21H00063	600UL
11248			0.30	64	INR	6	04C	+17.27	TECTEH			21H00063	600UL
11249	90	147	0.72	79	INR	6	01H	+16.83	TECTEH			21H00062	600UL
11250			0.71	79	INR	6	01H	+21.82	TECTEH			21H00062	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11251			0.48	54	INR	6	04H	+18.75	TECTEH			21H00062	600UL
11252	1	148							TECTEH			21H00085	600UL
11253	3	148							TECTEH			21H00084	600UL
11254	5	148							TECTEH			21H00085	600UL
11255	7	148							TECTEH			21H00084	600UL
11256	9	148							TECTEH			21H00083	600UL
11257	11	148	0.43	47	INR	6	04H	+32.96	TECTEH			21H00082	600UL
11258	13	148							TECTEH			21H00083	600UL
11259	15	148							TECTEH			21H00082	600UL
11260	17	148							TECTEH			21H00081	600UL
11261	19	148							TECTEH			21H00080	600UL
11262	21	148	3.00	187	INR	1	F01	+3.57	TECTEH			21H00081	600UL
11263			4.22	182	INR	1	F01	+6.70	TECTEH			21H00081	600UL
11264					INF		F05	+5.05	TECTEH	HR		21H00081	600UL
11265	23	148							TECTEH			21H00080	600UL
11266	25	148							TECTEH			21H00077	600UL
11267	27	148	0.52	55	INR	6	06C	+16.59	TECTEH			21H00076	600UL
11268	29	148	1.02	39	INR	6	F08	+0.55	TECTEH			21H00077	600UL
11269					INF		F12	+8.90	TECTEH	HR		21H00077	600UL
11270	31	148							TECTEH			21H00076	600UL
11271	33	148							TECTEH			21H00077	600UL
11272	35	148	0.41	61	INR	6	04C	+19.43	TECTEH			21H00076	600UL
11273	37	148							TECTEH			21H00077	600UL
11274	39	148	0.41	43	INR	6	05H	+38.98	TECTEH			21H00076	600UL
11275			0.50	74	INR	6	06C	+10.23	TECTEH			21H00076	600UL
11276	41	148	0.45	80	INR	6	01H	+5.68	TECTEH			21H00077	600UL
11277	43	148							TECTEH			21H00076	600UL
11278	45	148	0.56	60	INR	6	04H	+38.24	TECTEH			21H00077	600UL
11279			0.92	92	INR	6	F01	+2.84	TECTEH			21H00077	600UL
11280			0.83	65	INR	6	F04	+10.65	TECTEH			21H00077	600UL
11281	47	148							TECTEH			21H00076	600UL
11282	49	148							TECTEH			21H00076	600UL
11283	51	148							TECTEH			21H00075	600UL
11284	53	148							TECTEH			21H00074	600UL
11285	55	148	0.49	66	INR	6	06H	+10.47	TECTEH			21H00075	600UL
11286					INF		06C	+22.98	TECTEH	HR		21H00075	600UL
11287			0.48	74	INR	6	06C	+24.11	TECTEH			21H00075	600UL
11288	57	148							TECTEH			21H00074	600UL
11289	59	148							TECTEH			21H00075	600UL
11290	61	148							TECTEH			21H00074	600UL
11291	63	148							TECTEH			21H00075	600UL
11292	65	148							TECTEH			21H00074	600UL
11293	67	148							TECTEH			21H00075	600UL
11294	69	148							TECTEH			21H00074	600UL
11295	71	148							TECTEH			21H00075	600UL
11296	73	148							TECTEH			21H00074	600UL
11297	75	148	0.49	83	INR	6	TSC	+13.01	TECTEH			21H00075	600UL
11298					INF		TSC	+20.03	TECTEH	HR		21H00075	600UL
11299	77	148	0.33	65	INR	6	06C	+23.26	TECTEH			21H00074	600UL
11300	79	148							TECTEH			21H00075	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11301	81	148	0.35	69	INR	6	04C	+14.07	TECTEH			21H00074	600UL
11302	83	148	0.52	38	INR	6	F06	+13.76	TECTEH			21H00063	600UL
11303					INF		F07	+2.15	TECTEH	HR		21H00063	600UL
11304	85	148	0.92	77	INR	6	01H	+27.15	TECTEH			21H00062	600UL
11305					INF		F06	+15.20	TECTEH	HR		21H00062	600UL
11306			1.36	116	INR	6	F07	-0.23	TECTEH			21H00062	600UL
11307					INF		F07	+0.95	TECTEH	HR		21H00062	600UL
11308			0.39	73	INR	6	06C	+37.25	TECTEH			21H00062	600UL
11309	87	148	0.60	79	INR	6	01H	+17.46	TECTEH			21H00063	600UL
11310			0.41	85	INR	6	01H	+26.57	TECTEH			21H00063	600UL
11311			0.58	80	INR	6	F03	+7.78	TECTEH			21H00063	600UL
11312	89	148	0.53	63	INR	6	06C	+18.53	TECTEH			21H00062	600UL
11313	2	149							TECTEH			21H00085	600UL
11314	4	149							TECTEH			21H00084	600UL
11315	6	149							TECTEH			21H00084	600UL
11316	8	149							TECTEH			21H00083	600UL
11317	10	149							TECTEH			21H00082	600UL
11318	12	149							TECTEH			21H00083	600UL
11319	14	149	0.43	61	INR	6	02H	+28.82	TECTEH			21H00082	600UL
11320	16	149	0.28	91	INR	6	02C	+37.75	TECTEH			21H00081	600UL
11321	18	149							TECTEH			21H00080	600UL
11322	20	149							TECTEH			21H00081	600UL
11323	22	149							TECTEH			21H00080	600UL
11324	24	149							TECTEH			21H00080	600UL
11325	26	149							TECTEH			21H00079	600UL
11326	28	149							TECTEH			21H00078	600UL
11327	30	149							TECTEH			21H00077	600UL
11328	32	149	0.35	147	INR	3	02H	+3.12	TECTEH			21H00076	600UL
11329			0.72	76	INR	6	03H	+2.52	TECTEH			21H00076	600UL
11330			0.33	70	INR	6	03H	+20.24	TECTEH			21H00076	600UL
11331			0.36	76	INR	6	02C	+33.75	TECTEH			21H00076	600UL
11332	34	149							TECTEH			21H00077	600UL
11333	36	149							TECTEH			21H00076	600UL
11334	38	149							TECTEH			21H00077	600UL
11335	40	149	0.37	51	INR	6	05H	+23.17	TECTEH			21H00076	600UL
11336	42	149	0.44	63	INR	6	05H	+24.19	TECTEH			21H00077	600UL
11337			0.36	83	INR	6	04C	+4.06	TECTEH			21H00077	600UL
11338	44	149							TECTEH			21H00076	600UL
11339	46	149							TECTEH			21H00077	600UL
11340	48	149							TECTEH			21H00076	600UL
11341	50	149							TECTEH			21H00075	600UL
11342	52	149							TECTEH			21H00074	600UL
11343	54	149	0.35	75	INR	6	02H	+23.89	TECTEH			21H00075	600UL
11344	56	149							TECTEH			21H00074	600UL
11345	58	149	0.43	101	INR	6	03C	+17.18	TECTEH			21H00075	600UL
11346	60	149	0.30	76	INR	6	TSH	+15.54	TECTEH			21H00074	600UL
11347			0.37	93	INR	6	03H	+21.04	TECTEH			21H00074	600UL
11348			0.38	48	INR	6	05H	+22.57	TECTEH			21H00074	600UL
11349			0.55	79	INR	6	01C	+4.16	TECTEH			21H00074	600UL
11350	62	149							TECTEH			21H00075	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11351	64	149	0.30	61	INR	6	06H	+6.51	TECTEH			21H00074	600UL
11352	66	149	0.31	47	INR	6	04H	+38.37	TECTEH			21H00075	600UL
11353			0.29	57	INR	6	05H	+3.64	TECTEH			21H00075	600UL
11354			0.40	50	INR	6	05H	+9.32	TECTEH			21H00075	600UL
11355			0.31	35	INR	6	05H	+10.23	TECTEH			21H00075	600UL
11356			0.47	79	INR	6	02C	+5.02	TECTEH			21H00075	600UL
11357	68	149							TECTEH			21H00074	600UL
11358	70	149	0.26	79	INR	6	TSC	+6.91	TECTEH			21H00075	600UL
11359	72	149							TECTEH			21H00074	600UL
11360	74	149							TECTEH			21H00075	600UL
11361	76	149							TECTEH			21H00074	600UL
11362	78	149	0.41	79	INR	6	01C	+5.46	TECTEH			21H00075	600UL
11363	80	149							TECTEH			21H00074	600UL
11364	82	149	0.33	51	INR	6	06H	+15.09	TECTEH			21H00062	600UL
11365	84	149	0.28	74	INR	6	01H	+3.20	TECTEH			21H00063	600UL
11366			0.46	72	INR	6	01H	+4.48	TECTEH			21H00063	600UL
11367			0.45	71	INR	6	F01	+7.43	TECTEH			21H00063	600UL
11368			0.30	94	INR	6	06C	+25.59	TECTEH			21H00063	600UL
11369			0.38	76	INR	6	05C	+24.24	TECTEH			21H00063	600UL
11370			0.27	69	INR	6	04C	+20.67	TECTEH			21H00063	600UL
11371			0.78	77	INR	6	TSC	+8.92	TECTEH			21H00063	600UL
11372	86	149							TECTEH			21H00062	600UL
11373	1	150							TECTEH			21H00085	600UL
11374	3	150							TECTEH			21H00084	600UL
11375	5	150							TECTEH			21H00085	600UL
11376	7	150							TECTEH			21H00084	600UL
11377	9	150							TECTEH			21H00083	600UL
11378	11	150							TECTEH			21H00082	600UL
11379	13	150							TECTEH			21H00083	600UL
11380	15	150							TECTEH			21H00082	600UL
11381	17	150							TECTEH			21H00081	600UL
11382	19	150							TECTEH			21H00080	600UL
11383	21	150	4.07	186	INR	1	F07	+9.72	TECTEH			21H00081	600UL
11384	23	150							TECTEH			21H00080	600UL
11385	25	150	0.44	35	INR	3	F01	+16.99	TECTEH			21H00079	600UL
11386	27	150							TECTEH			21H00078	600UL
11387	29	150							TECTEH			21H00079	600UL
11388	31	150							TECTEH			21H00078	600UL
11389	33	150							TECTEH			21H00079	600UL
11390	35	150							TECTEH			21H00078	600UL
11391	37	150	0.20	147	INR	3	02H	+23.26	TECTEH			21H00079	600UL
11392	39	150	0.41	78	INR	6	06C	+12.88	TECTEH			21H00078	600UL
11393			0.45	77	INR	6	04C	+21.71	TECTEH			21H00078	600UL
11394	41	150	0.19	97	INR	3	F05	+3.15	TECTEH			21H00079	600UL
11395			0.67	118	INR	3	04C	+7.54	TECTEH			21H00079	600UL
11396			0.53	124	INR	3	03C	+35.77	TECTEH			21H00079	600UL
11397			0.60	126	INR	3	02C	+38.02	TECTEH			21H00079	600UL
11398	43	150							TECTEH			21H00078	600UL
11399	45	150							TECTEH			21H00079	600UL
11400	47	150							TECTEH			21H00078	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11401	49	150							TECTEH			21H00078	600UL
11402	51	150							TECTEH			21H00075	600UL
11403	53	150	0.37	85	INR	6	03H	+16.43	TECTEH			21H00074	600UL
11404			0.82	70	INR	6	06H	+29.53	TECTEH			21H00074	600UL
11405			0.36	71	INR	6	05C	+18.87	TECTEH			21H00074	600UL
11406			0.83	77	INR	6	TSC	+18.58	TECTEH			21H00074	600UL
11407	55	150							TECTEH			21H00075	600UL
11408	57	150	0.99	133	INR	3	06C	+29.72	TECTEH			21H00074	600UL
11409	59	150							TECTEH			21H00075	600UL
11410	61	150							TECTEH			21H00074	600UL
11411	63	150	1.07	82	INR	6	01H	+30.34	TECTEH			21H00075	600UL
11412			0.69	80	INR	6	02H	+19.75	TECTEH			21H00075	600UL
11413			0.51	62	INR	6	06H	+29.75	TECTEH			21H00075	600UL
11414			0.59	70	INR	6	F12	+4.38	TECTEH			21H00075	600UL
11415					INF		07C	+9.24	TECTEH	HR		21H00075	600UL
11416			0.97	76	INR	6	06C	+12.98	TECTEH			21H00075	600UL
11417			0.53	84	INR	6	05C	+3.48	TECTEH			21H00075	600UL
11418			1.05	80	INR	6	01C	+20.94	TECTEH			21H00075	600UL
11419			0.62	84	INR	6	TSC	+1.04	TECTEH			21H00075	600UL
11420			0.73	78	INR	6	TSC	+12.34	TECTEH			21H00075	600UL
11421	65	150							TECTEH			21H00074	600UL
11422	67	150							TECTEH			21H00075	600UL
11423	69	150							TECTEH			21H00074	600UL
11424	71	150	1.17	69	INR	6	02C	+2.03	TECTEH			21H00075	600UL
11425	73	150							TECTEH			21H00074	600UL
11426	75	150							TECTEH			21H00075	600UL
11427	77	150	0.41	124	INR	3	04C	+25.74	TECTEH			21H00074	600UL
11428	79	150							TECTEH			21H00074	600UL
11429	81	150	0.37	142	INR	3	03H	+15.74	TECTEH			21H00074	600UL
11430			0.28	133	INR	3	06H	+21.96	TECTEH			21H00074	600UL
11431	83	150							TECTEH			21H00063	600UL
11432	85	150							TECTEH			21H00062	600UL
11433	2	151	0.57	79	INR	6	TSH	+20.42	TECTEH			21H00085	600UL
11434	4	151							TECTEH			21H00084	600UL
11435	6	151							TECTEH			21H00084	600UL
11436	8	151							TECTEH			21H00083	600UL
11437	10	151	0.39	104	INR	6	06C	+5.14	TECTEH			21H00082	600UL
11438	12	151	0.61	83	INR	6	01H	+4.14	TECTEH			21H00083	600UL
11439	14	151							TECTEH			21H00082	600UL
11440	16	151							TECTEH			21H00081	600UL
11441	18	151							TECTEH			21H00080	600UL
11442	20	151							TECTEH			21H00081	600UL
11443	22	151							TECTEH			21H00080	600UL
11444	24	151							TECTEH			21H00080	600UL
11445	26	151							TECTEH			21H00079	600UL
11446	28	151							TECTEH			21H00078	600UL
11447	30	151							TECTEH			21H00079	600UL
11448	32	151	0.70	84	INR	6	02H	+34.10	TECTEH			21H00078	600UL
11449	34	151							TECTEH			21H00079	600UL
11450	36	151	4.61	182	INR	1	F01	+6.61	TECTEH			21H00078	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11451					INF		F04	+3.74	TECTEH	HR		21H00078	600UL
11452					INF		F05	+3.74	TECTEH	HR		21H00078	600UL
11453	38	151	0.42	113	INR	3	04H	+22.92	TECTEH			21H00079	600UL
11454			0.29	126	INR	3	06C	+19.01	TECTEH			21H00079	600UL
11455			0.44	123	INR	3	06C	+36.55	TECTEH			21H00079	600UL
11456			0.42	114	INR	3	04C	+13.38	TECTEH			21H00079	600UL
11457	40	151							TECTEH			21H00078	600UL
11458	42	151	0.44	118	INR	3	F07	+2.69	TECTEH			21H00079	600UL
11459					INF		F08	+9.43	TECTEH	HR		21H00079	600UL
11460			0.36	130	INR	3	TSC	+6.12	TECTEH			21H00079	600UL
11461	44	151							TECTEH			21H00078	600UL
11462	46	151							TECTEH			21H00079	600UL
11463	48	151	0.45	67	INR	6	F06	+3.08	TECTEH			21H00078	600UL
11464	50	151							TECTEH			21H00075	600UL
11465	52	151							TECTEH			21H00074	600UL
11466	54	151							TECTEH			21H00075	600UL
11467	56	151	0.40	124	INR	3	F06	+7.83	TECTEH			21H00074	600UL
11468			0.37	131	INR	3	TSC	+10.73	TECTEH			21H00074	600UL
11469	58	151							TECTEH			21H00075	600UL
11470	60	151	0.46	139	INR	3	05C	+22.91	TECTEH			21H00074	600UL
11471	62	151							TECTEH			21H00075	600UL
11472	64	151							TECTEH			21H00074	600UL
11473	66	151	0.93	78	INR	6	01H	+20.45	TECTEH			21H00075	600UL
11474			0.79	42	INR	6	04H	+24.34	TECTEH			21H00075	600UL
11475			0.44	54	INR	6	04H	+26.06	TECTEH			21H00075	600UL
11476			0.34	84	INR	6	F03	+2.51	TECTEH			21H00075	600UL
11477			1.21	77	INR	6	01C	+14.10	TECTEH			21H00075	600UL
11478	68	151							TECTEH			21H00074	600UL
11479	70	151							TECTEH			21H00075	600UL
11480	72	151							TECTEH			21H00074	600UL
11481	74	151							TECTEH			21H00075	600UL
11482	76	151	0.34	139	INR	3	02H	+19.98	TECTEH			21H00074	600UL
11483	78	151							TECTEH			21H00075	600UL
11484	80	151	0.39	136	INR	3	05H	+14.25	TECTEH			21H00074	600UL
11485	82	151	0.42	70	INR	6	04H	+26.60	TECTEH			21H00062	600UL
11486			0.39	78	INR	6	06H	+4.56	TECTEH			21H00062	600UL
11487			0.37	68	INR	6	06H	+32.13	TECTEH			21H00062	600UL
11488	1	152							TECTEH			21H00085	600UL
11489	3	152							TECTEH			21H00084	600UL
11490	5	152							TECTEH			21H00085	600UL
11491	7	152							TECTEH			21H00084	600UL
11492	9	152	0.61	65	INR	6	04H	+9.44	TECTEH			21H00083	600UL
11493	11	152							TECTEH			21H00082	600UL
11494	13	152							TECTEH			21H00083	600UL
11495	15	152							TECTEH			21H00082	600UL
11496	17	152							TECTEH			21H00081	600UL
11497	19	152							TECTEH			21H00080	600UL
11498	21	152	5.25	185	INR	1	F01	+6.36	TECTEH			21H00081	600UL
11499			5.25	185	INR	1	F05	+2.98	TECTEH			21H00081	600UL
11500					INF		F05	+4.53	TECTEH	HR		21H00081	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11501	23	152	3.52		ADS	6	05C	+18.25 TO+36.68	TECTEH			21H00080	600UL
11502	25	152	0.80	59	INR	6	05C	+2.09	TECTEH			21H00079	600UL
11503	27	152							TECTEH			21H00078	600UL
11504	29	152							TECTEH			21H00079	600UL
11505	31	152							TECTEH			21H00078	600UL
11506	33	152	0.37	101	INR	3	06H	+22.15	TECTEH			21H00079	600UL
11507	35	152							TECTEH			21H00078	600UL
11508	37	152	0.44	114	INR	3	01H	+30.27	TECTEH			21H00079	600UL
11509			0.37	108	INR	3	02H	+3.69	TECTEH			21H00079	600UL
11510	39	152	0.56	80	INR	6	TSH	+20.57	TECTEH			21H00078	600UL
11511	41	152							TECTEH			21H00079	600UL
11512	43	152							TECTEH			21H00078	600UL
11513	45	152	0.32	57	INR	3	03H	+12.12	TECTEH			21H00079	600UL
11514			0.32	69	INR	3	06C	-0.05	TECTEH			21H00079	600UL
11515			0.55	112	INR	3	05C	+28.05	TECTEH			21H00079	600UL
11516	47	152							TECTEH			21H00078	600UL
11517	49	152							TECTEH			21H00078	600UL
11518	51	152							TECTEH			21H00075	600UL
11519	53	152							TECTEH			21H00074	600UL
11520	55	152							TECTEH			21H00075	600UL
11521	57	152	0.59	111	INR	3	02C	+26.77	TECTEH			21H00074	600UL
11522	59	152							TECTEH			21H00075	600UL
11523	61	152							TECTEH			21H00074	600UL
11524	63	152	0.52	63	INR	6	06H	+19.93	TECTEH			21H00075	600UL
11525			0.73	80	INR	6	05C	+38.48	TECTEH			21H00075	600UL
11526	65	152							TECTEH			21H00074	600UL
11527	67	152							TECTEH			21H00075	600UL
11528	69	152							TECTEH			21H00074	600UL
11529	71	152							TECTEH			21H00075	600UL
11530	73	152							TECTEH			21H00074	600UL
11531	75	152							TECTEH			21H00075	600UL
11532	77	152							TECTEH			21H00074	600UL
11533	79	152							TECTEH			21H00075	600UL
11534	81	152	0.31	96	INR	3	04H	+24.92	TECTEH			21H00074	600UL
11535			0.46	150	INR	3	F06	+10.96	TECTEH			21H00074	600UL
11536			0.52	145	INR	3	06C	+20.95	TECTEH			21H00074	600UL
11537			0.35	134	INR	3	04C	+15.23	TECTEH			21H00074	600UL
11538			0.58	123	INR	3	02C	+15.37	TECTEH			21H00074	600UL
11539			0.48	115	INR	3	02C	+17.22	TECTEH			21H00074	600UL
11540	2	153							TECTEH			21H00085	600UL
11541	4	153							TECTEH			21H00084	600UL
11542	6	153							TECTEH			21H00084	600UL
11543	8	153							TECTEH			21H00083	600UL
11544	10	153							TECTEH			21H00082	600UL
11545	12	153							TECTEH			21H00083	600UL
11546	14	153							TECTEH			21H00082	600UL
11547	16	153							TECTEH			21H00081	600UL
11548	18	153	0.47	52	INR	6	04H	+5.00	TECTEH			21H00080	600UL
11549	20	153							TECTEH			21H00081	600UL
11550	22	153							TECTEH			21H00080	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11551	24	153	0.63	79	INR	6	01C	+31.85	TECTEH			21H00080	600UL
11552	26	153							TECTEH			21H00079	600UL
11553	28	153							TECTEH			21H00078	600UL
11554	30	153							TECTEH			21H00079	600UL
11555	32	153	0.50	70	INR	6	05C	+29.90	TECTEH			21H00078	600UL
11556	34	153							TECTEH			21H00079	600UL
11557	36	153							TECTEH			21H00078	600UL
11558	38	153	0.37	127	INR	3	TSH	+18.48	TECTEH			21H00079	600UL
11559	40	153							TECTEH			21H00078	600UL
11560	42	153							TECTEH			21H00079	600UL
11561	44	153							TECTEH			21H00078	600UL
11562	46	153	0.36	128	INR	3	TSC	+12.07	TECTEH			21H00079	600UL
11563	48	153							TECTEH			21H00078	600UL
11564	50	153	0.55	40	INR	6	F05	+0.47	TECTEH			21H00075	600UL
11565	52	153							TECTEH			21H00075	600UL
11566	54	153							TECTEH			21H00074	600UL
11567	56	153							TECTEH			21H00075	600UL
11568	58	153							TECTEH			21H00074	600UL
11569	60	153							TECTEH			21H00075	600UL
11570	62	153							TECTEH			21H00074	600UL
11571	64	153							TECTEH			21H00075	600UL
11572	66	153							TECTEH			21H00074	600UL
11573	68	153							TECTEH			21H00075	600UL
11574	70	153							TECTEH			21H00074	600UL
11575	72	153							TECTEH			21H00075	600UL
11576	74	153	0.40	64	INR	3	F03	+3.58	TECTEH			21H00074	600UL
11577	76	153							TECTEH			21H00075	600UL
11578	78	153							TECTEH			21H00074	600UL
11579	1	154							TECTEH			21H00085	600UL
11580	3	154							TECTEH			21H00084	600UL
11581	5	154							TECTEH			21H00085	600UL
11582	7	154							TECTEH			21H00084	600UL
11583	9	154							TECTEH			21H00083	600UL
11584	11	154							TECTEH			21H00082	600UL
11585	13	154							TECTEH			21H00083	600UL
11586	15	154							TECTEH			21H00082	600UL
11587	17	154							TECTEH			21H00081	600UL
11588	19	154							TECTEH			21H00080	600UL
11589	21	154	5.06	183	INR	P1	F01	+6.47	TECTEH			21H00081	600UL
11590					INF		F05	+4.97	TECTEH	HR		21H00081	600UL
11591	23	154							TECTEH			21H00080	600UL
11592	25	154							TECTEH			21H00079	600UL
11593	27	154							TECTEH			21H00078	600UL
11594	29	154							TECTEH			21H00079	600UL
11595	31	154	1.70	184	INR	1	TSH	+14.08	TECTEH			21H00078	600UL
11596					INF		04H	-12.02 TO-7.86	TECTEH	HR		21H00078	600UL
11597			2.47	45	ADS	6	04H	-7.85 TO+8.54	TECTEH			21H00078	600UL
11598					INF		04H	+8.55 TO+37.00	TECTEH	HR		21H00078	600UL
11599			1.17	185	INR	1	05H	+7.07	TECTEH			21H00078	600UL
11600			1.50	183	INR	1	06H	+24.61	TECTEH			21H00078	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11601			0.44	86	INR	6	F06	+7.26	TECTEH			21H00078	600UL
11602			1.97	183	INR	1	06C	+4.94	TECTEH			21H00078	600UL
11603	33	154	0.50	160	INR	3	07H	+3.75	TECTEH			21H00079	600UL
11604			4.27	181	INR	1	F01	+7.29	TECTEH			21H00079	600UL
11605					INF		F08	-1.12	TECTEH	HR		21H00079	600UL
11606			1.37	218	INR	6	F08	+0.00	TECTEH			21H00079	600UL
11607	35	154							TECTEH			21H00078	600UL
11608	37	154							TECTEH			21H00079	600UL
11609	39	154							TECTEH			21H00078	600UL
11610	41	154	0.62	121	INR	3	03H	+7.63	TECTEH			21H00079	600UL
11611	43	154							TECTEH			21H00078	600UL
11612	45	154	0.33	115	INR	3	05C	+13.31	TECTEH			21H00079	600UL
11613	47	154							TECTEH			21H00078	600UL
11614	49	154	0.35	72	INR	6	01H	+20.00	TECTEH			21H00078	600UL
11615	51	154	0.50	75	INR	6	06H	+4.02	TECTEH			21H00075	600UL
11616			1.15	49	INR	6	F04	+0.00	TECTEH			21H00075	600UL
11617			0.71	84	INR	6	02C	+29.00	TECTEH			21H00075	600UL
11618	53	154							TECTEH			21H00074	600UL
11619	55	154							TECTEH			21H00075	600UL
11620	57	154							TECTEH			21H00074	600UL
11621	59	154							TECTEH			21H00075	600UL
11622	61	154							TECTEH			21H00074	600UL
11623	63	154	0.75	82	INR	6	02C	+4.00	TECTEH			21H00075	600UL
11624	65	154	0.21	120	INR	3	03C	+34.93	TECTEH			21H00074	600UL
11625	67	154							TECTEH			21H00075	600UL
11626	69	154							TECTEH			21H00074	600UL
11627	71	154							TECTEH			21H00075	600UL
11628	73	154							TECTEH			21H00074	600UL
11629	75	154							TECTEH			21H00074	600UL
11630	2	155							TECTEH			21H00085	600UL
11631	4	155							TECTEH			21H00084	600UL
11632	6	155							TECTEH			21H00084	600UL
11633	8	155							TECTEH			21H00083	600UL
11634	10	155							TECTEH			21H00082	600UL
11635	12	155							TECTEH			21H00083	600UL
11636	14	155							TECTEH			21H00082	600UL
11637	16	155	0.58	69	INR	6	04H	+11.51	TECTEH			21H00081	600UL
11638	18	155							TECTEH			21H00080	600UL
11639	20	155							TECTEH			21H00081	600UL
11640	22	155							TECTEH			21H00080	600UL
11641	24	155	0.65	157	INR	3	06H	+17.37	TECTEH			21H00080	600UL
11642	26	155							TECTEH			21H00079	600UL
11643	28	155	0.41	74	INR	6	03H	+21.21	TECTEH			21H00078	600UL
11644	30	155							TECTEH			21H00079	600UL
11645	32	155	0.69	60	INR	6	F05	+9.51	TECTEH			21H00078	600UL
11646	34	155							TECTEH			21H00079	600UL
11647	36	155	5.00	180	INR	1	F01	+6.70	TECTEH			21H00078	600UL
11648					INF		F05	+3.44	TECTEH	HR		21H00078	600UL
11649	38	155	0.34	121	INR	3	04H	+23.18	TECTEH			21H00079	600UL
11650			0.31	112	INR	3	05H	+18.20	TECTEH			21H00079	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11651			0.35	109	INR	3	06C	+16.69	TECTEH			21H00079	600UL
11652	40	155							TECTEH			21H00078	600UL
11653	42	155							TECTEH			21H00079	600UL
11654	44	155							TECTEH			21H00078	600UL
11655	46	155							TECTEH			21H00079	600UL
11656	48	155							TECTEH			21H00078	600UL
11657	50	155							TECTEH			21H00075	600UL
11658	52	155							TECTEH			21H00074	600UL
11659	54	155							TECTEH			21H00075	600UL
11660	56	155							TECTEH			21H00074	600UL
11661	58	155							TECTEH			21H00075	600UL
11662	60	155	0.59	135	INR	3	02H	+25.95	TECTEH			21H00074	600UL
11663			0.34	130	INR	3	06H	+4.79	TECTEH			21H00074	600UL
11664	62	155	0.38	64	INR	6	TSH	+20.87	TECTEH			21H00075	600UL
11665			0.65	85	INR	6	02H	+4.67	TECTEH			21H00075	600UL
11666			0.42	77	INR	6	03H	+17.68	TECTEH			21H00075	600UL
11667			0.49	63	INR	6	06H	+3.13	TECTEH			21H00075	600UL
11668	64	155							TECTEH			21H00074	600UL
11669	66	155							TECTEH			21H00075	600UL
11670	68	155							TECTEH			21H00074	600UL
11671	70	155							TECTEH			21H00075	600UL
11672	72	155	1.67	180	INR	1	TSC	+2.58	TECTEH			21H00074	600UL
11673	1	156							TECTEH			21H00085	600UL
11674	3	156							TECTEH			21H00084	600UL
11675	5	156							TECTEH			21H00085	600UL
11676	7	156							TECTEH			21H00084	600UL
11677	9	156							TECTEH			21H00083	600UL
11678	11	156							TECTEH			21H00082	600UL
11679	13	156							TECTEH			21H00083	600UL
11680	15	156							TECTEH			21H00082	600UL
11681	17	156							TECTEH			21H00081	600UL
11682	19	156							TECTEH			21H00080	600UL
11683	21	156	5.60	185	INR	1	F01	+6.45	TECTEH			21H00081	600UL
11684					INF		F05	+5.46	TECTEH	HR		21H00081	600UL
11685	23	156							TECTEH			21H00080	600UL
11686	25	156							TECTEH			21H00079	600UL
11687	27	156							TECTEH			21H00078	600UL
11688	29	156							TECTEH			21H00079	600UL
11689	31	156							TECTEH			21H00078	600UL
11690	33	156	0.65	121	INR	3	06H	+22.34	TECTEH			21H00079	600UL
11691			0.44	113	INR	3	TSC	+11.75	TECTEH			21H00079	600UL
11692	35	156	0.48	88	INR	6	01H	+25.33	TECTEH			21H00078	600UL
11693	37	156							TECTEH			21H00079	600UL
11694	39	156							TECTEH			21H00078	600UL
11695	41	156			INF		F07	+5.35	TECTEH	HR		21H00079	600UL
11696			1.26	136	INR	3	F07	+6.46	TECTEH			21H00079	600UL
11697					INF		F08	+6.01	TECTEH	HR		21H00079	600UL
11698			0.42	118	INR	3	05C	+17.27	TECTEH			21H00079	600UL
11699			0.73	123	INR	3	04C	+4.27	TECTEH			21H00079	600UL
11700	43	156							TECTEH			21H00078	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11701	45	156							TECTEH			21H00079	600UL
11702	47	156	0.29	78	INR	6	04C	+6.84	TECTEH			21H00078	600UL
11703	49	156							TECTEH			21H00078	600UL
11704	51	156							TECTEH			21H00075	600UL
11705	53	156	0.21	173	INR	3	07H	+4.57	TECTEH			21H00074	600UL
11706					INF		07H	+6.75	TECTEH	HR		21H00074	600UL
11707					INF		06C	+29.80	TECTEH	HR		21H00074	600UL
11708			0.46	125	INR	3	06C	+34.16	TECTEH			21H00074	600UL
11709	55	156							TECTEH			21H00075	600UL
11710	57	156							TECTEH			21H00074	600UL
11711	59	156							TECTEH			21H00075	600UL
11712	61	156	0.38	142	INR	3	02C	+36.69	TECTEH			21H00074	600UL
11713	63	156							TECTEH			21H00075	600UL
11714	65	156							TECTEH			21H00074	600UL
11715	67	156	0.59	47	INR	6	F06	+10.77	TECTEH			21H00075	600UL
11716	69	156							TECTEH			21H00074	600UL
11717	2	157							TECTEH			21H00085	600UL
11718	4	157							TECTEH			21H00084	600UL
11719	6	157							TECTEH			21H00084	600UL
11720	8	157							TECTEH			21H00083	600UL
11721	10	157	0.81	83	INR	6	02C	+13.86	TECTEH			21H00082	600UL
11722	12	157	0.56	67	INR	6	02H	+29.71	TECTEH			21H00083	600UL
11723	14	157							TECTEH			21H00082	600UL
11724	16	157	0.55	74	INR	6	01H	+5.00	TECTEH			21H00081	600UL
11725	18	157	0.38	128	INR	3	02H	+24.00	TECTEH			21H00080	600UL
11726	20	157							TECTEH			21H00081	600UL
11727	22	157							TECTEH			21H00080	600UL
11728	24	157							TECTEH			21H00080	600UL
11729	26	157							TECTEH			21H00079	600UL
11730	28	157							TECTEH			21H00078	600UL
11731	30	157							TECTEH			21H00079	600UL
11732	32	157							TECTEH			21H00078	600UL
11733	34	157							TECTEH			21H00079	600UL
11734	36	157							TECTEH			21H00078	600UL
11735	38	157			INF		F09	+0.00	TECTEH	HR		21H00079	600UL
11736			0.46	121	INR	3	04C	+5.28	TECTEH			21H00079	600UL
11737			0.47	137	INR	3	03C	+30.96	TECTEH			21H00079	600UL
11738	40	157							TECTEH			21H00078	600UL
11739	42	157							TECTEH			21H00079	600UL
11740	44	157							TECTEH			21H00078	600UL
11741	46	157	0.41	104	INR	3	F04	+8.32	TECTEH			21H00079	600UL
11742			1.65	149	INR	3	F07	+7.44	TECTEH			21H00079	600UL
11743					INF		F07	+15.47	TECTEH	HR		21H00079	600UL
11744			0.40	132	INR	3	F08	+2.88	TECTEH			21H00079	600UL
11745					INF		F09	+7.41	TECTEH	HR		21H00079	600UL
11746					INF		F09	+8.01	TECTEH	HR		21H00079	600UL
11747	48	157							TECTEH			21H00078	600UL
11748	50	157	0.52	53	INR	6	05H	+18.70	TECTEH			21H00075	600UL
11749	52	157							TECTEH			21H00075	600UL
11750	54	157							TECTEH			21H00074	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11751	56	157	0.27	89	INR	6	01C	+1.69	TECTEH			21H00075	600UL
11752	58	157	0.63	82	INR	6	05C	+15.79	TECTEH			21H00074	600UL
11753	60	157	0.51	83	INR	6	02H	+31.70	TECTEH			21H00075	600UL
11754			0.50	68	INR	6	03H	+10.33	TECTEH			21H00075	600UL
11755			0.60	117	INR	6	F03	+8.06	TECTEH			21H00075	600UL
11756			0.46	79	INR	6	02C	+15.60	TECTEH			21H00075	600UL
11757			0.51	81	INR	6	TSC	+16.15	TECTEH			21H00075	600UL
11758	62	157	0.35	75	INR	6	06C	+28.05	TECTEH			21H00074	600UL
11759	64	157							TECTEH			21H00075	600UL
11760	66	157							TECTEH			21H00074	600UL
11761	1	158							TECTEH			21H00085	600UL
11762	3	158							TECTEH			21H00084	600UL
11763	5	158	0.72	37	INR	6	04H	+25.44	TECTEH			21H00085	600UL
11764	7	158							TECTEH			21H00084	600UL
11765	9	158							TECTEH			21H00083	600UL
11766	11	158							TECTEH			21H00082	600UL
11767	13	158							TECTEH			21H00083	600UL
11768	15	158							TECTEH			21H00082	600UL
11769	17	158							TECTEH			21H00081	600UL
11770	19	158							TECTEH			21H00080	600UL
11771	21	158	0.79	62	INR	6	06C	+7.22	TECTEH			21H00081	600UL
11772	23	158							TECTEH			21H00080	600UL
11773	25	158							TECTEH			21H00079	600UL
11774	27	158							TECTEH			21H00078	600UL
11775	29	158							TECTEH			21H00079	600UL
11776	31	158							TECTEH			21H00078	600UL
11777	33	158	0.46	112	INR	3	02H	+6.03	TECTEH			21H00079	600UL
11778	35	158							TECTEH			21H00078	600UL
11779	37	158							TECTEH			21H00079	600UL
11780	39	158	2.42	77	INR	6	07H	+6.63	TECTEH			21H00078	600UL
11781	41	158							TECTEH			21H00079	600UL
11782	43	158							TECTEH			21H00078	600UL
11783	45	158							TECTEH			21H00079	600UL
11784	47	158							TECTEH			21H00078	600UL
11785	49	158							TECTEH			21H00078	600UL
11786	51	158							TECTEH			21H00075	600UL
11787	53	158							TECTEH			21H00074	600UL
11788	55	158							TECTEH			21H00075	600UL
11789	57	158							TECTEH			21H00074	600UL
11790	59	158							TECTEH			21H00075	600UL
11791	61	158							TECTEH			21H00074	600UL
11792	63	158							TECTEH			21H00074	600UL
11793	2	159							TECTEH			21H00085	600UL
11794	4	159							TECTEH			21H00084	600UL
11795	6	159	0.51	67	INR	6	03C	+16.84	TECTEH			21H00084	600UL
11796	8	159							TECTEH			21H00083	600UL
11797	10	159							TECTEH			21H00082	600UL
11798	12	159	0.63	90	INR	6	02H	+2.28	TECTEH			21H00083	600UL
11799	14	159							TECTEH			21H00082	600UL
11800	16	159							TECTEH			21H00081	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11801	18	159							TECTEH			21H00080	600UL
11802	20	159	0.53	75	INR	6	04C	+9.05	TECTEH			21H00081	600UL
11803	22	159							TECTEH			21H00080	600UL
11804	24	159							TECTEH			21H00080	600UL
11805	26	159							TECTEH			21H00079	600UL
11806	28	159							TECTEH			21H00078	600UL
11807	30	159							TECTEH			21H00079	600UL
11808	32	159							TECTEH			21H00078	600UL
11809	34	159							TECTEH			21H00079	600UL
11810	36	159	0.46	59	INR	6	F06	+7.72	TECTEH			21H00078	600UL
11811	38	159	0.38	135	INR	3	03H	+13.17	TECTEH			21H00079	600UL
11812			1.19	155	INR	3	F05	+7.53	TECTEH			21H00079	600UL
11813			0.34	122	INR	3	03C	+3.54	TECTEH			21H00079	600UL
11814	40	159							TECTEH			21H00078	600UL
11815	42	159	0.39	132	INR	3	TSC	+21.43	TECTEH			21H00079	600UL
11816	44	159	0.96	69	INR	6	04H	+0.00	TECTEH			21H00078	600UL
11817	46	159	0.85	134	INR	3	01C	+1.94	TECTEH			21H00079	600UL
11818	48	159							TECTEH			21H00078	600UL
11819	50	159			INF		03C	+9.76	TECTEH	HR		21H00075	600UL
11820			0.52	87	INR	6	03C	+12.02	TECTEH			21H00075	600UL
11821	52	159							TECTEH			21H00074	600UL
11822	54	159	1.36	96	NQH	3	F06	+2.01	TECTEH			21H00075	600UL
11823	56	159							TECTEH			21H00074	600UL
11824	58	159							TECTEH			21H00075	600UL
11825	60	159							TECTEH			21H00074	600UL
11826	1	160	0.69	46	INR	6	03H	+20.49 TO+38.93	TECTEH			21H00085	600UL
11827			1.14	44	INR	6	04H	+33.62 TO+3.77	TECTEH			21H00085	600UL
11828	3	160							TECTEH			21H00084	600UL
11829	5	160							TECTEH			21H00085	600UL
11830	7	160							TECTEH			21H00084	600UL
11831	9	160							TECTEH			21H00083	600UL
11832	11	160							TECTEH			21H00082	600UL
11833	13	160							TECTEH			21H00083	600UL
11834	15	160							TECTEH			21H00082	600UL
11835	17	160	0.67	68	INR	6	05H	+37.20	TECTEH			21H00081	600UL
11836	19	160							TECTEH			21H00080	600UL
11837	21	160							TECTEH			21H00081	600UL
11838	23	160							TECTEH			21H00080	600UL
11839	25	160							TECTEH			21H00079	600UL
11840	27	160							TECTEH			21H00078	600UL
11841	29	160							TECTEH			21H00079	600UL
11842	31	160							TECTEH			21H00078	600UL
11843	33	160							TECTEH			21H00079	600UL
11844	35	160							TECTEH			21H00078	600UL
11845	37	160	0.17	98	INR	3	05H	+22.29	TECTEH			21H00079	600UL
11846			0.29	95	INR	3	06H	+7.57	TECTEH			21H00079	600UL
11847	39	160							TECTEH			21H00078	600UL
11848	41	160							TECTEH			21H00079	600UL
11849	43	160							TECTEH			21H00078	600UL
11850	45	160	0.38	111	INR	3	04H	+35.06	TECTEH			21H00079	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11851			0.50	127	INR	3	06C	+32.24	TECTEH			21H00079	600UL
11852					INF		06C	+36.24	TECTEH	HR		21H00079	600UL
11853	47	160	0.67	80	INR	6	07H	+6.65	TECTEH			21H00078	600UL
11854	49	160	0.48	89	INR	6	06H	+6.28	TECTEH			21H00078	600UL
11855			0.84	85	INR	6	04C	+22.93	TECTEH			21H00078	600UL
11856	51	160							TECTEH			21H00075	600UL
11857	53	160							TECTEH			21H00074	600UL
11858	55	160	0.63	72	INR	6	04H	+37.76	TECTEH			21H00075	600UL
11859	57	160							TECTEH			21H00074	600UL
11860	2	161							TECTEH			21H00085	600UL
11861	4	161							TECTEH			21H00084	600UL
11862	6	161							TECTEH			21H00084	600UL
11863	8	161							TECTEH			21H00083	600UL
11864	10	161							TECTEH			21H00082	600UL
11865	12	161	0.49	77	INR	6	TSH	+8.96	TECTEH			21H00083	600UL
11866			0.39	73	INR	6	TSH	+10.15	TECTEH			21H00083	600UL
11867			0.38	67	INR	6	05C	+8.52	TECTEH			21H00083	600UL
11868	14	161							TECTEH			21H00082	600UL
11869	16	161							TECTEH			21H00081	600UL
11870	18	161							TECTEH			21H00080	600UL
11871	20	161	0.40	71	INR	6	06C	+32.46	TECTEH			21H00081	600UL
11872	22	161							TECTEH			21H00080	600UL
11873	24	161	0.61	121	INR	3	01H	+18.72	TECTEH			21H00080	600UL
11874			0.56	128	INR	3	01H	+20.60	TECTEH			21H00080	600UL
11875	26	161	0.36	122	INR	3	03C	+27.11	TECTEH			21H00079	600UL
11876	28	161							TECTEH			21H00078	600UL
11877	30	161							TECTEH			21H00079	600UL
11878	32	161							TECTEH			21H00078	600UL
11879	34	161							TECTEH			21H00079	600UL
11880	36	161							TECTEH			21H00078	600UL
11881	38	161	0.35	130	INR	3	06H	+3.10	TECTEH			21H00079	600UL
11882	40	161							TECTEH			21H00078	600UL
11883	42	161	0.47	132	INR	3	06C	+5.01	TECTEH			21H00079	600UL
11884	44	161	0.42	73	INR	6	03C	+36.84	TECTEH			21H00078	600UL
11885	46	161							TECTEH			21H00079	600UL
11886	48	161							TECTEH			21H00078	600UL
11887	50	161							TECTEH			21H00075	600UL
11888	52	161							TECTEH			21H00074	600UL
11889	1	162							TECTEH			21H00085	600UL
11890	3	162							TECTEH			21H00084	600UL
11891	5	162							TECTEH			21H00085	600UL
11892	7	162							TECTEH			21H00084	600UL
11893	9	162							TECTEH			21H00083	600UL
11894	11	162							TECTEH			21H00082	600UL
11895	13	162							TECTEH			21H00083	600UL
11896	15	162							TECTEH			21H00082	600UL
11897	17	162							TECTEH			21H00081	600UL
11898					NDF	3	TEH	+18.13	TEHTSH			21H00087	610PP
11899	19	162							TECTEH			21H00080	600UL
11900	21	162	4.69	184	INR	P1	F01	+6.33	TECTEH			21H00081	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11901				INF		F05	+5.24	TECTEH	HR		21H00081	600UL
11902	23 162							TECTEH			21H00080	600UL
11903	25 162	0.42	125	INR	3	02C	+25.42	TECTEH			21H00079	600UL
11904				INF		02C	+27.01	TECTEH	HR		21H00079	600UL
11905	27 162							TECTEH			21H00078	600UL
11906	29 162							TECTEH			21H00079	600UL
11907	31 162							TECTEH			21H00078	600UL
11908	33 162							TECTEH			21H00079	600UL
11909	35 162							TECTEH			21H00078	600UL
11910	37 162							TECTEH			21H00079	600UL
11911	39 162	0.19	69	INR	6	02H	+14.14	TECTEH			21H00078	600UL
11912		0.88	68	INR	6	07H	+8.04	TECTEH			21H00078	600UL
11913	41 162	0.82	140	INR	3	F04	+8.74	TECTEH			21H00079	600UL
11914				INF		F04	+10.06	TECTEH	HR		21H00079	600UL
11915		0.70	124	INR	3	05C	+29.29	TECTEH			21H00079	600UL
11916				INF		05C	+31.21	TECTEH	HR		21H00079	600UL
11917	43 162							TECTEH			21H00078	600UL
11918	45 162							TECTEH			21H00079	600UL
11919	47 162							TECTEH			21H00078	600UL
11920	49 162	0.36	84	INR	6	02C	+12.07	TECTEH			21H00078	600UL
11921	2 163							TECTEH			21H00085	600UL
11922	4 163							TECTEH			21H00084	600UL
11923	6 163							TECTEH			21H00084	600UL
11924	8 163	0.43	63	INR	6	TSH	+10.27	TECTEH			21H00083	600UL
11925		0.51	75	INR	6	01H	+22.45	TECTEH			21H00083	600UL
11926	10 163							TECTEH			21H00082	600UL
11927	12 163							TECTEH			21H00083	600UL
11928	14 163							TECTEH			21H00082	600UL
11929	16 163							TECTEH			21H00081	600UL
11930	18 163							TECTEH			21H00080	600UL
11931	20 163							TECTEH			21H00081	600UL
11932	22 163							TECTEH			21H00080	600UL
11933	24 163							TECTEH			21H00080	600UL
11934	26 163	0.67	125	INR	3	TSH	+8.28	TECTEH			21H00079	600UL
11935	28 163							TECTEH			21H00078	600UL
11936	30 163							TECTEH			21H00079	600UL
11937	32 163							TECTEH			21H00078	600UL
11938	34 163							TECTEH			21H00079	600UL
11939	36 163							TECTEH			21H00078	600UL
11940	38 163	0.71	120	INR	3	02C	+10.89	TECTEH			21H00079	600UL
11941	40 163	0.44	72	INR	6	05H	+6.26	TECTEH			21H00078	600UL
11942		0.48	79	INR	6	03C	+18.47	TECTEH			21H00078	600UL
11943	42 163							TECTEH			21H00079	600UL
11944	44 163							TECTEH			21H00078	600UL
11945	1 164							TECTEH			21H00085	600UL
11946	3 164							TECTEH			21H00084	600UL
11947	5 164							TECTEH			21H00085	600UL
11948	7 164							TECTEH			21H00084	600UL
11949	9 164							TECTEH			21H00083	600UL
11950	11 164							TECTEH			21H00082	600UL

ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE SIZE
11951	13 164							TECTEH			21H00083	600UL
11952	15 164							TECTEH			21H00082	600UL
11953	17 164							TECTEH			21H00081	600UL
11954	19 164							TECTEH			21H00080	600UL
11955	21 164	5.24	185	INR	1	F01	+6.37	TECTEH			21H00081	600UL
11956				INF		F05	+2.99	TECTEH	HR		21H00081	600UL
11957	23 164							TECTEH			21H00080	600UL
11958	25 164							TECTEH			21H00079	600UL
11959	27 164							TECTEH			21H00078	600UL
11960	29 164							TECTEH			21H00079	600UL
11961	31 164							TECTEH			21H00078	600UL
11962	33 164							TECTEH			21H00079	600UL
11963	35 164							TECTEH			21H00078	600UL
11964	37 164							TECTEH			21H00079	600UL
11965	39 164							TECTEH			21H00078	600UL
11966	2 165							TECTEH			21H00085	600UL
11967	4 165							TECTEH			21H00084	600UL
11968	6 165							TECTEH			21H00084	600UL
11969	8 165							TECTEH			21H00083	600UL
11970	10 165							TECTEH			21H00082	600UL
11971	12 165							TECTEH			21H00083	600UL
11972	14 165							TECTEH			21H00082	600UL
11973	16 165							TECTEH			21H00081	600UL
11974	18 165	0.41	144	INR	3	04C	+17.98	TECTEH			21H00080	600UL
11975	20 165							TECTEH			21H00081	600UL
11976	22 165							TECTEH			21H00080	600UL
11977	24 165							TECTEH			21H00080	600UL
11978	26 165							TECTEH			21H00079	600UL
11979	28 165							TECTEH			21H00078	600UL
11980	30 165			INF		F01	+4.73	TECTEH	HR		21H00079	600UL
11981		3.69	181	INR	1	F01	+6.25	TECTEH			21H00079	600UL
11982	32 165							TECTEH			21H00078	600UL
11983	1 166							TECTEH			21H00085	600UL
11984	3 166							TECTEH			21H00084	600UL
11985	5 166							TECTEH			21H00085	600UL
11986	7 166	0.35	83	INR	3	TSH	+11.72	TECTEH			21H00084	600UL
11987	9 166							TECTEH			21H00083	600UL
11988	11 166							TECTEH			21H00082	600UL
11989	13 166							TECTEH			21H00083	600UL
11990	15 166							TECTEH			21H00082	600UL
11991	17 166							TECTEH			21H00081	600UL
11992	19 166							TECTEH			21H00080	600UL
11993	21 166	5.02	183	INR	1	F01	+5.97	TECTEH			21H00081	600UL
11994				INF		F01	+7.63	TECTEH	HR		21H00081	600UL
11995				INF		F05	+5.47	TECTEH	HR		21H00081	600UL
11996	23 166							TECTEH			21H00080	600UL
11997	25 166							TECTEH			21H00079	600UL
11998	2 167							TECTEH			21H00085	600UL
11999	4 167							TECTEH			21H00084	600UL
12000	6 167							TECTEH			21H00084	600UL

	ROW	COL	VOLTS	DEG	PCT	CHN	FLAW	LOCATION	EXTENT	UTIL1	UTIL2	CAL GROUP	PROBE	SIZE
12001	8	167							TECTEH			21H00083	600	UL
12002	10	167							TECTEH			21H00082	600	UL
12003	12	167							TECTEH			21H00082	600	UL
12004	14	167							TECTEH			21H00081	600	UL
12005	16	167							TECTEH			21H00080	600	UL

Docket Nos. 50-336
50-423
B18321

Attachment 2

Millstone Nuclear Power Station Unit Nos. 2 and 3

Millstone Unit No. 3 Annual Report

PEWPDD20
sosinrv

MILLSTONE NUCLEAR POWER STATION
REG. GUIDE 1.16 REPORT

30-jan-2001
Unit: 3

Work & Job Function	# of Personnel			Total Man-mRem		
	Station	Utility	Contract	Station	Utility	Contract
Inservice Inspection						
Engineering Staff	5	0	1	0	0	0
HealthPhysics and Lab	4	0	0	4	0	0
Maint and Construction	8	0	4	4	0	0
Operations	0	0	0	0	0	0
Supv and Office Staff	0	0	0	0	0	0
Refueling Operations						
Engineering Staff	6	0	2	15	0	0
HealthPhysics and Lab	11	1	2	8	2	1
Maint and Construction	18	0	10	7	0	10
Operations	0	0	0	0	0	0
Supv and Office Staff	0	0	0	0	0	0
Routine Oper and Surv						
Engineering Staff	150	23	57	95	18	50
HealthPhysics and Lab	52	2	27	1066	0	180
Maint and Construction	94	18	74	212	11	195
Operations	22	0	2	104	0	8
Supv and office Staff	14	4	11	1	0	7
Routine Plant Maint						
Engineering Staff	92	24	48	89	19	60
HealthPhysics and Lab	39	1	22	72	0	8
Maint and Construction	331	65	635	838	59	385
Operations	134	0	21	739	0	7
Supv and Office Staff	39	13	70	1	3	10
Special Plant Maint						
Engineering Staff	41	4	13	49	0	47
HealthPhysics and Lab	28	1	6	203	0	6
Maint and Construction	91	21	202	233	9	2292
Operations	5	0	1	2	0	0
Supv and Office Staff	8	0	5	1	0	0
Waste Processing						
Engineering Staff	3	1	3	2	0	0
HealthPhysics and Lab	26	1	10	204	19	18
Maint and Construction	47	8	45	226	15	151
Operations	1	0	0	9	0	0
Supv and Office Staff	2	0	0	9	0	0
Job Totals						
Engineering Staff	297	52	124	250	37	157
HealthPhysics and Lab	160	6	67	1557	21	213
Maint and Construction	589	112	970	1520	94	3033
Operations	162	0	24	854	0	15
Supv and Office Staff	63	17	86	12	3	17
Unit 3 Total	1271	187	1271	4193	155	3435

Note: Report contains electronic dosimeter or PIC dose only

Dose of persons with <100 mrem IS INCLUDED

PRIMARY COOLANT IODINE SPIKING

In accordance with Technical Specification 6.9.1.2, the following is a report of primary coolant iodine spiking occurring during 2000.

During 2000, the specific activity of the primary coolant did not exceed the limits in the Technical Specifications.

CHALLENGES TO RELIEF/SAFETY VALVES

In accordance with Technical Specification 6.9.1.2, the following is a report of challenges to relief/safety valves during 2000.

There were no challenges made to the primary relief/safety valves in 2000.