

March 2, 2001

Mr. Otto L. Maynard
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KA 66839

SUBJECT: WOLF CREEK GENERATING STATION - ISSUANCE OF AMENDMENT RE:
ELIMINATION OF REQUIREMENTS FOR POST ACCIDENT SAMPLING
SYSTEMS (TAC NO. MB0678)

Dear Mr. Maynard:

The Commission has issued the enclosed Amendment No. 137 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The amendment consists of changes to the Technical Specifications (TS) in response to your application dated December 7, 2000.

The amendment deletes TS Section 5.5.3, "Post Accident Sampling," for Wolf Creek Generating Station and thereby eliminates the requirements to have and maintain the post-accident sampling system (PASS). The amendment also revises TS 5.5.2, "Primary Coolant Sources Outside Containment," to reflect the elimination of PASS.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures: 1. Amendment No. 137 to NPF-42
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

PUBLIC
PDIV-2 Reading
RidsNrrDlpmPdiv(SRichards)
RidsNrrPMJDonohew
RidsNrrLAEPeyton
RidsOGCRp
RidsACRSACNWMailCenter
WBeckner
GHill (2)
LHurley, RIV
DBujol, RIV
WJohnson, RIV

Accession No. ML0100

OFFICE	PDIV-2/PM	PDIV-2/LA	CLIIP-PASS	OGC	PDIV-2/SC
NAME	JDonohew:lcc	EPeyton	WReckley	C Mucco	SDembek
DATE	2/13/2001	2/12/01	2/13/01	2/27/01	3/1/01

DOCUMENT NAME: G:\PDIV-2\WolfCreek\AMD-MB0678.wc.wpd

OFFICIAL RECORD COPY

NR-058



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 2, 2001

Mr. Otto L. Maynard
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KA 66839

SUBJECT: WOLF CREEK GENERATING STATION - ISSUANCE OF AMENDMENT RE:
ELIMINATION OF REQUIREMENTS FOR POST ACCIDENT SAMPLING
SYSTEMS (TAC NO. MB0678)

Dear Mr. Maynard:

The Commission has issued the enclosed Amendment No. 137 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station. The amendment consists of changes to the Technical Specifications (TS) in response to your application dated December 7, 2000.

The amendment deletes TS Section 5.5.3, "Post Accident Sampling," for Wolf Creek Generating Station and thereby eliminates the requirements to have and maintain the post-accident sampling system (PASS). The amendment also revises TS 5.5.2, "Primary Coolant Sources Outside Containment," to reflect the elimination of PASS.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures: 1. Amendment No. 137 to NPF-42
2. Safety Evaluation

cc w/encls: See next page

Wolf Creek Generating Station

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Vice President & Chief Operating Officer
Wolf Creek Nuclear Operating Corporation
P. O. Box 411
Burlington, KS 66839

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Superintendent Licensing
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, KS 66839

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 311
Burlington, KS 66839

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
8201 NRC Road
Steedman, MO 65077-1032

Chief Engineer
Utilities Division
Kansas Corporation Commission
1500 SW Arrowhead Road
Topeka, KS 66604-4027

Office of the Governor
State of Kansas
Topeka, KS 66612

Attorney General
Judicial Center
301 S.W. 10th
2nd Floor
Topeka, KS 66612

County Clerk
Coffey County Courthouse
Burlington, KS 66839

Vick L. Cooper, Chief
Radiation Control Program, RCP
Kansas Department of Health
and Environment
Bureau of Air and Radiation
Forbes Field Building 283
Topeka, KS 66620



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 137
License No. NPF-42

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Wolf Creek Generating Station (the facility) Facility Operating License No. NPF-42 filed by the Wolf Creek Nuclear Operating Corporation (the Corporation), dated December 7, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-42 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 137 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented on or before December 1, 2001.

FOR THE NUCLEAR REGULATORY COMMISSION



Stephen Dembek, Chief, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: March 2, 2001

ATTACHMENT TO LICENSE AMENDMENT NO. 137

FACILITY OPERATING LICENSE NO. NPF-42

DOCKET NO. 50-482

Replace the following page of the Appendix A Technical Specifications with the attached page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

5.0-7

INSERT

5.0-7

5.5 Programs and Manuals (continued)

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include appropriate portions of Containment Spray, Safety Injection, Chemical and Volume Control, Residual Heat Removal, and Nuclear Sampling System (Post Accident Sampling System only (until such time as a modification eliminates the PASS penetration as a potential leakage path)). The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at refueling cycle intervals or less.

5.5.3 Not Used.

5.5.4 Radioactive Effluent Controls Program

This program conforms to 10 CFR 50.36a for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- b. Limitations on the concentrations of radioactive material released in liquid effluents to unrestricted areas, conforming to 10 times the concentration values in, Appendix B, Table 2, Column 2, to 10 CFR 20.1001-20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents in accordance with 10 CFR 20.1302 and with the methodology and parameters in the ODCM;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative and projected dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days.
- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be in accordance with the following:
 - 1. For noble gases: a dose rate ≤ 500 mrem/yr to the whole body and a dose rate ≤ 3000 mrem/yr to the skin, and
 - 2. For iodine-131, for iodine-133, for tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: a dose rate ≤ 1500 mrem/yr to any organ.
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;

(continued)



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 137 TO FACILITY OPERATING LICENSE NO. NPF-42

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

1.0 INTRODUCTION

By application dated December 7, 2000, Wolf Creek Nuclear Operating Corporation (the licensee) requested changes to the Technical Specifications (TS, Appendix A to Facility Operating License No. NPF-42) for the Wolf Creek Generating Station (WCGS). The proposed changes would delete TS 5.5.3, "Post Accident Sampling."

In the aftermath of the accident at Three Mile Island (TMI), Unit 2, the U.S. Nuclear Regulatory Commission (NRC) imposed requirements on licensees for commercial nuclear power plants to install and maintain the capability to obtain and analyze post-accident samples of the reactor coolant and containment atmosphere. The desired capabilities of the Post Accident Sampling System (PASS) were described in NUREG-0737, "Clarification of TMI Action Plan Requirements." The NRC issued orders to licensees with plants operating at the time of the TMI accident to confirm the installation of PASS capabilities (generally as they had been described in NUREG-0737). A requirement for PASS and related administrative controls was added to the TSs of the operating plants and was included in the initial TS for plants licensed during the 1980s and 90s. Additional expectations regarding PASS capabilities were included in Regulatory Guide 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants To Assess Plant and Environs Conditions During and Following an Accident."

Significant improvements have been achieved since the TMI accident in the areas of understanding risks associated with nuclear plant operations and developing better strategies for managing the response to potentially severe accidents at nuclear plants. Recent insights about plant risks and alternate severe accident assessment tools have led the NRC staff to conclude that some TMI Action Plan items can be revised without reducing the ability of licensees to respond to severe accidents. The NRC's efforts to oversee the risks associated with nuclear technology more effectively and to eliminate undue regulatory costs to licensees have prompted the NRC to consider eliminating the requirements for PASS in TS and other parts of the licensing bases of operating reactors.

The staff has completed its review of the topical reports submitted by the Combustion Engineering Owners Group (CEOG) and the Westinghouse Owners Group (WOG) that proposed the elimination of PASS. The justifications for the proposed elimination of PASS requirements center on evaluations of the various radiological and chemical sampling and their potential usefulness in responding to a severe reactor accident or making decisions regarding

actions to protect the public from possible releases of radioactive materials. As explained in more detail in the staff's safety evaluations for the two topical reports, the staff has reviewed the available sources of information for use by decision-makers in developing protective action recommendations and assessing core damage. Based on this review, the staff found that the information provided by PASS is either unnecessary or is effectively provided by other indications of process parameters or measurement of radiation levels. The staff agrees, therefore, with the owners groups that licensees can remove the TS requirements for PASS, revise (as necessary) other elements of the licensing bases, and pursue possible design changes to alter or remove existing PASS equipment.

2.0 BACKGROUND

In a letter dated May 5, 1999 (as supplemented by letter dated April 14, 2000), the CEOG submitted Topical Report CE NPSD-1157, Revision 1, "Technical Justification for the Elimination of the Post-Accident Sampling System From the Plant Design and Licensing Bases for CEOG Utilities." A similar proposal was submitted on October 26, 1998 (as supplemented by letters dated April 28, 1999, April 10 and May 22, 2000), by the WOG in its Topical Report WCAP-14986, "Post Accident Sampling System Requirements: A Technical Basis." The reports provided evaluations of the information obtained from PASS samples to determine the contribution of the information to plant safety and accident recovery. The reports considered the progression and consequences of core damage accidents and assessed the accident progression with respect to plant abnormal and emergency operating procedures, severe accident management guidance, and emergency plans. The reports provided the owners groups' technical justifications for the elimination for the various PASS sampling requirements. The specific samples and the staff's findings are described in the following evaluation.

The NRC staff prepared this model safety evaluation (SE) relating to the elimination of requirements on post accident sampling and solicited public comment (65 FR 49271) in accordance with the consolidated line item improvement process (CLIP). The use of the CLIP in this matter is intended to help the NRC to efficiently process amendments that propose to remove the PASS requirements from TS. Licensees of nuclear power reactors to which this model apply were informed (65 FR 65018) that they could request amendments confirming the applicability of the SE to their reactors and providing the requested plant-specific verifications and commitments.

3.0 EVALUATION

The technical evaluations for the elimination of PASS sampling requirements are provided in the safety evaluations dated May 16, 2000, for the CEOG topical report CE NPSD-1157 and June 14, 2000, for the WOG topical report WCAP-14986. The NRC staff's safety evaluations approving the topical reports are located in the NRC's Agencywide Documents Access and Management System (ADAMS) (Accession Numbers ML003715250 for CE NPSD-1157 and ML003723268 for WCAP-14986).

The ways in which the requirements and recommendations for PASS were incorporated into the licensing bases of commercial nuclear power plants varied as a function of when plants were licensed. Plants that were operating at the time of the TMI accident are likely to have been the

subject of confirmatory orders that imposed the PASS functions described in NUREG-0737 as obligations. The issuance of plant specific amendments to adopt this change, which would remove PASS and related administrative controls from TS, supersede the PASS specific requirements imposed by post-TMI confirmatory orders.

As described in its safety evaluations for the topical reports, the staff finds that the following PASS sampling requirements may be eliminated for plants of Combustion Engineering and Westinghouse designs:

1. reactor coolant dissolved gases
2. reactor coolant hydrogen
3. reactor coolant oxygen
4. reactor coolant pH
5. reactor coolant chlorides
6. reactor coolant boron
7. reactor coolant conductivity
8. reactor coolant radionuclides
9. containment atmosphere hydrogen concentration
10. containment oxygen
11. containment atmosphere radionuclides
12. containment sump pH
13. containment sump chlorides
14. containment sump boron
15. containment sump radionuclides

The staff agrees that sampling of radionuclides is not required to support emergency response decision-making during the initial phases of an accident because the information provided by PASS is either unnecessary or is effectively provided by other indications of process parameters or measurement of radiation levels. Therefore, it is not necessary to have dedicated equipment to obtain this sample in a prompt manner.

The staff does, however, believe that there could be significant benefits to having information about the radionuclides existing post-accident in order to address public concerns and plan for long-term recovery operations. As stated in the safety evaluations for the topical reports, the staff has found that licensees could satisfy this function by developing contingency plans to describe existing sampling capabilities and what actions (e.g., assembling temporary shielding) may be necessary to obtain and analyze highly radioactive samples from the reactor coolant system (RCS), containment sump, and containment atmosphere. (See item 4.1 under Licensee Verifications and Commitments). These contingency plans must be available to be used by a licensee during an accident; however, these contingency plans do not have to be carried out in emergency plan drills or exercises. The contingency plans for obtaining samples from the RCS, containment sump, and containment atmosphere may also enable a licensee to derive information on parameters such as hydrogen concentrations in containment and boron concentration and pH of water in the containment sump. The staff considers the sampling of the containment sump to be potentially useful in confirming calculations of pH and boron concentrations and confirming that potentially unaccounted for acid sources have been

sufficiently neutralized. The use of the contingency plans for obtaining samples would depend on the plant conditions and the need for information by the decision-makers responsible for responding to the accident.

In addition, the staff considers radionuclide sampling information to be useful in classifying certain types of events (such as a reactivity excursion or mechanical damage) that could cause fuel damage without having an indication of overheating on core exit thermocouples. However, the staff agrees with the topical reports' contentions that other indicators of failed fuel, such as letdown radiation monitors (or normal sampling system), can be correlated to the degree of failed fuel. (See item 4.2 under Licensee Verifications and Commitments).

In lieu of the information that would have been obtained from PASS, the staff believes that licensees should maintain or develop the capability to monitor radioactive iodines that have been released to offsite environs. Although this capability may not be needed to support the immediate protective action recommendations during an accident, the information would be useful for decision-makers trying to limit the public's ingestion of radioactive materials. (See item 4.3 under Licensee Verifications and Commitments.)

The staff believes that the changes related to the elimination of PASS that are described in the topical reports, related safety evaluations and this proposed change to TS are unlikely to result in a decrease in the effectiveness of a licensee's emergency plan. Each licensee, however, must evaluate possible changes to its emergency plan in accordance with 10 CFR 50.54(q) to determine if the change decreases the effectiveness of its site-specific plan. Evaluations and reporting of changes to emergency plans should be performed in accordance with applicable regulations and procedures.

The staff notes that redundant, safety-grade, containment hydrogen concentration monitors are required by 10 CFR 50.44(b)(1), are addressed in NUREG-0737 Item II.F.1 and Regulatory Guide 1.97, and are relied upon to meet the data reporting requirements of 10 CFR Part 50, Appendix E, Section VI.2.a.(i)(4). The staff concludes that during the early phases of an accident, the safety-grade hydrogen monitors provide an adequate capability for monitoring containment hydrogen concentration. The staff sees value in maintaining the capability to obtain grab samples for complementing the information from the hydrogen monitors in the long term (i.e., by confirming the indications from the monitors and providing hydrogen measurements for concentrations outside the range of the monitors). As previously mentioned, the licensee's contingency plan (see item 4.1 under Licensee Verifications and Commitments) for obtaining highly radioactive samples will include sampling of the containment atmosphere and may, if deemed necessary and practical by the appropriate decision-makers, be used to supplement the safety-related hydrogen monitors.

The TS include an administrative requirement for a program to minimize to levels as low as practicable the leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident. The program includes preventive maintenance, periodic inspections, and leak tests for the identified systems. PASS is specifically listed in TS 5.5.2 as falling under the scope of this requirement. The applicability

of this specification depends on whether or not PASS is maintained as a system that is a potential leakage path.

The licensee has stated that a plant change will be implemented such that PASS would not be a potential leakage path outside containment for highly radioactive fluids. The modification will not, however, be made during the implementation period for this amendment. The licensee has proposed to add the following phrase to the reference to PASS in TS 5.5.2:

"(until such time as a modification eliminates the PASS penetration as a potential leakage path)."

The above phrase makes clear that TS 5.5.2 remains applicable to the PASS as long as it is a possible leakage path and reflects that the actual modification of the piping system may be scheduled beyond the implementation period for this amendment. Requirements in NRC regulations (10 CFR Part 50, Appendix J) and other TS provide adequate regulatory controls over the licensee's modification to eliminate PASS as a potential leakage path. Following the modification to eliminate PASS as a potential leakage path, the licensee may elect (in order to maintain clarity and simplicity of the requirement) to revise TS 5.5.2 to remove the reference to PASS, including the phrase added by this amendment.

The elimination of PASS affects the discussion in the Bases section for TS 3.4.15, "RCS Leakage Detection Instrumentation." The current Bases mention the capabilities of PASS as an alternative way to monitor the containment atmosphere for detecting RCS leakage. Although the licensee's application included possible wording for the revised Bases discussion for TS 3.4.15, the licensee will formally address the change to the Bases in accordance with the TS Bases Control Program described in TS 5.5.14.

4.0 VERIFICATIONS AND COMMITMENTS

As requested by the staff in the notice of availability for this TS improvement, the licensee has addressed the following plant-specific verifications and commitments.

- 4.1 Each licensee should verify that it has, and make a regulatory commitment to maintain (or make a regulatory commitment to develop and maintain), contingency plans for obtaining and analyzing highly radioactive samples of reactor coolant, containment sump, and containment atmosphere.

The licensee has made a regulatory commitment to develop contingency plans for obtaining and analyzing highly radioactive samples from the RCS, containment sump, and containment atmosphere. The licensee has committed to maintain the contingency plans within its emergency response plan or emergency plan implementing procedures. The licensee will implement this commitment with the implementation of this amendment which will be completed on or before December 1, 2001.

- 4.2 Each licensee should verify that it has, and make a regulatory commitment to maintain (or make a regulatory commitment to develop and maintain), a capability for classifying fuel damage events at the Alert level threshold (typically this is 300 $\mu\text{Ci/ml}$ dose equivalent iodine). This capability may utilize the normal sampling system and/or correlations of sampling or letdown line dose rates to coolant concentrations.

The licensee has made a regulatory commitment to develop a capability for classifying fuel damage events at the Alert level threshold. The licensee has committed to maintain the capability for the Alert classification within its emergency plan implementing procedures. The licensee will implement this commitment with the implementation of this amendment which will be completed on or before December 1, 2001.

- 4.3 Each licensee should verify that it has, and make a regulatory commitment to maintain (or make a regulatory commitment to develop and maintain), the capability to monitor radioactive iodines that have been released to offsite environs.

The licensee has verified that it has the capability to monitor radioactive iodines that have been released to offsite environs. The licensee has committed to maintain the capability for monitoring iodines within its emergency plan implementing procedures. The licensee has implemented this commitment.

The NRC staff finds that reasonable controls for the implementation and for subsequent evaluation of proposed changes pertaining to the above regulatory commitments are provided by the licensee's administrative processes, including its commitment management program. Should the licensee choose to incorporate a regulatory commitment into the emergency plan, final safety analysis report, or other document with established regulatory controls, the associated regulations would define the appropriate change-control and reporting requirements. The staff has determined that the commitments do not warrant the creation of regulatory requirements which would require prior NRC approval of subsequent changes. The NRC staff has agreed that NEI 99-04, Revision 0, "Guidelines for Managing NRC Commitment Changes," provides reasonable guidance for the control of regulatory commitments made to the NRC staff. (See Regulatory Issue Summary 2000-17, Managing Regulatory Commitments Made by Power Reactor Licensees to the NRC Staff, dated September 21, 2000.) The commitments should be controlled in accordance with the industry guidance or comparable criteria employed by a specific licensee. The staff may choose to verify the implementation and maintenance of these commitments in a future inspection or audit.

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Kansas State Official was notified of the proposed issuance of the amendment. The State official had no comments.

6.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involve no significant increase in the amounts and no

significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (66 FR 2026). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: William Reckley

Date: March 2, 2001