

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

March 1, 2001

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Serial No.: 01-129
NLOS/GDM R0
Docket No.: 50-280
License No.: DPR-32

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT 1
REVISION OF INSERVICE INSPECTION SUMMARY REPORT
FOR THE 2000 REFUELING OUTAGE

In a letter dated August 4, 2000 (Serial Number 00-359), Virginia Electric and Power Company (Dominion) provided the Inservice Inspection (ISI) Summary Report for the Surry Unit 1 2000 refueling outage. This report provided a summary of the examinations performed during the outage for the third inservice inspection interval. Subsequent to the submittal of the ISI Summary Report, we identified an additional completed Form NIS-2, "Owner's Report for Repairs or Replacements," that had been inadvertently omitted from the report. The form is attached and we request that you insert the attached page into the August 4, 2000 ISI Summary Report previously submitted.

We apologize for any inconvenience this may have caused. If you have any questions or require additional information, please do not hesitate to contact us.

Very truly yours,



L. N. Hartz
Vice President - Nuclear Engineering and Services

Attachment

Commitments made in this letter: None.

A047

cc: U. S. Nuclear Regulatory Commission Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23 T85
Atlanta, GA 30303-3415

Mr. R. A. Musser
NRC Senior Resident Inspector
North Anna Power Station

Mr. R. Smith
Authorized Nuclear Inspector
Surry Power Station

Surry Power Station Unit 1
Inservice Inspection Summary Report
2000 Refueling Outage
Additional NIS-2 Form

Dominion

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Virginia Electric & Power Company Date May 22, 2000
 Name _____
5000 Dominion Blvd., Glen Allen, VA 23060 Sheet 1 of 1
 Address _____

2. Plant Surry Power Station Unit: 1
 Name _____
5570 Hog Island Road, Surry, VA 23883 R/R-00-043 W.O.#00410274-01
 Address _____ Repair Organization P.O. No. Job No. , etc.

3. Work Performed By Virginia Electric & Power Company Type Code Symbol Stamp N/A
 Name _____ Authorization No. N/A
5000 Dominion Blvd., Glen Allen, VA 23060 Expiration Date N/A
 Address _____

4. Identification of System Residual Heat Removal

5. (a) Applicable Construction Code ANSI B31.1 1955 Edition, N/A Addenda, N-1 through N-13 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, Or Replacement	ASME Code Stamped (Yes or No)
6" Pipe	Energy & Process Corp.	Heat #444514	N/A	Mark #01-RH-DCP-99-021	N/A	Replacement	No
6" Gate Valve	Flowserve Corp.	Valve Serial # E915A-1-1	N/A	Mark #01-RH-DCP-99-021	N/A	Replacement	No
6" 90 Degree Elbow	Dubose National Energy Services	Heat 3445360 Trace # 14676	N/A	Mark #01-RH-DCP-99-021	N/A	Replacement	No

7. Description of Work Fabricate & Installed 6" Gate Valve and Piping / Code Case N-416-1 applies

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks P.O.45027060 (6"Pipe) P.O.45027317 (6"Gate Valve) P.O.45037873 (6' Elbow)
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NA

Certificate of Authorization No. NA Expiration Date NA

Signed D. L. Logan ISE Engineer Date 5/22 2000
Owner or Owner's Designee, Title 19-00

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Virginia and employed by HSBI and I Co. of Hartford, Ct. have inspected the components described in this Owner's Report during the period 3/8/00 to 1/05/01, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

D. L. Smith Commissions Va. 883 (R)
Inspector's Signature National Board, State, Province, and Endorsements

Date 1/05 to 2001