

2/10/00

Plugging NRR + Comm TA's on SEP:

Shouldn't insurance cost less if risk is less.

CT: → Release of large amount of Rx could have a substantial impact on the consequences.

TA1: Much better draft than June draft.

TA2: Fire in waste storage area?

NRR: We are having a contractor look at it.

MACCS safety Run:

Errors in inventory, DCFs, etc. ?

F1/24

TA3: Zr fire - 10 to 12 hours to get Zr fire.
Adiabatic heating?

Hubbard: No

TA3: Security -- how being dovetailed w/ Security Reengineering?

Barrett: I do not know.

TA3: Late decommissioning?
Early decommissioning?

Barrett: Late decommissioning is after 5 years.

TA4: ~~Do~~ industry + NRC have tools to analyze TH

Klabon: we are sending a user need to RES on this.
Industry has used CFD, and have not been
very successful.