

From: Jason Schaperow *JES*
To: "KNU@inel.gov"@GATED.nrcsmtp
Date: Fri, Feb 25, 2000 3:00 PM
Subject: Re: SCDAP/RELAP5 calculations of first fuel rod failure for BWR

Thank you.

Jason

>>> "Darrell L Knudson/KNU/CC01/INEEL/US" <KNU@inel.gov> 02/25 10:09 AM >>>

> What is the temperature of the cladding at the time of failure (152 sec)
> in the SCDAP/RELAP5 and FRAPCON-3 calculations of first fuel rod failure
> for BWR (Task 27)?

>
>
>
1210 K

CC: Charles Tinkler

F/27