

RO WRITTEN EXAM COMMENTS

Q #	U/E	COMMENT
2	U	Credible distractors for A, C, D?
3	E	A credible distractor?
6	U	B, D credible distractors?
9	E	B credible distractor?
11	E	1 or 2 pumps trip? All or lost FBV?
12	E	CET cues response. Add That increase to stem
13		Reference required?
14	E	Clarify time post-trip
16	U	Margin to SAT goes to zero - ans A. In order for superheat - core would have to be void of water
19	E	Reword C to state "vent RB via RB leak detector"
24	E	change "appropriate" to "procedure required"
25		Reference required?
35	E	Personnel "Air" Lock
36	E	Replace "most likely"
41	E	Curve needed?
46	E	Reword "most likely"
48	E	Reword "primary"
51	E	Can A or D cause B?
57	E	Spell out OPC "Overspeed Protection Controller"
60	U	Cues earlier question (#4) on condenser vacuum
65	E	"flowrates" versus "flows" in the stem
67	U	A, C, D credible distractors?
77	U	B, C, D credible distractors? (especially B!)
84	E	Technical Specification required? Direct lookup?
88	E	Technical Specification required? Direct lookup?
91	E	B credible distractor?
93	E	B spelling?
97	E	Technical Specification required? Direct lookup?
99	E	A credible distractor?

SRO WRITTEN EXAM COMMENTS

Q #	U/E	COMMENT
12	U	C, D credible distractors?
16	E	B only distractor with fire brigade in it?
21		Direct lookup if Technical Specification provided?
23	E	Avoid use of True / False and "NOT" in stem
26	E	In accordance with procedure ...
27	E	In accordance with procedure ...
47	E	from recall?
84	U	C, D credible distractors?
85	E	from recall?
86	U	A, C credible distractors?
96	U	B, C, D credible distractors? "A" is only ESF equipment.