herecg two Jart. dec Idaho National Engineering & Environmental Laboratory SPA". HRA Worksheet DRAFT 1/12/99 12/27/99 SPAR HRA Human Error Worksheet (Page 1 of 3) Best Case Initiating Event:_____ Sequence Number:_____Basic Event Code: HEP-RECG-FWSTART Plant: Basic Event Context: Basic Event Description: Does this task contain a significant amount of diagnosis activity? YES X (start with Part I, p. 1) NO (skip Part I, p. 1; start with Part II, p. 2) Why? Part I. DIAGNOSIS A. Evaluate PSFs for the diagnosis portion of the task. If non-nominal PSF levels are selected, please **PSF** Levels Multiplier for **PSFs** Diagnosis note specific reasons in this column P(failure) = 1.0Time is expansive due to leakage and boil off Available Time Inadequate time ratio. 10 Barely adequate time <20 min 1 Nominal time . 30 min Extra time >60 min 0.1 X Expansive time >24 hrs 0.01 5 Operator has had alarms, recognizes there is a Extreme Stress problem. X 2 High Nominal 1 5 Complexity Highly complex 2 Moderately complex 1 Nominal **Obvious** diagnosis 0.1 10 Assumes a highly trained staff. Experience/Training Low Nominal 1 x 0.5 High 50 Assumes procedures that are in diagnosis. Procedures Not available 5 Available, but poor Nominal 1 x 0.5 Diagnostic/symptom oriented 50 Ergonomics Missing/Misleading Assumes alarms for temperature and level. 10 Poor Nominal 1 X Good 0.5 Fitness for Duty Unfit P(failure) = 1.0Degraded Fitness 5 x ï Nominal 2 Assumes a crew and procedures that interact Work Processes Poor well in a good facility. X Nominal

SPAR HRA Worksheet DRAFT 1/12/99

B. Calculate the Diagnos	Good sis Failure Probability	0.8					
(1) If all PSF ratings are	nominal, then the Diag	nosis Failure Pi	robability = 10)E-2			
(2) Otherwise, Time	Stress Complexity	Experience/	Procedures	Ergonomics		Work Processes	•
Diagnosis: 10E-2x.01	x <u>2</u> x <u>1</u>	x <u>.5</u>	x <u>.5</u>	x <u>.5</u>	x <u>1</u>	x <u>.8</u>	= <u>2x10-5</u>

Diagnosis Failure Probability SPAR HRA Worksheet DRAFT 1/12/99

.

Idaho National Engineering & Environmental Laboratory

SPAR HRA Human Error Worksheet (Page 2 of 3) Best Case						
Plant: Initiat	ting Event: Sequer	nce Number:	Basic Event Code: <u>HEP-RECG-FWSTART</u>			
Basic Event Context			· · · · · · · · · · · · · · · · · · ·			
Basic Event Descript	tion:					
		Part II. AC	rion			
A. Evaluate PSFs for th PSFs	e action portion of the task. PSF Levels	Multiplier for Action	If non-nominal PSF levels are selected, please note specific reasons in this column			
Available Time	Inadequate time	P(failure) = 1.0				
	Time available . time required	10	•• 			
	Nominal time Time available>50 x time required	1				
Stress	Extreme High Nominal	5				
Complexity	Highly complex Moderately complex Nominal	5 2 1				
Experience/Training	Low Nominal High	3 1 0.5				
Procedures	Not available Available, but poor Nominal	50	····			
Ergonomics	Missing/Misleading Poor Nominal	50 10 1				
Fitness for Duty	Good Unfit	0.5 P(failure) = 1.0				
	Degraded Fitness Nominal	5	····			
Work Processes	Poor Nominal Good	5 1 0.5	····			

B. Calculate the Action Failure Probability

(1) If all PSF ratings are nominal, then the Action Failure Probability = 10E-3

SFAV, HRA Worksheet DRAFT 1/12/99

(2) Otherwise,	Time	Stress	Complexity	Experience/ Training	Procedures			Work Processes		
Action: 10E-3	x	x	x	x	x	x	x	x	= Action Failure Probability	

SPAR HRA Humar	Error Worksheet	(Page 3 of 3)	Best Case
----------------	-----------------	---------------	-----------

Plant:____

Initiating Event:_____ Sequence Number:_____Basic Event Code: HEP- RECG-FWSTART____

PART III. CALCULATE THE TASK FAILURE PROBABILITY WITHOUT FORMAL DEPENDENCE (Pw/op)

Calculate the Task Failure Probability Without Formal Dependence $(P_{w/od})$ by adding the Diagnosis Failure Probability (from Part I, p.1) and the Action Failure Probability (from Part II, p. 2).

	If all PSFs are nomina	If all PSFs are nominal, then		
Diagnosis Failure Probability: _	Diagnosis Failure Probability:	10E-2		
Action Failure Probability: +_	Action Failure Probability:	<u>+10E-3</u>		
Task Failure Without Formal Dependence (P _{w/od}) =_	P _(w/od)	= 1.1x10E-2		

Part IV. DEPENDENCY

For all tasks, except the first task in the sequence, use the table and formulae below to calculate the Task Failure Probability With Formal Dependence (P_{wd}).

If there is a reason why failure on previous tasks should not be considered, explain here:

		D	ependency (Condition Ta	
Crew (same or	Time (close in	Location (same or	Cues (additional or	Dependency	Number of Human Action Failures Rule
different)	time or not close in time	different)	not additional)		- Not Applicable. Why?
Same	Close	Same	-	complete	If this error is the 3rd error in the sequence , then the dependency is at least moderate .
					If this error is the 4th error in the sequence, then the dependency is at least high.
					This rule may be ignored only if there is compelling evidence for less dependence with the previous tasks. Explain above.
		Different	-	high	•
	Not Close	Same	No Additional	high	•
			Additional	moderate	
		Different	No Additional	moderate	
			Additional	low	-
Different	Close	-	-	moderate	• •
	Not Close	-	-	low	

Using P_{w/od} = Probability of Task Failure Without Formal Dependence (calculated in Part III, p. 3):

For Complete Dependence the probability of failure is 1.

For High Dependence the probability of failure is $(1 + P_{w/od})/2$ For Moderate Dependence the probability of failure is $(1+6 \times P_{w/od})/7$ For Low Dependence the probability of failure is $(1+19 \times P_{w/od})/20$ For Zero Dependence the probability of failure is $P_{w/od}$

Calculate $P_{w/d}$ using the appropriate values:

(1 + (*))/ = Task Failure Probability With Formal Dependence (P_{wd})