1 Idaho National Engineering & Environmental Laboratory

SPAR HRA Human Error Worksheet (Page 1 of 3) Best Case

Plant: Initiating Event:		quence Number:	Basic Event Code: HEP-SFP-STRLPI
Basic Event Co	ntext:		
Basic Event De	scription:		
Does this task con 2) Why?	tain a significant amount of di	-	(start with Part I, p. 1) NO X (skip Part I, p. 1; start with Part II, p.
		DI DIAGNO	2010
A Evaluata DCEs	for the diagnosis portion of th	Part I. DIAGNO	7515
PSFs.	PSF Levels	Multiplier for Diagnosis	If non-nominal PSF levels are selected, please note specific reasons in this column
Available Time	Inadequate time	P(failure) = 1.0	
	Barely adequate time		
	Fytra time >60 min	min 1	
	Expansive time >24	0.1 hrs 0.01	•••••
Stress	Evtreme	5	
	High	2	
	Nominal	1	••••
Complexity	Highly complex	5	
	Moderately complex	2	••••
		1	
	Obvious diagnosis	0.1	
Experience/Training	***************************************	10	••••
	Nominal	1	•••••
	High	0.5	
Procedures	Not available	50	•••••
	Available, but poor Nominal	1	••••
	Diagnostic/symptom	0.5	·····
	oriented		
Ergonomics	Missing/Misleading	50	=
	Poor	10	·····
	Nominal	1	••••
	Good	0.5	· · · · · · · · · · · · · · · · · · ·
Fitness for Duty	Unfit	P(failure) = 1.0	
	Degraded Fitness	5	••••
	Nominal	1	······
Work Processes	Poor	2	
	Nominal	1	·····
	Good	0.8	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
B Calculate the D	Diagnosis Failure Probability		Υ Σ ^ν

(1) If all PSF ratings are nominal, then the Diagnosis Failure Probability = 10E-2

Diagnosis Failure Probability

SPAR HRA Human Error Worksheet (Page 2 of 3) Best Case

Plant: Initia	ting Event: Sequer	nce Number:	Basic Event Code: HEP-SFP-STRLPI
Basic Event Context	:		
Basic Event Descrip	tion:		
A. Freshina DCFs for th	a action mortion of the took	Part II. AC	TION
PSFs	PSF Levels	Multiplier for Action	If non-nominal PSF levels are selected, please note specific reasons in this column
Available Time	Inadequate time	P(failure) = 1.0	Time more than sufficient due to boil off and leakage ratios.
	Time available ≈ time required Nominal time	10	•• ••
	Time available>50 x time required	0.01 X	
Stress	Extreme High Nominal	5 2 X 1	Stress high, failure has occurred.
Complexity	Highly complex Moderately complex Nominal	5 2 X 1	May involve valve lineup.
Experience/Training	Low Nominal High	3 1 0.5 X	Highly trained staff.
Procedures	Not available Available, but poor Nominal	50 5 1 X	
Ergonomics	Missing/Misleading	50	Well laid out and labeled controls and valves matched to procedures.
	Poor Nominal Good	10 1 0.5 X	•••
Fitness for Duty	Unfit	P(failure) = 1.0	
	Degraded Fitness Nominal	5 1 X	•••
Work Processes	Poor	5	Crew and procedures that interact well in a good facility.
	Nominal Good	1 0.5 X	

- B. Calculate the Action Failure Probability
- (1) If all PSF ratings are nominal, then the Action Failure Probability = 10E-3

(2) Otherwise,	Time	Stress	Complexity	Experience/ Training	Procedures	Ergonomics		Work Processes	
Action: 10E-3	x <u>.01</u>	x <u>2</u>	x <u>2</u>	x <u>.5</u>	x <u>1</u>	x <u>.5</u>	x <u>1</u>	x <u>.5</u>	= <u>5E-6</u> Action Failure Probability

SPAR HRA Human Error Worksheet (Page 3 of 3) Best Case

Plant: initiating b	:vent:	Sequence NumberBasic Event Code. ner-or-or	TINET I			
PART III. CALCULA	FE THE TA	ASK FAILURE PROBABILITY WITHOUT FORMAL D $(P_{W/OD})$	EPENDENCE			
Calculate the Task Failure Prop. 1) and the Action Failure Prop. 1		hout Formal Dependence ($P_{w/od}$) by adding the Diagnosis Failure Probabom Part II, p. 2).	ility (from Part I,			
If all PSFs are nominal, then						
Diagnosis Failure Probability:		Diagnosis Failure Probability:	10E-2			
Action Failure Probability:	+	Action Failure Probability:	<u>+10E-3</u>			
Task Failure Without Formal Dependence (P _{w/od})	=	P _(w/od)	= 1.1x10E-2			
		Part IV. DEPENDENCY				
For all tasks, except the first tandard Dependence (P_{wd}) .	ask in the seq	quence, use the table and formulae below to calculate the Task Failure P	robability With			
If there is a reason why failure	on previous	s tasks should not be considered, explain here:				
		Dependency Condition Table				

Crew (same or different)	Time (close in time or not close in time	Location (same or different)	Cues (additional or not additional)	Dependency	Number of Human Action Failures Rule - Not Applicable. Why?
Same	Close	Same	-	complete	If this error is the 3rd error in the sequence, then the dependency is at least moderate.
			-		If this error is the 4th error in the sequence, then the dependency is at least high.
					This rule may be ignored only if there is compelling evidence for less dependence with the previous tasks. Explain above.
		Different	-	high	•
	Not Close	Same	No Additional	high	•
			Additional	moderate	·
		Different	No Additional	moderate	
		7 h 0 0 0	Additional	low	·
Different	Close		-	moderate	
	Not Close	-	-	low	-

Using $P_{w/od}$ = Probability of Task Failure Without Formal Dependence (calculated in Part III, p. 3):

For Complete Dependence the probability of failure is 1.

For High Dependence the probability of failure is $(1 + P_{w/od})/2$

For Moderate Dependence the probability of failure is $(1+6 \times P_{w/od})/7$

For Low Dependence the probability of failure is $(1+19 \times P_{w/od})/20$

For Zero Dependence the probability of failure is $P_{\mbox{\tiny w/od}}$

Calculate $P_{w/d}$ using the appropriate values:

(1 + (*))/ = Task Failure Probability With Formal Dependence (P_{wd})