



Nebraska Public Power District
Nebraska's Energy Leader

NLS2001026
March 7, 2001

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Core Operating Limits Report, Cycle 20, Revision 1
Cooper Nuclear Station
NRC Docket No. 50-298, DPR-46


Reference: Letter NLS2000046 to U.S. Nuclear Regulatory Commission from J. H. Swailes (Nebraska Public Power District) dated April 18, 2000, "Core Operating Limits Report, Cooper Nuclear Station, NRC Docket 50-298, DPR-46."

Gentlemen:

By letter dated April 18, 2000 (Reference), the Nebraska Public Power District (District) submitted the Core Operating Limits Report (COLR) for Cycle 20 operation at Cooper Nuclear Station. Since that submittal our fuel vendor has derived improved generic thermal-mechanical limits for the GE9B product line. The new generic thermal-mechanical limits for the GE9B fuel will provide additional operating margin for the GE9B fuel. The generic limits change some of the Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) limits of the GE9B fuel shown in the Cycle 20 Core Operating Limits Report Revision 0 (Reference). The COLR is being revised to update the MAPLGHRs for the GE9B fuel to the new generic values.

Should you have any questions regarding this matter, please contact Michael Boyce at (402) 825-5100.

Sincerely,



John H. Swailes
Vice President of Nuclear Energy

/cb

Attachment

A001

NLS2001026
March 7, 2001
page 2 of 2

cc: Regional Administrator w/attachment
USNRC Region IV

Senior Project Manager w/attachment
USNRC - NRR Project Directorate IV-1

Senior Resident Inspector w/attachment
USNRC

NPG Distribution w/o attachment

Records w/attachment

COOPER NUCLEAR STATION

CORE OPERATING LIMITS REPORT

Cycle 20
Revision 1

CORE OPERATING LIMITS REPORT

Table of Contents

List of Figures	ii
Signature Page	1
1.0 Introduction	2
2.0 Core Operating Limits	2
2.1 Rod Block Monitor Upscale Set Point	2
2.2 Average Planar Linear Heat Generation Limits	3
2.3 Linear Heat Generation Rate Limit	3
2.4 Minimum Critical Power Ratio Limits	3-4
2.5 Power to Flow Map	4-5
3.0 References.....	6

CORE OPERATING LIMITS REPORT

List of Figures

<u>Number</u>	<u>Title</u>	<u>Page</u>
1	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with LPCI Modification and Bypass Holes Plugged, 3.50 w/o with 10GZ GE8x8NB Fuel	7
2	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with LPCI Modification and Bypass Holes Plugged, 3.50 w/o with 10GZ1 GE8x8NB Fuel	8
3	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with LPCI Modification and Bypass Holes Plugged 3.48 w/o with 11GZ GE8x8NB Fuel	9
4	Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with LPCI Modification and Bypass Holes Plugged 3.85 w/o with 14GZ GE14 Fuel	10
5	Flow Dependent MAPLHGR Factor ($MAPFAC_F$)	11
6	Power Dependent MAPLHGR Factor ($MAPFAC_P$)	12
7	Power Dependent MCPR Limits, $MCPR_P$ and K_P	13
8	Flow Dependent MCPR Limits, $MCPR_F$	14
9,10	Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE8x8NB Fuel (various exposure ranges)	15, 16
11	Minimum Critical Power Ratio (MCPR) versus Tau with One Turbine Bypass Valve Unavailable (based on tested measured scram time as defined in Reference 4), GE8x8NB Fuel	17
12,13	Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE14 Fuel (various exposure ranges)	18, 19
14	Minimum Critical Power Ratio (MCPR) versus Tau with One Turbine Bypass Valve Unavailable (based on tested measured scram time as defined in Reference 4), GE14 Fuel	20
15	CNS Power/Flow Map	21

Signature Page

Revision 1

Preparer:

Eric K Rockett
Print

Eric K Rockett 1/30/01
Sign/Date

Reviewer:

Paul Ballinger
Print

Paul Ballinger 2/13/01
Sign/Date

RE Manager:

Jerry L. Lewis
Print

Jerry L. Lewis 3 Mar 01
Sign/Date

1.0 INTRODUCTION

The Core Operating Limits Report provides the limits for operation of the Cooper Nuclear Station for Cycle 20. It includes the limits for the Rod Block Monitor Upscale Set Point, Average Planar Linear Heat Generation Rate (APLHGR), and Minimum Critical Power Ratio (MCPR). If any of these limits is exceeded, action will be taken as defined in the Technical Specifications.

The core operating limit values have been determined using the NRC-approved methodologies given in References 1, 2, 10, and 11 and have been established such that all applicable plant safety analysis limits are met.

2.0 CORE OPERATING LIMITS

Cooper Nuclear Station shall operate within the bounds of the below limits/values. The applicable Technical Specifications are referenced in each subsection.

2.1 Rod Block Monitor Upscale Set Point

The Technical Specifications reflect a reference to Allowable Values for the Rod Block Monitor (RBM) upscale (power referenced) trip level setting, found in Reference 9, are as follows:

<u>Lowest Rated MCPR Limit</u>	<u>Low Trip Set Point (LTSP)</u> (LPSP ≤ P ≤ IPSP)	<u>Intermed Trip Set Point (ITSP)</u> (IPSP < P ≤ HPSP)	<u>High Trip Set Point (HTSP)</u> (HPSP < P)
≥ 1.20	≤ 114.0/125	≤ 108.5/125	≤ 104.5/125
≥ 1.25	≤ 117.0/125	≤ 112.5/125	≤ 107.5/125
≥ 1.30	≤ 120.0/125	≤ 115.0/125	≤ 110.5/125

LPSP, IPSP, and HPSP are the Low Power Set Point, Intermediate Power Set Point, and High Power Set Point, respectively.

The trip level settings associated with this MCPR limit have been generically calculated and verified to bound the Rod Withdrawal Error Analysis for Cycle 20 operation.

Technical Specification Reference: 3.3.2.1

2.2 Average Planar Linear Heat Generation Limits

The most limiting lattice APLHGR value (excluding natural uranium) for each fuel bundle as a function of Planar Average Exposure, core power, and core flow is calculated by multiplying the value from Figures 1, 2, 3, and 4 by the smaller of the MAPLHGR Flow Factor, $MAPFAC_F$ (Figure 5) or the Power-Dependent MAPLHGR Factor, $MAPFAC_P$, (Figure 6). APLHGR values determined with the SAFER/GESTR-LOCA methodology are given in References 2, 3, and 5 while $MAPFAC_F$ and $MAPFAC_P$ were determined in Reference 8.

The calculated maximum APLHGR (MAPLHGR) limits in Figures 1, 2, 3, and 4 are conservative values bounding all fuel lattice types (excluding natural uranium) in a given fuel bundle design. MAPLHGR limits for each individual fuel lattice design in a bundle design, as a function of axial location and average planar exposure, are determined based on the approved methodology referenced in Technical Specification 5.6.5 and loaded in the process computer for use in core monitoring calculations. The MAPLHGR values for these lattices, along with the axial location of each lattice in the bundle, are considered proprietary information by General Electric and are given in Reference 3 as a function of planar average exposure.

The MAPLHGR limits referred to above are for two recirculation loop operations. For single loop operation, the limiting APLHGR value is multiplied by 0.77 for GE8x8 NB fuel (as can be found in Reference 5) and by 0.85 for GE14 fuel (as can be found in Reference 5).

Technical Specification Reference: 3.2.1 and 3.4.1

2.3 Linear Heat Generation Rate Limit

The limiting power density and maximum allowable Linear Heat Generation Rate (LHGR) referred to in Technical Requirements Manual Section T 3.2.1 is the design LHGR. The design LHGR for fuel type GE 8x8 NB is 14.4 kW/ft as found in Reference 12. The design LHGR for fuel type GE14 is 13.4 kW/ft as found in Reference 13.

2.4 Minimum Critical Power Ratio Limits

The operating limit MCPR (OLMCPR) values are a function of core thermal power, core flow, fuel bundle, scram time (τ), and fuel exposure. The scram time (τ) is determined from CNS Procedure 10.9, Control Rod Scram Time Evaluation. The OLMCPR values are as follows:

For core thermal power ≥ 25 percent and <30 percent of rated power, the OLMCPR is the power dependent MCPR ($MCPR_P$) from Figure 7.

For core thermal power ≥ 30 percent of rated power, the OLMCPR is the greater of either:

The applicable flow dependent MCPR ($MCPR_F$) determined from Figure 8, or

The appropriate scram time (τ) dependent MCPR at rated power from Figures 9, 10, 12, and 13, multiplied by the applicable power dependent MCPR multiplier (K_P) from Figure 7.

The appropriate scram time (τ) dependent MCPR at rated power with One Turbine Bypass Valve Unavailable is shown in Figures 11 and 14.

The system response time for the Turbine Bypass System to be at 80% of rated bypass flow is 0.3 seconds.

For single recirculation loop operation, the OLMCPR is 0.01 greater than the two recirculation loop operation OLMCPR.

Technical Specification References: 3.2.2, 3.4.1 and 3.7.7

2.5 Power/Flow Map

The power/flow map defining the Stability Exclusion Region can be found as Figure 15. References 5 and 6 reflect the documents describing the current Cooper Nuclear Station power/flow map. The Stability Exclusion Region boundary is given by the equation

$$P = P_B \left(\frac{P_A}{P_B} \right)^{\frac{1}{2} \left[\frac{W - W_B}{W_A - W_B} + \left(\frac{W - W_B}{W_A - W_B} \right)^2 \right]}$$

where,

P = a core thermal power value on the region boundary (% of rated),

W = the core flow rate corresponding to power, P , on the region boundary (% of rated),

P_A = core thermal power at point A (% of rated),

P_B = core thermal power at point B (% of rated),

W_A = core flow rate at point A (% of rated), and
 W_B = core flow rate at point B (% of rated).

Technical Specification Reference: 3.4.1


3.0 REFERENCES

1. NEDE-24011-P-A-13-US, August 1996, *General Electric Standard Application for Reactor Fuel*. (The approved revision at the time the reload analyses were performed.)
2. NEDC-32687P, Revision 1, March 1997, *Cooper Nuclear Station SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis*.
3. *Lattice Dependent MAPLHGR Report for Cooper Nuclear Station Reload 19, Cycle 20*, J11-03650-10M, Revision 0.
4. Letter (with attachment), R.H. Buckholz (GE) to P.S. Check (NRC) dated September 5, 1980, *Response to NRC Request for Information on ODYN Computer Model*.
5. *Supplemental Reload Licensing Report for Cooper Nuclear Station Reload 19, Cycle 20*, J11-03650-10, Revision 0.
6. GENE-A13-00395-01, Class I, November, 1996, *Application of the "Regional Exclusion with Flow-Biased APRM Neutron Flux Scram" Stability Solution (Option 1-D) to the Cooper Nuclear Station, Licensing Topical Report*.
7. Letter from James R. Hall (NRC) to G. R. Horn (NPPD) dated September 23, 1997, *Approval of SAFER/GESTAR LOCA Analysis for Cooper Nuclear Station (TAC NO. M98293.)*
8. GE-NE-L12-00867-12, *Cooper Nuclear Station MIG Project Task 900: Transient Analysis*, Revision 0, December 1999.
9. NEDC 98-024, Revision 2, December 1999, *APRM - RBM Setpoint Calculation*.
10. NEDO-31960-A and NEDO-31960-A Supplement 1, *BWR Owner's Group Long-Term Stability Solutions Licensing Methodology*. (The approved revision at the time the reload analysis is performed.)
11. NEDE-23785-1-P-A, *The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident*, Volume III, Revision 1, October 1984.
12. *Nuclear Design Report for Cooper Nuclear Station Reload, 18*, J11-03354-03, July 1998.
13. GE-NE-L12-00867-09-01, *Cooper Nuclear Station MIG Project Task 407: SAFER/GESTR Analysis*, December 1999.
14. Letter from S. Shelton (GNF) to J.L. Lewis (NPPD) dated December 21, 2000, *GE9B LHGR Relaxation for Cooper Nuclear Station*.

CORE OPERATING LIMITS REPORT

Figure 1

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus
Exposure with LPCI Modification and Bypass Holes Plugged, 3.50 w/o with 10GZ
GE8x8NB Fuel




DATA COORDINATES (Reference 14)

Planar Average Exposure (GWD/ST)	MAPLHGR (kW/ft)
0.0	11.59
0.2	11.63
1.0	11.71
2.0	11.85
3.0	12.00
4.0	12.13
5.0	12.26
6.0	12.38
7.0	12.52
8.0	12.65
9.0	12.80
10.0	12.84
12.5	12.81
13.24	12.72
15.0	12.52
20.0	11.78
25.0	11.09
27.22	10.96
35.0	10.53
45.0	9.54
48.08	8.24
54.02	5.74

CORE OPERATING LIMITS REPORT

Figure 2

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus
Exposure with LPCI Modification and Bypass Holes Plugged, 3.50 w/o with
10GZ1 GE8x8NB Fuel




DATA COORDINATES (Reference 14)

Planar Average Exposure (GWD/ST)	MAPLHGR (kW/ft)
0.0	11.59
0.2	11.63
1.0	11.71
2.0	11.84
3.0	11.99
4.0	12.14
5.0	12.26
6.0	12.39
7.0	12.53
8.0	12.66
9.0	12.81
10.0	12.85
12.5	12.79
13.24	12.71
15.0	12.51
20.0	11.78
25.0	11.08
27.22	10.96
35.0	10.53
45.0	9.51
48.08	8.21
54.00	5.75

CORE OPERATING LIMITS REPORT

Figure 3

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with
LPCI Modification and Bypass Holes Plugged, 3.48 w/o with 11GZ GE8x8NB Fuel




DATA COORDINATES (Reference 14)

<u>Planar Average Exposure</u> (GWD/ST)	<u>MAPLHGR</u> (kW/ft)
0.0	10.85
0.2	10.90
1.0	11.01
2.0	11.17
3.0	11.36
4.0	11.56
5.0	11.76
6.0	11.91
7.0	12.07
8.0	12.23
9.0	12.38
10.0	12.48
12.5	12.61
13.24	12.57
15.0	12.47
20.0	11.79
25.0	11.11
27.22	10.98
35.0	10.49
45.0	9.43
48.08	8.13
53.87	5.70

CORE OPERATING LIMITS REPORT

Figure 4

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) versus Exposure with LPCI Modification and Bypass Holes Plugged, 3.85 w/o with 14GZ GE14 Fuel



DATA COORDINATES (Reference 3)

Planar Average Exposure (GWD/ST)	MAPLHGR (kW/ft)
0.0	8.57
0.2	8.65
1.0	8.79
2.0	9.01
3.0	9.22
4.0	9.42
5.0	9.54
6.0	9.65
7.0	9.72
8.0	9.79
9.0	9.86
10.0	9.93
11.0	10.01
12.0	10.10
13.0	10.20
14.0	10.30
15.0	10.39
17.0	10.54
20.0	10.45
25.0	10.05
30.0	9.63
35.0	9.18
40.0	8.69
45.0	8.13
50.0	7.50
55.0	6.84
56.86	6.58

CORE OPERATING LIMITS REPORT


Figure 5

Reference 8

Figure 3-11

Cooper Nuclear Station

Flow-Dependent MAPLHGR Factor, MAPFAC(f)




CORE OPERATING LIMITS REPORT

Figure 6

Reference 8

Figure 3-9
Cooper Nuclear Station
Power-Dependent MAPLHGR Factor MAPFAC(p)




CORE OPERATING LIMITS REPORT

Figure 7

Reference 8

Figure 3-8
Cooper Nuclear Station
Power-Dependent MCPR Limits, Kp and MCPRp




CORE OPERATING LIMITS REPORT

Figure 8

Reference 8


Figure 3-10
Cooper Nuclear Station
Flow-Dependent MCPR Limits, MCPR(f)



CORE OPERATING LIMITS REPORT

Figure 9

Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE8X8NB Fuel




Exposure range: BOC20 to EHFP20 - 2205 MWd/MT

CORE OPERATING LIMITS REPORT

Figure 10

Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE8X8NB Fuel




Exposure range: EHFP20 - 2205 MWd/MT to EOC20

CORE OPERATING LIMITS REPORT

Figure 11

Minimum Critical Power Ratio (MCPR) versus Tau with One Turbine Bypass Valve Unavailable
(based on tested measured scram time as defined in Reference 4), GE8X8NB Fuel




Exposure range: BOC20 to EOC20

CORE OPERATING LIMITS REPORT

Figure 12

Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE14 Fuel




Exposure range: BOC20 to EHFP20 - 2205 MWd/MT

CORE OPERATING LIMITS REPORT

Figure 13

Minimum Critical Power Ratio (MCPR) versus Tau (based on tested measured scram time as defined in Reference 4), GE14 Fuel




Exposure range: EHFP20 - 2205 MWd/MT to EOC20

CORE OPERATING LIMITS REPORT

Figure 14

Minimum Critical Power Ratio (MCPR) versus Tau with One Turbine Bypass Valve Unavailable
(based on tested measured scram time as defined in Reference 4), GE14 Fuel




Exposure range: BOC20 to EOC20

CORE OPERATING LIMITS REPORT

Figure 15

Power to Flow Map



Exclusion Region Endpoints

Point A	70.9% rated power	43.2% rated flow
Point B	41.0% rated power	32.5% rated flow

ATTACHMENT 3 LIST OF NRC COMMITMENTS

Correspondence Number: NLS2001026

The following table identifies those actions committed to by the District in this document. Any other actions discussed in the submittal represent intended or planned actions by the District. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the NL&S Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

COMMITMENT	COMMITTED DATE OR OUTAGE
None	