SCHWSTART. doc Idaho National Engineering & Environmental Laboratory

SPAR HRA Human Error Worksheet (Page 1 of 3) Sensitivity Case

Plant: Init	iating Event: Sequence	Number:	Basic Event Code: <u>HEP-FW-START</u>
Basic Event Conte	xt:		
Basic Event Descr	iption:		
Does this task contain Why?	a significant amount of diagnosis	activity? YES (s	tart with Part I, p. 1) NO (skip Part I, p. 1; start with Part II, p. 2)
	Pa	art I. DIAGNO	sis
A. Evaluate PSFs for	the diagnosis portion of the task.		
PSFs	PSF Levels	Multiplier for Diagnosis	If non-nominal PSF levels are selected, please note specific reasons in this column
Available Time	Inadequate time	P(failure) = 1.0	
	Barely adequate time <20 min	10	
	Nominal time ≈ _30 min		
	Extra time >60 min	0.1	
	Expansive time >24 hrs	0.01	
Stress	Extreme	5	•••
	High	2	···
	Nominal	1	
Complexity	Highly complex	5	···
	Moderately complex	2	
	Nominal	1	······································
	Obvious diagnosis	0.1	w
Experience/Training	Low	10	
	Nominal	1	•••
	High	0.5	
Procedures	Not available	50	•••
	Available, but poor Nominal	1	
	Nominal Diagnostic/symptom		•••
	oriented		_
Ergonomics	Missing/Misleading	50	
	Poor	10	•••
	Nominal	1	
	Good	0.5	
Fitness for Duty	Unfit	P(failure) = 1.0	
	Degraded Fitness	5	···
	Nominal	1	
Work Processes	Poor	2	
	Nominal	1	···
	Good	0.8	. 2
B. Calculate the Diag	gnosis Failure Probability		4/3

í	11	If all PSF	ratings are	nominal.	then the	Diagnosis	Failure	Probability =	10E-2
٦		II all I SI	I dillings unv	- mommu,	uicii uic	DIUZIIOSIS	Lanuic	110000111119	1022

(2) Otherwise, Time Stress Complexity Experience/ Procedures Ergonomics Fitness Work
Training for Duty Processes

Diagnosis: 10E-2x___ x__ x__ x__ x__ x__ x__ x__ Diagnosis
Failure Probability

SPAR HRA Human Error Worksheet (Page 2 of 3) Sensitivity Case

Plant: Initiati	ng Event: Seque	nce Number:	Basic Event Code: <u>HEP-FW-START</u>
Basic Event Context:			
Basic Event Descripti	on:	<u></u>	
•		Part II. AC	CTION
A. Evaluate PSFs for the PSFs	action portion of the task. PSF Levels	Multiplier for Action	If non-nominal PSF levels are selected, please note specific reasons in this column
Available Time	Inadequate time	P(failure) = 1.0	Time expansive due to boil off and leakage ratio.
	Time available ≈ time required	10	
	Nominal time Time available>50 x time required	0.01 X	
Stress	Extreme High Nominal	5 2 X 1	
Complexity	Highly complex Moderately complex Nominal	5 X 2	Requires multiple steps.
Experience/Training	Low Nominal High	3 1 0.5 X	No training.
Procedures	Not available Available, but poor Nominal	50 X 5	No procedures.
Ergonomics	Missing/Misleading Poor Nominal Good	50 10 1 X 0.5	
Fitness for Duty	Unfit Degraded Fitness	P(failure) = 1.0	••••
	Nominal	1 X	
Work Processes	Poor Nominal Good	5 1 X 0.5	

- B. Calculate the Action Failure Probability
- (1) If all PSF ratings are nominal, then the Action Failure Probability = 10E-3
- (2) Otherwise, Time Stress Complexity Experience/ Procedures Ergonomics Fitness Work
 Training for Duty Processes

Action: 10E-3 x.01 x2 x5

х<u>З</u>

x<u>50</u>

x<u>1</u>

x<u>1</u>

x<u>1</u>

=<u>.15</u> Action

Failure Probability

SPAR HRA Human Error Worksheet (Page 3 of 3) Sensitivity Case

Plant:	Initiating Eve	ent: Seq	uence Number	r:Basic Event Code: <u>HEP-FW-START_</u>		
PART III. CALCULATE THE TASK FAILURE PROBABILITY WITHOUT FORMAL DEPENDENCE ($P_{W/\text{OD}}$)						
Calculate the Task Failure Probability Without Formal Dependence ($P_{w/od}$) by adding the Diagnosis Failure Probability (from Part I, p. 1) and the Action Failure Probability (from Part II, p. 2).						
				If all PSFs are nominal, then		
Diagnosis Failu	re Probability:			Diagnosis Failure Probability: 10E-2		
Action Failure	Probability: +	.15		Action Failure Probability: <u>+10E-3</u>		
Task Failure W Formal Depend	ithout lence (P _{w/od}) =	.15		$P_{(w/cd)} = 1.1x10E-2$		
		·	Part IV. DE	EPENDENCY		
For all tasks, except the first task in the sequence, use the table and formulae below to calculate the Task Failure Probability With Formal Dependence (P_{wd}).						
If there is a reason why failure on previous tasks should not be considered, explain here:						
Dependency Condition Table						
Crew (same or	Time (close in	Location (same or	Cues (additional or	Dependency Number of Human Action Failures Rule - Not Applicable, Why?		

Dependency Condition 14210					
Crew	Time	Location	Cues	Dependency	Number of Human Action Failures Rule
(same or different)	(close in time or not close in time	(same or different)	(additional or not additional)		- Not Applicable. Why?
Same	Close	Same	-	complete	If this error is the 3rd error in the sequence, then the dependency is at least moderate.
					If this error is the 4th error in the sequence, then the dependency is at least high.
					This rule may be ignored only if there is compelling evidence for less dependence with the previous tasks. Explain above.
		Different	<u></u>	high	•
	Not Close	Same	No Additional Additional	high moderate	• •
		Different	No Additional Additional	moderate low	• •
Different	Close	<u> </u>	-	moderate	
	Not Close	*	-	low	•

Using $P_{w/od}$ = Probability of Task Failure Without Formal Dependence (calculated in Part III, p. 3):

For Complete Dependence the probability of failure is 1.

For High Dependence the probability of failure is $(1 + P_{w/od})/2$

For Moderate Dependence the probability of failure is (1+6 x P_{w/od})/7

For Low Dependence the probability of failure is $(1+19 \times P_{w/od})/20$

For Zero Dependence the probability of failure is $P_{\text{w/od}}$

Calculate $P_{\text{\tiny w/d}}$ using the appropriate values:

(1 + (*))/ = Task Failure Probability With Formal Dependence (P_{wd})