



A Subsidiary of RGS Energy Group, Inc.

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001 • 716-771-3250

www.rge.com

JOSEPH A. WIDAY
VICE PRESIDENT & PLANT MANAGER
GINNA STATION

February 28, 2001


U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I
Washington, D.C. 20555

Subject: Emergency Operating Procedures
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

As requested, enclosed are Ginna Station Emergency Operating Procedures.

Very truly yours,


Joseph A. Widay

JAW/jdw

xc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Ginna USNRC Senior Resident Inspector

Enclosure(s):

E Index
ECA Index
FIG Index
E-1, Rev 21
E-3, Rev 27
ECA-3.3, Rev 24
FIG-4.0, Rev 2

AL02

REPORT NO. 01
REPORT: NPSP0200
DOC TYPE: PRE

GINNA NUCLEAR POWER PLANT
PROCEDURES INDEX
EMERGENCY PROCEDURE

02/28/01 PAGE: 1

PARAMETERS: DOC TYPES - PRE PRECA PRFIG STATUS: EF QU 5 YEARS ONLY:

PROCEDURE NUMBER	PROCEDURE TITLE	REV	EFFECT DATE	LAST REVIEW	NEXT REVIEW	ST
E-0	REACTOR TRIP OR SAFETY INJECTION	027	05/18/00	05/01/98	05/01/03	EF
E-1	LOSS OF REACTOR OR SECONDARY COOLANT	021	02/28/01	05/01/98	05/01/03	EF
E-2	FAULTED STEAM GENERATOR ISOLATION	009	12/20/00	05/01/98	05/01/03	EF
E-3	STEAM GENERATOR TUBE RUPTURE	027	02/28/01	05/01/98	05/01/03	EF
TOTAL FOR PRE	4					

REPORT NO. 01
REPORT: NPSPO200
DOC TYPE: PRECA

GINNA NUCLEAR POWER PLANT
PROCEDURES INDEX
EMERGENCY CONTINGENCY ACTIONS PROC

02/28/01 PAGE: 2

PARAMETERS: DOC TYPES - PRE PRECA PRFIG STATUS: EF QU 5 YEARS ONLY:

PROCEDURE NUMBER	PROCEDURE TITLE	REV	EFFECT DATE	LAST REVIEW	NEXT REVIEW	ST
ECA-0.0	LOSS OF ALL AC POWER	022	05/18/00	05/01/98	05/01/03	EF
ECA-0.1	LOSS OF ALL AC POWER RECOVERY WITHOUT SI REQUIRED	017	12/02/99	05/01/98	05/01/03	EF
ECA-0.2	LOSS OF ALL AC POWER RECOVERY WITH SI REQUIRED	012	10/18/99	05/01/98	05/01/03	EF
ECA-1.1	LOSS OF EMERGENCY COOLANT RECIRCULATION	018	12/02/99	05/01/98	05/01/03	EF
ECA-1.2	LOCA OUTSIDE CONTAINMENT	005	05/01/98	05/01/98	05/01/03	EF
ECA-2.1	UNCONTROLLED DEPRESSURIZATION OF BOTH STEAM GENERATORS	020	03/31/00	05/01/98	05/01/03	EF
ECA-3.1	SGTR WITH LOSS OF REACTOR COOLANT SUBCOOLED RECOVERY DESIRED	019	03/31/00	05/01/98	05/01/03	EF
ECA-3.2	SGTR WITH LOSS OF REACTOR COOLANT SATURATED RECOVERY DESIRED	022	03/31/00	05/01/98	05/01/03	EF
ECA-3.3	SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	024	02/28/01	05/01/98	05/01/03	EF
TOTAL FOR PRECA	9					

PARAMETERS: DOC TYPES - PRE PRECA PRFIG STATUS: EF QU 5 YEARS ONLY:


PROCEDURE NUMBER	PROCEDURE TITLE	REV	EFFECT DATE	LAST REVIEW	NEXT REVIEW	ST
FIG-1.0	FIGURE MIN SUBCOOLING	000	05/01/98	05/01/98	05/01/03	EF
FIG-2.0	FIGURE SDM	002	10/13/00	05/01/98	05/01/03	EF
FIG-3.0	FIGURE NAT CIRC C/D WITH SHROUD FANS	000	05/01/98	05/01/98	05/01/03	EF
FIG-3.1	FIGURE NAT CIRC C/D WITHOUT SHROUD FANS	001	02/08/01	05/01/98	05/01/03	EF
FIG-3.2	FIGURE NC C/D WITH VOID IN UPPER HEAD	000	05/01/98	05/01/98	05/01/03	EF
FIG-4.0	FIGURE RCP SEAL LEAKOFF	002	02/28/01	05/01/98	05/01/03	EF
FIG-5.0	FIGURE RHR INJECTION	000	05/01/98	05/01/98	05/01/03	EF
FIG-6.0	FIGURE MIN RCS INJECTION	000	05/01/98	05/01/98	05/01/03	EF
FIG-7.0	FIGURE INTACT S/G PRESSURE	001	05/18/98	05/01/98	05/01/03	EF
FIG-8.0	FIGURE TSAT	000	05/01/98	05/01/98	05/01/03	EF
FIG-9.0	FIGURE TECH SPEC C/D	001	02/15/01	05/01/98	05/01/03	EF
FIG-9.1	FIGURE C/D LIMITS	000	05/01/98	05/01/98	05/01/03	EF
FIG-10.0	FIGURE LIMIT A	000	05/01/98	05/01/98	05/01/03	EF
FIG-11.0	FIGURE SOAK LIMITS	000	05/01/98	05/01/98	05/01/03	EF
FIG-12.0	FIGURE CNMT HYDROGEN	000	05/01/98	05/01/98	05/01/03	EF
FIG-13.0	FIGURE BACK PRESSURE	000	05/01/98	05/01/98	05/01/03	EF
FIG-14.0	FIGURE IA ISOL	000	05/01/98	05/01/98	05/01/03	EF
TOTAL FOR PRFIG	17					

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 1 of 21
-------------	--	-------------------------

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23



RESPONSIBLE MANAGER

2-28-2001

EFFECTIVE DATE

CATEGORY 1.0

REVIEWED BY: _____

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 2 of 21
-----------------	--	-----------------------------

A. PURPOSE - This procedure provides actions to recover from a loss of reactor or secondary coolant.

B. ENTRY CONDITIONS/SYMPTOMS

1. ENTRY CONDITIONS - This procedure is entered from:

- a. E-0, REACTOR TRIP OR SAFETY INJECTION, and FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, when a PRZR PORV is stuck open and its block valve can not be closed.
- b. E-0, REACTOR TRIP OR SAFETY INJECTION, with any of the following symptoms: high containment radiation, high containment pressure, or high containment recirculation sump level.
- c. E-0, REACTOR TRIP OR SAFETY INJECTION, ECA-2.1, UNCONTROLLED DEPRESSURIZATION OF BOTH STEAM GENERATORS, and FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, when RCS pressure is less than the shutoff head pressure of the RHR pumps or is decreasing.
- d. ES-1.1, SI TERMINATION, and FR-I.2, RESPONSE TO LOW PRESSURIZER LEVEL, if SI has to be reinitiated.
- e. E-2, FAULTED STEAM GENERATOR ISOLATION, after identification and isolation of a faulted S/G.
- f. ECA-0.2, LOSS OF ALL AC POWER RECOVERY WITH SI REQUIRED, after normal injection mode conditions are established.
- g. ECA-1.2, LOCA OUTSIDE CONTAINMENT, when a LOCA outside containment is isolated.
- h. FR-C.1, RESPONSE TO INADEQUATE CORE COOLING, and FR-C.2, RESPONSE TO DEGRADED CORE COOLING, after core cooling has been reestablished.
- i. FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, after secondary heat sink has been reestablished and all PRZR PORVs are closed.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION

IF RWST LEVEL DECREASES TO LESS THAN 28%, THEN THE SI SYSTEM SHOULD BE ALIGNED FOR COLD LEG RECIRCULATION USING ES-1.3, TRANSFER TO COLD LEG RECIRCULATION, STEP 1.

- NOTE:
- o FOLDOUT page should be open AND monitored periodically.
 - o Critical Safety Function Status Trees should be monitored. (Refer to Appendix 1 for Red Path Summary.)
 - o Conditions should be evaluated for Site Contingency Reporting (Refer to EPIP-1.0, GINNA STATION EVENT EVALUATION AND CLASSIFICATION).
 - o Adverse CNMT values should be used whenever CNMT pressure is greater than 4 psig or CNMT radiation is greater than 10^{+05} R/hr.

1 Monitor RCP Trip Criteria:

- | | |
|---|------------------|
| a. RCP status - ANY RCP RUNNING | a. Go to Step 2. |
| b. SI pumps - AT LEAST TWO RUNNING | b. Go to Step 2. |
| c. RCS pressure minus maximum S/G pressure - LESS THAN 175 psig [400 psig adverse CNMT] | c. Go to Step 2. |
| d. Stop both RCPs | |

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

2 Check If S/G Secondary Side Is Intact:

- o Pressure in both S/Gs - STABLE OR INCREASING
- o Pressure in both S/Gs - GREATER THAN 110 PSIG

IF any S/G pressure decreasing in an uncontrolled manner OR completely depressurized, THEN verify faulted S/G isolated unless needed for RCS cooldown:

- Steamlines
- Feedlines

IF NOT, THEN go to E-2, FAULTED STEAM GENERATOR ISOLATION, Step 1.

NOTE: TDAFW pump flow control valves fail open on loss of IA.

* 3 Monitor Intact S/G Levels:

- a. Narrow range level - GREATER THAN 5% [25% adverse CNMT]
- b. Control feed flow to maintain narrow range level between 17% [25% adverse CNMT] and 50%

a. Maintain total feed flow greater than 200 gpm until narrow range level greater than 5% [25% adverse CNMT] in at least one S/G.

b. IF narrow range level in any S/G continues to increase in an uncontrolled manner, THEN go to E-3, STEAM GENERATOR TUBE RUPTURE, Step 1.

* 4 Monitor If Secondary Radiation Levels Are Normal

- o Steamline radiation monitor (R-31 and R-32)
- o Request RP sample S/Gs for activity

IF steamline radiation monitors NOT available, THEN dispatch AO to locally check steamline radiation.

IF abnormal radiation levels detected in any S/G, THEN go to E-3, STEAM GENERATOR TUBE RUPTURE, Step 1.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

.....

CAUTION

IF ANY PRZR PORV OPENS BECAUSE OF HIGH PRZR PRESSURE, IT SHOULD BE CLOSED AFTER PRESSURE DECREASES TO LESS THAN 2335 PSIG (REFER TO STEP 5B).

.....

* 5 Monitor PRZR PORV Status:

a. Power to PORV block valves - AVAILABLE

a. Restore power to block valves unless block valve was closed to isolate an open PORV:

- MOV-515, MCC D position 6C
- MOV-516, MCC C position 6C

b. PORVs - CLOSED

b. IF PRZR pressure less than 2335 psig, THEN manually close PORVs.

IF any PORV can NOT be closed, THEN manually close its block valve. IF block valve can NOT be closed, THEN dispatch AO to locally check breaker.

- MOV-515, MCC D position 6C
- MOV-516, MCC C position 6C

c. Block valves - AT LEAST ONE OPEN

c. Open one block valve unless it was closed to isolate an open PORV.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

IF OFFSITE POWER IS LOST AFTER SI RESET, THEN SELECTED SW PUMPS AND ONE CCW PUMP WILL AUTO START ON EMERGENCY D/G. MANUAL ACTION WILL BE REQUIRED TO RESTART SAFEGUARDS EQUIPMENT.

6 Reset SI

7 Reset CI:

a. Depress CI reset pushbutton

b. Verify annunciator A-26, CNMT ISOLATION - EXTINGUISHED

b. Perform the following:

- 1) Reset SI.
- 2) Depress CI reset pushbutton.

8 Verify Adequate SW Flow:

a. Check at least two SW pumps - RUNNING

a. Manually start SW pumps as power supply permits (257 kw each).

IF less than two SW pumps running, THEN perform the following:

- 1) Ensure SW isolation.
- 2) Dispatch AO to establish normal shutdown alignment (Refer to Attachment SD-1)
- 3) Go to Step 10.

b. Dispatch AO to establish normal shutdown alignment (Refer to Attachment SD-1)

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

9 Establish IA to CNMT:

- | | |
|---|--|
| <p>a. Verify non-safeguards busses energized from offsite power</p> <ul style="list-style-type: none"> o Bus 13 normal feed - CLOSED <li style="text-align: center;">-OR- o Bus 15 normal feed - CLOSED <p>b. Verify turbine building SW isolation valves - OPEN</p> <ul style="list-style-type: none"> • MOV-4613 and MOV-4670 • MOV-4614 and MOV-4664 <p>c. Verify adequate air compressors - RUNNING</p> <p>d. Check IA supply:</p> <ul style="list-style-type: none"> o Pressure - GREATER THAN 60 PSIG o Pressure - STABLE OR INCREASING <p>e. Reset both trains of XY relays for IA to CNMT AOV-5392</p> <p>f. Verify IA to CNMT AOV-5392 - OPEN</p> | <p>a. Perform the following:</p> <ol style="list-style-type: none"> 1) Close non-safeguards bus tie breakers: <ul style="list-style-type: none"> • Bus 13 to Bus 14 tie • Bus 15 to Bus 16 tie 2) Verify adequate emergency D/G capacity to run air compressors (75 kw each).

<u>IF NOT</u>, <u>THEN</u> evaluate if CNMT RECIRC fans should be stopped (Refer to Attachment CNMT RECIRC FANS). 3) <u>WHEN</u> bus 15 restored, <u>THEN</u> reset control room lighting. <p>b. Manually align valves.</p> <p>c. Manually start air compressors as power supply permits (75 kw each). <u>IF</u> air compressors can <u>NOT</u> be started, <u>THEN</u> dispatch AO to locally reset compressors as necessary.</p> <p>d. Perform the following:</p> <ol style="list-style-type: none"> 1) Continue attempts to restore IA (Refer to AP-IA.1, LOSS OF INSTRUMENT AIR). 2) Continue with Step 10. <u>WHEN</u> IA restored, <u>THEN</u> do Steps 9e and f. |
|---|--|

EOP:

E-1

TITLE:

LOSS OF REACTOR OR SECONDARY COOLANT

REV: 21

PAGE 8 of 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

10 Check Normal Power Available
To Charging Pumps:

- o Bus 14 normal feed breaker -
CLOSED
- o Bus 16 normal feed breaker -
CLOSED

Verify adequate emergency D/G
capacity to run charging pumps
(75 kw each).

IF NOT, THEN evaluate if CNMT
RECIRC fans can be stopped (Refer
to Attachment CNMT RECIRC FANS).

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 9 of 21
-----------------	--	-----------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
11 Check If Charging Flow Has Been Established:	a. Charging pumps - ANY RUNNING	a. Perform the following: <ol style="list-style-type: none"> 1) <u>IF</u> CCW flow is lost to any RCP thermal barrier <u>OR</u> any RCP #1 seal outlet temperature offscale high, <u>THEN</u> dispatch AO with key to RWST gate to close seal injection needle valve(s) to affected RCP: <ul style="list-style-type: none"> • V-300A for RCP A • V-300B for RCP B 2) Ensure HCV-142 open, demand at 0%.
	b. Charging pump suction aligned to RWST: <ul style="list-style-type: none"> o LCV-112B - OPEN o LCV-112C - CLOSED 	b. Manually align valves as necessary. <p><u>IF</u> LCV-112B can <u>NOT</u> be opened, <u>THEN</u> dispatch AO to locally open manual charging pump suction from RWST (V-358 located in charging pump room).</p> <p><u>IF</u> LCV-112C can <u>NOT</u> be closed, <u>THEN</u> perform the following:</p> <ol style="list-style-type: none"> 1) Verify charging pump A <u>NOT</u> running and place in PULL STOP. 2) Direct AO to close V-268 to isolate charging pumps B and C from VCT (V-268 located in charging pump room).
	c. Start charging pumps as necessary and adjust charging flow to restore PRZR level	

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

12 Check If SI Should Be Terminated:

- | | |
|---|--|
| <p>a. RCS pressure:</p> <ul style="list-style-type: none"> o Pressure - GREATER THAN 1625 psig [1825 psig adverse CNMT] o Pressure - STABLE OR INCREASING <p>b. RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING</p> <p>c. Secondary heat sink:</p> <ul style="list-style-type: none"> o Total feed flow to intact S/Gs - GREATER THAN 200 GPM <p style="text-align: center;">-OR-</p> <ul style="list-style-type: none"> o Narrow range level in at least one intact S/G - GREATER THAN 5% [25% adverse CNMT] <p>d. PRZR level - GREATER THAN 5% [30% adverse CNMT]</p> | <p>a. Do <u>NOT</u> stop SI pumps. Go to Step 13.</p> <p>b. Do <u>NOT</u> stop SI pumps. Go to Step 13.</p> <p>c. <u>IF</u> neither condition satisfied, <u>THEN</u> do <u>NOT</u> stop SI pumps. Go to Step 13.</p> <p>d. Do <u>NOT</u> stop SI pumps. Perform the following:</p> <ol style="list-style-type: none"> 1) <u>IF</u> normal PRZR spray available, <u>THEN</u> try to stabilize RCS pressure with PRZR spray. 2) Go to Step 13. |
| <p>e. Go to ES-1.1, SI TERMINATION, Step 1.</p> | |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

***13 Monitor If CNMT Spray Should Be Stopped:**

- a. CNMT spray pumps - RUNNING
- b. Check the following:
 - o CNMT pressure - LESS THAN 4 PSIG
 - o Sodium hydroxide tank level - LESS THAN 55%
- c. Reset CNMT spray
- d. Check NaOH tank outlet valves - CLOSED
 - AOV-836A
 - AOV-836B
- e. Stop CNMT spray pumps and place in AUTO
- f. Close CNMT spray pump discharge valves
 - MOV-860A
 - MOV-860B
 - MOV-860C
 - MOV-860D

- a. Go to Step 14.
- b. Continue with Step 14. WHEN BOTH conditions satisfied, THEN do Steps 13c through f.
- d. Place NaOH tank outlet valve controllers to MANUAL and close valves.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

.....

CAUTION

- o IF OFFSITE POWER IS LOST AFTER SI RESET, THEN SELECTED SW PUMPS AND ONE CCW PUMP WILL AUTO START ON EMERGENCY D/G. MANUAL ACTION WILL BE REQUIRED TO RESTART SAFEGUARDS EQUIPMENT.
- o RCS PRESSURE SHOULD BE MONITORED. IF RCS PRESSURE DECREASES IN AN UNCONTROLLED MANNER TO LESS THAN 250 PSIG [465 PSIG ADVERSE CNMT], THEN THE RHR PUMPS MUST BE MANUALLY RESTARTED TO SUPPLY WATER TO THE RCS.

.....

***14** Monitor If RHR Pumps Should Be Stopped:

a. Check RCS pressure:

1) Pressure - GREATER THAN 250 psig [465 psig adverse CNMT]

1) Go to Step 16.

2) RCS pressure - STABLE OR INCREASING

2) Go to Step 15.

b. Stop RHR pumps and place in AUTO

15 Check RCS And S/G Pressures

a. Check pressures in both S/Gs - STABLE OR INCREASING

a. Return to Step 1.

b. Check pressures in both S/Gs - GREATER THAN 110 PSIG

b. Monitor RCS pressure. IF RCS pressure does NOT increase after faulted S/G dryout, THEN go to Step 16.

c. Check RCS pressure - STABLE OR DECREASING

c. Return to Step 1.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

16 Check If Emergency D/Gs
Should Be Stopped:

a. Verify AC emergency busses
energized by offsite power:

- o Emergency D/G output breakers
- OPEN
- o AC emergency bus voltage -
GREATER THAN 420 VOLTS
- o AC emergency bus normal feed
breakers - CLOSED

b. Stop any unloaded emergency D/G
and place in standby (Refer to
Attachment D/G STOP)

a. Perform the following:

- 1) Close non-safeguards bus tie
breakers as necessary:
 - Bus 13 to Bus 14 tie
 - Bus 15 to Bus 16 tie
- 2) Place the following pumps in
PULL STOP:
 - EH pumps
 - Turning gear oil pump
 - HP seal oil backup pump
- 3) Ensure condenser steam dump
mode control in MANUAL.
- 4) Restore power to MCCs:
 - A from Bus 13
 - B from Bus 15
 - E from Bus 15
 - F from Bus 15
- 5) Start HP seal oil backup pump.
- 6) Ensure D/G load within limits.
- 7) WHEN bus 15 restored, THEN
reset control room lighting
breaker.
- 8) Refer to Attachment SI/UV for
other equipment lost with
loss of offsite power.
- 9) Try to restore offsite power
(Refer to ER-ELEC.1,
RESTORATION OF OFFSITE POWER).

EOP:

E-1

TITLE:

LOSS OF REACTOR OR SECONDARY COOLANT

REV: 21

PAGE 14 of 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

17 Check If RHR Should Be Throttled:

a. Check RHR Pumps - ANY RUNNING

b. Check RWST level - LESS THAN 70%

c. RHR flow - LESS THAN 1500 GPM PER OPERATING PUMP

a. Go to step 18.

b. Continue with Step 18. WHEN RWST level less than 70%, THEN perform step 17b.

c. Manually adjust RHR Hx outlet valves equally to reduce flow to less than 1500 gpm per operating pump

- RHR Hx A, HCV-625
- RHR Hx B, HCV-624

IF flow can NOT be reduced manually, THEN dispatch an AO with locked valve key to locally adjust RHR Hx outlet valve handwheels equally to reduce flow.

- RHR Hx A, HCV-625 handwheel
- RHR Hx B, HCV-624 handwheel

EOP:

E-1

TITLE:

LOSS OF REACTOR OR SECONDARY COOLANT

REV: 21

PAGE 15 of 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

18 Verify CNMT Sump
Recirculation Capability:

a. Check RHR and CCW systems:

1) Power available to emergency
AC busses and MCCs required
for CNMT sump recirculation

- o Bus 14 and bus 18 -
ENERGIZED
- o MCC C - ENERGIZED
- o Bus 16 and bus 17 -
ENERGIZED
- o MCC D - ENERGIZED

2) RHR pumps and valves -
OPERABLE

3) CCW pumps and Hx - OPERABLE

b. Check SW pumps - AT LEAST 2
PUMPS AVAILABLE

c. Dispatch AO to check AUX BLDG
sub-basement for RHR system
leakage (AUX BLDG sub-basement
key may be required)

a. Restore power to at least one
train of emergency AC busses.
IF at least one train of cold
leg recirculation capability can
NOT be verified, THEN go to
ECA-1.1, LOSS OF EMERGENCY
COOLANT RECIRCULATION, Step 1.

b. Attempt to restore at least 2 SW
pumps to operable. IF only 1 SW
pump available, THEN refer to
Attachment MIN SW for additional
guidance.

c. IF any RHR pump seal leakage
indicated, THEN leakage should
be evaluated and isolated if
necessary.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

19 Evaluate Plant Status:

- a. Check auxiliary building radiation - NORMAL

- Plant vent iodine (R-10B)
- Plant vent particulate (R-13)
- Plant vent gas (R-14)

- CCW liquid monitor (R-17)
- LTDN line monitor (R-9)
- CHG pump room (R-4)

- b. Direct RP to obtain following samples:

- RCS boron
- RCS activity
- CNMT hydrogen
- CNMT sump boron

- c. Verify adequate Rx head cooling:

- 1) Verify at least one control rod shroud fan - RUNNING
- 2) Verify one Rx compartment cooling fan - RUNNING

- a. Notify RP and refer to appropriate AR-RMS procedure.

IF the cause is a loss of RCS inventory outside CNMT, THEN go to ECA-1.2, LOCA OUTSIDE CONTAINMENT, Step 1.

- 1) Manually start one fan as power supply permits (45 kw)

- 2) Perform the following:

- o Dispatch AO to reset UV relays at MCC C and MCC D.
- o Manually start one fan as power supply permits (23 kw)

EOP:

E-1

TITLE:

LOSS OF REACTOR OR SECONDARY COOLANT

REV: 21

PAGE 17 of 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

20 Check If RCS Cooldown And
Depressurization Is Required:

a. RCS pressure - GREATER THAN
250 psig [465 psig adverse CNMT]

a. IF RHR pump flow greater than
475 gpm, THEN go to Step 21.

b. Go to ES-1.2, POST LOCA COOLDOWN
AND DEPRESSURIZATION, Step 1

EOP:

E-1

TITLE:

LOSS OF REACTOR OR SECONDARY COOLANT

REV: 21

PAGE 18 of 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: IF D/Gs supplying emergency AC busses, THEN non-essential loads may be shed as necessary to allow start of additional SW pumps.

21 Establish Adequate SW Flow:

a. Verify at least two SW pumps -
RUNNING

a. Start additional SW pumps as
power supply permits (257 kw
each). IF only 1 SW pump
operable, THEN perform the
following:

1) Ensure Attachment MIN SW is
in progress.

2) Go to Step 22.

b. Verify AUX BLDG SW isolation
valves - OPEN

b. Manually align valves.

- MOV-4615 and MOV-4734
- MOV-4616 and MOV-4735

This Step continued on the next page.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

(Step 21 continued from previous page)

c. Dispatch AO to perform the following:

1) Check BOTH CCW Hx - INSERVICE

2) Verify total SW flow to CCW Hxs - GREATER THAN 5000 GPM

1) Perform the following:

a) Locally place BOTH CCW Hxs in service

b) Locally adjust total SW flow equally to available CCW Hxs to between 5000 gpm and 6000 gpm

- V-4619
- V-4620

2) Perform the following:

a) Isolate SW to screenhouse and air conditioning headers.

- MOV-4609/MOV-4780 - AT LEAST ONE CLOSED
- MOV-4663/MOV-4733 - AT LEAST ONE CLOSED

b) Direct AO to locally adjust total SW flow equally to available CCW Hxs to between 5000 gpm and 6000 gpm (V-4619 and V-4620).

c) Direct AO to locally isolate SW return from SFP Hxs:

- SFP Hx A (V-4622)
- SFP Hx B (V-8689)

d) Verify SW portions of Attachment SD-1 are complete.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

22 Establish CCW flow to RHR Hxs:

a. Check both CCW pumps - RUNNING

a. Perform the following:

- 1) Start CCW pumps as power supply permits (124 kw each)
- 2) IF both CCW pumps are running, THEN go to step 22b.
- 3) IF only one CCW pump is running, THEN perform the following:

a) Direct AO to isolate CCW to boric acid evaporator

o Close V-760A

b) Manually open CCW MOV to only one operable RHR Loop

o Open MOV-738A

-OR-

o Open MOV-738B

c) Go to step 23.

b. Manually open CCW valves to RHR Hxs

b. Dispatch AO to locally open valves.

- MOV-738A
- MOV-738B

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 21 of 21
-------------	--	--------------------------

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

23 Check If Transfer To Cold Leg
Recirculation Is Required:

a. RWST level - LESS THAN 28%

a. Return to Step 17.

b. Go to ES-1.3, TRANSFER TO COLD
LEG RECIRCULATION, Step 1

-END-

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 1 of 1
-------------	--	------------------------

E-1 APPENDIX LIST

- TITLE
- 1) RED PATH SUMMARY
 - 2) FIGURE MIN SUBCOOLING (FIG-1.0)
 - 3) ATTACHMENT CNMT RECIRC FANS (ATT-4.0)
 - 4) ATTACHMENT D/G STOP (ATT-8.1)
 - 5) ATTACHMENT SD-1 (ATT-17.0)
 - 6) ATTACHMENT SI/UV (ATT-8.4)
 - 7) ATTACHMENT MIN SW (ATT-2.1)
 - 8) FOLDOUT

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 1 of 1
-------------	--	------------------------

RED PATH SUMMARY

- a. SUBCRITICALITY - Nuclear power greater than 5%
- b. CORE COOLING - Core exit T/Cs greater than 1200°F
-OR-
Core exit T/Cs greater than 700°F AND
RVLIS level (no RCPs) less than 52% [55%
adverse CNMT]
- c. HEAT SINK - Narrow range level in all S/Gs less than 5%
[25% adverse CNMT] AND total feedwater flow
less than 200 gpm
- d. INTEGRITY - Cold leg temperatures decrease greater than
100°F in last 60 minutes AND RCS cold leg
temperature less than 285°F
- e. CONTAINMENT - CNMT pressure greater than 60 psig

EOP: E-1	TITLE: LOSS OF REACTOR OR SECONDARY COOLANT	REV: 21 PAGE 1 of 1
-----------------	--	----------------------------

FOLDOUT PAGE

1. RCP TRIP CRITERIA

IF BOTH conditions listed below occur, THEN trip both RCPs:

- a. SI pumps - AT LEAST TWO RUNNING
- b. RCS pressure minus maximum S/G pressure - LESS THAN 175 PSIG [400 psig adverse CNMT]

2. SI REINITIATION CRITERIA

IF EITHER condition listed below occurs, THEN manually start SI pumps as necessary:

- o RCS subcooling based on core exit T/Cs - LESS THAN 0° F USING FIGURE MIN SUBCOOLING
- OR -
- o PRZR level - CHARGING CAN NOT CONTROL LEVEL GREATER THAN 5% [30% adverse CNMT]

3. SI TERMINATION CRITERIA

IF ALL conditions listed below occur, THEN go to ES-1.1, SI TERMINATION, Step 1:

- a. RCS subcooling based on core exit T/Cs - GREATER THAN 0° F USING FIGURE MIN SUBCOOLING
- b. Total feed flow to intact S/Gs - GREATER THAN 200 GPM
- OR -
Narrow range level in at least one intact S/G - GREATER THAN 5% [25% adverse CNMT]
- c. RCS pressure:
 - o GREATER THAN 1625 PSIG [1825 psig adverse CNMT]
 - o STABLE OR INCREASING
- d. PRZR level - GREATER THAN 5% [30% adverse CNMT]

4. SECONDARY INTEGRITY CRITERIA

IF any S/G pressure is decreasing in an uncontrolled manner or is completely depressurized AND has not been isolated, THEN go to E-2, FAULTED S/G ISOLATION, Step 1.

5. E-3 TRANSITION CRITERIA

IF any S/G level increased in an uncontrolled manner or any S/G has abnormal radiation, THEN manually start SI pumps as necessary AND go to E-3, STEAM GENERATOR TUBE RUPTURE, Step 1.

6. COLD LEG RECIRCULATION SWITCHOVER CRITERION

IF RWST level decreases to less than 28%, THEN go to ES-1.3, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

7. AFW SUPPLY SWITCHOVER CRITERION


IF CST level decreases to less than 5 feet, THEN switch to alternate AFW water supply (Refer to ER-AFW.1, ALTERNATE WATER SUPPLY TO AFW PUMPS).

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 1 of 41
-------------	--	-------------------------

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23



RESPONSIBLE MANAGER

2-28-2001

EFFECTIVE DATE

CATEGORY 1.0

REVIEWED BY: _____

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 2 of 41
-----------------	--	-----------------------------

A. PURPOSE - This procedure provides actions to terminate leakage of reactor coolant into the secondary system following a steam generator tube rupture (SGTR), this procedure should also be used for a SGTR in one S/G and a fault in the other S/G.

B. ENTRY CONDITIONS/SYMPTOMS

1. ENTRY CONDITIONS - This procedure is entered from:

- a. E-0, REACTOR TRIP OR SAFETY INJECTION, when condenser air ejector radiation or blowdown radiation is abnormal, or
- b. E-0, REACTOR TRIP OR SAFETY INJECTION, E-1, LOSS OF REACTOR OR SECONDARY COOLANT, E-2, FAULTED STEAM GENERATOR ISOLATION, and FR-H.3, RESPONSE TO STEAM GENERATOR HIGH LEVEL, when secondary radiation is abnormal, or
- c. E-0, REACTOR TRIP OR SAFETY INJECTION, E-1, LOSS OF REACTOR OR SECONDARY COOLANT, E-2, FAULTED STEAM GENERATOR ISOLATION, ES-1.2, POST LOCA COOLDOWN AND DEPRESSURIZATION, ECA-3.3, SGTR WITHOUT PRESSURIZER PRESSURE CONTROL, when an intact S/G narrow range level increases in an uncontrolled manner.
- d. ECA-3.3, SGTR WITHOUT PRESSURIZER PRESSURE CONTROL, when pressurizer pressure control is restored.
- e. Any FOLDOUT page that has E-3 transition criteria whenever either S/G level increases in an uncontrolled manner or either S/G has abnormal radiation.

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 3 of 41
-----------------	--	-----------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

- NOTE:
- o FOLDOUT page should be open AND monitored periodically.
 - o Critical Safety Function Status Trees should be monitored (Refer to Appendix 1 for Red Path Summary).
 - o Personnel should be available for sampling during this procedure.
 - o Conditions should be evaluated for Site Contingency Reporting (EPIP-1.0, GINNA STATION EVENT EVALUATION AND CLASSIFICATION).
 - o Adverse CNMT values should be used whenever CNMT pressure is greater than 4 psig or CNMT radiation is greater than 10^{+05} R/hr.

*** 1 Monitor RCP Trip Criteria:**

- | | |
|---|------------------|
| a. RCP status - ANY RCP RUNNING | a. Go to Step 2. |
| b. SI pumps - AT LEAST TWO RUNNING | b. Go to Step 2. |
| c. RCS pressure minus maximum S/G pressure - LESS THAN 175 psig [400 psig adverse CNMT] | c. Go to Step 2. |
| d. Stop both RCPs | |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

.....

CAUTION

IF OFFSITE POWER IS LOST AFTER SI RESET, THEN SELECTED SW PUMPS AND ONE CCW PUMP WILL AUTO START ON EMERGENCY D/G. MANUAL ACTION WILL BE REQUIRED TO RESTART SAFEGUARDS EQUIPMENT.

.....

2 Identify Ruptured S/G(s):

Perform the following:

- o Unexpected increase in either S/G narrow range level
 - OR-
- o High radiation indication on main steamline radiation monitor
 - R-31 for S/G A
 - R-32 for S/G B
 - OR-
- o AO reports local indication of high steamline radiation
 - OR-
- o RP reports high radiation from S/G activity sample

- a. Reset SI
- b. Continue with Steps 10 through 16. WHEN ruptured S/G(s) identified, THEN do Steps 3 through 9.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 o IF THE TDAFW PUMP IS THE ONLY AVAILABLE SOURCE OF FEED FLOW, STEAM SUPPLY TO THE TDAFW PUMP MUST BE MAINTAINED FROM ONE S/G.
 o AT LEAST ONE S/G SHALL BE MAINTAINED AVAILABLE FOR RCS COOLDOWN.

3 Isolate Flow From Ruptured S/G(s):

- | | |
|--|--|
| <ul style="list-style-type: none"> a. Adjust ruptured S/G ARV controller to 1050 psig in AUTO b. Check ruptured S/G ARV - CLOSED c. Close ruptured S/G TDAFW pump steam supply valve and place in PULL STOP <ul style="list-style-type: none"> • S/G A, MOV-3505A • S/G B, MOV-3504A d. Verify ruptured S/G blowdown valve - CLOSED <ul style="list-style-type: none"> • S/G A, AOV-5738 • S/G B, AOV-5737 | <ul style="list-style-type: none"> b. <u>WHEN</u> ruptured S/G pressure less than 1050 psig, <u>THEN</u> verify S/G ARV closed. <u>IF NOT</u> closed, <u>THEN</u> place controller in MANUAL and close S/G ARV.

 <u>IF</u> S/G ARV can <u>NOT</u> be closed, <u>THEN</u> dispatch AO to locally isolate. c. Dispatch AO with locked valve key to locally isolate steam from ruptured S/G to TDAFW pump. <ul style="list-style-type: none"> • S/G A, V-3505 • S/G B, V-3504 d. Place S/G blowdown and sample valve isolation switch to CLOSE.

 <u>IF</u> blowdown can <u>NOT</u> be isolated manually, <u>THEN</u> dispatch AO to locally isolate blowdown. <ul style="list-style-type: none"> • S/G A, V-5701 • S/G B, V-5702 |
|--|--|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

4 Complete Ruptured S/G
Isolation:

a. Close ruptured S/G MSIV -
RUPTURED S/G MSIV CLOSED

a. Perform the following:

- 1) Close intact S/G MSIV.
- 2) Place intact S/G ARV controller at 1005 psig in AUTO.
- 3) Adjust condenser steam dump controller to 1050 psig in AUTO.
- 4) Place condenser steam dump mode selector switch to MANUAL.
- 5) Adjust reheat steam supply controller cam to close reheat steam supply valves.
- 6) Ensure turbine stop valves - CLOSED.
- 7) Dispatch AO to complete ruptured S/G isolation (Refer to Attachment RUPTURED S/G, parts A and B).

b. Dispatch AO to complete ruptured S/G isolation (Refer to Attachment RUPTURED S/G part A)

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 IF ANY RUPTURED S/G IS FAULTED, FEED FLOW TO THAT S/G SHOULD REMAIN ISOLATED DURING SUBSEQUENT RECOVERY ACTIONS UNLESS NEEDED FOR RCS COOLDOWN.

5 Check Ruptured S/G Level:

- | | |
|--|--|
| <p>a. Narrow range level - GREATER THAN 5% [25% adverse CNMT]</p> <p>b. Close MDAFW pump discharge valve to ruptured S/G</p> <ul style="list-style-type: none"> • S/G A, MOV-4007 • S/G B, MOV-4008 <p>c. Pull stop MDAFW pump for ruptured S/G</p> <p>d. Close TDAFW pump flow control valve to ruptured S/G</p> <ul style="list-style-type: none"> • S/G A, AOV-4297 • S/G B, AOV-4298 <p>e. Verify MDAFW pump crosstie valves - CLOSED</p> <ul style="list-style-type: none"> • MOV-4000A • MOV-4000B | <p>a. <u>IF</u> ruptured S/G <u>NOT</u> faulted, <u>THEN</u> perform the following:</p> <p>1) Maintain feed flow to ruptured S/G until level greater than 5% [25% adverse CNMT].</p> <p>2) Continue with Step 6. <u>WHEN</u> ruptured S/G level greater than 5% [25% adverse CNMT], <u>THEN</u> do Steps 5b through e.</p> <p>b. Dispatch A0 to locally close valve.</p> <p>d. Dispatch A0 with locked valve key to locally close TDAFW pump manual feedwater isolation valve to ruptured S/G.</p> <ul style="list-style-type: none"> • S/G A, V-4005 • S/G B, V-4006 <p>e. Manually close valves.</p> |
|--|--|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

6 Verify Ruptured S/G Isolated:

a. Check ruptured MSIV - CLOSED

a. Ensure air ejector/gland steam supply and flange heating steam isolated. (Refer to ATTACHMENT RUPTURED S/G, part B).

b. Check TDAFW pump steam supply from ruptured S/G - ISOLATED

b. Continue efforts to isolate steam supply from ruptured S/G:

- S/G A, MOV-3505A OR V-3505
- S/G B, MOV-3504A OR V-3504

c. Ruptured S/G pressure - GREATER THAN 300 PSIG

c. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

7 Establish Condenser Steam Dump Pressure Control:

a. Verify condenser available:

- o Intact S/G MSIV - OPEN
- o Annunciator G-15, STEAM DUMP ARMED - LIT

a. Adjust S/G ARV controllers to maintain intact S/G pressure in AUTO and go to Step 8.

b. Adjust condenser steam dump controller HC-484 to maintain intact S/G pressure and verify in AUTO

c. Place steam dump mode selector switch to MANUAL

EOP:

E-3

TITLE:

STEAM GENERATOR TUBE RUPTURE

REV: 27

PAGE 9 of 41

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

.....

CAUTION

IF OFFSITE POWER IS LOST AFTER SI RESET, THEN SELECTED SW PUMPS AND ONE CCW PUMP WILL AUTO START ON EMERGENCY D/G. MANUAL ACTION WILL BE REQUIRED TO RESTART SAFEGUARDS EQUIPMENT.

.....

8 Reset SI

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

RUPTURED S/G LEVEL SHALL BE MAINTAINED GREATER THAN 5% [25% ADVERSE CNMT] DURING THE RCS COOLDOWN, UNLESS THE RUPTURED S/G IS ALSO FAULTED.

NOTE: Following initiation of controlled cooldown or depressurization, RCP trip criteria is no longer applicable.

9 Initiate RCS Cooldown:

- a. Determine required core exit temperature from below table

RUPTURED SG PRESSURE	REQUIRED CORE EXIT TEMPERATURE (°F)
1100 PSIG	525 [505 adverse CNMT]
1000 PSIG	510 [490 adverse CNMT]
900 PSIG	500 [475 adverse CNMT]
800 PSIG	485 [460 adverse CNMT]
700 PSIG	465 [440 adverse CNMT]
600 PSIG	450 [420 adverse CNMT]
500 PSIG	425 [395 adverse CNMT]
400 PSIG	405 [370 adverse CNMT]
300 PSIG	375 [330 adverse CNMT]

- b. IF ruptured S/G MSIV closed, THEN initiate dumping steam to condenser from intact S/G at maximum rate

- b. Manually or locally initiate steam dump from intact S/G at maximum rate using S/G ARV.

IF no intact S/G available, THEN perform the following:

- o Use faulted S/G.

-OR-

- o IF a ruptured S/G must be used, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

- c. Core exit T/Cs - LESS THAN REQUIRED TEMPERATURE

- c. Continue with Step 10. WHEN core exit T/Cs less than required, THEN do Step 9d.

- d. Stop RCS cooldown and stabilize core exit T/Cs less than required temperature

EOP:

E-3

TITLE:

STEAM GENERATOR TUBE RUPTURE

REV: 27

PAGE 11 of 41

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: TDAFW pump flow control valves fail open on loss of IA. |

10 Monitor Intact S/G Level: |

a. Narrow range level - GREATER THAN 5% [25% adverse CNMT] |

a. Maintain total feed flow greater than 200 gpm until narrow range level greater than 5% [25% adverse CNMT] in at least one S/G. |

b. Control feed flow to maintain narrow range level between 17% [25% adverse CNMT] and 50% |

b. IF narrow range level in the intact S/G continues to increase in an uncontrolled manner, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1. |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

.....
CAUTION
 IF ANY PRZR PORV OPENS BECAUSE OF HIGH PRZR PRESSURE, IT SHOULD BE CLOSED AFTER PRESSURE DECREASES TO LESS THAN 2335 PSIG (REFER TO STEP 11B).

11 Monitor PRZR PORVs And Block Valves:

a. Power to PORV block valves - AVAILABLE

a. Restore power to block valves unless block valve was closed to isolate an open PORV:

- MOV-515, MCC D position 6C
- MOV-516, MCC C position 6C

b. PORVs - CLOSED

b. IF PRZR pressure less than 2335 psig, THEN manually close PORVs.

IF any PORV can NOT be closed, THEN manually close its block valve. IF block valve can NOT be closed, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

c. Block valves - AT LEAST ONE OPEN

c. Open one block valve unless it was closed to isolate an open PORV.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

12 Reset CI:

a. Depress CI reset pushbutton

b. Verify annunciator A-26, CNMT
ISOLATION - EXTINGUISHED

b. Perform the following:

1) Reset SI.

2) Depress CI reset pushbutton.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

13 Monitor All AC Busses -
BUSSES ENERGIZED BY OFFSITE
POWER

- o Normal feed breakers to all 480
volt busses - CLOSED
- o 480 volt bus voltage - GREATER
THAN 420 VOLTS
- o Emergency D/G output breakers -
OPEN

Perform the following:

- a. IF any AC emergency bus normal
feed breaker open, THEN ensure
associated D/G breaker closed.
- b. Perform the following as
necessary:
 - 1) Close non-safeguards bus tie
breakers:
 - Bus 13 to Bus 14 tie
 - Bus 15 to Bus 16 tie
 - 2) Place the following pumps in
PULL STOP:
 - EH pumps
 - Turning gear oil pump
 - HP seal oil backup pump
 - 3) Restore power to MCCs.
 - A from Bus 13
 - B from Bus 15
 - E from Bus 15
 - F from Bus 15
 - 4) Start HP seal oil backup pump.
 - 5) Start CNMT RECIRC fans as
necessary.
 - 6) Ensure D/G load within limits.
 - 7) WHEN bus 15 restored, THEN
reset control room lighting.
- c. Try to restore offsite power to
all AC busses (Refer to
ER-ELEC.1, RESTORATION OF
OFFSITE POWER).

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

14 Verify Adequate SW Flow: |

a. Check at least two SW pumps -
RUNNING |a. Manually start SW pumps as power
supply permits (257 kw each). |IF less than two SW pumps
running, THEN: |

1) Ensure SW isolation. |

2) Dispatch AO to establish
normal shutdown alignment
(Refer to Attachment SD-1) |

3) Go to Step 16. |

b. Dispatch AO to establish normal
shutdown alignment (Refer to
Attachment SD-1) |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

15 Establish IA to CNMT:

a. Verify non-safeguards busses energized

o Bus 13 normal feed - CLOSED

-OR-

o Bus 15 normal feed - CLOSED

b. Verify turbine building SW isolation valves - OPEN

- MOV-4613 and MOV-4670
- MOV-4614 and MOV-4664

c. Verify adequate air compressors - RUNNING

d. Check IA supply:

o Pressure - GREATER THAN 60 PSIG

o Pressure - STABLE OR INCREASING

e. Reset both trains of XY relays for IA to CNMT AOV-5392

f. Verify IA to CNMT AOV-5392 - OPEN

a. Perform the following:

1) Close non-safeguards bus tie breakers:

- Bus 13 to Bus 14 tie
- Bus 15 to Bus 16 tie

2) Verify adequate emergency D/G capacity to run air compressors (75 kw each).

IF NOT, THEN evaluate if CNMT RECIRC fans should be stopped (Refer to Attachment CNMT RECIRC FANS).

b. Manually align valves.

c. Manually start air compressors as power supply permits (75 kw each). IF air compressors can NOT be started, THEN dispatch AO to locally reset compressors as necessary.

d. Perform the following:

1) Continue attempts to restore IA (Refer to AP-IA.1, LOSS OF INSTRUMENT AIR).

2) Continue with Step 16. WHEN IA restored, THEN do Steps 15e and f.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

CAUTION

RCS PRESSURE SHOULD BE MONITORED. IF RCS PRESSURE DECREASES IN AN UNCONTROLLED MANNER TO LESS THAN 250 PSIG [465 PSIG ADVERSE CNMT], THEN THE RHR PUMPS MUST BE MANUALLY RESTARTED TO SUPPLY WATER TO THE RCS.

16 Check If RHR Pumps Should Be Stopped:

- | | |
|---|---|
| <ul style="list-style-type: none"> a. Check RCS pressure - GREATER THAN 250 psig [465 psig adverse CNMT] | <ul style="list-style-type: none"> a. Go to Step 17. |
| <ul style="list-style-type: none"> b. Stop RHR pumps and place both in AUTO | |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

17 Establish Charging Flow:

a. Charging pumps - ANY RUNNING

a. Perform the following:

- 1) IF CCW flow is lost to any RCP thermal barrier OR any RCP #1 seal outlet temperature offscale high, THEN dispatch AO with key to RWST gate to locally close seal injection needle valves to affected RCP.

- V-300A for RCP A
- V-300B for RCP B

- 2) Ensure HCV-142 demand at 0%.

b. Align charging pump suction to RWST:

- b. IF LCV-112B can NOT be opened, THEN dispatch AO to locally open manual charging pump suction from RWST (V-358 located in charging pump room).

- o LCV-112B - OPEN
- o LCV-112C - CLOSED

IF LCV-112C can NOT be closed, THEN perform the following:

- 1) Verify charging pump A NOT running and place in PULL STOP.
- 2) Direct AO to close V-268 to isolate charging pumps B and C from VCT (V-268 located in charging pump room).

c. Start charging pumps as necessary and establish 75 gpm total charging flow

- Charging line flow
- Seal injection

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

18 Check If RCS Cooldown Should Be Stopped:

- a. Core exit T/Cs - LESS THAN REQUIRED TEMPERATURE
- b. Stop RCS cooldown
- c. Stabilize core exit T/Cs - LESS THAN REQUIRED TEMPERATURE

19 Check Ruptured S/G Pressure - STABLE OR INCREASING

20 Check RCS Subcooling Based On Core Exit T/Cs - GREATER THAN 20°F USING FIGURE MIN SUBCOOLING

- a. Do NOT proceed until core exit T/Cs less than required temperature.

IF pressure continues to decrease to less than 250 psi above the pressure of the intact S/G, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1 .

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: SI ACCUMs may inject during RCS depressurization.

21 Depressurize RCS To Minimize
Break Flow And Refill PRZR:

- | | |
|---|--|
| <p>a. Check the following:</p> <ul style="list-style-type: none"> o Ruptured S/G level - LESS THAN 90% [80% adverse CNMT] o Any RCP - RUNNING o IA to CNMT - AVAILABLE <p>b. Spray PRZR with maximum available spray until ANY of the following conditions satisfied:</p> <ul style="list-style-type: none"> o PRZR level - GREATER THAN 75% [65% adverse CNMT] <li style="padding-left: 40px;">-OR- o RCS pressure - LESS THAN SATURATION USING FIGURE MIN SUBCOOLING <li style="padding-left: 40px;">-OR- o <u>BOTH</u> of the following: <ul style="list-style-type: none"> 1) RCS pressure - LESS THAN RUPTURED S/G PRESSURE 2) PRZR level - GREATER THAN 5% [30% adverse CNMT] <p>c. Close normal PRZR spray valves:</p> <ul style="list-style-type: none"> 1) Adjust normal spray valve controller to 0% DEMAND 2) Verify PRZR spray valves - CLOSED <ul style="list-style-type: none"> • PCV-431A • PCV-431B <p>d. Verify auxiliary spray valve (AOV-296) - CLOSED</p> <p>e. Go to Step 24</p> | <p>a. Go to Step 22.</p> <p>c. Stop associated RCP(s).</p> <p>d. Decrease charging speed to minimum and ensure charging valve to loop B cold leg open (AOV-294).</p> |
|---|--|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

.....

CAUTION

- o THE PRT MAY RUPTURE IF A PRZR PORV IS USED TO DEPRESSURIZE THE RCS. THIS MAY RESULT IN ABNORMAL CNMT CONDITIONS.
- o CYCLING OF THE PRZR PORV SHOULD BE MINIMIZED.
- o THE UPPER HEAD REGION MAY VOID DURING RCS DEPRESSURIZATION IF RCPS ARE NOT RUNNING. THIS MAY RESULT IN A RAPIDLY INCREASING PRZR LEVEL.

.....

- NOTE:
- o If auxiliary spray is in use, spray flow may be increased by closing normal charging valve AOV-294 and normal PRZR spray valves.
 - o When using a PRZR PORV select one with an operable block valve.

22 Depressurize RCS Using PRZR PORV To Minimize Break Flow And Refill PRZR:

- | | |
|--|--|
| <ul style="list-style-type: none"> a. Verify IA to CNMT - AVAILABLE b. PRZR PORVs - AT LEAST ONE AVAILABLE | <ul style="list-style-type: none"> a. Refer to Attachment N2 PORVS to operate PORVs. b. <u>IF</u> auxiliary spray available, <u>THEN</u> return to Step 21b. <p><u>IF</u> auxiliary spray can <u>NOT</u> be established, <u>THEN</u> go to ECA-3.3, SGTR WITHOUT PRESSURIZER PRESSURE CONTROL, Step 1.</p> |
|--|--|

This Step continued on the next page.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

(Step 22 continued from previous page)

- c. Open one PRZR PORV until ANY of the following conditions satisfied:
 - o PRZR level - GREATER THAN 75% [65% adverse CNMT]
 - OR-
 - o RCS pressure - LESS THAN SATURATION USING FIGURE MIN SUBCOOLING
 - OR-
 - o BOTH of the following:
 - 1) RCS pressure - LESS THAN RUPTURED S/G PRESSURE
 - 2) PRZR level - GREATER THAN 5% [30% adverse CNMT]
- d. Close PRZR PORVs

- c. IF auxiliary spray available, THEN return to step 21b.
 - 1) IF auxiliary spray can NOT be established, THEN go to ECA-3.3, SGTR WITHOUT PRESSURIZER PRESSURE CONTROL, Step 1.
- d. IF either PRZR PORV can NOT be closed, THEN close associated block valve.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
23 Check RCS Pressure - INCREASING		<p>Close block valve for the PRZR PORV that was opened.</p> <p><u>IF</u> pressure continues to decrease, <u>THEN</u> perform the following:</p> <ul style="list-style-type: none">a. Monitor the following conditions for indication of leakage from PRZR PORV:<ul style="list-style-type: none">o PORV outlet temp (TI-438) <u>NOT</u> decreasing.o PRT pressure, level or temperature continue to increase.b. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 SI MUST BE TERMINATED WHEN TERMINATION CRITERIA ARE SATISFIED TO PREVENT
 OVERFILLING OF THE RUPTURED S/G.

24 Check If SI Flow Should Be Terminated:

- | | |
|---|--|
| <ul style="list-style-type: none"> a. RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING b. Secondary heat sink: <ul style="list-style-type: none"> o Total feed flow to S/G(s) - GREATER THAN 200 GPM AVAILABLE <li style="text-align: center;">-OR- o Narrow range level in at least one intact S/G - GREATER THAN 5% [25% adverse CNMT] c. RCS pressure - STABLE OR INCREASING d. PRZR level - GREATER THAN 5% [30% adverse CNMT] | <ul style="list-style-type: none"> a. Do <u>NOT</u> stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1. b. <u>IF</u> neither condition satisfied, <u>THEN</u> do <u>NOT</u> stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1. c. Do <u>NOT</u> stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1. d. Do <u>NOT</u> stop SI pumps. Return to Step 6. |
|---|--|

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
25	Stop SI Pumps And Place In AUTO	
26	Establish Required Charging Line Flow:	
	a. Charging pumps - ANY RUNNING	a. Perform the following: 1) <u>IF</u> CCW flow is lost to any RCP thermal barrier <u>OR</u> any RCP #1 seal outlet temperature offscale high, <u>THEN</u> dispatch AO with key to RWST gate to locally isolate seal injection to affected RCP: • RCP A, V-300A • RCP B, V-300B 2) Ensure HCV-142 open. 3) Start one charging pump.
	b. Establish 20 gpm charging line flow	

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
*27	Monitor SI Reinitiation Criteria:	
a.	RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING	a. Manually start SI pumps as necessary and go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.
b.	PRZR level - GREATER THAN 5% [30% adverse CNMT]	b. Control charging flow to maintain PRZR level.
		<u>IF</u> PRZR level can <u>NOT</u> be maintained, <u>THEN</u> manually start SI pumps as necessary and go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

28 Check If SI ACCUMs Should Be Isolated:

a. Check the following:

- o RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING
- o PRZR level - GREATER THAN 5% [30% adverse CNMT]

b. Dispatch AO with locked valve key to locally close breakers for SI ACCUM discharge valves

- MOV-841, MCC C position 12F
- MOV-865, MCC D position 12C

c. Close SI ACCUM discharge valves

- MOV-841
- MOV-865

d. Locally reopen breakers for MOV-841 and MOV-865

a. Manually operate SI pumps as necessary and go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

c. Vent any unisolated ACCUMs:

1) Open vent valves for unisolated SI ACCUMs.

- ACCUM A, AOV-834A
- ACCUM B, AOV-834B

2) Open HCV-945.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

29 Verify Adequate SW Flow To
CCW Hx:

- | | |
|--|--|
| <p>a. Verify at least three SW pumps -
RUNNING</p> | <p>a. Manually start pumps as power
supply permits (257 kw each).
<u>IF</u> less than two SW pumps can be
operated, <u>THEN</u> go to Step 36.</p> |
| <p>b. Verify AUX BLDG SW isolation
valves - AT LEAST ONE SET OPEN</p> <ul style="list-style-type: none"> • MOV-4615 and MOV-4734 • MOV-4616 and MOV-4735 | <p>b. Manually align valves.</p> |
| <p>c. Verify CNMT RECIRC fan
annunciator C-2, HIGH
TEMPERATURE ALARM - EXTINGUISHED</p> | <p>c. Dispatch AO to locally throttle
flow to CCW Hx to between
5000 gpm and 6000 gpm total flow.</p> |

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

30 Check If Normal CVCS
Operation Can Be Established

a. Verify IA restored:

- o IA to CNMT (AOV-5392) - OPEN
- o IA pressure - GREATER THAN
60 PSIG

b. Verify instrument bus D -
ENERGIZED

c. CCW pumps - ANY RUNNING

d. Charging pump - ANY RUNNING

a. Continue with Step 36. WHEN IA
restored, THEN do Steps 30
through 35.

b. Energize MCC B. IF MCC B NOT
available, THEN perform the
following:

- 1) Verify MCC A energized.
- 2) Place instrument bus D on
maintenance supply.

c. Perform the following:

- 1) IF any RCP #1 seal outlet
temperature offscale high,
THEN isolate CCW to thermal
barrier of affected RCP(s).

- RCP A, MOV-749A and MOV-759A
- RCP B, MOV-749B and MOV-759B

- 2) Manually start one CCW pump.

d. Continue with Step 36. WHEN any
charging pump running, THEN do
Steps 31 through 35.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

31 Check If Seal Return Flow
Should Be Established:

a. Verify RCP #1 seal outlet
temperature - LESS THAN 235°F

b. Verify RCP seal outlet valves -
OPEN

- AOV-270A
- AOV-270B

c. Reset both trains of XY relays
for RCP seal return isolation
valve MOV-313

d. Open RCP seal return isolation
valve MOV-313

e. Verify RCP #1 seal leakoff flow
- LESS THAN 6.0 GPM

f. Verify RCP #1 seal leakoff flow
- GREATER THAN 0.8 GPM

a. Go to Step 32.

b. Manually open valves as
necessary.

d. Perform the following:

- 1) Place MOV-313 switch to OPEN.
- 2) Dispatch AO with key to RWST
gate to locally open MOV-313.

e. Perform the following:

- 1) Trip the affected RCP
- 2) Allow 4 minutes for pump
coast down, THEN close the
affected RCP seal discharge
valve

- RCP A, AOV-270A
- RCP B, AOV-270B

IF both RCP seal discharge
valves are shut, THEN go to
Step 32.

f. Refer to AP-RCP.1, RCP SEAL
MALFUNCTION.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

32 Verify PRZR Level - GREATER THAN 13% [40% adverse CNMT]

Continue with Step 34. WHEN PRZR level increases to greater than 13% [40% adverse CNMT], THEN do Step 33.

33 Establish Normal Letdown:

IF RCP seal return has been established, THEN establish excess letdown as follows:

- a. Establish charging line flow to REGEN Hx - GREATER THAN 20 GPM
- b. Place the following switches to CLOSE:
 - Letdown orifice valves (AOV-200A, AOV-200B, and AOV-202)
 - Letdown isolation valve AOV-371
 - Loop B cold leg to REGEN Hx AOV-427
- c. Place letdown controllers in MANUAL at 40% open
 - TCV-130
 - PCV-135
- d. Reset both trains of XY relays for AOV-371 and AOV-427
- e. Open AOV-371 and AOV-427
- f. Open letdown orifice valves as necessary
- g. Place TCV-130 in AUTO at 105°F
- h. Place PCV-135 in AUTO at 250 psig
- i. Adjust charging pump speed and HCV-142 as necessary

- o Place excess letdown divert valve, AOV-312, to NORMAL.
- o Ensure CCW from excess letdown open, (AOV-745).
- o Open excess letdown isolation valve AOV-310.
- o Slowly open HCV-123 to maintain excess letdown temperature less than 195°F and pressure less than 100 psig.
- o Adjust charging pump speed as necessary.

IF RCP seal return NOT established, THEN consult TSC to determine if excess letdown should be placed in service.

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 32 of 41
-----------------	--	------------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

34 Check VCT Makeup System:

- | | |
|---|--|
| <ul style="list-style-type: none"> a. Adjust boric acid flow control valve in AUTO to 9.5 gpm b. Adjust RMW flow control valve in AUTO to 40 gpm c. Verify the following: <ul style="list-style-type: none"> 1) RMW mode selector switch in AUTO 2) RMW control armed - RED LIGHT LIT d. Check VCT level: <ul style="list-style-type: none"> o Level - GREATER THAN 20%
-OR- o Level - STABLE OR INCREASING | <ul style="list-style-type: none"> c. Adjust controls as necessary. d. Manually increase VCT makeup flow as follows: <ul style="list-style-type: none"> 1) Ensure BA transfer pumps and RMW pumps running. <u>IF NOT</u>, <u>THEN</u> reset MCC C and MCC D UV lockouts as necessary. 2) Place RMW flow control valve HCV-111 in MANUAL and increase RMW flow. 3) Increase boric acid flow as necessary. |
|---|--|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

35 Check Charging Pump Suction
Aligned To VCT:

a. VCT level - GREATER THAN 20%

a. IF VCT level can NOT be maintained greater than 5%, THEN perform the following:

1) Ensure charging pump suction aligned to RWST

o LCV-112B open

o LCV-112C closed

2) Continue with Step 36. WHEN VCT level greater than 40%, THEN do Step 35b.

b. Verify charging pumps aligned to VCT

b. Manually align valves as necessary.

o LCV-112C - OPEN

o LCV-112B - CLOSED

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
RCS AND RUPTURED S/G PRESSURES MUST BE MAINTAINED LESS THAN 1050 PSIG.

***36** Control RCS Pressure And Charging Flow To Minimize RCS-To-Secondary Leakage:

a. Perform appropriate action(s) from table:

PRZR LEVEL	RUPTURED S/G NARROW RANGE LEVEL		
	INCREASING	DECREASING	OFFSCALE HIGH
LESS THAN 13% [40% ADVERSE CNMT]	<ul style="list-style-type: none"> o Increase charging flow o Depressurize RCS using Step 36b 	<ul style="list-style-type: none"> o Increase charging flow 	<ul style="list-style-type: none"> o Increase charging flow o Maintain RCS and ruptured S/G pressure equal
BETWEEN 13% [40% ADVERSE CNMT] AND 50%	<ul style="list-style-type: none"> o Depressurize RCS using Step 36b 	<ul style="list-style-type: none"> o Energize PRZR heaters 	<ul style="list-style-type: none"> o Maintain RCS and ruptured S/G pressure equal
BETWEEN 50% AND 75% [65% ADVERSE CNMT]	<ul style="list-style-type: none"> o Depressurize RCS using Step 36b o Decrease charging flow 	<ul style="list-style-type: none"> o Energize PRZR heaters 	<ul style="list-style-type: none"> o Maintain RCS and ruptured S/G pressure equal
GREATER THAN 75% [65% ADVERSE CNMT]	<ul style="list-style-type: none"> o Decrease charging flow 	<ul style="list-style-type: none"> o Energize PRZR heaters 	<ul style="list-style-type: none"> o Maintain RCS and ruptured S/G pressure equal

b. Control pressure using normal PRZR spray, if available, to obtain desired results for Step 36a

b. IF letdown is in service, THEN use auxiliary spray (AOV-296). IF NOT, THEN use one PRZR PORV.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

37 Monitor If CNMT Spray Should Be Stopped:

- a. CNMT spray pumps - ANY RUNNING
- b. Verify CNMT pressure - LESS THAN 4 PSIG
- c. Reset CNMT spray
- d. Check NaOH tank outlet valves - CLOSED
 - AOV-836A
 - AOV-836B
- e. Stop CNMT spray pumps and place in AUTO
- f. Close CNMT spray pump discharge valves
 - MOV-860A
 - MOV-860B
 - MOV-860C
 - MOV-860D

- a. Go to Step 38.
- b. Continue with Step 38. WHEN CNMT pressure less than 4 psig, THEN do Steps 37c through f.
- d. Place NaOH tank outlet valve controllers to MANUAL and close valves.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

38 Check If Emergency D/Gs
Should Be Stopped:

- | | |
|--|--|
| <p>a. Verify AC emergency busses energized by offsite power:</p> <ul style="list-style-type: none"> o Emergency D/G output breakers - OPEN o AC emergency bus voltage - GREATER THAN 420 VOLTS o AC emergency bus normal feed breakers - CLOSED <p>b. Stop any unloaded emergency D/G and place in standby (Refer to Attachment D/G STOP)</p> | <p>a. Try to restore offsite power (Refer to ER-ELEC.1, RESTORATION OF OFFSITE POWER).</p> |
|--|--|

39 Minimize Secondary System
Contamination:

- | | |
|---|--|
| <p>a. Isolate reject from hotwell to CST:</p> <ul style="list-style-type: none"> o Place hotwell level controller (LC-107) in MANUAL at 50% o Verify hotwell level - STABLE <p>b. Check status of local actions to complete ruptured S/G isolation (Refer to Attachment RUPTURED S/G)</p> | <p>a. <u>IF</u> hotwell level increasing, <u>THEN</u> direct RP to sample hotwells for activity.</p> |
|---|--|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

40 Energize PRZR Heaters As
Necessary To Saturate PRZR
Water At Ruptured S/G Pressure

41 Check RCP Cooling:

Establish normal cooling to RCPs
(Refer to Attachment SEAL COOLING).

a. Check CCW to RCPs:

- o Annunciator A-7, RCP 1A CCW
RETURN HIGH TEMP OR LOW FLOW
- EXTINGUISHED
- o Annunciator A-15, RCP 1B CCW
RETURN HIGH TEMP OR LOW FLOW
- EXTINGUISHED

b. Check RCP seal injection:

- o Labyrinth seal D/Ps - GREATER
THAN 15 INCHES OF WATER

-OR-

- o RCP seal injection flow to
each RCP - GREATER THAN 6 GPM

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 IF RCP SEAL COOLING HAD PREVIOUSLY BEEN LOST, THEN THE AFFECTED RCP SHOULD NOT BE STARTED PRIOR TO A STATUS EVALUATION.

42 Check RCP Status:

a. RCPs - AT LEAST ONE RUNNING

a. Perform the following:

1) Try to start one RCP:

a) Ensure conditions for starting an RCP.

o Bus 11A or 11B energized.

o Refer to Attachment RCP START.

b) IF RVLIS level (no RCPs) less than 95%, THEN perform the following:

o Increase PRZR level to greater than 65% [82% adverse CNMT].

o Dump steam to establish RCS subcooling based on core exit T/Cs to greater than 20°F using Figure MIN SUBCOOLING.

o Energize PRZR heaters as necessary to saturate PRZR water

c) Start one RCP.

2) IF an RCP can NOT be started, THEN verify natural circulation (Refer to Attachment NC).

IF natural circulation can NOT be verified, THEN increase dumping steam.

b. Stop all but one RCP

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: Adverse CNMT conditions or loss of forced air cooling may result in failure of NIS detectors.

43 Check If Source Range Detectors Should Be Energized:

a. Source range channels - DEENERGIZED

a. Go to Step 43e.

b. Check intermediate range flux - EITHER CHANNEL LESS THAN 10⁻¹⁰ AMPS

b. Perform the following:

1) IF neither intermediate range channel is decreasing, THEN initiate boration.

2) Continue with Step 44. WHEN flux is LESS THAN 10⁻¹⁰ amps on any operable channel, THEN do Steps 43c through e.

c. Check the following:

c. Continue with Step 44. WHEN either condition met, THEN do Steps 43d and e.

o Both intermediate range channels - LESS THAN 10⁻¹⁰ AMPS

-OR-

o Greater than 20 minutes since reactor trip

d. Verify source range detectors - ENERGIZED

d. Manually energize source range detectors by depressing P-6 permissive defeat pushbuttons (2 of 2).

IF source ranges can NOT be restored, THEN refer to ER-NIS.1, SR MALFUNCTION and go to Step 44.

e. Transfer Rk-45 recorder to one source range and one intermediate range channel

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

44 Establish Normal Shutdown Alignment:

a. Check condenser - AVAILABLE

a. Dispatch A0 to perform Attachment SD-2.

b. Perform the following:

- o Open generator disconnects
 - 1G13A71
 - 9X13A73
- o Place voltage regulator to OFF
- o Open turbine drain valves
- o Rotate reheater steam supply controller cam to close valves
- o Place reheater dump valve switches to HAND
- o Stop all but one condensate pump

c. Verify adequate Rx head cooling:

- 1) Verify at least one control rod shroud fan - RUNNING
- 2) Verify one Rx compartment cooling fan - RUNNING

1) Manually start one fan as power supply permits (45 kw)

2) Perform the following:

- o Dispatch A0 to reset UV relays at MCC C and MCC D.
- o Manually start one fan as power supply permits (23 kw)

d. Verify Attachment SD-1 - COMPLETE

EOP:

E-3

TITLE:

STEAM GENERATOR TUBE RUPTURE

REV: 27

PAGE 41 of 41

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

45 Consult TSC To Determine
Appropriate Post-SGTR
Cooldown Procedure:

- o Go to ES-3.1, POST-SGTR COOLDOWN
USING BACKFILL, Step 1

-OR-

- o Go to ES-3.2, POST-SGTR COOLDOWN
USING BLOWDOWN, Step 1

-OR-

- o Go to ES-3.3, POST-SGTR COOLDOWN
USING STEAM DUMP, Step 1

-END-

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 1 of 1
-----------------	--	----------------------------

E-3 APPENDIX LIST

TITLE

- 1) RED PATH SUMMARY
- 2) FIGURE MIN SUBCOOLING (FIG-1.0)
- 3) ATTACHMENT CNMT RECIRC FANS (ATT-4.0)
- 4) ATTACHMENT D/G STOP (ATT-8.1)
- 5) ATTACHMENT N2 PORVS (ATT-12.0)
- 6) ATTACHMENT NC (ATT-13.0)
- 7) ATTACHMENT SEAL COOLING (ATT-15.2)
- 8) ATTACHMENT RCP START (ATT-15.0)
- 9) ATTACHMENT RUPTURED S/G (ATT-16.0)
- 10) ATTACHMENT SD-1 (ATT-17.0)
- 11) ATTACHMENT SD-2 (ATT-17.1)
- 12) FOLDOUT

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 1 of 1
-------------	--	------------------------

RED PATH SUMMARY

- a. SUBCRITICALITY - Nuclear power greater than 5%
- b. CORE COOLING - Core exit T/Cs greater than 1200°F
-OR-
Core exit T/Cs greater than 700°F AND
RVLIS level (no RCPs) less than 52% [55%
adverse CNMT]
- c. HEAT SINK - Narrow range level in all S/Gs less than 5%
[25% adverse CNMT] AND total feedwater flow
less than 200 gpm
- d. INTEGRITY - Cold leg temperatures decrease greater than
100°F in last 60 minutes AND RCS cold leg
temperature less than 285°F
- e. CONTAINMENT - CNMT pressure greater than 60 psig

EOP: E-3	TITLE: STEAM GENERATOR TUBE RUPTURE	REV: 27 PAGE 1 of 1
-----------------	--	----------------------------

FOLDOUT PAGE

1. SI REINITIATION CRITERIA

Following SI termination, IF either condition listed below occurs, THEN start SI pumps manually as necessary and go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1:

- o RCS subcooling based on core exit T/Cs - LESS THAN 0°F USING REQUIREMENTS OF FIGURE MIN SUBCOOLING.

OR

- o PRZR level - CHARGING CAN NOT CONTROL LEVEL GREATER THAN 5% [30% adverse CNMT].

2. SECONDARY INTEGRITY CRITERIA

IF any S/G pressure is decreasing in an uncontrolled manner or is completely depressurized AND has not been isolated, THEN go to E-2, FAULTED S/G ISOLATION, Step 1, UNLESS faulted S/G needed for RCS cooldown.

3. COLD LEG RECIRCULATION SWITCHOVER CRITERION

IF RWST level decreases to less than 28%, THEN go to ES-1.3, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

4. AFW SUPPLY SWITCHOVER CRITERION

IF CST level decreases to less than 5 feet, THEN switch to alternate AFW water supply (Refer to ER-AFW.1, ALTERNATE WATER SUPPLY TO AFW PUMPS).

5. MULTIPLE S/G TUBE RUPTURE CRITERIA

IF any intact S/G level increases in in an uncontrolled manner OR IF any intact S/G has abnormal radiation, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 1 of 27
-----------------	---	-------------------------

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 23



RESPONSIBLE MANAGER

2-28-2001

EFFECTIVE DATE

CATEGORY 1.0

REVIEWED BY: _____

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 2 of 27
-----------------	---	-------------------------

- A. PURPOSE - This procedure provides actions for a SGTR with coincident loss of normal and auxiliary PRZR sprays and PORVs.
- B. ENTRY CONDITIONS/SYMPTOMS
 - 1. ENTRY CONDITIONS - This procedure is entered from:
 - a. E-3, STEAM GENERATOR TUBE RUPTURE, when PRZR pressure control is not available.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

- NOTE:
- o Foldout page should be open AND monitored periodically.
 - o Adverse CNMT values should be used whenever CNMT pressure is greater than 4 psig or CNMT radiation is greater than 10^{+05} R/hr.

1 Check Ruptured S/G Narrow
Range Level - LESS THAN 80%
[60% adverse CNMT]

Go to Step 8.

2 Check RCP Status - AT LEAST
ONE RUNNING

Try to start one RCP:

a. Establish conditions for
starting RCP.

- o Bus 11A and Bus 11B energized

- o Refer to Attachment RCP START

b. Start one RCP. IF no RCP can be
started, THEN go to Step 4.

3 Check IF Normal PRZR Spray
Available:

a. Verify the following:

- 1) Verify IA to CNMT - AVAILABLE

- 2) Verify spray valve associated
with running RCP - OPERABLE

a. Perform the following:

- 1) Place PRZR heater control
group to PULL STOP.

- 2) Place PRZR heater backup
group to OFF.

- 3) Place normal spray valve
controllers to MANUAL at 0%.

- 4) Go to Step 4.

b. Go to E-3, STEAM GENERATOR TUBE
RUPTURE, Step 21

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

4 Try To Restore PRZR PORV:

a. Block valves - AT LEAST ONE OPEN

- MOV-516 for PCV-430
- MOV-515 for PCV-431C

b. Check IA to CNMT - AVAILABLE

c. Verify at least one PRZR PORV flow path - AVAILABLE

d. Go to E-3, STEAM GENERATOR TUBE RUPTURE, Step 22

a. Open one block valve unless it was closed to isolate an open PORV.

If block valves can NOT be opened, THEN dispatch A0 to locally ensure breakers to block valves closed.

- MOV-515, MCC D position 6C
- MOV-516, MCC C position 6C

b. Refer to Attachment N2 PORVS to operate PORVs.

c. Go to Step 5.

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 5 of 27
-----------------	---	-------------------------

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: If auxiliary spray is the only means of RCS pressure control, THEN the 320°F ΔT limit between the spray line and PRZR does not apply.

5 Try To Establish Auxiliary Spray:

a. Charging pumps - AT LEAST ONE RUNNING

a. Perform the following:

- 1) IF CCW flow is lost to any RCP thermal barrier OR any RCP #1 seal outlet temperature offscale high, THEN locally isolate seal injection to affected RCP.

- RCP A, V-300A
- RCP B, V-300B

2) Ensure HCV-142 demand at 0%.

3) Start charging pumps as necessary.

IF charging not available, THEN go to Step 6.

b. Establish auxiliary spray flow:

b. IF auxiliary spray can NOT be established, THEN go to Step 6.

1) Open auxiliary spray valve (AOV-296)

2) Close charging valve to loop B cold leg (AOV-294)

c. Go to E-3, STEAM GENERATOR TUBE RUPTURE, Step 21b

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: TDAFW pump flow control valves fail open on loss of IA.

* 6 Monitor Intact S/G Level:

a. Narrow range level - GREATER THAN 5% [25% adverse CNMT]

a. Maintain total feed flow greater than 200 gpm until narrow range level greater than 5% [25% adverse CNMT] in at least one S/G.

b. Control feed flow to maintain narrow range level between 17% [25% adverse CNMT] and 50%

b. IF narrow range level in intact S/G continues to increase in an uncontrolled manner, THEN go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

7 Check PRZR Level - GREATER THAN 5% [30% adverse CNMT]

Return to Step 1.

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 7 of 27
-----------------	---	-------------------------

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

8 Check If SI Can Be Terminated:

a. RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING

a. Do NOT stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

b. Secondary heat sink:

b. IF neither condition satisfied, THEN do NOT stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

o Total feed flow to intact S/Gs - GREATER THAN 200 GPM AVAILABLE

-OR-

o Narrow range level in intact S/G - GREATER THAN 5% [25% adverse CNMT]

c. RVLIS indication

c. Do NOT stop SI pumps. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

o Level (no RCPs) - GREATER THAN 77% [82% adverse CNMT]

-OR-

o Fluid fraction (any RCP running) - GREATER THAN 84%

d. Any ruptured S/G narrow range level - INCREASING IN AN UNCONTROLLED MANNER OR OFFSCALE HIGH

d. Do NOT stop SI pumps. Return to Step 2.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

9 Stop SI Pumps and Place In
AUTO

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

10 Check If Charging Flow Has Been Established:

a. Charging pumps - ANY RUNNING

a. Perform the following:

- 1) IF CCW flow is lost to any RCP thermal barrier OR any RCP #1 seal outlet temperature offscale high, THEN dispatch AO with key to RWST gate to close seal injection needle valve(s) to affected RCP:

- RCP A, V-300A
- RCP B, V-300B

- 2) Ensure HCV-142 open, demand at 0%.

b. Charging pump suction aligned to RWST:

b. Manually align valves as necessary.

- o LCV-112B - OPEN
- o LCV-112C - CLOSED

IF LCV-112B can NOT be opened, THEN dispatch AO to locally open manual charging pump suction from RWST (V-358 located in charging pump room).

IF LCV-112C can NOT be closed, THEN perform the following:

- 1) Verify charging pump A NOT running and place in PULL STOP.
- 2) Direct AO to close V-268 to isolate charging pumps B and C from VCT (V-268 located in charging pump room).

c. Start charging pumps as necessary and adjust charging flow to perform the following:

- o Restore PRZR level
- o Maintain RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

***11 Monitor RCS Inventory:**

- o RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING
- o RVLIS indication
 - o Level (no RCPs) - GREATER THAN 77% [82% adverse CNMT]
- OR-
- o Fluid fraction (any RCP running) - GREATER THAN 84%

Perform the following:

- a. Manually start SI pumps as necessary.
- b. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1.

12 Verify Adequate SW Flow To CCW Hx:

- a. Verify at least two SW pumps - RUNNING
- b. Verify AUX BLDG SW isolation valves - OPEN
 - MOV-4615 and MOV-4734
 - MOV-4616 and MOV-4735
- c. Verify CNMT RECIRC fan annunciator C-2, HIGH TEMPERATURE ALARM - EXTINGUISHED

- a. Manually start pumps as power supply permits (257 kw per pump). IF less than two SW pumps can be operated, THEN go to Step 20.
- b. Manually align valves.
- c. Dispatch AO to locally throttle flow to CCW Hx to between 5000 gpm and 6000 gpm total flow.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

13 Check If Normal CVCS
Operation Can Be Established

a. Verify IA restored:

- o IA to CNMT (AOV-5392) - OPEN
- o IA pressure - GREATER THAN
60 PSIG

b. Verify instrument bus D -
ENERGIZED

c. CCW pumps - ANY RUNNING

d. Charging pump - ANY RUNNING

a. Continue with Step 17. WHEN IA restored, THEN do Steps 13 through 16.

b. Energize MCC B. IF MCC B NOT available, THEN perform the following:

- 1) Verify MCC A energized.
- 2) Place instrument bus D on maintenance supply.

c. Perform the following:

- 1) IF any RCP #1 seal outlet temperature offscale high, THEN isolate CCW to thermal barrier of affected RCP(s).

- RCP A, MOV-749A and MOV-759A
- RCP B, MOV-749B and MOV-759B

- 2) Manually start one CCW pump.

d. Continue with Step 20. WHEN any charging pump running, THEN do Steps 14 through 17.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: If PRZR level is less than 13%, letdown may be established by placing AOV-427 to OPEN.

14 Establish Normal Letdown:

- a. Establish charging line flow to REGEN Hx - GREATER THAN 20 GPM
- b. Place the following switches to CLOSE:
 - Letdown orifice valves (AOV-200A, AOV-200B, and AOV-202)
 - AOV-371, letdown isolation valve
 - AOV-427, loop B cold leg to REGEN Hx
- c. Place letdown controllers in MANUAL at 40% open
 - TCV-130
 - PCV-135
- d. Reset both trains of XY relays for AOV-371 and AOV-427
- e. Open AOV-371 and AOV-427
- f. Open letdown orifice valves as necessary
- g. Place TCV-130 in AUTO at 105°F
- h. Place PCV-135 in AUTO at 250 psig
- i. Adjust charging pump speed and HCV-142 as necessary

IF RCP seal return has been established, THEN establish excess letdown as follows:

- o Place excess letdown divert valve, AOV-312, to NORMAL.
- o Ensure CCW from excess letdown open. (AOV-745).
- o Open excess letdown isolation valve AOV-310.
- o Slowly open HCV-123 to maintain excess letdown temperature less than 195°F and pressure less than 100 psig.
- o Adjust charging pump speed as necessary.

IF RCP seal return NOT established, THEN consult TSC to determine if excess letdown should be placed in service.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

15 Check VCT Makeup System:

- | | |
|---|--|
| <ul style="list-style-type: none"> a. Adjust boric acid flow control valve in AUTO to 9.5 gpm b. Adjust RMW flow control valve in AUTO to 40 gpm c. Verify the following: <ul style="list-style-type: none"> 1) RMW mode selector switch in AUTO 2) RMW control armed - RED LIGHT LIT d. Check VCT level: <ul style="list-style-type: none"> o Level - GREATER THAN 20%
-OR- o Level - STABLE OR INCREASING | <ul style="list-style-type: none"> c. Adjust controls as necessary. d. Manually increase VCT makeup flow as follows: <ul style="list-style-type: none"> 1) Ensure BA transfer pumps and RMW pumps running. <u>IF NOT</u>, <u>THEN</u> reset MCC C and MCC D UV lockouts as necessary. 2) Place RMW flow control valve HCV-111 in MANUAL. 3) Increase RMW flow. |
|---|--|

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 14 of 27
-----------------	---	--------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
16 Check Charging Pump Suction Aligned To VCT:	<p>a. VCT level - GREATER THAN 20%</p> <p>b. Verify charging pumps aligned to VCT</p> <ul style="list-style-type: none"> o LCV-112C - OPEN o LCV-112B - CLOSED 	<p>a. <u>IF</u> VCT level can <u>NOT</u> be maintained greater than 5%. <u>THEN</u> perform the following:</p> <ol style="list-style-type: none"> 1) Ensure charging pump suction aligned to RWST <ul style="list-style-type: none"> o LCV-112B open o LCV-112C closed 2) Continue with Step 17. <u>WHEN</u> VCT level greater than 40%, <u>THEN</u> do Step 16b. <p>b. Manually align valves as necessary.</p>

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
17 Check RCP Cooling:	<ul style="list-style-type: none">a. Check CCW to RCPs:<ul style="list-style-type: none">o Annunciator A-7, RCP 1A CCW RETURN HIGH TEMP OR LOW FLOW - EXTINGUISHEDo Annunciator A-15, RCP 1B CCW RETURN HIGH TEMP OR LOW FLOW - EXTINGUISHEDb. Check RCP seal injection:<ul style="list-style-type: none">o Labyrinth seal D/Ps - GREATER THAN 15 INCHES OF WATER	Establish normal cooling to RCPs (Refer to Attachment SEAL COOLING).
	-OR-	
	<ul style="list-style-type: none">o RCP seal injection flow to each RCP - GREATER THAN 6 GPM	

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 16 of 27
-----------------	---	--------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
18 Check If Seal Return Flow Should Be Established:		
a. Verify RCP #1 seal outlet temperature - LESS THAN 235°F		a. Go to Step 19.
b. Verify RCP seal outlet valves - OPEN • AOV-270A • AOV-270B		b. Manually open valves as necessary.
c. Reset both trains of XY relays for RCP seal return isolation valve MOV-313		
d. Open RCP seal return isolation valve MOV-313		d. Perform the following: 1) Place MOV-313 switch to OPEN. 2) Dispatch AO with key to RWST gate to locally open MOV-313.
e. Verify RCP #1 seal leakoff flow - LESS THAN 6.0 GPM		e. Perform the following: 1) Trip the affected RCP 2) Allow 4 minutes for pump coast down, <u>THEN</u> close the affected RCP seal discharge valve • RCP A, AOV-270A • RCP B, AOV-270B
		IF both RCP seal discharge valves are shut, <u>THEN</u> go to Step 19.
f. Verify RCP #1 seal leakoff flow - GREATER THAN 0.8 GPM		f. Refer to AP-RCP.1, RCP SEAL MALFUNCTION.

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 17 of 27
-----------------	---	--------------------------

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

19 Equalize Charging And Letdown Flows:

- a. Verify charging pump controllers in manual
- b. Control charging and seal injection flows to equal letdown and seal leakoff flows

20 Check If Emergency D/Gs Should Be Stopped:

- | | |
|--|---|
| <ul style="list-style-type: none"> a. Verify AC emergency busses energized by offsite power: <ul style="list-style-type: none"> o Emergency D/G output breakers - OPEN o AC emergency bus voltage - GREATER THAN 420 VOLTS o AC emergency bus normal feed breakers - CLOSED b. Stop any unloaded emergency D/G and place in standby (Refer to Attachment D/G STOP) | <ul style="list-style-type: none"> a. Try to restore offsite power (Refer to ER-ELEC.1, RESTORATION OF OFFSITE POWER). |
|--|---|

21 Minimize Secondary System Contamination:

- | | |
|---|---|
| <ul style="list-style-type: none"> a. Isolate reject from hotwell to CST: <ul style="list-style-type: none"> o Place hotwell level controller (HC-107) in MANUAL at 50% o Verify hotwell level - STABLE b. Verify local actions to complete isolation of ruptured S/G (Refer to Attachment RUPTURED S/G) | <ul style="list-style-type: none"> a. <u>IF</u> hotwell level increasing, <u>THEN</u> direct RP to sample hotwells for activity. |
|---|---|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: Adverse CNMT conditions or loss of forced air cooling may result in failure of NIS detectors.

22 Check If Source Range Detectors Should Be Energized:

- | | |
|--|---|
| <p>a. Source range channels - DEENERGIZED</p> <p>b. Check intermediate range flux - EITHER CHANNEL LESS THAN 10^{-10} AMPS</p> <p>c. Check the following:</p> <ul style="list-style-type: none"> o Both intermediate range channels - LESS THAN 10^{-10} AMPS <p style="text-align: center;">-OR-</p> <ul style="list-style-type: none"> o Greater than 20 minutes since reactor trip <p>d. Verify source range detectors - ENERGIZED</p> <p>e. Transfer Rk-45 recorder to one source range and one intermediate range channel</p> | <p>a. Go to Step 22e.</p> <p>b. Perform the following:</p> <ul style="list-style-type: none"> 1) <u>IF</u> neither intermediate range channel is decreasing, <u>THEN</u> initiate boration. 2) Continue with Step 23. <u>WHEN</u> flux is LESS THAN 10^{-10} amps on any operable channel, <u>THEN</u> do Steps 22c through e. <p>c. Continue with Step 23. <u>WHEN</u> either condition met, <u>THEN</u> do Steps 22d and e.</p> <p>d. Manually energize source range detectors by depressing P-6 permissive defeat pushbuttons (2 of 2).</p> <p><u>IF</u> source ranges can <u>NOT</u> be restored, <u>THEN</u> refer to ER-NIS.1, SR MALFUNCTION and go to Step 22.</p> |
|--|---|

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 19 of 27
-----------------	---	--------------------------

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

23 Establish Normal Shutdown Alignment:

a. Check condenser - AVAILABLE

a. Dispatch AO to perform Attachment SD-2.

b. Perform the following:

- o Open generator disconnects
 - 1G13A71
 - 9X13A73
- o Place voltage regulator to OFF
- o Open turbine drain valves
- o Rotate reheater steam supply controller cam to close valves
- o Place reheater dump valve switches to HAND
- o Stop all but one condensate pump

c. Verify adequate Rx head cooling:

- 1) Verify at least one control rod shroud fan - RUNNING
- 2) Verify one Rx compartment cooling fan - RUNNING

1) Manually start one fan as power supply permits (45 kw)

2) Perform the following:

- o Dispatch AO to reset UV relays at MCC C and MCC D.
- o Manually start one fan as power supply permits (23 kw)

d. Verify Attachment SD-1 - COMPLETE

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: Plant staff should decide whether to repair PRZR pressure control systems or continue with this procedure. If PRZR pressure control is established, PRZR level should be restored to greater than 5% [30% adverse CNMT] and then further recovery should continue with E-3, STEAM GENERATOR TUBE RUPTURE, Step 32.

24 Check If SI ACCUMs Should Be Isolated:

a. Check the following:

- o RCS subcooling based on core exit T/Cs - GREATER THAN 0°F USING FIGURE MIN SUBCOOLING
- o RVLIS indication
 - o Level (no RCPs - GREATER THAN 77% [82% adverse CNMT])

-OR-

b. Dispatch AO with locked valve key to locally close breakers for SI ACCUM discharge valves

- MOV-841, MCC C position 12F
- MOV-865, MCC D position 12C

c. Close SI ACCUM discharge valves

- MOV-841
- MOV-865

d. Locally reopen breakers for MOV-841 and MOV-865

a. Return to Step 11.

c. Vent any unisolated ACCUMs:

- 1) Open vent valves for unisolated SI ACCUMs.

- ACCUM A, AOV-834A
- ACCUM B, AOV-834B

- 2) Open HCV-945.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE: Leakage from ruptured S/G into RCS will dilute RCS boron concentration.

25 Verify Adequate Shutdown Margin

- a. Direct RP to sample RCS and ruptured S/G for boron concentration
- b. Verify boron concentration -
GREATER THAN REQUIREMENTS OF
FIGURE SDM

- b. Borate as necessary.

26 Maintain Required RCP Seal Injection Flow And Labyrinth Seal D/P:

- o Labyrinth seal D/P to each RCP -
GREATER THAN 15 INCHES OF WATER
- o RCP seal injection flow -
GREATER THAN 6 GPM

Perform the following:

- o Adjust charging flow to REGEN Hx, HCV-142 as necessary.

-OR-

- o Dispatch AO to adjust seal injection needle valves V-300A and V-300B if necessary.

27 Initiate RCS Cooldown to 350°F In RCS Cold Legs:

- a. Establish and maintain cooldown rate in RCS cold legs - LESS THAN 100°F/HR
- b. Dump steam to condenser from intact S/G

- b. Manually or locally dump steam using intact S/G ARV.

IF no intact S/G available, THEN use faulted S/G.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
------	--------------------------	-----------------------

CAUTION
 RCS AND RUPTURED S/G PRESSURES MUST BE MAINTAINED LESS THAN THE RUPTURED S/G
 ARV SETPOINT.

28 Control Charging Flow To
 Maintain RCS Subcooling:

- | | |
|--|--|
| <p>a. RCS subcooling based on core exit T/Cs - GREATER THAN 20°F USING FIGURE MIN SUBCOOLING</p> <p>b. Ruptured S/G narrow range level - LESS THAN 90% [80% adverse CNMT]</p> <p>c. Ruptured S/G narrow range level - STABLE OR DECREASING</p> | <p>a. Increase charging flow to maintain subcooling greater than 20°F using Figure MIN SUBCOOLING and go to Step 29.</p> <p>b. Control charging flow to maintain RCS pressure at ruptured S/G pressure and go to Step 29.</p> <p>c. <u>IF</u> ruptured S/G level increasing, <u>THEN</u> decrease charging flow to stabilize level. Maintain RCS subcooling greater than 20°F using Figure MIN SUBCOOLING.</p> |
|--|--|

29 Check If RCS Cooldown Should Be Stopped:

- | | |
|---|------------------------------|
| <p>a. RCS cold leg temperatures - LESS THAN 350°F</p> <p>b. Stop RCS cooldown</p> | <p>a. Return to Step 25.</p> |
|---|------------------------------|

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
30	Check RCS Pressure - GREATER THAN 400 PSIG [300 PSIG adverse CNMT]	Go to Step 33.
*31	Monitor Ruptured S/G Narrow Range Level - GREATER THAN 17% [25% adverse CNMT]	<p>Refill ruptured S/G to 80% [60% adverse CNMT] using feed flow.</p> <p><u>IF</u> any of the following conditions occurs, <u>THEN</u> stop feed flow to ruptured S/G:</p> <ul style="list-style-type: none"> o Ruptured S/G pressure decreases in an uncontrolled manner. <p style="text-align: center;">-OR-</p> <ul style="list-style-type: none"> o Ruptured S/G pressure increases to 1020 psig. <p style="text-align: center;">-OR-</p> <ul style="list-style-type: none"> o Ruptured S/G pressure decreases to 350 psig psig <u>AND</u> ruptured S/G level greater than 5% [25% adverse CNMT]

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT.OBTAINED

CAUTION
 o STEAM SHOULD NOT BE RELEASED FROM A RUPTURED S/G IF WATER MAY EXIST IN ITS STEAMLINe.
 o RUPTURED S/G PRESSURE MAY DECREASE RAPIDLY WHEN STEAM IS RELEASED.

32 Depressurize RCS And Ruptured S/G To 400 PSIG [300 PSIG adverse CNMT]

a. Perform the following:

- o Decrease charging and increase letdown to initiate backfill

-OR-

- o Initiate blowdown from ruptured S/G

-OR-

- o Dump steam from ruptured S/G

b. Check RCS pressure - LESS THAN 400 psig [300 psig adverse CNMT]

b. Return to Step 31.

c. Stop RCS depressurization

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

33 Check If RHR Normal Cooling
Can Be Established:

- | | |
|---|---|
| <p>a. RCS cold leg temperature - LESS THAN 350°F</p> <p>b. RCS pressure - LESS THAN 400 psig [300 psig adverse CNMT]</p> <p>c. Place RCS overpressure protection system in service (Refer to O-7, ALIGNMENT AND OPERATION OF THE REACTOR VESSEL OVERPRESSURE PROTECTION SYSTEM)</p> <p>d. Establish RHR normal cooling (Refer to Attachment RHR COOL)</p> | <p>a. Return to Step 27.</p> <p>b. Return to Step 31.</p> <p>c. <u>IF</u> RCS overpressure protection system can <u>NOT</u> be placed in service, <u>THEN</u> notify TSC of potential Tech Spec violation if RHR system is placed in service.</p> |
|---|---|

NOTE: Leakage from ruptured S/G into RCS will dilute RCS boron concentration.

34 Verify Adequate Shutdown
Margin

- | | |
|---|--------------------------------|
| <p>a. Direct RP to sample RCS and ruptured S/G for boron concentration</p> <p>b. Verify boron concentration - GREATER THAN REQUIREMENTS OF FIGURE SDM</p> | <p>b. Borate as necessary.</p> |
|---|--------------------------------|

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

35 Initiate RCS Cooldown To Cold Shutdown:

- a. Establish and maintain cooldown rate in RCS cold legs - LESS THAN 100°F/HR
- b. Use RHR system if in service
- c. Dump steam to condenser from intact S/G

- c. Manually or locally dump steam from intact S/G using ARVs.

IF no intact S/G available and RHR system NOT in service, THEN use faulted S/G.

36 Control Charging Flow To Maintain RCS Subcooling:

- a. RCS subcooling based on core exit T/Cs - GREATER THAN 20°F USING FIGURE MIN SUBCOOLING
- b. Ruptured S/G narrow range level - LESS THAN 90% [80% adverse CNMT]
- c. Ruptured S/G narrow range level - STABLE OR DECREASING

- a. Increase charging flow to maintain subcooling greater than 20°F using Figure MIN SUBCOOLING and go to Step 37.

- b. Control charging flow to maintain RCS pressure at ruptured S/G pressure and go to Step 37.

- c. IF ruptured S/G level increasing, THEN decrease charging flow to stabilize level. Maintain RCS subcooling greater than 20°F using Figure MIN SUBCOOLING.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

***37 Monitor RCP Operation:**

- | | |
|--|------------------------------|
| a. RCPs - ANY RUNNING | a. Go to Step 39. |
| b. Check the following: | b. Stop the affected RCP(s). |
| o RCP #1 seal D/P - GREATER
THAN 220 PSID | |
| o Check RCP seal leakage -
WITHIN THE NORMAL OPERATING
RANGE OF FIGURE RCP SEAL
LEAKOFF | |

38 Check Core Exit T/Cs - LESS
THAN 200° F

Return to Step 34.

39 Evaluate Long Term Plant
Status:

- a. Maintain cold shutdown conditions
- b. Consult TSC

-END-

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 1 of 1
-----------------	---	------------------------

ECA-3.3 APPENDIX LIST

TITLE

- 1) RED PATH SUMMARY
- 2) FIGURE MIN SUBCOOLING (FIG-1.0)
- 3) FIGURE SDM (FIG-2.0)
- 4) FIGURE RCP SEAL LEAKOFF (FIG-4.0)
- 5) ATTACHMENT RCP START (ATT-15.0)
- 6) ATTACHMENT N2 PORVS (ATT-12.0)
- 7) ATTACHMENT RUPTURED S/G (ATT-16.0)
- 8) ATTACHMENT D/G STOP (ATT-8.1)
- 9) ATTACHMENT SD-1 (ATT-17.0)
- 10) ATTACHMENT SEAL COOLING (ATT-15.2)
- 11) ATTACHMENT SD-2 (ATT-17.1)
- 12) ATTACHMENT RHR COOL (ATT-14.1)
- 13) FOLDOUT

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 1 of 1
-----------------	---	------------------------

RED PATH SUMMARY

- a. SUBCRITICALITY - Nuclear power greater than 5%
- b. CORE COOLING - Core exit T/Cs greater than 1200°F
-OR-
Core exit T/Cs greater than 700°F AND
RVLIS level (no RCPs) less than 52% [55%
adverse CNMT]
- c. HEAT SINK - Narrow range level in all S/Gs less than 5%
[25% adverse CNMT] AND total feedwater flow
less than 200 gpm
- d. INTEGRITY - Cold leg temperatures decrease greater than
100°F in last 60 minutes AND RCS cold leg
temperature less than 285°F
- e. CONTAINMENT - CNMT pressure greater than 60 psig

EOP: ECA-3.3	TITLE: SGTR WITHOUT PRESSURIZER PRESSURE CONTROL	REV: 24 PAGE 1 of 1
-----------------	---	------------------------

FOLDOUT PAGE

1. SI REINITIATION CRITERIA

IF EITHER condition listed below occurs, THEN manually start SI pumps as necessary and go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED, Step 1:

- o RCS subcooling based on core exit TCs - LESS THAN 0°F USING REQUIREMENTS OF FIGURE MIN SUBCOOLING

- OR -

- o Check RVLIS indication:

Level (no RCPs) - LESS THAN 77% [82% adverse CNMT]
Fluid Fraction (any RCP running) - LESS THAN 84%

2. SECONDARY INTEGRITY CRITERIA

IF any S/G pressure is decreasing in an uncontrolled manner or is completely depressurized AND has not been isolated, THEN go to E-2, FAULTED S/G ISOLATION, Step 1, UNLESS faulted S/G needed for RCS cooldown.

3. COLD LEG RECIRCULATION SWITCHOVER CRITERION

IF RWST level decreases to less than 28%, THEN go to ES-1.3, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

4. AFW SUPPLY SWITCHOVER CRITERION

IF CST level decreases to less than 5 feet, THEN switch to alternate AFW water supply (Refer to ER-AFW.1, ALTERNATE WATER SUPPLY TO AFW PUMPS).

EOP: FIG-4.0	TITLE: FIGURE RCP SEAL LEAKOFF	REV: 2 PAGE 1 of 1
-----------------	-----------------------------------	-----------------------

Responsible Manager *Richard J. ...*

Date 2-28-2001

FIGURE RCP SEAL LEAKOFF

#1 SEAL LEAK RATE (GPM)

