

March 14, 2001

Mr. H. L. Sumner, Jr.
Vice President - Nuclear
Hatch Project
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT -
EDWIN I. HATCH NUCLEAR PLANT, UNIT 2 (TAC NO. MB1379)

Dear Mr. Sumner:

The Commission has requested the Office of the *Federal Register* to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing." This notice relates to your amendment application dated March 9, 2001, which would revise the Technical Specifications only until the Fall 2001, Unit 2, refueling outage. The revision would allow Mode 2 (startup) operation with two required intermediate range monitors per trip system.

Sincerely,

/RA/

Leonard N. Olshan, Senior Project Manager
Project Directorate II-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-366

Enclosure: Notice

cc w/encl: See next page

March 14, 2001

Mr. H. L. Sumner, Jr.
Vice President - Nuclear
Hatch Project
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT -
EDWIN I. HATCH NUCLEAR PLANT, UNIT 2 (TAC NO. MB1379)

Dear Mr. Sumner:

The Commission has requested the Office of the *Federal Register* to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing." This notice relates to your amendment application dated March 9, 2001, which would revise the Technical Specifications only until the Fall 2001, Unit 2, refueling outage. The revision would allow Mode 2 (startup) operation with two required intermediate range monitors per trip system.

Sincerely,

/RA/

Leonard N. Olshan, Senior Project Manager
Project Directorate II-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-366

Enclosure: Notice

cc w/encl: See next page

Distribution: MBanerjee RidsOgcRp
PUBLIC RErch RidsAcrcAcnwMailCenter
PDII-1 Rdg. CHawes RidsRgn2MailCenter
GJanosko LOlshan
Document Name: C:\INDMB1379.wpd

OFFICE	PDII-1:PM	PDII-1:LA	PDII-1:SC(A)
NAME	LOlshan:cn	CHawes	MBanerjee
DATE	3/14/2001	3/13/2001	3/14/2001

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION
SOUTHERN NUCLEAR OPERATING COMPANY, INC., ET AL
DOCKET NO. 50-366

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-5 issued to the Southern Nuclear Operating Company, Inc., et al (the licensee) for operation of Edwin I. Hatch Nuclear Plant, Unit 2, located in Appling County, Georgia.

The proposed amendment would allow Mode 2 (startup) operation with two required intermediate range monitor (IRM) channels and will be in effect only until the Fall 2001 refueling outage.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As

required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

The intermediate range monitors (IRMs) monitor neutron flux levels in the reactor core during startup. The IRM detectors are capable of generating a trip signal during a continuous rod withdrawal error in the startup range. However, the IRMs perform no function related to the probability of occurrence of a previously evaluated accident. Also, the IRM trip signal is not necessary to mitigate the limiting control rod withdrawal error. The limiting case assumes the trip signal is generated from the safety-related average power range monitor (APRM). Therefore, the consequences of this previously evaluated abnormal operating transient are not increased.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

The proposed change reduces the number of required operable IRM channels per trip system from three to two. However, the manner in which the actuation logic functions and the systems respond are unaffected by the proposed change. Furthermore, the IRMs will continue to perform their design function of core monitoring during startup and mitigating non-limiting transient events that are postulated to occur during startup. Therefore, the proposed change cannot create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

The Bases for Unit 2 Technical Specifications Table 3.3.1.1-1 state that the "IRMs are capable of generating trip signals that can be used to prevent fuel damage resulting from abnormal operating transients in the intermediate power [startup] range." The proposed change ensures the IRMs will still effectively mitigate these events. The most significant source of reactivity change is due to a control rod withdrawal error. With the proposed change, the IRMs will continue to provide protection against rod withdrawal errors, and peak fuel energy depositions will remain below the 170 cal/gm threshold criterion defined in the Technical Specifications Bases. Therefore, the proposed change does not reduce a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By April 19, 2001, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing

and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>). If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must

consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Ernest L. Blake, Jr., Esquire, Shaw, Pittman, Potts and Trowbridge, 2300 N Street, NW., Washington, DC, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated March 9, 2001, which is available for public inspection at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 14th day of March 2001

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Leonard N. Olshan, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation