



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 12, 2001

Mr. J. A. Scalice  
Chief Nuclear Officer  
and Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2, AND 3 - ISSUANCE OF  
AMENDMENTS RELATING TO LOW-PRESSURE COOLANT INJECTION PUMP  
OPERABILITY REQUIREMENTS (TAC NOS. MB0161, MB0162 AND MB0163)

Dear Mr. Scalice:

The Commission has issued the enclosed Amendment Nos. 240, 269, and 229 to Facility Operating License Nos. DPR-33, DPR-52, and DPR-68 for the Browns Ferry Nuclear Plant Units 1, 2, and 3, respectively. These amendments are in response to your application dated October 6, 2000 (TS-406).

These amendments revise the Technical Specifications (TS) to provide Required Actions and Completion Times for use under conditions when one LPCI pump in both LPCI subsystems is inoperable. This action is consistent with a change to the NUREG-1433 Improved Standard TS identified as TSTF-318.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink that reads "William O. Long".

William O. Long, Sr. Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-259, 50-260 and 50-296

- Enclosures:
1. Amendment No. 240 to License No. DPR-33
  2. Amendment No. 269 to License No. DPR-52
  3. Amendment No. 229 to License No. DPR-68
  4. Safety Evaluation

cc w/enclosures: See next page

NRR-058

March 12, 2001

Mr. J. A Scalice  
Chief Nuclear Officer  
and Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2, AND 3 - ISSUANCE OF  
AMENDMENTS RELATING TO LOW-PRESSURE COOLANT INJECTION PUMP  
OPERABILITY REQUIREMENTS (TAC NOS. MB0161, MB0162 AND MB0163)

Dear Mr. Scalice:

The Commission has issued the enclosed Amendment Nos. 240 , 269 , and 229 to Facility  
Operating License Nos. DPR-33, DPR-52, and DPR-68 for the Browns Ferry Nuclear Plant  
Units 1, 2, and 3, respectively. These amendments are in response to your application dated  
October 6, 2000 (TS-406).

These amendments revise the Technical Specifications (TS) to provide Required Actions and  
Completion Times for use under conditions when one LPCI pump in both LPCI subsystems is  
inoperable. This action is consistent with a change to the NUREG-1433 Improved Standard TS  
identified as TSTF-318.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be  
included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

William O. Long, Sr. Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-259, 50-260 and 50-296

- Enclosures: 1. Amendment No. 240 to License No. DPR-33
- 2. Amendment No. 269 to License No. DPR-52
- 3. Amendment No. 229 to License No. DPR-68
- 4. Safety Evaluation

cc w/enclosures: See next page

**DISTRIBUTION:**

PUBLIC	PDII-2 Reading	RidsNrrDlpmLpdII	RidsNrrDlpmLpdII2
RidsNrrPMWLong	BClayton (Hardcopy)	RidsOgcRp	RidsAcrsAcnwMailCenter
GHill (6 Hardcopies)	WBeckner (e-Mail)	TLiu (e-Mail)	RidsRegion2MailCenter
RDennig (e-Mail)	NGilles (e-Mail)		

DOCUMENT NAME: G:\PDII-2\Browns Ferry\B0161amd.wpd

To receive a copy of this document, indicate "C" in the box						
OFFICE	PDII-2/PM	PDII-2/LA	RTSP/SC	OGC	PDII-2/SC	
NAME	WLong <i>W</i>	BClayton <i>BC</i>	RDennig <i>RD</i>		RCorreia <i>RC</i>	
DATE	2/2/01	3/1/01	2/5/01	2/2/01	2/8/01	

Official Record Copy



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 240  
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated October 6, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 240, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard P. Correia, Chief, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: **March 12, 2001**

ATTACHMENT TO LICENSE AMENDMENT NO. 240

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

Insert

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.1 ECCS - Operating

LCO 3.5.1 Each ECCS injection/spray subsystem and the Automatic Depressurization System (ADS) function of six safety/relief valves shall be OPERABLE.

APPLICABILITY: MODE 1, MODES 2 and 3, except high pressure coolant injection (HPCI) and ADS valves are not required to be OPERABLE with reactor steam dome pressure  $\leq$  150 psig.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One low pressure ECCS injection/spray subsystem inoperable.</p> <p><u>OR</u></p> <p>One low pressure coolant injection (LPCI) pump in both LPCI subsystems inoperable.</p>	<p>A.1 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	7 days
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Be in MODE 4.</p>	<p>12 hours</p> <p>36 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. HPCI System inoperable.	C.1 Verify by administrative means RCIC System is OPERABLE.  <u>AND</u>  C.2 Restore HPCI System to OPERABLE status.	Immediately    14 days
D. HPCI System inoperable.  <u>AND</u>  Condition A entered.	D.1 Restore HPCI System to OPERABLE status.  <u>OR</u>  D.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours   72 hours
E. One ADS valve inoperable.	E.1 Restore ADS valve to OPERABLE status.	14 days
F. One ADS valve inoperable.  <u>AND</u>  Condition A entered.	F.1 Restore ADS valve to OPERABLE status.  <u>OR</u>  F.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours   72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>G. Two or more ADS valves inoperable.</p> <p><u>OR</u></p> <p>Required Action and associated Completion Time of Condition C, D, E, or F not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Reduce reactor steam dome pressure to <math>\leq 150</math> psig.</p>	<p>12 hours</p> <p>36 hours</p>
<p>H. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition A.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p>	<p>H.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>



BASES

---

LCO  
(continued)

LPCI subsystems may be considered OPERABLE during alignment and operation for decay heat removal when below the actual RHR low pressure permissive pressure in MODE 3, if capable of being manually realigned (remote or local) to the LPCI mode and not otherwise inoperable. At these low pressures and decay heat levels, a reduced complement of ECCS subsystems should provide the required core cooling, thereby allowing operation of RHR shutdown cooling when necessary.

---

APPLICABILITY

All ECCS subsystems are required to be OPERABLE during MODES 1, 2, and 3, when there is considerable energy in the reactor core and core cooling would be required to prevent fuel damage in the event of a break in the primary system piping. In MODES 2 and 3, when reactor steam dome pressure is  $\leq 150$  psig, ADS and HPCI are not required to be OPERABLE because the low pressure ECCS subsystems can provide sufficient flow below this pressure. ECCS requirements for MODES 4 and 5 are specified in LCO 3.5.2, "ECCS - Shutdown."

---

ACTIONS

A.1

If any one low pressure ECCS injection/spray subsystem is inoperable, or if one LPCI pump in both LPCI subsystems is inoperable, the inoperable subsystem(s) must be restored to OPERABLE status within 7 days. In this condition, the remaining OPERABLE subsystems provide adequate core cooling during a LOCA. However, overall ECCS reliability is reduced, because a single failure in one of the remaining OPERABLE subsystems, concurrent with a LOCA, may result in the ECCS not being able to perform its intended safety function.

---

(continued)

BASES

---

ACTIONS

C.1 and C.2 (continued)

out of service for maintenance or other reasons. It does not mean to perform the Surveillances needed to demonstrate the OPERABILITY of the RCIC System. If the OPERABILITY of the RCIC System cannot be verified, however, Condition G must be immediately entered. If a single active component fails concurrent with a design basis LOCA, there is a potential, depending on the specific failure, that the minimum required ECCS equipment will not be available. A 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

D.1 and D.2

If any one low pressure ECCS injection/spray subsystem, or if one LPCI pump in both LPCI subsystems, is inoperable in addition to an inoperable HPCI System, the inoperable low pressure ECCS injection/spray subsystem or the HPCI System must be restored to OPERABLE status within 72 hours. In this Condition, adequate core cooling is ensured by the OPERABILITY of the ADS and the remaining low pressure ECCS subsystems. However, the overall ECCS reliability is significantly reduced because a single failure in one of the remaining OPERABLE subsystems concurrent with a design basis LOCA may result in the ECCS not being able to perform its intended safety function. Since both a high pressure system (HPCI) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the HPCI System or the low pressure ECCS injection/spray subsystem to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)

BASES

---

ACTIONS  
(continued)

E.1

The LCO requires six ADS valves to be OPERABLE in order to provide the ADS function. Reference 13 contains the results of an analysis that evaluated the effect of one ADS valve being out of service. Per this analysis, operation of only five ADS valves will provide the required depressurization. However, overall reliability of the ADS is reduced, because a single failure in the OPERABLE ADS valves could result in a reduction in depressurization capability. Therefore, operation is only allowed for a limited time. The 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

F.1 and F.2

If any one low pressure ECCS injection/spray subsystem, or one LPCI pump in both LPCI subsystems, is inoperable in addition to one inoperable ADS valve, adequate core cooling is ensured by the OPERABILITY of HPCI and the remaining low pressure ECCS injection/spray subsystem. However, overall ECCS reliability is reduced because a single active component failure concurrent with a design basis LOCA could result in the minimum required ECCS equipment not being available. Since both a high pressure system (ADS) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the low pressure ECCS subsystem or the ADS valve to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 269  
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated October 6, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 269, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard P. Correia, Chief, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: **March 12, 2001**

ATTACHMENT TO LICENSE AMENDMENT NO.269

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

Insert

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.1 ECCS - Operating

LCO 3.5.1 Each ECCS injection/spray subsystem and the Automatic Depressurization System (ADS) function of six safety/relief valves shall be OPERABLE.

APPLICABILITY: MODE 1, MODES 2 and 3, except high pressure coolant injection (HPCI) and ADS valves are not required to be OPERABLE with reactor steam dome pressure  $\leq$  150 psig.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One low pressure ECCS injection/spray subsystem inoperable.</p> <p><u>OR</u></p> <p>One low pressure coolant injection (LPCI) pump in both LPCI subsystems inoperable.</p>	<p>A.1 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	7 days
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Be in MODE 4.</p>	<p>12 hours</p> <p>36 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. HPCI System inoperable.	C.1 Verify by administrative means RCIC System is OPERABLE.  <u>AND</u>  C.2 Restore HPCI System to OPERABLE status.	Immediately     14 days
D. HPCI System inoperable.  <u>AND</u>  Condition A entered.	D.1 Restore HPCI System to OPERABLE status.  <u>OR</u>  D.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours    72 hours
E. One ADS valve inoperable.	E.1 Restore ADS valve to OPERABLE status.	14 days
F. One ADS valve inoperable.  <u>AND</u>  Condition A entered.	F.1 Restore ADS valve to OPERABLE status.  <u>OR</u>  F.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours    72 hours

(continued)



ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>G. Two or more ADS valves inoperable.</p> <p><u>OR</u></p> <p>Required Action and associated Completion Time of Condition C, D, E, or F not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Reduce reactor steam dome pressure to ≤ 150 psig.</p>	<p>12 hours</p> <p>36 hours</p>
<p>H. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition A.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p>	<p>H.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

BASES

---

LCO  
(continued)

LPCI subsystems may be considered OPERABLE during alignment and operation for decay heat removal when below the actual RHR low pressure permissive pressure in MODE 3, if capable of being manually realigned (remote or local) to the LPCI mode and not otherwise inoperable. At these low pressures and decay heat levels, a reduced complement of ECCS subsystems should provide the required core cooling, thereby allowing operation of RHR shutdown cooling when necessary.

---

APPLICABILITY

All ECCS subsystems are required to be OPERABLE during MODES 1, 2, and 3, when there is considerable energy in the reactor core and core cooling would be required to prevent fuel damage in the event of a break in the primary system piping. In MODES 2 and 3, when reactor steam dome pressure is  $\leq 150$  psig, ADS and HPCI are not required to be OPERABLE because the low pressure ECCS subsystems can provide sufficient flow below this pressure. ECCS requirements for MODES 4 and 5 are specified in LCO 3.5.2, "ECCS - Shutdown."

---

ACTIONS

A.1

If any one low pressure ECCS injection/spray subsystem is inoperable, or if one LPCI pump in both LPCI subsystems is inoperable, the inoperable subsystem(s) must be restored to OPERABLE status within 7 days. In this condition, the remaining OPERABLE subsystems provide adequate core cooling during a LOCA. However, overall ECCS reliability is reduced, because a single failure in one of the remaining OPERABLE subsystems, concurrent with a LOCA, may result in the ECCS not being able to perform its intended safety function.

---

(continued)

BASES

---

ACTIONS

C.1 and C.2 (continued)

out of service for maintenance or other reasons. It does not mean to perform the Surveillances needed to demonstrate the OPERABILITY of the RCIC System. If the OPERABILITY of the RCIC System cannot be verified, however, Condition G must be immediately entered. If a single active component fails concurrent with a design basis LOCA, there is a potential, depending on the specific failure, that the minimum required ECCS equipment will not be available. A 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

D.1 and D.2

If any one low pressure ECCS injection/spray subsystem, or if one LPCI pump in both LPCI subsystems, is inoperable in addition to an inoperable HPCI System, the inoperable low pressure ECCS injection/spray subsystem or the HPCI System must be restored to OPERABLE status within 72 hours. In this Condition, adequate core cooling is ensured by the OPERABILITY of the ADS and the remaining low pressure ECCS subsystems. However, the overall ECCS reliability is significantly reduced because a single failure in one of the remaining OPERABLE subsystems concurrent with a design basis LOCA may result in the ECCS not being able to perform its intended safety function. Since both a high pressure system (HPCI) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the HPCI System or the low pressure ECCS injection/spray subsystem to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)

BASES

---

ACTIONS  
(continued)

E.1

The LCO requires six ADS valves to be OPERABLE in order to provide the ADS function. Reference 13 contains the results of an analysis that evaluated the effect of one ADS valve being out of service. Per this analysis, operation of only five ADS valves will provide the required depressurization. However, overall reliability of the ADS is reduced, because a single failure in the OPERABLE ADS valves could result in a reduction in depressurization capability. Therefore, operation is only allowed for a limited time. The 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

F.1 and F.2

If any one low pressure ECCS injection/spray subsystem, or one LPCI pump in both LPCI subsystems, is inoperable in addition to one inoperable ADS valve, adequate core cooling is ensured by the OPERABILITY of HPCI and the remaining low pressure ECCS injection/spray subsystem. However, overall ECCS reliability is reduced because a single active component failure concurrent with a design basis LOCA could result in the minimum required ECCS equipment not being available. Since both a high pressure system (ADS) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the low pressure ECCS subsystem or the ADS valve to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 229  
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated October 6, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 229, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard P. Correia, Chief, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: March 12, 2001

ATTACHMENT TO LICENSE AMENDMENT NO. 229

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

Remove

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

Insert

3.5-1  
3.5-2  
3.5-3  
B 3.5-8  
B 3.5-10  
B 3.5-11

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS) AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.1 ECCS - Operating

LCO 3.5.1 Each ECCS injection/spray subsystem and the Automatic Depressurization System (ADS) function of six safety/relief valves shall be OPERABLE.

APPLICABILITY: MODE 1, MODES 2 and 3, except high pressure coolant injection (HPCI) and ADS valves are not required to be OPERABLE with reactor steam dome pressure  $\leq$  150 psig.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One low pressure ECCS injection/spray subsystem inoperable.</p> <p><u>OR</u></p> <p>One low pressure coolant injection (LPCI) pump in both LPCI subsystems inoperable.</p>	<p>A.1 Restore low pressure ECCS injection/spray subsystem(s) to OPERABLE status.</p>	7 days
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Be in MODE 4.</p>	<p>12 hours</p> <p>36 hours</p>

(continued)



ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. HPCI System inoperable.	C.1 Verify by administrative means RCIC System is OPERABLE.  <u>AND</u>  C.2 Restore HPCI System to OPERABLE status.	Immediately     14 days
D. HPCI System inoperable.  <u>AND</u>  Condition A entered.	D.1 Restore HPCI System to OPERABLE status.  <u>OR</u>  D.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours    72 hours
E. One ADS valve inoperable.	E.1 Restore ADS valve to OPERABLE status.	14 days
F. One ADS valve inoperable.  <u>AND</u>  Condition A entered.	F.1 Restore ADS valve to OPERABLE status.  <u>OR</u>  F.2 Restore low pressure ECCS injection/spray subsystem to OPERABLE status.	72 hours    72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>G. Two or more ADS valves inoperable.</p> <p><u>OR</u></p> <p>Required Action and associated Completion Time of Condition C, D, E, or F not met.</p>	<p>G.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>G.2 Reduce reactor steam dome pressure to <math>\leq 150</math> psig.</p>	<p>12 hours</p> <p>36 hours</p>
<p>H. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition A.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p>	<p>H.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

BASES

---

LCO  
(continued)

LPCI subsystems may be considered OPERABLE during alignment and operation for decay heat removal when below the actual RHR low pressure permissive pressure in MODE 3, if capable of being manually realigned (remote or local) to the LPCI mode and not otherwise inoperable. At these low pressures and decay heat levels, a reduced complement of ECCS subsystems should provide the required core cooling, thereby allowing operation of RHR shutdown cooling when necessary.

---

APPLICABILITY

All ECCS subsystems are required to be OPERABLE during MODES 1, 2, and 3, when there is considerable energy in the reactor core and core cooling would be required to prevent fuel damage in the event of a break in the primary system piping. In MODES 2 and 3, when reactor steam dome pressure is  $\leq 150$  psig, ADS and HPCI are not required to be OPERABLE because the low pressure ECCS subsystems can provide sufficient flow below this pressure. ECCS requirements for MODES 4 and 5 are specified in LCO 3.5.2, "ECCS - Shutdown."

---

ACTIONS

A.1

If any one low pressure ECCS injection/spray subsystem is inoperable, or if one LPCI pump in both LPCI subsystems is inoperable, the inoperable subsystem(s) must be restored to OPERABLE status within 7 days. In this condition, the remaining OPERABLE subsystems provide adequate core cooling during a LOCA. However, overall ECCS reliability is reduced, because a single failure in one of the remaining OPERABLE subsystems, concurrent with a LOCA, may result in the ECCS not being able to perform its intended safety function.

---

(continued)

BASES

---

ACTIONS

C.1 and C.2 (continued)

out of service for maintenance or other reasons. It does not mean to perform the Surveillances needed to demonstrate the OPERABILITY of the RCIC System. If the OPERABILITY of the RCIC System cannot be verified, however, Condition G must be immediately entered. If a single active component fails concurrent with a design basis LOCA, there is a potential, depending on the specific failure, that the minimum required ECCS equipment will not be available. A 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

D.1 and D.2

If any one low pressure ECCS injection/spray subsystem, or if one LPCI pump in both LPCI subsystems, is inoperable in addition to an inoperable HPCI System, the inoperable low pressure ECCS injection/spray subsystem or the HPCI System must be restored to OPERABLE status within 72 hours. In this Condition, adequate core cooling is ensured by the OPERABILITY of the ADS and the remaining low pressure ECCS subsystems. However, the overall ECCS reliability is significantly reduced because a single failure in one of the remaining OPERABLE subsystems concurrent with a design basis LOCA may result in the ECCS not being able to perform its intended safety function. Since both a high pressure system (HPCI) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the HPCI System or the low pressure ECCS injection/spray subsystem to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)

BASES

---

ACTIONS  
(continued)

E.1

The LCO requires six ADS valves to be OPERABLE in order to provide the ADS function. Reference 13 contains the results of an analysis that evaluated the effect of one ADS valve being out of service. Per this analysis, operation of only five ADS valves will provide the required depressurization. However, overall reliability of the ADS is reduced, because a single failure in the OPERABLE ADS valves could result in a reduction in depressurization capability. Therefore, operation is only allowed for a limited time. The 14 day Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

F.1 and F.2

If any one low pressure ECCS injection/spray subsystem, or one LPCI pump in both LPCI subsystems, is inoperable in addition to one inoperable ADS valve, adequate core cooling is ensured by the OPERABILITY of HPCI and the remaining low pressure ECCS injection/spray subsystem. However, overall ECCS reliability is reduced because a single active component failure concurrent with a design basis LOCA could result in the minimum required ECCS equipment not being available. Since both a high pressure system (ADS) and a low pressure subsystem are inoperable, a more restrictive Completion Time of 72 hours is required to restore either the low pressure ECCS subsystem or the ADS valve to OPERABLE status. This Completion Time is based on a reliability study cited in Reference 11 and has been found to be acceptable through operating experience.

---

(continued)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 240 TO FACILITY OPERATING LICENSE NO. DPR-33,  
AMENDMENT NO. 269 TO FACILITY OPERATING LICENSE NUMBER DPR-52,  
AND AMENDMENT NO. 229 TO FACILITY OPERATING LICENSE NUMBER DPR-68  
TENNESSEE VALLEY AUTHORITY  
BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2, AND 3  
DOCKET NOS. 50-259, 50-260, AND 50-296

1.0 INTRODUCTION

By letter dated October 6, 2000, the Tennessee Valley Authority (TVA, the licensee) submitted a request (TS-406) for amendments to licenses DPR-33, DPR-52 and DPR-68. The proposed amendments would revise Condition A of Technical Specification 3.5.1, "ECCS - Operating," by adding provisions for the inoperability of one Low Pressure Coolant Injection (LPCI) pump in each of the two Emergency Core Cooling System (ECCS) divisions for Browns Ferry Nuclear Plant (BFN), Units 1, 2, and 3. The existing TS provides for the inoperability of two LPCI pumps when both are in the same subsystem, but does not encompass conditions when there are two inoperable LPCI pumps with the pumps being in different subsystems.

2.0 BACKGROUND

By William D. Beckner's letter dated June 29, 1999, the NRC approved 23 changes to the Standard Technical Specifications (STS). One of the changes, "TSTF-318," revised the BWR/4 STS (NUREG-1433), Specification 3.5.1 by adding to Limiting Condition for Operation (LCO) Actions, Condition A, a provision for the inoperability of one LPCI pump in both LPCI subsystems during Modes 1, 2, and 3 for up to 7 days [i.e., it allows two inoperable LPCI pumps (i.e., one in each subsystem or two from one subsystem) for 7 days in Modes 1, 2, and 3].

The standard BWR/4 RHR configuration, which is applicable to BFN, consists of two LPCI pumps in each of two LPCI (ECCS injection mode) subsystems, for a total of four LPCI pumps. Typically, one subsystem contains LPCI pumps A and C and the second subsystem contains residual heat removal (RHR) pumps B and D. (Note: The LPCI pumps also serve as RHR pumps. The terms "LPCI pump" and "RHR pump" are used interchangeably in this evaluation.) The pre-TSTF-318 STS Section 3.5.1 Condition A (and the current BFN TS) allow one low pressure ECCS injection/spray subsystem (i.e., one or both LPCI pumps in one subsystem) to be inoperable for 7 days during Modes 1, 2, and 3. However, there is no provision for the

ENCLOSURE

potential circumstance of two inoperable LPCI pumps when the pumps are not in the same subsystem.

In its review of TSTF-318, the staff determined that it is acceptable to have two LPCI pumps, one in each of the two subsystems out-of-service inoperable because this configuration reflects an enhanced probability of at least one LPCI pump being available for post loss-of-coolant accident (LOCA) injection. With one subsystem inoperable, the LOCA can eliminate the availability of the remaining subsystem for injection (i.e., the flow would be lost through the break), while a LOCA during operation with only one LPCI pump in each ECCS subsystem will remove the availability of one of the two remaining LPCI pumps. Additionally, during an event that does not impact LPCI availability and requires LPCI injection, one pump in each subsystem provides equal or greater injection flow than two pumps in a single subsystem, depending on the specific LPCI configuration.

### 3.0 EVALUATION

The LPCI configuration of each unit at BFN is consistent with that of the typical BWR-4 generic design reflected in the NUREG-1433 STS. There are four LPCI pumps (A, B, C & D) arranged in two subsystems or loops. In the event of an accident LPCI Subsystem 1 would inject emergency coolant into the reactor vessel via Recirculation Loop 1, and LPCI Subsystem 2 would inject emergency coolant into the vessel via Recirculation Loop 2. If a LOCA occurs due to a break in one of the two recirculation loops, at a point between the Recirculation Pump Discharge Valve and the Reactor Pressure Vessel, the injection flow from the associated LPCI subsystem is spilled and unavailable for core cooling.

The licensee's application states that LCOs added by TSTF-318 reflect an enhanced reliability of at least one LPCI pump being available for post-LOCA injection. With one subsystem (two LPCI pumps in one loop) inoperable, the location of the LOCA pipe break can eliminate the availability of the remaining LPCI subsystem for injection, while the LOCA location during operation with one operable LPCI pump in each ECCS division can only remove one of the two remaining LPCI pumps. The licensee further stated that during an event in which LPCI availability is unaffected and requires LPCI injection, one pump in each LPCI subsystem provides more injection flow than two pumps in a single subsystem.

In addition to specifying Required Actions and Completion Times for conditions of inoperable LPCI pumps, Section 3.5.1 of the existing BFN TS also provides Required Actions and Completion Times for Conditions D, F and H, when LPCI pumps are inoperable at the same time as other ECCS subsystems and components (i.e., Automatic Depressurization System, High Pressure Coolant Injection System). The wording of Conditions D, F and H would be revised to reflect the fact that Condition A can be entered with two low pressure ECCS injection/spray subsystems inoperable when the conditions are due to having one LPCI pump in each subsystem inoperable.

The staff has determined that TSTF-318 is applicable to BFN and that the proposed change allows the technical specifications to recognize an additional LPCI configuration that continues to ensure that the design basis analysis is met and is bounded by the currently allowed configuration. In addition, the proposed change is an improvement of the current TS requirements which would require entry into LCO 3.0.3 and a plant shutdown in the event of one inoperable pump in each LPCI subsystem. Since the LPCI pumps also serve as RHR

pumps, the proposed amendment would preclude the licensee having to put the plant in the RHR shutdown cooling configuration at a time when RHR capability is degraded. The proposed amendment is, therefore, acceptable.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Alabama State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (66 FR 9387). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Tilda Liu

Date: **March 12, 2001**



Mr. J. A. Scalice  
Tennessee Valley Authority

**BROWNS FERRY NUCLEAR PLANT**

cc:

Mr. Karl W. Singer, Senior Vice President  
Nuclear Operations  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager  
Nuclear Licensing  
Tennessee Valley Authority  
4X Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Jack A. Bailey, Vice President  
Engineering & Technical Services  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Timothy E. Abney, Manager  
Licensing and Industry Affairs  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Mr. Karl W. Singer, Site Vice President  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Browns Ferry Nuclear Plant  
10833 Shaw Road  
Athens, AL 35611

General Counsel  
Tennessee Valley Authority  
ET 10H  
400 West Summit Hill Drive  
Knoxville, TN 37902

State Health Officer  
Alabama Dept. of Public Health  
RSA Tower - Administration  
Suite 1552  
P.O. Box 303017  
Montgomery, AL 36130-3017

Mr. Robert J. Adney, General Manager  
Nuclear Assurance  
Tennessee Valley Authority  
5M Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Chairman  
Limestone County Commission  
310 West Washington Street  
Athens, AL 35611

Mr. Ashok S. Bhatnagar, Plant Manager  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609