

March 20, 2001

Mr. H. B. Barron  
Vice President, McGuire Site  
Duke Energy Corporation  
12700 Hagers Ferry Road  
Huntersville, NC 28078-8985

SUBJECT: MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 RE: PROPOSED MEETING TO  
DISCUSS PROMATEC HEMYC 1-HOUR AND MT 3-HOUR FIRE BARRIER  
SYSTEMS (TAC NO. MB1311)

Dear Mr. Barron:

During a November 1999 fire protection inspection at Carolina Power & Light Company's Shearon Harris Nuclear Power Plant (HNP), NRC Region II inspectors identified a potential issue associated with Promatec Hemyc 1-hour and MT 3-hour fire barrier systems not being qualified to meet Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, Appendix R, safe shutdown separation requirements. In a November 23, 1999, Task Interface Agreement (TIA 99-028; ADAMS Accession No. ML003671052), Region II requested the Office of Nuclear Reactor Regulation's (NRR's) assistance to resolve this issue. In its August 1, 2000, response to TIA 99-028 (ADAMS Accession No. ML003736721), the NRR staff concluded that the fire rating of the installed fire wrap at HNP was indeterminate.

The Nuclear Energy Institute (NEI) confirmed that the plants listed below use Hemyc or MT fire wrap to comply with 10 CFR Part 50, Appendix R, safe shutdown separation requirements.

Arkansas Nuclear One Units 1 and 2	Beaver Valley Unit 1
Catawba Units 1 and 2	FitzPatrick
Ginna	Harris
Indian Point Units 2 and 3	McGuire Units 1 and 2
Robinson 2	Vermont Yankee
Waterford	

The NRR staff requested that NEI coordinate a generic industry initiative to address the Hemyc and MT fire barrier issue, but NEI declined. Therefore, the staff will be working with the affected licensees to resolve this issue. The staff's planned course of action includes meeting with the affected licensees as a group to discuss (1) the technical issues, (2) the applicability of the issues to the affected plants, and (3) the ultimate resolution of the issue. We are requesting that the affected licensees take the issue on as a voluntary initiative and propose an approach for resolving the issue.

H. B. Barron

- 2 -

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

*/RA/*

Robert E. Martin, Senior Project Manager, Section II-1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

*/RA/*

Robert E. Martin, Senior Project Manager, Section II-1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

Distribution:

PUBLIC  
PD II-1 Rdg.  
GJanosko  
RidsNrrDlpmLpdii1 (paper copy)  
SRosenberg  
RLaufer  
MBanerjee

RidsNrrLACHawes (paper copy)  
RidsNrrPMRMartin (paper copy)  
RidsOgcRp  
GHill (2) (paper copies)  
RidsAcrsAcnwMailCenter  
RidsRgn2MailCenter

DOCUMENT NAME: C:\LtrMB1311.wpd

OFFICE	PDII-1/PM	PDII-1/LA	SPLB	SPLB	PDII-1/SC(A)
NAME	RMartin:cn	CHawes	DFrumkin	DWeiss	MBanerjee
DATE	3/13/01	3/13/01	3/14/01	3/14/01	3/19/01

McGuire Nuclear Station

cc:

Ms. Lisa F. Vaughn  
Legal Department (PBO5E)  
Duke Energy Corporation  
422 South Church Street  
Charlotte, North Carolina 28201-1006

County Manager of  
Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Michael T. Cash  
Regulatory Compliance Manager  
Duke Energy Corporation  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Anne Cottingham, Esquire  
Winston and Strawn  
1400 L Street, NW.  
Washington, DC 20005

Senior Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Dr. John M. Barry  
Mecklenburg County  
Department of Environmental  
Protection  
700 N. Tryon Street  
Charlotte, North Carolina 28202

Mr. Steven P. Shaver  
Senior Sales Engineer  
Westinghouse Electric Company  
5929 Carnegie Blvd.  
Suite 500  
Charlotte, North Carolina 28209

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of  
Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas  
Manager - Nuclear Regulatory  
Licensing  
Duke Energy Corporation  
526 South Church Street  
Charlotte, North Carolina 28201-1006

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335

Mr. Richard M. Fry, Director  
Division of Radiation Protection  
North Carolina Department of  
Environment, Health and Natural  
Resources  
3825 Barrett Drive  
Raleigh, North Carolina 27609-7721

Mr. T. Richard Puryear  
Owners Group (NCEMC)  
Duke Energy Corporation  
4800 Concord Road  
York, South Carolina 29745

Mr. Fred Emerson  
Nuclear Energy Institute  
1776 I Street, NW., Suite 400  
Washington, DC 20006