

March 12, 2001

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop P1-137
Washington, DC 20555-0001



ULNRC-04406

Gentlemen:

**DOCKET NUMBER 50-483
UNION ELECTRIC CO.
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPF-30
MONTHLY OPERATING REPORT
FEBRUARY/2001**

The enclosed Monthly Operating Report for February/2001 is submitted pursuant to Section 5.6.4 of the Callaway Unit 1 Technical Specifications.

Warren A. Witt

Warren A. Witt
Manager, Callaway Plant

WAW/JER/slk

Enclosure

IE24

ULNRC-04406

March 12, 2001

Page 2

cc: Mr. Ellis W. Merschoff
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. Jack Donohew (2 copies)
Licensing Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 7E1
Washington, DC 20555-2738

Manager, Electric Department
Missouri Public Service Commission
PO Box 360
Jefferson City, MO 65102

Mr. Thomas A. Baxter
Shaw, Pittman, Potts, & Trowbridge
2300 N. Street N.W.
Washington, DC 20037

Enclosure
ULNRC-04406
March 12, 2001

DOCKET NO.: 50-483
UNIT NAME: CALLAWAY UNIT 1
COMPLETED BY: J. E. Ready
TELEPHONE: 573/676-8617
FAX: 573/676-4202

REPORTING PERIOD: February/2001

1. DESIGN ELECTRICAL RATING (MWe-Net): 1171
2. MAX. DEPEND. CAPACITY (MWe-Net): 1125

	<u>THIS MONTH</u>	<u>YR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	672	1416	128,531
4. HOURS GENERATOR ON-LINE	672	1416	126,065.7
5. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6. NET ELECTRICAL ENERGY GENERATED (MWH)	778,452	1,642,614	138,416,010

Enclosure
ULNRC-04406
March 12, 2001

UNIT SHUTDOWNS

DOCKET NO.: 50-483
UNIT NAME: CALLAWAY UNIT 1
COMPLETED BY: J. E. Ready
TELEPHONE: 573/676-8617
FAX: 573/676-4202

REPORT MONTH: February/2001

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u> F: FORCED S: SCHEDULED	<u>DURATION</u> (HOURS)	<u>REASON</u>	<u>METHOD OF</u> <u>SHUTTING DOWN</u> <u>THE REACTOR</u>	<u>CORRECTIVE</u> <u>ACTIONS/COMMENT</u>
------------	-------------	--	----------------------------	---------------	--	---

SUMMARY

The Callaway plant operated at approximately 100% power for the month of February. The Plant was downpowered to approximately 92% for seven hours on February 4th to perform Main Turbine Control Valve testing.

- | <u>REASON</u> | <u>METHOD</u> |
|--|--------------------|
| A: EQUIPMENT FAILURE (EXPLAIN) | 1: MANUAL |
| B: MAINT. OR TEST | 2: MANUAL SCRAM |
| C: REFUELING | 3: AUTOMATIC SCRAM |
| D: REGULATORY RESTRICTION | 4: CONTINUATION |
| E: OPERATOR TRAINING / LICENSE EXAMINATION | 5: OTHER (EXPLAIN) |
| F: ADMINISTRATIVE | |
| G: OPERATIONAL ERROR (EXPLAIN) | |
| H: OTHER (EXPLAIN) | |