

March 21, 2001

Mr. John T. Herron  
Vice President Operations  
Entergy Operations, Inc.  
17265 River Road  
Killona, LA 70066-0751

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - PROPOSED MEETING  
TO DISCUSS PROMATEC HEMYC 1-HOUR AND MT 3-HOUR FIRE BARRIER  
SYSTEMS

Dear Mr. Herron:

During a November 1999 fire protection inspection at Carolina Power & Light Company's Shearon Harris Nuclear Power Plant (HNP), Nuclear Regulatory Commission (NRC) Region II inspectors identified a potential issue associated with Promatec Hemyc 1-hour and MT 3-hour fire barrier systems not being qualified to meet 10 CFR Part 50, Appendix R, safe shutdown separation requirements. In a November 23, 1999, Task Interface Agreement (TIA 99-028; Agencywide Documents Access and Management System (ADAMS) Accession No. ML003671052), Region II requested the Office of Nuclear Reactor Regulation's (NRR's) assistance to resolve this issue. In its August 1, 2000, response to TIA 99-028 (ADAMS Accession No. ML003736721), the NRR staff concluded that the fire rating of the installed fire wrap at HNP was indeterminate.

The Nuclear Energy Institute (NEI) confirmed that the plants listed below use Hemyc or MT fire wrap to comply with 10 CFR Part 50, Appendix R, safe shutdown separation requirements.

Arkansas Nuclear One Units 1 and 2  
Catawba Units 1 and 2  
Ginna  
Indian Point Units 2 and 3  
Robinson 2  
Waterford

Beaver Valley Unit 1  
FitzPatrick  
Harris  
McGuire Units 1 and 2  
Vermont Yankee

NRR staff had requested that NEI coordinate a generic industry initiative to address the Hemyc and MT fire barrier issue, but NEI declined. Therefore, the staff will be working with the affected licensees to resolve this issue. The staff's planned course of action includes meeting with the affected licensees as a group to discuss (1) the technical issues, (2) the applicability of the issues to the affected plants, and (3) the ultimate resolution of the issue. We are requesting that the affected licensees take the issue on as a voluntary initiative and propose an approach for resolving the issue.

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

*/RA/*

N. Kalyanam, Project Manager  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

John T. Herron

- 2 -

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

**/RA/**

N. Kalyanam, Project Manager  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

Distribution:

PD IV-1 Rdg	PUBLIC	RLaufer
RidsNrrDlpmLpdiv1 (RGramm)	Rids OgcRp	RidsAcrsAcnwACRS
RidsRgn4MailCenter (KBrockman)	RidsNrrLADJohnson	RidsNrrPMNKalyanam
	DFrumkin	

ACCESSION NUMBER: ML010800098

\*see previous concurrence

OFFICE	PDIV-1/PM	PDIV-1/LA	SPLB	SC:SPLB	PDIV-1/SC
NAME	NKalyanam	DJohnson	DFrumkin *	EWeiss *	RGramm
DATE	3/20/01	3/20/01	03/ 06 /01	03/ 06/01	3/21/01

OFFICIAL RECORD COPY

### Waterford Generating Station 3

cc:

Administrator  
Louisiana Department of Environmental Quality  
P. O. Box 82215  
Baton Rouge, LA 70884-2215

Vice President, Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286

Director  
Nuclear Safety Assurance  
Entergy Operations, Inc.  
17265 River Road  
Killona, LA 70066-0751

Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

General Manager Plant Operations  
Waterford 3 SES  
Entergy Operations, Inc.  
17265 River Road  
Killona, LA 70066-0751

Licensing Manager  
Entergy Operations, Inc.  
17265 River Road  
Killona, LA 70066-0751

Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Resident Inspector/Waterford NPS  
P. O. Box 822  
Killona, LA 70066-0751

Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Parish President Council  
St. Charles Parish  
P. O. Box 302  
Hahnville, LA 70057

Executive Vice-President  
and Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Chairman  
Louisiana Public Services Commission  
Baton Rouge, LA 70825-1697

Fred Emerson  
Nuclear Energy Institute  
1776 I Street, N.W., Suite 400  
Washington, DC 20006