

October 23, 1989

Docket No. 50-333

Mr. John C. Brons  
Executive Vice President, Nuclear  
Generation  
Power Authority of the State of  
New York  
123 Main Street  
White Plains, New York 10601

DISTRIBUTION

<del>Docket file</del>	WJones
NRC & Local PDRs	JCalvo
PDI-1 Rdg	ACRS (10)
SVarga	GPA/PA
AD/RI	OC/LFMB
CVogan	RCapra
RCapra	JWiggins
DLaBarge	WHodges
OGC	TMeek (4)
DHagan	EJordan

Dear Mr. Brons:

SUBJECT: AMENDMENT NO. 139 PAGE CORRECTION (TAC 73289)

When Amendment No. 139 was issued on October 2, 1989, to Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power Plant, Technical Specification page number 177 erroneously contained information which had been deleted in the submittal and approved in the safety evaluation. This information was inadvertently reinserted when the page was upgraded to include an amendment which had been issued since the original submittal concerning the Containment Atmosphere Continuous Leak Rate Monitor was generated. Please replace page 177 in Amendment No. 139 with the attached.

We regret any inconvenience this may have caused.

Sincerely,

Original signed by

David E. LaBarge, Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Page 177

cc: w/enclosure  
See next page

OFC	:PDI-1	:PDI-1	:OGC	:PDI-1	:	:	:
NAME	:CVogan	:DLaBarge/bah:	:	:RCapra	:	:	:
DATE	:10/23/89	:10/23/89	:10/ /89	:10/23/89	:	:	:

OFFICIAL RECORD COPY  
Document Name: AMEND 139 CORRECTION

8911060347 891023  
PDR ADOCK 05000333  
P PNU

*DF 01*  
*11*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 23, 1989

Docket No. 50-333

Mr. John C. Brons  
Executive Vice President, Nuclear  
Generation  
Power Authority of the State of  
New York  
123 Main Street  
White Plains, New York 10601

Dear Mr. Brons:

SUBJECT: AMENDMENT NO. 139 PAGE CORRECTION (TAC 73289)

When Amendment No. 139 was issued on October 2, 1989, to Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear Power Plant, Technical Specification page number 177 erroneously contained information which had been deleted in the submittal and approved in the safety evaluation. This information was inadvertently reinserted when the page was upgraded to include an amendment which had been issued since the original submittal concerning the Containment Atmosphere Continuous Leak Rate Monitor was generated. Please replace page 177 in Amendment No. 139 with the attached.

We regret any inconvenience this may have caused.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. LaBarge".

David E. LaBarge, Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Page 177

cc: w/enclosure  
See next page

Mr. John C. Brons  
Power Authority of the State of New York

James A. FitzPatrick Nuclear  
Power Plant

cc:

Mr. Gerald C. Goldstein  
Assistant General Counsel  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, New York 12223

Resident Inspector's Office  
U. S. Nuclear Regulatory Commission  
Post Office Box 136  
Lycoming, New York 13093

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Mr. William Fernandez  
Resident Manager  
James A. FitzPatrick Nuclear  
Power Plant  
Post Office Box 41  
Lycoming, New York 13093

Mr. A. Klausman  
Senior Vice President - Appraisal  
and Compliance Services  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019

Mr. J. A. Gray, Jr.  
Director Nuclear Licensing - BWR  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. George Wilverding, Manager  
Nuclear Safety Evaluation  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Supervisor  
Town of Scriba  
R. D. #4  
Oswego, New York 13126

Mr. R. E. Beedle  
Vice President Nuclear Support  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. J. P. Bayne, President  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019

Mr. S. S. Zulla  
Vice President Nuclear Engineering  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. Richard Patch  
Quality Assurance Superintendent  
James A. FitzPatrick Nuclear  
Power Plant  
Post Office Box 41  
Lycoming, New York 13093

Mr. William Josiger, Vice President  
Operations and Maintenance  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Charlie Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, New York 10271

JAFNPP

3.7 (cont'd)

4. Pressure Suppression Chamber-Reactor Building Vacuum Breakers
  - a. Except as specified in 3.7.A.4.b below, two Pressure Suppression Chamber-Reactor Building Vacuum Breakers shall be operable at all times when the primary containment integrity is required. The setpoint of the differential pressure instrumentation which actuates the pressure suppression chamber reactor building vacuum breakers shall be  $\leq 0.5$  psi below reactor building pressure.
  - b. From and after the date that one of the pressure suppression chamber-reactor building vacuum breakers is made or found to be inoperable for any reason, reactor operation is permissible only during the succeeding 7 days, unless such vacuum

4.7 (cont'd)

4. Pressure Suppression Chamber-Reactor Building Vacuum Breakers
  - a. The pressure suppression chamber-reactor building vacuum breakers and associated instrumentations including setpoint shall be checked for proper operation every three months.

8911060352 891023  
PDR ADDCK 05000333  
P PNU