



*Handwritten initials and scribbles*

Carolina Power & Light Company  
PO Box 165  
New Hill NC 27562

James Scarola  
Vice President  
Harris Nuclear Plant

SERIAL: HNP-98-158  
10 CFR 50.90

DEC - 7 1998

DEC 15 1998

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
RETYPE TECHNICAL SPECIFICATION PAGES FOR SPENT FUEL POOL WATER  
LEVEL AND REVISED FUEL HANDLING ACCIDENT ANALYSES

Dear Sir or Madam:

On September 1, 1998, Carolina Power & Light Company (CP&L) requested a Licensed Amendment to revise the Harris Nuclear Plant (HNP) Technical Specifications (TS) 3/4.9.11 related to "Water Level - New and Spent Fuel Pools." As a result of a recently issued License Amendment, CP&L is submitting a retyped TS page which supersedes a page included in the September 1, 1998 submittal.

On October 20, 1998, the NRC issued License Amendment No. 84 to the HNP TS, which revised multiple TS pages as a result of changes to TS 3.0.4 and 4.0.4, "Limiting Conditions for Operation and Surveillance Requirements." Issuance of Amendment 84 independently affected one page, (3/4 9-13), from the September 1, 1998 request, which is currently under NRC review. Enclosure 1 contains the retyped TS page which incorporates changes resulting from the issuance of Amendment No. 84.

Please refer any questions regarding this matter to Mr. J. H. Eads at (919) 362-2646.

Sincerely,

MSE/twk

Enclosure

- c: Mr. J. B. Brady (NRC Senior Resident Inspector, HNP)
- Mr. S. C. Flanders (NRR Project Manager, HNP)
- Mr. M. Fry (Acting Director N.C. DEHNR)
- ~~Mr. A. Royel~~ (NRC Regional Administrator, Region II)

*Handwritten initials and date: B/DA 24*

bc:

Ms. D. B. Alexander  
Mr. G. E. Attarian  
Mr. R. H. Bazemore  
Mr. H. K. Chernoff  
Mr. B. H. Clark  
Mr. W. F. Conway  
Mr. G. W. Davis  
Mr. R. J. Field  
Mr. K. N. Harris  
Ms. L. N. Hartz  
Mr. W. J. Hindman  
Mr. C. S. Hinnant

Mr. G. J. Kline  
Ms. W. C. Langston  
Mr. R. D. Martin  
Mr. J. W. McKay  
Mr. P. M. Odom  
Mr. W. S. Orser  
Mr. P. M. Sawyer  
Mr. J. M. Taylor  
Mr. C. A. VanDenburgh  
Licensing File(s)  
Nuclear Records

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
RETYPE TECHNICAL SPECIFICATION PAGES FOR  
SPENT FUEL POOL WATER LEVEL AND REVISED FUEL  
HANDLING ACCIDENT ANALYSES

RETYPE TS PAGE

3/4 9-13

## REFUELING OPERATIONS

### 3/4.9.11 WATER LEVEL - NEW AND SPENT FUEL POOLS

#### LIMITING CONDITION FOR OPERATION

---

3.9.11 At least 23 feet of water shall be maintained over the top of fuel rods within irradiated fuel assemblies seated in the storage racks.

APPLICABILITY: Whenever irradiated fuel assemblies are in a pool.

#### ACTION:

- a. With the requirements of the above specification not satisfied, suspend all movement of fuel assemblies and crane operations with loads in the affected pool area and restore the water level to within its limit within 4 hours.
- b. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.9.11 At least once per 7 days, when irradiated fuel assemblies are in a pool, the water level in that pool shall be determined to be at least its minimum required depth.