



Carolina Power & Light Company  
PO Box 165  
New Hill NC 27562

James Scarola  
Vice President  
Harris Nuclear Plant

SERIAL: HNP-99-053  
10CFR50.90

MAR 19 1999

'99 MAR 29 10:13

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION  
SPENT FUEL POOL WATER LEVEL AND REVISED FUEL HANDLING ACCIDENT  
ANALYSES

Dear Sir or Madam:

Per telephone conversation with the NRC staff on 3/17/99, Harris Nuclear Plant (HNP) submits additional information for the proposed Spent Fuel Pool Water Level and Revised Fuel Handling Accident Analyses License Amendment request, dated September 1, 1998.

NRC Questions:


1. What is the value of the atmospheric dispersion coefficient (X/Q) used in evaluating the Main Control Room dose during a radiological accident?
2. Has the proposed submittal affected the Main Control Room dose with respect to the most limiting accident?

HNP Response:

1. The X/Q value in evaluating Main Control Room dose during a radiological accident is  $7.68 \times 10^{-3} \text{ sec/m}^3$ .
2. The HNP FSAR states that the LOCA event is the most limiting event for control room habitability dose criteria. The increase in dose resulting from the revised fuel handling accident analyses, described in the September 1, 1998 submittal, is small relative to the Main Control Room dose as a result of a LOCA. The LOCA accident remains the most limiting accident with respect to Main Control Room dose.

Please refer any questions regarding this submittal to Mr. J. H. Eads at (919) 362-2646.

Sincerely,



25  
B/AB

MSE/mse

c:     **Mr. J. B. Brady, NRC Sr. Resident Inspector**  
         **Mr. Mel Fry, Acting Director, N. C. DEHNR**  
         **Mr. R. J. Laufer, NRC Project Manager**  
         **Mr. L. A. Reyes, NRC Regional Administrator**