

March 26, 2001

Mr. J. W. Moyer, Vice President  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550

SUBJECT: PROPOSED MEETING TO DISCUSS PROMATEC HEMYC 1-HOUR AND MT  
3-HOUR FIRE BARRIER SYSTEMS

Dear Mr. Moyer:

During a November 1999 fire protection inspection at Carolina Power & Light Company's Shearon Harris Nuclear Power Plant (HNP), NRC Region II inspectors identified a potential issue associated with Promatec Hemyc 1-hour and MT 3-hour fire barrier systems not being qualified to meet 10 CFR Part 50, Appendix R, safe shutdown separation requirements. In a November 23, 1999, Task Interface Agreement (TIA 99-028; ADAMS Accession No. ML003671052), Region II requested the Office of Nuclear Reactor Regulation's (NRR's) assistance to resolve this issue. In its August 1, 2000, response to TIA 99-028 (ADAMS Accession No. ML003736721), the NRR staff concluded that the fire rating of the installed fire wrap at HNP was indeterminate.

The Nuclear Energy Institute (NEI) confirmed that the plants listed below use Hemyc or MT fire wrap to comply with 10 CFR Part 50, Appendix R, safe shutdown separation requirements.

Arkansas Nuclear One Units 1 and 2	Beaver Valley Unit 1
Catawba Units 1 and 2	FitzPatrick
GINNA	Harris
Indian Point Units 2 and 3	McGuire Units 1 and 2
Robinson 2	Vermont Yankee
Waterford	

NRR staff had requested that NEI coordinate a generic industry initiative to address the Hemyc and MT fire barrier issue, but NEI declined. Therefore, the staff will be working with the affected licensees to resolve this issue. The staff's planned course of action includes meeting with the affected licensees as a group to discuss (1) the technical issues, (2) the applicability of the issues to the affected plants, and (3) the ultimate resolution of the issue. We are requesting that the affected licensees take the issue on as a voluntary initiative and propose an approach for resolving the issue.

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

*/RA/*

R. Subbaratnam, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-261

cc: See next page  
Fred Emerson, NEI

March 26, 2001

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

*/RA/*

R. Subbaratnam, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-261

cc: See next page  
Fred Emerson, NEI

Distribution:

Docket File	PUBLIC	RLaufer
PD II Rdg	OGC	ACRS
DFrumkin	B. Bonser, RII	

FILENAME - G:\PDII-2\Robinson\FireBarrierltr.wpd \*see previous concurrence

OFFICE	PM:PDII	LA:PDII	SPLB	SC:SPLB	SC:PDII	
NAME	RSubbaratnam	EDunnington	DFrumkin *	EWeiss *	RCorreia	
DATE	3/23/01	3/23/01	03/ 06 /01	03/ 06/01	03/23/01	
COPY	Yes/No	Yes/No	Yes/No	Yes/No	Yes/No	

OFFICIAL RECORD COPY

Mr. J. W. Moyer  
Carolina Power & Light Company

H. B. Robinson Steam Electric  
Plant, Unit No. 2

cc:

Mr. William D. Johnson  
Vice President and Corporate Secretary  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

Mr. Mel Fry, Director  
N.C. Department of Environment  
and Natural Resources  
Division of Radiation Protection  
3825 Barrett Dr.  
Raleigh, North Carolina 27609-7721

Ms. Karen E. Long  
Assistant Attorney General  
State of North Carolina  
Post Office Box 629  
Raleigh, North Carolina 27602

Mr. Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
Post Office Box 29520  
Raleigh, North Carolina 27626-0520

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
H. B. Robinson Steam Electric Plant  
2112 Old Camden Road  
Hartsville, South Carolina 29550

Mr. Virgil R. Autry, Director  
South Carolina Department of Health  
Bureau of Land & Waste Management  
Division of Radioactive Waste Management  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. T. P. Cleary  
Plant General Manager  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant, Unit No. 2  
3581 West Entrance Road  
Hartsville, SC 29550

Mr. Terry C. Morton  
Manager  
Performance Evaluation and  
Regulatory Affairs CPB 7  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602-1551

Mr. T. D. Walt  
Director of Site Operations  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant, Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550

Mr. John H. O'Neill, Jr.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW.  
Washington, DC 20037-1128

Public Service Commission  
State of South Carolina  
Post Office Drawer 11649  
Columbia, South Carolina 29211

Mr. B. L. Fletcher III  
Manager - Regulatory Affairs  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
3581 West Entrance Road  
Hartsville, South Carolina 29550-07901 West

Mr. H. K. Chernoff  
Supervisor, Licensing/Regulatory Programs  
Carolina Power & Light Company  
H. B. Robinson Steam Electric Plant,  
Unit No. 2  
Entrance Road  
Hartsville, South Carolina 29550