

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Exelon Generation Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

March 23, 2001

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - ISSUANCE OF
AMENDMENTS (TAC NOS. MB0987 AND MB0988)

Dear Mr. Kingsley:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 184 to Facility Operating License No. DPR-19 and Amendment No. 179 to Facility Operating License No. DPR-25 for Dresden, Units 2 and 3. The amendments are in response to your application dated February 29, 2000, as supplemented by letter dated January 11, 2001. The application and supplement were submitted by Commonwealth Edison Company (ComEd), which has since merged to form Exelon Generation Company, LLC (EGC). By letter dated February 7, 2001, EGC, the licensee, assumed responsibility for all pending NRC actions that were requested by ComEd.

The amendments reduce the number of safety valves required for overpressure protection at Dresden Nuclear Power Station, Unit 2, by removing from Technical Specifications (TS) Section 3.6.E, the safety valve function and setpoint of the Target Rock safety/relief valve. The amendments also move the remaining safety valve lift pressure setpoints from TS Section 3.6.E to TS Section 4.6.E, change the number of required safety valves from nine to eight, and remove footnote "c" of Unit 3 TS Section 4.6.E.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Lawrence W. Rossbach, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-237 and 50-249

Enclosures: 1. Amendment No. 184 to DPR-19
2. Amendment No. 179 to DPR-25
3. Safety Evaluation

DISTRIBUTION:

PUBLIC	AMendiola	WBeckner	ACRS
PD3 r/f	LRossbach	CRosenberg	MRing, RIII
SBajwa	OGC	G. Hill (4)	

DOCUMENT NAME: G:\PDIII-2\dresden\AMDb0987.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

*See previous concurrence

OFFICE	PM:LPD3	E	LA:LPD3		BC:SRXB		BC:EMEB		OGC	
NAME	LRossbach		THarris	JWermiel			*Elmbro			
DATE	03/19/01		03/22/01	03/05/01			03/05/01		03/21/01	

OFFICE	SC:LPD3
NAME	AMendiola
DATE	03/23/01

OFFICIAL RECORD COPY

NRR-058



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 23, 2001

Mr. Oliver D. Kingsley, President
Exelon Nuclear
Exelon Generation Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - ISSUANCE OF
AMENDMENTS (TAC NOS. MB0987 AND MB0988)

Dear Mr. Kingsley:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 184 to Facility Operating License No. DPR-19 and Amendment No. 179 to Facility Operating License No. DPR-25 for Dresden, Units 2 and 3. The amendments are in response to your application dated February 29, 2000, as supplemented by letter dated January 11, 2001. The application and supplement were submitted by Commonwealth Edison Company (ComEd), which has since merged to form Exelon Generation Company, LLC (EGC). By letter dated February 7, 2001, EGC, the licensee, assumed responsibility for all pending NRC actions that were requested by ComEd.

The amendments reduce the number of safety valves required for overpressure protection at Dresden Nuclear Power Station, Unit 2, by removing from Technical Specifications (TS) Section 3.6.E, the safety valve function and setpoint of the Target Rock safety/relief valve. The amendments also move the remaining safety valve lift pressure setpoints from TS Section 3.6.E to TS Section 4.6.E, change the number of required safety valves from nine to eight, and remove footnote "c" of Unit 3 TS Section 4.6.E.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Lawrence W. Rossbach, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-237 and 50-249

Enclosures: 1. Amendment No. 184 to DPR-19
2. Amendment No. 179 to DPR-25
3. Safety Evaluation



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

EXELON GENERATION COMPANY, LLC

DOCKET NO. 50-237

DRESDEN NUCLEAR POWER STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 184
License No. DPR-19


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Exelon Generation Company, LLC (the licensee, formerly Commonwealth Edison Company) dated February 29, 2000, as supplemented by letter dated January 11, 2001, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-19 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 184 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Anthony J. Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 23, 2001

O. Kingsley
Exelon Generation Company, LLC

Dresden Nuclear Power Station
Units 2 and 3

cc:

Exelon Generation Company, LLC
Site Vice President - Dresden
6500 N. Dresden Road
Morris, Illinois 60450-9765

Mr. John Skolds
Chief Operating Officer
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Exelon Generation Company, LLC
Station Manager - Dresden
6500 N. Dresden Road
Morris, Illinois 60450-9765

Mr. John Cotton
Senior Vice President, Operation Support
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Exelon Generation Company, LLC
Regulatory Assurance Manager - Dresden
6500 N. Dresden Road
Morris, Illinois 60450-9765

Mr. William Bohlke
Senior Vice President, Nuclear Services
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

U.S. Nuclear Regulatory Commission
Dresden Resident Inspectors Office
6500 N. Dresden Road
Morris, Illinois 60450-9766

Mr. H. Gene Stanley
Vice President
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, Illinois 60450

Mr. Christopher Crane
Senior Vice President
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Jeffrey Benjamin
Vice President - Licensing And Regulatory
Affairs
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Document Control Desk-Licensing
Exelon Generation Company, LLC
1400 Opus Place, Suite 500
Downers Grove, Illinois 60515

O. Kingsley
Exelon Generation Company, LLC

- 2 -

Dresden Nuclear Power Station
Units 2 and 3

Mr. R. M. Krich
Director - Licensing
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. Robert Helfrich
Senior Counsel, Nuclear
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, IL 60515



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

EXELON GENERATION EDISON COMPANY, LLC

DOCKET NO. 50-249

DRESDEN NUCLEAR POWER STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 179
License No. DPR-25


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Exelon Generation Company, LLC (the licensee, formerly Commonwealth Edison Company) dated February 29, 2000, as supplemented by letter dated January 11, 2001, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B. of Facility Operating License No. DPR-25 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 179, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Anthony J. Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 23, 2001

ATTACHMENT TO LICENSE AMENDMENT NOS. 184 AND 179

FACILITY OPERATING LICENSE NOS. DPR-19 AND DPR-25

DOCKET NOS. 50-237 AND 50-249

Revise the Appendix "A" Technical Specifications by replacing the page identified below with the attached page. The revised page is identified by amendment number and contain a vertical line in the margin indicating the area of change.

REMOVE

3/4.6-7

INSERT

3/4.6-7

PRIMARY SYSTEM BOUNDARY

Safety Valves 3/4.6.E

3.6 - LIMITING CONDITIONS FOR OPERATION

E. Safety Valves

Excluding the Target Rock valve, the safety valve function of the reactor coolant system safety valves shall be OPERABLE.

APPLICABILITY:

OPERATIONAL MODE(s) 1, 2 and 3.

ACTION:

1. With the safety valve function of one or more of the above required safety valves inoperable, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
2. Deleted

4.6 - SURVEILLANCE REQUIREMENTS

E. Safety Valves

1. Deleted.
2. At least once per 18 months, 1/2 of the safety valves shall be removed, set pressure tested and reinstalled or replaced with spares that have been previously set pressure tested and stored in accordance with manufacturer's recommendations. At least once per 40 months, the safety valves shall be rotated such that all 8 safety valves are removed, set pressure tested and reinstalled or replaced with spares that have been previously set pressure tested and stored in accordance with manufacturer's recommendations.

Verify the safety function lift setpoints^(a) of the required safety valves are as follows:

2 safety valves @1240 psig $\pm 1\%$
2 safety valves @1250 psig $\pm 1\%$
4 safety valves @1260 psig $\pm 1\%$

a The lift setting pressure shall correspond to ambient conditions of the valves at nominal operating temperatures and pressures



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 184 TO FACILITY OPERATING LICENSE NO. DPR-19
AND AMENDMENT NO. 179 TO FACILITY OPERATING LICENSE NO. DPR-25
EXELON GENERATION COMPANY, LLC
DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3
DOCKET NOS. 50-237 AND 50-249

1.0 INTRODUCTION

By letter dated February 29, 2000, Commonwealth Edison Company (ComEd) proposed changes to the Technical Specifications (TS) for the Dresden Nuclear Power Station, Units 2 and 3. The proposed amendment would reduce the number of safety valves required for overpressure protection at Dresden, Unit 2, by removing from TS Section 3.6.E the safety valve function and setpoint of the Target Rock safety/relief valve (SRV). The proposed amendment would move the remaining safety valve lift pressure setpoints from TS Section 3.6.E to TS Section 4.6.E and change the number of required safety valves from nine to eight. The proposed amendment would also remove footnote "c" of Unit 3 TS Section 4.6.E since this footnote was only applicable to Unit 3, Cycle 15, (D3C15) which has been completed. By letter dated January 11, 2001, the licensee verified that they still wanted this amendment. The January 11, 2001, letter is within the scope of the original notice and does not change the staff's original no significant hazards consideration determination. The application and supplement were submitted by ComEd, which has since merged to form Exelon Generation Company, LLC (EGC, the licensee). By letter dated February 7, 2001, EGC assumed responsibility for all pending NRC actions that were requested by ComEd.

2.0 BACKGROUND

The Dresden Units have eight reactor coolant system (RCS) safety valves, four RCS relief valves, and one valve, manufactured by Target Rock, that serves as both a safety valve and as a relief valve. Transient analysis and design-basis documents for Dresden show that overpressure requirements are met with less than nine RCS safety valves. No credit is taken for the Target Rock SRV valve in the analysis used to meet the requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code.

By Amendment Number 168 dated June 4, 1999, the Dresden, Unit 3, Target Rock SRV safety valve function was removed from TS and the Unit 3 safety valve lift pressure setpoints were moved from TS Section 3.6.E to TS Section 4.6.E. The staff is using that amendment as a precedent for approving this request.

3.0 EVALUATION

The staff verified that the Dresden, Unit 2, design-basis for RCS overpressure protection and accident analysis, which is described in Sections 5.2 and 15.2 of the Dresden Updated Final Safety Analysis Report (UFSAR), does not credit the safety valve function of the Target Rock SRV. If the safety valve function of the Target Rock SRV is removed from the TS, TS Sections 3.6.E and 4.6.E will continue to specify operability requirements for the other eight RCS safety valves. The eight safety valves still specified in TS Sections 3.6.E and 4.6.E will provide adequate protection for overpressure transients and accident conditions.

The licensee proposed to move the remaining RCS safety valve lift pressure setpoints from TS Section 3.6.E to TS Section 4.6.E. The safety valve lift pressure setpoints are verified by surveillance tests and are more correctly specified under the surveillance section, TS Section 4.6.E, rather than the limiting condition for operation section, TS Section 3.6.E. This relocation of the RCS safety valve lift pressure setpoints follows the format of the Improved Standard Technical Specifications, NUREG-1433. This administrative change to TS does not reduce requirements.

The licensee proposed to remove footnote "c" from Dresden, Unit 3, TS 4.6.E. Footnote "c" extended to 60 months the 40 month surveillance requirements of TS 4.6.E for D3C15 only. D3C15 was completed on January 30, 1999, therefore, this footnote is no longer applicable. Removing this expired footnote from TS is an administrative change that does not reduce requirements.

On the basis of the preceding information, the staff has determined that it is not necessary to include the safety valve function of the Target Rock SRV in TS. The staff has also determined that the RCS safety valve lift pressure setpoints are more correctly specified in TS Section 4.6.E and that footnote "c" has expired. There are no negative safety consequences associated with deleting the Target Rock SRV safety valve function, relocating the lift pressure setpoints, or deleting footnote "c." The staff thus concludes that it is acceptable to remove the safety valve function of the Target Rock SRV from TS, to relocate the RCS safety valve lift pressure setpoints within TS, and to remove footnote "c."

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Illinois State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has made a final finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (66 FR 11055).

Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: L. Rossbach

Date: March 23, 2001