



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

August 11, 1992

Docket No. 50-333

Mr. Ralph E. Beedle
Executive Vice President, Nuclear
Generation
Power Authority of the State of
New York
123 Main Street
White Plains, New York 10601

Dear Mr. Beedle:

SUBJECT: CORRECTION TO AMENDMENT NO. 182 FOR JAMES A. FITZPATRICK NUCLEAR
POWER PLANT (TAC NO. M83412)

By letter dated July 13, 1992, the Commission issued Amendment No. 182 to
Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear
Power Plant.

A member of your staff contacted this office and informed us of an
administrative error in the above referenced amendment. Specifically, the
changes made to page 78 in Amendment No. 182 were incorporated into an
outdated revision of the page which did not account for the administrative
changes made in Amendment No. 181.

We have verified that the corrections are consistent with the amendment and
its supporting safety evaluation. As previously noted, this was clearly an
administrative error. Enclosed is the corrected page 78 for Facility
Operating License No. DPR-59. Please replace the existing page with the
corrected page.

Sincerely,

Brian C. McCabe, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

9208170245 920811
PDR ADDCK 05000333
P PDR

NRC FILE CENTER COPY

DF01

August 11, 1992

Docket No. 50-333

DISTRIBUTION:
See next page

Mr. Ralph E. Beedle
Executive Vice President, Nuclear
Generation
Power Authority of the State of
New York
123 Main Street
White Plains, New York 10601

Dear Mr. Beedle:

SUBJECT: CORRECTION TO AMENDMENT NO. 182 FOR JAMES A. FITZPATRICK NUCLEAR
POWER PLANT (TAC NO. M83412)

By letter dated July 13, 1992, the Commission issued Amendment No. 182 to
Facility Operating License No. DPR-59 for the James A. FitzPatrick Nuclear
Power Plant.

A member of your staff contacted this office and informed us of an
administrative error in the above referenced amendment. Specifically, the
changes made to page 78 in Amendment No. 182 were incorporated into an
outdated revision of the page which did not account for the administrative
changes made in Amendment No. 181.

We have verified that the corrections are consistent with the amendment and
its supporting safety evaluation. As previously noted, this was clearly an
administrative error. Enclosed is the corrected page 78 for Facility
Operating License No. DPR-59. Please replace the existing page with the
corrected page.

Sincerely,

Original signed by:

Brian C. McCabe, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

| | | | | | |
|--------|-----------------|-----------------------------|--------------------|--|--|
| OFFICE | PDI-1:LA | PDI-1:PM | PDI-1:PD | | |
| NAME | CVogon <i>w</i> | BMcCabe: <i>[Signature]</i> | RACapra <i>Row</i> | | |
| DATE | 8/5/92 | 8/11/92 | 8/11/92 | | |

OFFICIAL RECORD COPY
Document Name: FTZ83412.LTR

Mr. Ralph E. Beedle
Power Authority of the State of New York

James A. FitzPatrick Nuclear
Power Plant

cc:

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, New York 10019

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Post Office Box 136
Lycoming, New York 13093

Mr. Harry P. Salmon, Jr.
Resident Manager
James A. FitzPatrick Nuclear
Power Plant
Post Office Box 41
Lycoming, New York 13093

Mr. J. A. Gray, Jr.
Director Nuclear Licensing - BWR
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, New York 13126

Mr. John C. Brons, President
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

DISTRIBUTION:

Docket File

NRC & Local PDRs

PDI-1 Reading

S. Varga

J. Calvo

R. A. Capra

C. Vogan

B. McCabe

OGC

D. Hagan MNBB 3206

G. Hill (4) P1 22

Wanda Jones P-370

C. Grimes 11-E-22

ACRS (10)

OPA

OC/LFMB

Plant File

R. Jones 8-E-23

C. Cowgill, RI

9208180163 920811
 PDR ADDCK 05000333
 PDR

JAFNPP

TABLE 4.2-1

MINIMUM TEST AND CALIBRATION FREQUENCY FOR PCIS

| Instrument Channel (8) | Instrument Functional Test | Calibration Frequency | Instrument Check (4) |
|---|---|-----------------------|----------------------|
| 1) Reactor High Pressure (Shutdown Cooling Permissive) | (1) | Once/3 months | None |
| 2) Reactor Low-Low-Low Water Level | (1)(5) | (15) | Once/day |
| 3) Main Steam High Temp. | (1)(5) | (15) | Once/day |
| 4) Main Steam High Flow | (1)(5) | (15) | Once/day |
| 5) Main Steam Low Pressure | (1)(5) | (15) | Once/day |
| 6) Reactor Water Cleanup High Temp. | (1) | Once/3 months | None |
| 7) Condenser Low Vacuum | (1)(5) | (15) | Once/day |
| Logic System Functional Test (7) (9) | | Frequency | |
| 1) | Main Steam Line Isolation valves Main Steam Line Drain Valves Reactor Water Sample Valves | Once/6 months | |
| 2) | RHR - Isolation Valve Control Shutdown Cooling Valves | Once/6 months | |
| 3) | Reactor Water Cleanup Isolation | Once/6 months | |
| 4) | Drywell Isolation Valves TIP Withdrawal Atmospheric Control Valves | Once/6 months | |
| 5) | Standby Gas Treatment System Reactor Building Isolation | Once/6 months | |

NOTE: See notes following Table 4.2-5.