Rev: @2IM/1.00214 Line: 1

1926 EDT NRC-BHD WSH

014 ;

MSG: 0273X/84 TO: MR. R. C. DEYOUNG FROM: THOMAS J. SHIDELER, ITT BARTON INSTRUMENTS COMPANY DATE: OCTOBER 11, 1984 RE: NOTIFICATION OF DEFECT IN ACCORDANCE WITH 10CFR PART 21

art 2

-474

Publicly Available

JE19

ITT BARTON IS A SUPPLIER OF BASIC COMPONENTS TO THE NUCLEAR POWER INDUSTRY. THE SPECIFIC COMPONENTS BEING REPORTED ARE OUR MODEL 580A, MODEL 581A, AND MODEL 583A INDICATING AND NON-INDICATING DIFFERENTIAL PRESSURE SWITCHES. (THE MODEL 581-4 HYDRAULIC ISOLATOR USED AS PART OF THE REACTOR VESSEL LEVEL INDICATING SYSTEM IS NOT AFFECTED BY THIS REPORT.) THIS INFORMATION WAS MADE AVAILABLE TO ME ON OCTOBER 11, 1984.

AS A RESULT OF ITT BARTON'S CONTINUING TEST PROGRAM FOR 1E CLASS SAFETY RELATED INSTRUMENTS, A SWITCH SET-POINT SHIFT WHICH EXCEEDS THE SPECIFICATION FOR OUR MODEL 580A SERIES INSTRUMENTS HAS BEEN IDENTIFIED WHEN THEY ARE OPERATED AT TEMPERATURES ABOVE 225 DEGREES FAHRENHEIT (107 DEGREES CENTIGRADE). THE SHIFT HAS BEEN IDENTIFIED AS BEING THE RESULT OF RELIEVING OF STRESSES IN A SWITCH PLATE ASSEMBLY WHICH IS A SUB-ASSEMBLY OF THE COMPLETE INSTRUMENT.

IT HAS ALSO BEEN DETERMINED THAT, ONCE THE STRESS RELIEVING HAS ACCOMPLISHED, THE SWITCH SET-POINT SHIFT CONDITION IS ELIMINATED AND THE INSTRUMENTS, WITH STABILIZED SWITCH ASSEMBLIES INSTALLED, PERFORM WELL WITHIN SPECIFICATION LIMITS.

A REVIEW HAS BEEN CONDUCTED OF ALL CUSTOMER ORDERS FOR MODEL 580 SERIES INSTRUMENTS. THE PURPOSE OF THIS REVIEW WAS TO IDENTIFY THOSE APPLICATIONS WHERE THE CUSTOMER'S REQUIREMENTS FOR INSTRUMENT PERFORMANCE MAY EXCEED TEMPERATURES OF 225 DEGREES FAHRENHEIT (107 DEGREES CENTIGRADE). THOSE CUSTOMERS AFFECTED ARE:

> TEXAS UTILITIES GENERATING COMPANY PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE

FLORIDA POWER AND LIGHT

ROCHESTER GAS AND ELECTRIC

LONG ISLAND LIGHTING

CONSOLIDATED EDISON

THESE CUSTOMERS WILL BE NOTIFIED OF THE EXPECTED PERFORMANCE OF THEIR INSTRUMENTS AND, AT THEIR REQUEST, WILL BE PROVIDED WITH STRESS RELIEVED SWITCH ASSEMBLIES AND INSTALLATION INSTRUCTIONS.

NO NEW PARTS OR MATERIALS WERE INTRODUCED INTO THE PRODUCT AS A PART OF THE STRESS RELIEVING PROCESS AND THE TEMPERATURES INVOLVED ARE WITHIN THE MAXIMUM RATING FOR ALL SWITCH PLATE ASSEMBLY COMPONENTS. IT IS ITT BARTON'S OPINION, THEREFORE, THAT THERE IS NO EFFECT ON ANY PREVIOUS QUALIFICATION OF THESE PRODUCTS BY INTRODUCING THE STRESS RELIEVING OF SWITCH ASSEMBLIES AS A STANDARD OFFRATION.

ERELY,