

Note: Tables 4.6-1 and 4.6-2 have been deleted.

PNPS
TABLE 4.6-3

REACTOR VESSEL MATERIAL
SURVEILLANCE PROGRAM WITHDRAWAL SCHEDULE

<u>Capsule Number</u>	<u>Effective Full Power Years (EFPY)</u>
1	4.17
2	21 (approx.)
3	32 (End of Life)